



**CITY OF NOVI CITY COUNCIL
MARCH 24, 2025**

SUBJECT: Approval to purchase ASHRAE Level II energy audits through Information & Energy Services, Inc. in the amount of \$28,917, and amend the budget.

SUBMITTING DEPARTMENT: Integrated Solutions – Facilities Management

KEY HIGHLIGHTS:

- ASHRAE Level II energy audit to be performed at the Civic Center, DPW, Fire Station 4, Firearms Training Center, and Novi Ice Arena.
- This is the first phase of the previously approved \$100,000 grant agreement between EGLE and the City of Novi.
- The City of Novi will receive reimbursement for the costs of performing the energy audits through the grant funds secured. The remaining funds will be available to address the actionable items in the reports.

FINANCIAL IMPACT

	FY 24/25	Total
EXPENDITURE REQUIRED	\$ 28,917	\$ 28,197
BUDGET		
1. Energy Audit CEMS Grant 101-265.00-816.074	\$ 100,000	\$ 28,197
2. State Grants – CEMS 101-000.00-540.100	\$ 100,000	\$ 0
APPROPRIATION REQUIRED	\$ 0	\$ 0
FUND BALANCE IMPACT	\$ 0	\$ 0

BACKGROUND INFORMATION:

In November 2024, the City Council approved the \$100,000 grant agreement with the Department of Environment, Great Lakes, and Energy (EGLE) for the Community Energy Management Program (CEM). City Staff submitted a two-phased approach as part of the grant application approval. Phase 1 will conduct an American Society of Heating, Refrigeration, and Air-Conditioning (ASHRAE) Level II audit at five municipal facilities.

An ASHRAE Level II audit aims to identify possible areas where energy and water may be conserved. The Novi Civic Center, DPW, Fire Station 4, Firearms Training Center, and Novi Ice Arena buildings will benefit the most from these energy audits. The amount of HVAC equipment, lighting, domestic water heating, appliances, roofing, insulation, bathroom fixtures, and miscellaneous equipment in these structures makes them an ideal choice for immediate energy savings. Once the energy audit has been completed, the City will receive a comprehensive report on each building showing where energy can be conserved through repairs, upgrades, or best practices.

A Request for Proposal (RFP) was posted on the Michigan Intergovernmental Trade Network (MITN) website to solicit companies to perform the energy audits. Seven proposals were received and reviewed by City Staff. Of the proposals, Information & Energy Services, Inc. was the lowest bidder for \$28,917, has experience working with municipalities on energy audits, and fully understands the scope of work. If approved, costs incurred by the City of Novi to purchase this service will be reimbursed with the grant funds already secured through the CEM Program.

RECOMMENDED ACTION: Approval to purchase ASHRAE Level II energy audits through Information & Energy Services, Inc. in the amount of \$28,917, and amend the budget.

Information & Energy Services, Inc.

Request for Proposals – City of Novi Energy Audit

Attn: Finance Department
45175 Ten Mile Road
Novi, MI 48375

Due March 6, 2025 by 2:00pm

Legal Name of Firm: Information & Energy Services, Inc. (IES)

Company Headquarters: 21951 Purebred Ln. Escondido, CA 92029

Michigan Office: 815 Sleeth Rd. Commerce, MI 48382

Contact Name/Owner: Michael Rogers

Primary Contact Phone Number: 760-908-6321

Primary Contact Email: mrogers@iesenergy.com

Tax ID Number (EIN): 55-0830534





INFORMATION & ENERGY SERVICES, INC.

February 24, 2025

City of Novi
Attn: Finance Department
45175 Ten Mile Road
Novi, MI 48375

Re: Request for Proposals – Energy Audits

To Whom it May Concern,

Information & Energy Services, Inc. (IES) was established in 2003 and is headquartered in San Diego, CA. IES employees combined have over 130 years of experience in the energy industry. IES has satellite offices located throughout the United States including one located in Commerce, MI. Over the years, we have successfully served a diverse clientele, including but not limited to municipalities, military bases, Federal Government, K-12 schools, universities, hospitals, commercial, industrial facilities and various other facility types.

At the core of our energy initiatives are comprehensive energy audits, which serve as the foundation for recommending energy-saving measures tailored to each customer. These audits encompass high-level investment grade assessments, ASHRAE Level I, II, and III audits, as well as renewable energy feasibility assessments. In the past calendar year alone, IES conducted nationwide energy audits at over 300 buildings, with over half of those being for municipalities.

We are grateful for the opportunity to collaborate with the City of Novi to recommend possible energy and water conservation projects.

Sincerely,

Michael B. Rogers, P.E., C.E.M.
President
760-908-6321
mrogers@iesenergy.com

Firm Information

Firm Name: Information & Energy Services, Inc. (IES)

Owner/Principal's Name: Michael Rogers P.E., C.E.M

Number of Employees: 13

Years in Business: 21 years (inc. May 2003)

Headquarter Location: 21951 Purebred Lane, Escondido, CA 92029

Michigan Location: 815 Sleeth Rd. Commerce, MI 48382

Types of Certifications:

IES holds a variety of licenses and credentials including two CA Professional Engineers (PE #M30484, #M41755), AZ Professional Engineer (PE# M54788), NV Professional Engineer (PE# 027837), TX Professional Engineer (PE# 148031) California General Contractor License (CCL #867847), as well as multiple staff certifications for Certified Energy Manager (CEM) (#003596, #004768 and 26348), LEED Green Associate (#11093877, U.S. Green Building Council), Certified Building Commissioning Professional (CBCP# 2174 Association of Energy Engineers) Building Commissioning Professional Certification (BCxP# 8395185), and Project Management Professional PMP (#1939222, Project Management Institute).

IES was incorporated in 2003 in and has spent the last 21+ years performing a variety of energy consulting services throughout the United States. IES has audited thousands of locations throughout the United States, providing millions of dollars in energy savings recommendations. These services include, but are not limited to:

- Energy efficiency audits (ASHRAE Levels 1, 2 and 3, investment grade audits, etc.)
- Measurement & verification (M&V) services following IPMVP standards
- Whole building energy modeling
- Targeted energy modeling
- Renewable energy project feasibility studies and project development, including an emphasis on resiliency through microgrids, battery energy storage systems (BESS), etc.
- Electric vehicles (EVs), charging infrastructure and planning studies
- Utility provider rate analysis
- Assisting in compliance with new & changing building regulations
- Retro-Commissioning (RCx) Projects including those facilities with very tight tolerance such as hospitals and other research facilities
- Preparation of RFPs, bid support and construction management support on behalf of clients

Our mission is to improve energy and water efficiency for our customers, eliminating energy waste wherever possible while reducing energy costs in the process. At the same time, we understand the financial constraints many of our customers face and strive to identify all No & Low-Cost opportunities, available rebates/incentives and grants or other funding mechanisms. Many of our jobs have resulted in the implementation of high efficiency HVAC, LED lighting, Controls optimized for reducing consumption and implementing demand response procedures, improving electrical distribution, and Battery Energy Storage Systems (BESS). In some instances, these improvements were completely paid for by utility incentives.

IES has grown alongside the energy market and done work on both the supply and demand side of past projects. As a small company we remain flexible in our operations, realizing from the start that 100% customer satisfaction is vital to success. This flexibility allows us to perform services in a time-efficient matter at a competitive cost. As we continue to grow, we do not want to lose sight of our customer-oriented focus. Forming close relationships with our customers is vitally important to our continuing vision. IES takes pride in maintaining a multi-contractual relationship with many of our customers. We aim to make every client feel as if they are a part of the team themselves. We are always just a phone call away no matter the question and work to get requests done in a timely and effective manner.

Project Understanding and Approach

IES has extensive experience providing energy conservation and advising services to Industrial, Commercial, Federal, School Districts, and other types of facilities throughout the United States. IES has successfully completed hundreds of ASHRAE Level I, II and III audits across a wide range of facility types, including over 200 municipal buildings. These audits resulted in \$240.9 million worth of contracted energy efficiency projects at 129 municipal buildings, with those measures in various stages of completion at present. We feel that our experience with multiple types of facilities qualifies us to perform the tasks set forth in the objectives of the RFP in an expert fashion.

To meet the City of Novi energy goals, IES will investigate all aspects of energy usage. These areas generally include:

- Lighting
- HVAC
- Controls for HVAC, Lighting, Refrigeration, etc. (optimize Sequence of Operation for Energy Efficiency & Reducing Demand)
- Plug Load Appliances
- Refrigeration
- Energy Use and Behavior
- Renewable Energy Potential and Opportunities

Project Approach

The IES ASHRAE Level II Energy Audit Process will be conducted as follows:

- IES will conduct a Preliminary Meetings (Kick Off) through teleconference or in person where our Team will meet with the City Staff including the facilities management and other key representatives to lay out the audit process and to get a feel for each building's energy and water use. This will sharpen our focus towards the buildings energy saving goals and tailor recommendations towards those City Staff are interested in. We will consider the current energy usage; occupancy schedule and what buildings have had recent upgrades to determine optimal recommendations.
- After gaining the information from the Preliminary Meeting IES will work with the customer or Customer's Utility Providers (DTE, State of MI Energy Office, Federal Agencies, etc.) to gather at least the last 12 months of utility data. This is an integral part of establishing "Baseline" energy use for each building.
- Working directly with the City of Novi, IES will schedule a date to audit each building. IES plans on conducting all the on-site audits over 2 to 3 days in a single week. IES will need full access to these buildings in order to collect detailed

information on all energy consuming equipment and identify energy savings measures. Primary audit goals include but are not limited to:

- Identify all data necessary on Equipment/Systems operation
 - Identifying both low cost and capital energy and water conservation measures
 - Interview with site staff to determine optimal efficiency strategies given current building practices
 - Identify onsite renewable energy opportunities: Solar PV, solar thermal, cogeneration
 - Identify offsite renewable energy opportunities
 - Identify load shedding opportunities using battery storage systems
- IES will develop a report which meets an ASHRAE Level II survey including full utility analysis, building load profiles, energy conservation measure (ECM) recommendations including measure descriptions along with the modeled outputs such as the load balance broken out by energy using equipment, ECM savings, estimated costs, available rebates and overall payback.
 - IES anticipates developing a single report for the City of Novi. This report will outline findings for all buildings and organize energy conservation measures (ECMs) by building, along with recommendations for which measures should be pursued. IES is agreeable to providing separate reports for each site if desired.

Throughout the process, IES will give bi-monthly (every 2 weeks) updates on the current status of the energy audits and savings analysis through project close. IES will continue to support the City and key representatives post-audit to answer any ongoing questions about measures and provide support in the implementation of recommended measures.

The ASHRAE Level II audit report will include:

- **Executive Summary** of process and results
- **Synopsis** of site characteristics, including:
 - Facility overview
 - Site map
 - Energy systems summary for lighting, HVAC, refrigeration, etc.
 - Utility data analysis of last fiscal year for electricity, gas and water
 - Overview of previous energy projects
- **Site Energy Use Index (EUI)**

- **Load Balance and Energy Modeling**
- **Recommended Measures**
 - Measure description (area served, operating schedules and sequences, suspected issues, etc.)
 - Measure savings, cost impacts, CO2 levels, etc.
 - All measures will have a Simple Payback Period of less than 50 years unless approved for Targeted Measures only.
- **Renewable Energy Opportunity Summary** of renewable measures which could benefit the site
- **Any Additional Recommendations**
 - Includes measures with longer paybacks to be considered in the future as well as any improvements to health, safety and environment
- **Full Calculation Appendix**
 - Includes all calculations for measures described in the report
 - Includes full equipment database for lighting, HVAC, CO2 levels and other energy using equipment
- **Submission of the Report**

Finally, IES will ensure that the City and other key representatives have a working understanding of all energy savings measures and any new practices or equipment and will continue to be available for a walk of the five sites at the conclusion of the report to point out the energy efficiency improvement opportunities and after the project term to support the City of Novi's efforts.

Experience

The following summaries of both current and recent projects detail work which would be relevant to the services the City of Novi is requesting. Project references are included as well.

City of Fresno Phase 2 Energy Efficiency Project, Fresno, CA

Project Reference: Jake Torres, Director of Sales at ABS Energy, (858) 886-9447. 12520 High Bluff Dr. Ste. 345., San Diego, CA 92130

Dates of work: January 2021 to Present (Phased Approach, currently in phase 2)

IES has worked with ABS Energy on several projects within the last 5 years. One of the largest projects IES worked on was the City of Fresno Energy Conservation Project. The project encompassed identifying energy conservation measures throughout 59 facilities across all the city's parks, community centers, all police and fire stations, and several Administrative Buildings. IES was responsible for conducting site walkthroughs and developing full lighting (interior & exterior), HVAC, electrical distribution, pumping and controls assessments at each of these facilities.

IES has been responsible for developing project recommendations for replacement of interior and exterior lighting with LED fixtures, replacement of old HVAC units, addition of new HVAC controls and replacement of old transformers. Solar systems were also assessed at several locations. Within the recommendations an economic evaluation was conducted in both a simple payback and a life cycle analysis.

The final project will deliver over 2,500,000 kWh annual savings, saving over \$550,000 per year from the optimization, a savings of approximately 36% over the baseline. This energy savings equates to a reduction in CO2 Emissions of 1,953 Tons annually. IES has worked with implementation contractors and the city through contracting and implementation is going to be completed very soon. A follow-up project at the Fresno Zoo was also completed which evaluated similar measures in addition to specialty measures affecting animal enclosures and support structures.

City of Tempe Comprehensive Energy Audits, Tempe, AZ

Project Reference: Charlie Bladine, Facilities Manager, (480) 350-8563. 31 E. 5th St., Tempe, AZ 85281

Dates of work: March 2022 to Present

IES was selected to perform comprehensive ASHRAE level 2 energy audits for several facilities managed by the City of Tempe. To date, IES has audited two water treatment facilities for the City. Our recommendations of these two sites did not include any process

related (i.e.) pumping operations at the request of the City- however, identified savings measures would save over 300,000 kWh/ year and 24,000 gallons of water/year if measures were implemented. We continue to stand by as a resource for the City in the event that they wish to pursue implementing any of the requested measures, or should they wish to have more City facilities audited.

Sweetwater Union High School District, Chula Vista, CA

Project Reference: Ronald Malone, Director of Maintenance for SUHSD, (619) 691-5565. 642 Arizona St. Chula Vista, CA 91911

Dates of work: 2016 through Present

IES has worked with Sweetwater Union High School District (SUHSD) on numerous projects going back to 2008. Our most recent efforts began in 2016 with California's Proposition 39 project, which granted millions of dollars in State funding to K-12 public schools for the purpose of updating their energy using equipment to more efficient technologies. This involved performing ASHRAE Level 2 audits at all sites and developing a comprehensive project to utilize the Prop. 39 funds across all schools in an equitable manner. We worked with the District's Superintendent and Maintenance Office, along with the District's third party planners to develop a project bringing interior and exterior LED lighting and controls retrofits to all 27 campuses. HVAC and HVAC controls replacements were also included at nearly half of the schools in the District. The project was developed in a way to maximize energy savings and meet the District's equipment replacement needs while staying within the budget constraints of the State grant funds and ensuring that all site's received a significant portion of those funds. We worked with the District in tracking the performance of the newly installed measures and completed a State verification report tracking the use of the grant funds. The implementation of these measures reduced the District's electricity use by 17%.

IES has acted as the District's Energy Manager since the conclusion of the Prop. 39 program. We oversaw energy expenditures over this time, including during the COVID-19 pandemic. This was extremely unique with regards to forecasting the district's energy expenditures during a constantly evolving scenario. Along with providing an accurate forecast of the district's energy expenditures in these years, these actions led to several recommendations and actions to reduce energy use, which were realized. The most significant of these actions was the ongoing review and changes made to the District's multiple control systems, which eliminated unnecessary HVAC use while campuses were closed. Between April 2020 and June 2021, the approximate value of the avoided HVAC use came out to \$2.6 million, a decrease of 43% from their stated FY 20-21 energy budget of \$6.1 million, which was a direct result of our engineers' identifying areas where the

HVAC could be shut down and then directly adjusting site schedules to shut down the HVAC upon District approval.

Our energy management tasks have also included: setting up a monthly utility tracking matrix where energy is tracked by meter and by site, development of an HVAC condition matrix, site walks during District breaks to determine if any equipment was running while the campuses were closed, post site visit in depth analysis of each campus within the District, energy reporting on a District wide campus by campus basis, benchmarking of schools types utilizing EUI to determine which campuses are higher energy performers and which ones are lower energy performers, numerous reviews and adjustments of the District's HVAC control systems through the pandemic, continuous optimization of controls with respect to scheduled hours along with holidays to eliminate excess runtime without, the creation and upkeep of inventory matrices for the District's HVAC equipment, lighting and refrigeration, ongoing monthly review of the District's utility billing and review of the solar generation and power purchase agreements (PPAs) at each of the District's solar-equipped sites, identification of funding sources for energy related programs such as electric buses and electric vehicle charging stations and review of energy saving technologies presented to the District throughout our term.

The HVAC matrix we have developed and continue to maintain is utilized to easily decide which units at which sites need replacement soonest, making it easier to budget accordingly. This matrix has assisted in developing an HVAC controls replacement project enhancing the systems at five of the campuses with additional scope for HVAC replacements.

Additionally, we were able to identify solar PV metering issues with the District's PPA provider and worked with the provider to correct these issues.

As a result of our management, the District saved over \$2.6 million from its FY 20-21 energy budget of \$6.1 million. Other accomplishments were identifying and renewing the District's 3rd party power agreements and managing the installation of new energy efficient lighting, controls, high efficient HVAC and a battery energy storage system through SDG&E's IDSM program. This program installed over \$600,000 worth of energy saving technologies at the District Office which will save the site approximately \$31,000 per year in energy costs, reducing electricity consumption by 47% while minimizing their carbon footprint, all at no cost to the District.

Integrated Demand Side Management (IDSM) Pilot Program, San Diego County, CA
Project Reference: Sandra Williams, Project Manager III for SDG&E, (619) 676-8850.
8330 Century Park Ct. San Diego, CA 92123

Dates of work: 2019 through March 2024

IES designed, administered and managed the IDSM pilot program on behalf of SDG&E. Through the program, select customer sites within SDG&E's service territory received energy efficient LED lighting, lighting controls, HVAC, HVAC controls, energy efficient transformers, battery energy storage systems (BESS) and refrigeration optimization at no cost to the customers. Customers included local Grocery Outlet grocery stores, a school district office building, Petco Park, a local university campus and a couple of commercial manufacturing buildings.

The scope of work IES developed and subsequently oversaw included:

- retrofitting recessed troffer lighting fixtures with an LED troffer retrofit kit with integrated lighting controls.
- Lighting controls were optimized to the desired maximum output and outfitted with dimming capabilities for ambient light levels and occupancy on an individual fixture basis. The lighting controls in select spaces were programmed to respond to demand response (DR) events, dimming where allowable during such events and reducing building load.
- Select HVAC units were replaced as needed with new high efficiency units, and networked programmable web-based thermostats were installed to allow for a highly functional and cost-effective control solution. These were programmed to allow for a temperature set-back during a DR event, reducing building energy loads in these events.
- Transformers were replaced as needed with new high efficiency transformers to decrease load losses in the electrical distribution system and further improve building efficiency.
- A (62.5kW/250kW) battery energy storage system (BESS) was installed at most sites and was programmed with a sequence of operation based upon each site's individual load profile and utility rate tariff to reduce the overall cost of power by discharging the battery at peak times.
- Finally, sites which had a walk-in refrigeration system had those system's optimized through an initial retro-commission of the walk-in unit and then the installation of a thermal energy storage (TES) system with controls. The added thermal mass from the TES allows for the refrigeration system to run at a constant lower load thus improving efficiency. The additional thermal mass allows the box to stay colder for extended periods during power outages, improving resiliency at these locations.

The IDSM project was very comprehensive with respect to the work performed by IES as we:

- designed the Program Offering (measures offered, quantity of units to be replaced, etc.),
- selected the trade contractors through a formal RFP process for lighting, HVAC replacement, controls (lighting & HVAC), transformers, refrigeration optimization and battery storage systems, and
- managed the selected contractors through project completion, facilitating all communications regarding project milestones with each Customer and the utility.

The program has wrapped up with successful installations at seven (7) sites throughout San Diego County.

Fee Proposal Form



CITY OF NOVI
ENERGY AUDIT
FEE PROPOSAL FORM

We the undersigned as proposer, propose to furnish to the City of Novi, according to the specifications, terms, conditions and instructions attached hereto and made a part thereof:

Site Name	Square Footage	Cost per Square Ft	Total Cost
Civic Center	71,000	\$0.12	\$ 8,520
DPW	75,000	\$0.12	\$ 9,000
Firearms Training Ctr	7,800	\$0.15	\$ 1,170
Fire Station #4	11,380	\$0.15	\$ 1,707
Novi Ice Arena	71,000	\$ 0.12	\$ 8,520

TOTAL \$ 28,917

We acknowledge receipt of the following Addenda: Addendum #1
 (please indicate numbers)

EXCEPTIONS TO SPECIFICATIONS (all exceptions must be noted here):

COMMENTS: _____

REFERENCES: Please provide at least three client (3) references for projects of similar scope done in the last 3 years.

Company ABS Energy
Address 12520 High Bluff Dr. Ste 345 San Diego, CA 92130
Phone 858-886-9447 Contact name Jake Torres

Company City of Tempe
Address 31 E. 5th St. Tempe, AZ 85281
Phone 480-350-8563 Contact name Charlie Bladine

Company Sweetwater Union High School District
Address 642 Arizona St. Chula Vista, CA 91911
Phone 619-691-5565 Contact name Ronald Malone

THIS PROPOSAL SUBMITTED BY:

Company (Legal Registration) Information & Energy Services, Inc.


Address 21951 Purebred Ln

City Escondido State CA Zip 92029

Telephone 760-908-6321 Fax _____

Representative's Name Michael B. Rogers

Representative's Title President

Authorized Signature 

E-mail mrogers@iesenergy.com

Date 3/5/2025



Energy Audit Report

REPORT DATE: Date

PROPERTY INFORMATION:

Client Project Name

Property Address

City, County County, State Zip

PROJECT INFORMATION:

AEI Project No. Sample Project

Site Assessment Date: Date

PREPARED FOR:

Client Name

Client Address

Client City, State Zip Code

PREPARED BY:

AEI Consultants - Corporate Headquarters

2500 Camino Diablo

Walnut Creek, California 94597



Date

Client Contact Name

Client Name

Client Address

Client City, State Zip Code

Subject: Energy Audit Report
Client Project Name
Property Address
City, State Zip
AEI Project No. Sample Project

Dear Client Contact Name:

AEI Consultants is pleased to provide the *Energy Audit Report* of the above referenced property. This assessment was authorized and performed in accordance with the scope of services engaged.

We appreciate the opportunity to provide services to you. If you have any questions concerning this report, or if we can assist you in any other matter, please contact me at Phone Number or Email Address.

Sincerely,

A handwritten signature in black ink that reads "Brian Morgan". The signature is written in a cursive, flowing style.

AEI Contact
AEI Consultants

TABLE OF CONTENTS

1.0 CERTIFICATION/DISCLAIMER	4
2.0 EXECUTIVE SUMMARY	5
2.1 Energy Audit - Purpose and Scope	5
2.2 Summary of Energy Efficiency Measures (EEMs)	5
2.3 Energy and Water Efficiency Measures (EWEM) Table	7
2.4 Energy Benchmarking	9
3.0 BACKGROUND	10
3.1 Property Description	10
3.2 Occupancy and Use Schedules	12
3.3 Utility Analysis	12
3.4 End Use Analysis	17
4.0 BUILDING SYSTEMS	19
4.1 Occupancy	19
4.2 Building Envelope	19
5.0 RECOMMENDED EEMS	27
5.1 No-Cost/Low-Cost Measures	27
5.2 Capital Cost Measures	27
6.0 SIGNATURES OF PARTICIPATING PROFESSIONALS	31

TABLE OF APPENDICES

APPENDIX A: PROPERTY PHOTOGRAPHS
APPENDIX B: SUPPORTING DOCUMENTATION
APPENDIX C: ENERGY STAR EXISTING CONDITIONS SEP REPORT
APPENDIX D: QUALIFICATIONS
APPENDIX E: LIST OF COMMONLY USED ABBREVIATIONS

1.0 CERTIFICATION/DISCLAIMER

AEI has completed an Energy Audit for the Property located at Property Address, City, County County, State (the "Property"). AEI visited the site on Date.

The energy conservation opportunities contained in this report have been reviewed for technical accuracy. The reader is reminded that energy savings ultimately depend on variable factors including occupant behavior, weather, and quality of installation. Estimated installation costs are based on a variety of sources, including our own experience at similar facilities, our own pricing research using local contractors and vendors, and cost handbooks such as those produced by RS Means. The cost estimates represent the best judgment of the auditors for the proposed action. The Owner is encouraged to confirm these cost estimates independently since actual installed costs can vary widely for a particular installation. AEI does not guarantee installed cost estimates and shall in no event be liable should actual installed costs vary from the estimated costs herein.

AEI does not guarantee the costs savings estimated in this report. AEI shall in no event be liable should the actual energy savings vary from the savings estimated herein.

AEI certifies that it has no undisclosed interest in the Property and that AEI's employment and compensation are not contingent upon the findings or estimated costs to remedy any deficiencies due to deferred maintenance and any noted component or system replacements.

2.0 EXECUTIVE SUMMARY

AEI Consultants (AEI) was retained by Client Name to conduct an ASHRAE Level II Energy Audit, in conformance with the scope and limitations of ASHRAE *Procedures for Commercial Building Energy Audits*, Second Edition (2011), and ANSI/ASHRAE/ACCA Standard 211-2018, *Standard for Commercial Building Energy Audits* for the Property located at Property Address, City, County County, State (the "Property"). The Energy Efficiency Measures (EEMs) from the audit will be used to prepare a Statement of Energy Design Intent showing the effect of energy use reduction on the energy performance score.

2.1 ENERGY AUDIT - PURPOSE AND SCOPE

AEI has performed a comprehensive analysis of the Property to identify possible areas where Energy and Water may be conserved. The areas being considered include HVAC equipment, lighting, domestic water heating, appliances, fenestrations, insulation, roofing, bathroom fixtures, and miscellaneous equipment. AEI may also use infrared thermography to identify areas that may be losing energy.

Utility Analysis

AEI has performed a comprehensive utility analysis to determine the Energy and Water consumption of the buildings. The analysis utilizes at least 12 months of common area utility bills and as many tenant utility bills as possible. By observing peak loads during the year, a baseline for energy and water consumption can be determined.

Energy Audit Process

Where possible, in addition to the Site Survey, AEI has utilized construction drawings, interviews, repair records, etc. to determine the actual current efficiency of the Property's building envelopes and equipment.

Accuracy of Analysis

AEI used energy use simulation tools and spreadsheet calculations that base estimated savings on the as-built facility and energy consuming equipment's current operating condition. The simple payback calculations are based on the labor and material cost of the new equipment divided by the cost savings per year. AEI shall not be responsible for equipment that may not reach the end of its useful life or costs more to operate than noted in the EEMs.

Current Energy Code

The energy code adopted by State at the time of this report is 2021 International Energy Conservation Code (2021 IECC) or equivalent for Residential//Commercial construction. [<https://www.energycodes.gov/status-state-energy-code-adoption>]

2.2 SUMMARY OF ENERGY EFFICIENCY MEASURES (EEMs)

The following table presents the ASHRAE Energy Efficiency Measure table from *Procedures for Commercial Building Energy Audits*. Note that the water savings do not register in the tables. We have included our [Energy and Water Efficiency Measure tables](#) later in this report.

EEM Summary

Measure Number	Measure Description	ANNUAL ENERGY & COST SAVINGS			PAYBACK WITH INCENTIVE		Net Measure Cost	NPV*	Simple Payback (Year)
		Electricity Savings (kWh)	Gas/Fuel Savings (Therms)	Total Cost Savings	Measure Cost	Potential Utility Incentive			
EEM-1	Program Supply Temperature Reset (approximately 2.5 F) from 48 F to 50.5 F for the LAB AHU's at Building 1	102,261	20,450	\$26,770	\$5,500		\$5,500	\$176,903	0.2
EEM-2	Program Supply Temperature Reset (approximately 3 F) from 55 F to 58 F for the three Packaged Rooftop Units at Building 1	108,137	11,772	\$19,984	\$7,500		\$7,500	\$128,666	0.4
EEM-3	Program Demand Control Ventilation for the three Packaged Rooftop Units at Building 1, and install CO2 sensors at the office spaces	29,350	-	\$2,725	\$7,500		\$7,500	\$11,065	2.8
EEM-4	Provide Daylight Controls Near Skylights and Exterior Glass	3,264	-	\$303	\$720		\$720	\$1,142	2.4
EEM-5	Install 35 kW DC Solar PV system on available roof area-Since roof area is limited, a ground mount or placement at parking garage roof is possible. (Approximately 100 modules.) Note that a 30% Federal Investment Tax Credit is available for commercial systems, or a production credit of \$0.026/kWh of production credit for commercial systems, if the systems meet labor requirements issued by the Treasury Department, but neither are included in the pricing.	50,315	-	\$4,671	\$113,750	\$34,125	\$79,625	(\$39,859)	17.0
TOTALS (Recommended Measures)		293,327	32,222	\$54,453	\$134,970	\$34,125	\$100,845	\$277,916	1.9

2.3 ENERGY AND WATER EFFICIENCY MEASURES (EWEM) TABLE

The following EWEMs have been analyzed using calculations based on occupant usage, localized climate conditions, HVAC and ventilation operating hours, and lighting hours. The HVAC operating hours are approximations and may vary depending on the severity of the weather. Water consumption is based on the number of occupants and assumed running times for water consuming devices. The Property has been carefully evaluated for the EWEMs. The chart shows the initial investment, utility savings, utility cost savings, and paybacks for each EWEM. The utility cost increase over the life of the EWEMs implemented was not considered as a factor in the cost savings calculations.

EWEM Summary

EWEM Summary Description	Initial Cost	Electric Savings kWh	Gas Savings Therm	Water/ Sewer Savings kGal	Annual Utility \$ Savings	Simple Pay Back (Years)	Owner % Energy Savings	Owner % Water Savings	Projected GHG Emissions Reduction MTCO ₂ e
Program Supply Temperature Reset (approximately 2.5 F) from 48 F to 50.5 F for the LAB AHU's at Building 1801	\$5,500	102,261	20,450	0	\$26,770	0.2	4.42%	0.00%	140.16
Program Supply Temperature Reset (approximately 3 F) from 55 F to 58 F for the Packaged Rooftop Units at Building 1	\$7,500	108,137	11,772	0	\$19,927	0.4	2.85%	0.00%	96.30
Program Demand Control Ventilation for the three Packaged Rooftop Units at Building 1, and install CO ₂ sensors at the office spaces	\$7,500	29,350	0	0	\$2,725	2.8	0.18%	0.00%	9.30
Provide Daylight Controls Near Skylights and Exterior Glass	\$720	3,264	0	0	\$303	2.4	0.02%	0.00%	1.03
Install 35 kW DC Solar PV system on available roof area- Since roof area is limited, a ground mount or placement at parking garage roof is possible. (Approximately 100 modules.) Note that a 30% Federal Investment Tax Credit is available for commercial systems, or a production credit of \$0.026/kWh of production credit for commercial systems, if the systems meet labor requirements issued by the Treasury Department, but neither are included in the pricing.	\$113,750	50,315	0	0	\$4,670	24.4	0.32%	0.00%	15.94
Totals	\$134,970	293,327	32,222	0	\$27,229	4.96	7.79%	0.00%	262.73

2.4 ENERGY BENCHMARKING

The owner obtained whole Property utility data from the utility company. The campus' energy use was input into Energy Star Portfolio Manager to produce a baseline year Statement of Energy Performance (SEP) score. However, for this property type, a SEP score cannot be produced. The site energy use intensity (EUI) is calculated to be 278 kBtu/ft² and the National Median site EUI is 175 kBtu/ft².

3.0 BACKGROUND

3.1 PROPERTY DESCRIPTION

The Property is a parcel totaling approximately 20.38 acres and is located at Property Address in a commercial area of City, State. The Property is improved with One commercial building with lab in One two story building with other stories added recently in the major renovation. The older portion of the building was previously operated as department store in the early 1950's.

The net rentable area of all the combined units is 195,000 square feet and the gross building area of the Property is 195,000 square feet. The Property was originally developed in 1950 and underwent a substantial renovation in 2014.

The facility description is as follows: Property. follows the science, to find new ways to manage rare and often hard-to-treat diseases. By deciphering new pathways, and to discover first-of-their-kind treatments.

Since their start in 2002 with a small number of scientists, chemists and biologists in City, State, Client Name has grown into a global organization with a robust portfolio of treatments across Oncology and Inflammation & Autoimmunity. Today this passion for innovation is stronger than ever with a team of more than 2,000 employees.

The company takes a comprehensive approach to identifying new treatments for patients with cancer, enabling the company to explore both single agents and combinations of targeted and immuno-therapies from both within and beyond their portfolio. The company appears to collaborate with major universities and other companies to bring additional discovery platforms and therapeutics forward. Incyte's targeted therapy discovery efforts focus on identifying therapeutic intervention points within interdependent pathways that drive tumor growth, enabling them to leverage cross-program knowledge. Complementary to that is their immuno-therapy discovery strategy, which is built on a deep understanding of functional genomics, pharmacodynamics and state-of-the-art bioinformatics. Insights into the nuances of immune surveillance in health and disease are leading us to new opportunities to harness the immune system to fight cancer. The facility has world-class chemistry and biology groups to apply these learnings to develop small molecule, monoclonal antibody and bispecific antibody drug candidates for clinical testing.

As a result of the vast research several process systems (mainly industrial lab ventilation systems) are used for scientific and biologic research into various diseases including cancer. Several hundred lab fume hoods are used in conjunction with conducting research and clinical trials.

Amenities include a central cafeteria room with kitchen which is quite large in floor space. The Property does have an in-ground automatic sprinkler system.

The Project Team assessed a representative sample of the tenant spaces. The assessment also included the roof, parking areas and structures, building operational and structural components, and all exterior and common areas.

The site contact was Key Site Manager Name; phone: (215) 917-5226

Photographs



Side Elevation at the Building



LED Lights Lunch Area



Office LED Lighting-Typical



Rooftop at Bldg 1

EXISTING ENERGY AND WATER EFFICIENCY MEASURES AT THE PROPERTY

The following existing energy and water efficiency improvements were observed at the subject property:

1. High efficiency LED lighting for most areas
2. Double glazed metal framed windows
3. High efficiency air handling units with integrated variable speed drives
4. Occupancy sensors for all major lighting zones in the corridor and private offices
5. Occupancy sensor camera devices as part of the phoenix control valves at all lab spaces
6. CHW and HHW pumps equipped programmed for variable flow and variable speed drives
7. Programmable thermostats and Central EMS system which controls all the Lab exhaust fans, air handling units, and the three large packaged rooftop units.

3.2 OCCUPANCY AND USE SCHEDULES

The facility consists of several office spaces and lab spaces which encompass a large percentage of building 1. The estimated occupancy schedule is shown below.

Occupancy Schedule

Space	# of Occupants	Mon	Tues	Wed	Thurs	Fri	Sat	Sun
Leasing Office	800	9 hours	9 hours	9 hours	9 hours	9 hours	0	0
Lab Spaces	1000	24/7	24/7	24/7	24/7	24/7	24/7	24/7
Facility office	15 (Estimated)	8 hours	8 hours	8 hours	8 hours	8 hours	4 hours-estimated	0
Cafeteria	200-depending on lunch and breakfast schedules	4 hours	4 hours	4 hours	4 hours	4 hours	0	0

3.3 UTILITY ANALYSIS

The utility analysis covers the period of September 2022 to August 2023 and is based on bills obtained from the property owner. In the case of tenant bills a sample is normally used to establish an average energy consumption for the different size units. Both the electric and gas utilities are then converted to a common unit (kBtu's) so that the total energy can be examined and project an Energy Use and Cost Intensity for the property. The EUI can then be used to compare the property against similar properties to determine how efficiently the building is being operated.

EEM Summary Table		
Current Building Energy Usage	54,203,297	kBtu
Current Building Energy Cost	\$904,650	\$\$\$
Proposed Energy Savings	4,223,318	kBtu
Proposed Energy Cost Savings	\$27,229	\$\$\$
Energy Savings	7.8%	%
Energy Cost Savings	3.0%	%
Investment for ECM's	\$134,970	\$\$\$
Payback for Investments	4.96	Years
Site Energy Use		
Current Electric Site Energy	23,813,240	kBtu
Current Natural Gas Site Energy	30,390,056	kBtu
Total Building Area	185,000	SF
Proposed Electric Savings (kBtu)	1,001,125	kBtu
Proposed Gas Savings (kBtu)	3,222,193	kBtu
Site Energy Use Intensity		
Current Site Energy Use Intensity	277.97	kBtu/SF
Proposed Site Energy Use Intensity	256.31	kBtu/SF
Site Greenhouse Gas Emissions		
Current Site GHG Emissions	3812.69	MTCO2e/Yr
Proposed Site GHG Emissions	3549.96	MTCO2e/Yr
Source Energy Use Intensity		
Current Source Energy Use Intensity	505.57	kBtu/SF
Proposed Source Energy Use Intensity	473.85	kBtu/SF

3.3.1 UTILITY PROVIDERS



Utility Type	Utility Provider Name
Electricity	Utility Provider
Natural Gas	Utility Provider
Water	Utility Provider
Sewage Disposal/Treatment	Utility Provider

3.3.2 ELECTRICITY

The chart below shows the monthly consumption and cost of electric power for the Property. The cost per kWh is calculated in the fourth column. The bottom row shows the annual electrical power consumption and cost for the Property.

Electricity Chart



Billing Month & Year	Monthly Electricity Usage (kWh)	Monthly Electricity Cost	Cost per kWh	kBTU Usage (kWh x 3.41)
September-22	654,630	\$57,271	\$0.09	2,233,598
October-22	588,902	\$44,821	\$0.08	2,009,334
November-22	615,968	\$54,232	\$0.09	2,101,683
December-22	511,272	\$48,552	\$0.09	1,744,460
January-23	491,712	\$70,517	\$0.14	1,677,721
February-23	527,684	\$60,612	\$0.11	1,800,456
March-23	584,849	\$52,721	\$0.09	1,995,505
April-23	551,960	\$50,730	\$0.09	1,883,288
May-23	677,398	\$58,043	\$0.09	2,311,282
June-23	727,726	\$61,600	\$0.08	2,483,001
July-23	761,546	\$64,518	\$0.08	2,598,395
August-23	285,615	\$24,286	\$0.09	974,518
Annual Electricity Usage & Cost:	6,979,262	\$647,902	\$0.09	23,813,240



3.3.3 NATURAL GAS

The chart below shows the monthly consumption and cost of the natural gas for the Property. The cost per Therm is calculated in the fourth column. The bottom row shows the annual natural gas consumption and cost for the Property.

Billing Month & Year	Monthly Natural Gas Usage (Therms)	Monthly Natural Gas Cost	Cost per Therm	kBTU Usage (Therms x 100)
September-22	19,466	\$20,296	\$1.04	1,946,564
October-22	19,986	\$21,104	\$1.06	1,998,635
November-22	23,550	\$25,577	\$1.09	2,355,048
December-22	29,706	\$40,115	\$1.35	2,970,587
January-23	34,489	\$46,565	\$1.35	3,448,942
February-23	37,677	\$50,295	\$1.33	3,767,709
March-23	0	\$0	\$0.00	0
April-23	34,659	\$10,859	\$0.31	3,465,924
May-23	29,196	\$10,723	\$0.37	2,919,642
June-23	27,887	\$10,500	\$0.38	2,788,698
July-23	24,501	\$10,426	\$0.43	2,450,085
August-23	22,782	\$10,287	\$0.45	2,278,221
Annual Natural Gas Usage & Cost:	303,901	\$256,748	\$0.84	30,390,056



3.3.4 WATER AND SEWER

Water consumption and cost data were not provided.

3.4 END USE ANALYSIS


The following table presents the approximate end use analysis for all energy utilities on the Property:

Conversion Factor to kBtu

Input Unit 1	kWh	3.412142
Input Unit 2	therms	100
Input Unit 3	gallons (propane)	91.33
Combined Output Units	kBtu	1
Building Gross Floor Area	195,000	
Floor Area Units	ft^2	

End Use	Input Energy Units			Combined Energy Use	
	kWh	therms	gallons (propane)	kBtu	%
Air Compressors	-	-	-	-	0%
Cooking	-	-	-	-	0%
Cooling	4,922,667	-	-	16,796,838	31%
Heating	875,000	227,926	-	25,778,255	48%
Lighting (Exterior)	-	-	-	-	0%
Lighting (Interior)	200,665	-	-	684,697	1%
Miscellaneous	-	-	-	-	0%
Office Equipment	-	-	-	-	0%
Other Plug Loads	-	-	-	-	0%
Process	-	-	-	-	0%
Pumps	-	-	-	-	0%
Refrigeration	-	-	-	-	0%
Ventilation	980,930	-	-	3,347,072	6%
Water Heating	-	75,975	-	7,597,514	14%
Total Estimated	6,979,262	303,901	-	54,204,377	100%
Historical Billing	6,979,262	303,901	-	54,204,288	
Percent of Actual	100.0%	100.0%	0.0%	100.0%	
Total per ft^2	35.8	1.6	-	278.0	

Combined Fuel End-Use Breakdown



4.0 BUILDING SYSTEMS

4.1 OCCUPANCY

AEI visited approximately 80% of the building and 100% of all common areas which include all exterior common areas, observed the central BAS system, and conducted surveys on all of the mechanical equipment.

4.2 BUILDING ENVELOPE

4.2.1 FOUNDATION

The lab and corporate office buildings appear to be a steel braced frame structure and consists of a shallow foundation (thickened and reinforced concrete slab). The ground floor has standard concrete slab-on-grade construction that span to concrete beams, columns, and bearing walls. The foundations appeared to be in good condition.

4.2.2 FLOOR

4.2.3 STRUCTURE

The structures appears to be metal wood framed with wood truss joists and wood load bearing beams and columns.

4.2.4 EXTERIOR WALLS

The primary cladding on the exterior appears to be high end stucco with smooth brick and metal framing, with R-15 insulation (estimated). The exterior cladding appears to be in good condition.

Photographs



Side Elevation at the LAB Bldg 1801

4.2.5 DOORS AND WINDOWS

The entry doors into the buildings are metal framed. The weather stripping on each observed door appeared to be in good condition.

Glazing systems at the property consist of aluminum framed curtain wall ribbon window systems. The high curtain wall systems appear to be mostly double pane windows with metal frames, but the windows do not appear to be storm rated. Flashing at the building appears to be in good condition.

Photographs



Dual Pane Metal Framed Window

4.2.6 ROOF

The roof type is a standard TPO (Thermoplastic Polyolefin). No roof warranty was provided for our review. Roof accessories consist of mechanical equipment, plumbing vents, roof hatch, metal platform, limited telecommunication arrays and utility lines. No mechanical screen walls appear to be on the roof structure. The low-slope roof areas drain to internal roof drains oriented at structural low spots. Overflow drainage is provided by secondary drains adjacent to the primary drains. Internal roof drains appear to discharge to a subgrade drainage system. Skylight structures were observed on the roof which provide daylight to atrium areas on the lower floors.

Low roofs only have primary drains with no secondary drains. Consideration should be made to include secondary drains with next roof replacement. According to estimates, the insulation consists of R-15 rigid insulation.

Photographs



Rooftop at Bldg XXXX




Skylights with LED Lights

4.2.7 INSULATION SUMMARY

Envelope Component	U-Factor	Insulation R-Value
Exterior Walls	0.065	R-15
Rigid Roof Insulation (Polyurethane-Estimated)	0.045	R-25
Windows	0.55	R-1.81
Doors	0.65	R-1.5
Ground Floor	0.35	R-2.85
Between Floors	0.07	R-14 (Estimated)

Photographs



Dual Pane Metal Framed Window

4.2.8 LIGHTING

The following tables provide an inventory of observed lighting fixtures, lamp type, and wattage.

Lighting Audit (Common Area)

Area of Building	Existing Fixture	Total # Fixtures	Lamps Per Fixture	Total # of Lamps	LED Equivalent Wattage	Current kWh Usage	kWh Usage w/ LED	kWh Saved Per Year	Cost Per kWh	Current Annual Op Cost	Annual Cost Using LEDs	Savings	Cost to Install Lighting	Payback
Exterior Pole Lighting	1B 60W LED	50	1	50	0	13140	0	0	0.09	\$1,220	\$0	\$0	\$0	-
Wall Packs	1B 22W LED	80	1	80	0	7709	0	0	0.09	\$716	\$0	\$0	\$0	-
Parking Garage Lighting	1B 50W LED	20	1	20	0	8760	0	0	0.09	\$813	\$0	\$0	\$0	-
Office Recessed Can	1B 15W LED	120	1	120	0	5616	0	0	0.09	\$521	\$0	\$0	\$0	-
Common Corridor	1B 20W LED	150	1	150	0	9600	0	0	0.09	\$891	\$0	\$0	\$0	-
Office Linear Fixtures	2B 30W LED	550	2	1100	0	105600	0	0	0.09	\$9,803	\$0	\$0	\$0	-
Stairwells	2B 20W LED	350	2	700	0	44800	0	0	0.09	\$4,159	\$0	\$0	\$0	-
Common Corridor with Glass-Near Daylight	1B 20W LED	80	1	80	0	5,440	2,176	3,264	\$0.09	\$505	\$202	\$303	\$720	2.4

Photographs



2nd View Office LED Lighting



Corporate Office LED Lighting



Corridor LED Lighting



LED Lighting At Restroom

4.2.9 BUILDING MECHANICAL SYSTEMS

The heating and cooling systems consist of three large rooftop packaged AC units which serve the general occupied areas at various sections of the building. Additionally there are five large air handling units (AHU's) which primarily serve the lab spaces in the building on most floors of the building. There are three large exhaust lab hood fans which simultaneously exhaust air from the lab spaces and associated areas that need to be continuously exhausted from the areas that undergo biological and chemical processes in the building.

The ductwork from the lab units contains several zones which contain heating hot water reheat coils supplied by the central boilers for the heating source. The tonnages of the packaged rooftop units range from 60 to 80 tons. The supply fans on each of these large RTU's are equipped with VFD's. The rated efficiency of these units is approximately 9.5 to 10 EER.

The building is heavily centered on the function of laboratory fume hoods utilizing phoenix controls and occupancy camera sensors which can affect the sash opening levels. There are approximately 250 lab hoods in the building and are monitored by the building automation system. The AHU's serving the Lab areas have a supply temperature of 48°F to maintain

approximately 70°F in all the lab zones. Two 500 ton variable speed water cooled chillers provide chilled water to the five air handling units and utilize a variable chilled water pumping system, in which the chilled water pumps are equipped with VFD's.

The heating and cooling systems throughout Building 1 are controlled by the central BMS system. The front end is located in the facility manager's office however it appears the facility manager indicated the system can be controlled remotely as the system is web based and can be accessed at any location.

Domestic hot water is produced by four large natural gas water heaters that provide comfort and process domestic hot water throughout the building.

HVAC Equipment

Location or Unit Address	Description	Manufacturer	Model No.	Year of Manufacture	RUL	Quantity	Heating Fuel	Heating Capacity	Heating Efficiency (AFUE, TE, COP, HSPF)	Cooling Capacity (Tons)	Efficiency
Rooftop	Lab Exhaust Fans with VFD's	Strobic	TS4L750 Series	2014	12	3	N/A	N/A	0.9	1.1	11 EER (Est)
Rooftop-RTU's	Gas fired RTU	Daikin	MPS075E	2014	12	3	Gas	800 MBH	0.8	72	9.2 EER
Rooftop-LABs	AHU's	Aerofin	W120AW	2014	12	5	HHW	11.2 MBH	N/A	120	N/A
Mechanical Room	Water Cooled Chiller	York	YKH3F3P8	2014	16	2	N/A	N/A	N/A	500	11 EER
Zone Level	VAVs with hydronic reheat	Envirotech	SDR	2014	16	35	HHW	6 to 25 MBH	0.8	N/A	N/A
Mechanical Room	Steam Boiler	Triad High Press	Ser. 2000	2014	20	3	Gas	1513 lbs	0.7	N/A	N/A

Domestic Water Heating

Location of Unit Address	Manufacturer	Model No.	Year of Manufacture	Storage Capacity (Gal)	Input Capacity	Input Units of Measure (kW, BTUH, MBH)	Fuel (e.g., electric, natural gas)	Quantity	RUL	Efficiency (TE, AFUE, Energy Factor, etc.)
Mechanical Room	PVI	Unknown	2016	100	150	MBH	natural gas	4	12	96% TE

Photographs



Domestic Water Heater for LAB Areas



Strobic Fans and Rooftop



2nd set of Strobic Fans



Typical LAB Hood with Sash Control

4.2.10 APPLIANCES

There are no major appliances at the property.

4.2.11 LAUNDRY EQUIPMENT

There are no central laundry systems on the Property.

5.0 RECOMMENDED EEMS

The EEMs in the chart at the beginning of the report have been analyzed using calculations based on occupant usage, localized climate conditions, HVAC and ventilation operating hours, and lighting hours. The HVAC operating hours are approximations and may vary depending on the severity of the weather. Water consumption is based on the number of occupants and assumed running times for water consuming devices. The Property has been carefully evaluated for the EEMs. The chart shows the initial investment, utility savings, utility cost savings, and paybacks for each EEM. The utility cost increase over the life of the EEM implemented was not considered as a factor in the cost savings calculations.

5.1 NO-COST/LOW-COST MEASURES

There were no low cost measures identified for this site. Capital measures have been identified in the Capital Projects section.

5.2 CAPITAL COST MEASURES

EEM #1- Program Supply Temperature Reset (approximately 2.5°F) from 48°F to 50.5°F for the LAB AHU's at Building 1

The existing EMS control system operating the five Lab air handling units appear to be currently at constant temperature setpoint of 48°F providing conditioned air to all the Lab spaces. It is proposed to provide a supply temperature discharge air temperature reset strategy which is selectable by the operator with an option for a fixed supply air temperature setpoint as well. All reset strategies shall be stepwise and reset every five (5) minutes (adj.). All reset values shall be adjustable and available to the operator.

The measure will include installation and is estimated at approximately \$5,500.

Increasing the setpoint will reduce energy consumption on the LAB air handling units and Strobic exhaust fans as well as decrease the cooling load on the existing VFD chillers. One concern is that the process equipment could increase in heat load however a mild reset (at approximately 2°F) is still recommended which may not cause a heavy impact to the work spaces. The discharge air temperature setpoint is selected by the operator and set to a fixed value.

Some control adjustments from the facility manager and or contracted controls contractor may be required

Potential O&M savings: the long term O&M savings will result from operating fans at lower RPM and power, generating less wear on fan belts, housing, and motors. Installation and commissioning of this control measure can be installed with little impact on occupants and personnel.

There may be custom rebates available thru Delmarva Power, however an inquiry needs to be made as to the dollar amount per kWh saved for which the measure will qualify. The following is the weblink for applying for custom rebates thru Delmarva Power, which is the link for custom incentives:

website.com

EEM #2- Program Supply Temperature Reset (approximately 3°F) from 55°F to 58°F for the three Packaged Rooftop Units at Building 1

The existing EMS control system operating the three main packaged units appear to be currently at constant temperature setpoint of 48°F providing conditioned air to all the Lab spaces

The measure will include installation and is estimated at approximately \$7,500 based on an average cost of \$2,500 per control point that would need to be adjusted.

Increasing the setpoint will reduce energy consumption on the supply fans as well as decrease the cooling load on the existing Packaged RTU compressors This will also interactively reduce the heating required by the gas furnaces at the units and will save natural gas energy.

There should be no concerns on this measure as this resets the supply temperature by approximately 3°F during lower load conditions and appears to serve non-lab or non-critical areas of the building.

Some control adjustments from the facility manager and or contracted controls contractor may be required

Potential O&M savings: the long term O&M savings will result from operating fans at lower RPM and power, generating less wear on fan belts, housing, and motors. Installation and commissioning of this control measure can be installed with little impact on occupants and personnel.

There may be custom rebates available thru Delmarva Power, however an inquiry needs to be made as to the dollar amount per hp for which the measure will qualify.

The following is the weblink for applying for custom rebates through utility company, which is the link for custom incentives : website.com

EEM #3-Provide Demand Control Ventilation to three Packaged Rooftop Units with CO₂ sensor controls

The three existing Packaged Rooftop Units do not appear to be equipped with demand control ventilation

Measure will be installed at the unit with demand controls and CO₂ sensors to detect occupancy in some limited office spaces inside the building at office and limited corridor spaces.

Demand-controlled ventilation (DCV) is an energy-saving control strategy that reduces the rate at which outdoor air is delivered to a zone during periods of partial occupancy, which does appear to occur in the office portions of the building

The measure will include installation and is estimated at approximately \$7,500 based on an average cost of \$2,500 per control point that would need to be adjusted to re-program supply temperature setpoints. Assumes a constant supply temperature of approximately 55 F and some modulation of the outside air dampers but does not appear to be occupancy based, but rather temperature based.

Provide Demand Control Ventilation internal controls to three Packaged Rooftop Units with CO2 sensor controls. A sample case study is shown in the appendices.

Some control adjustments from the facility manager and or contracted controls contractor may be required

Potential O&M savings: the long term O&M savings will result from operating fans at lower RPM and power, generating less wear on fan belts, housing, and motors. Installation and commissioning of this control measure can be installed with little impact on occupants and personnel.

There may be custom rebates available thru Delmarva Power, however an inquiry needs to be made as to the dollar amount per hp for which the measure will qualify.

The following is the weblink for applying for custom rebates through Utility company which is the link for custom incentives : [Delmarva Power | Delmarva Power - An Exelon Company \(programprocessing.com\)](http://www.delmarvapower.com/programprocessing.com)

EEM #4- Provide Daylight Controls Near Skylights and Exterior Glass at Building 1

Existing LED interior lighting have areas at the building that could be controlled by day light controls.

AEI recommends: Installing daylight controls in some glass areas and skylit areas of the building to provide day light harvesting and reduce lighting power when sufficient daylight is available.

Basis for how the measure will save energy: Installing high-efficiency day light sensor controls will significantly reduce the property's electrical consumption while maintaining equivalent or better light levels. In addition, many of the recommended bulbs and fixtures have longer lifespans, which will reduce the number of bulbs replaced at the property.

The measure is expected to cost approximately \$720.

Key analytical assumptions: Lighting without day light controls uses more energy as verified by nameplate and heat output

The selected LED lamps should have a color temperature around 2,700K to 3,000K to provide the same "feel" as incandescent lighting.

Energy usage will decrease and lamp replacement frequencies will be less frequent.

Rebates/Incentives available from utility company or municipality: Possible incentives are available through Utility Company Generally an account executive is assigned to the property and a custom rebate may be available. No prescriptive rebates were found for this measure.

EEM #5

Install 35 kW Solar PV system on available roof area. (Approximately 100 modules.). Note that a 30% Federal Investment Tax Credit is available for commercial systems, or a production credit of \$0.026/kWh of production credit for commercial systems, if the systems meet labor requirements issued by the Treasury Department, but neither are included in the pricing.

The building has a high electricity baseload, installation of a solar PV array would offset a percentage of the load.

There is ample space on the south flat roof sections to install a solar PV system. The property is located in a region with a significant solar days.

The estimated cost of this measure is \$113,750. A 30% Federal tax rebate is available, but is not accounted for the in the proposed cost.

Solar modules not only generate electricity but also provide shading to the roof membrane and partly protect it from weather.

The installation of the system will not affect any facility operation.

EEM SIMULATION RESULTS

Input parameters in each modeled building were changed to reflect the proposed changes in conditions then a simulation was run to predict the results. The simulation tool considers the interactive effects on all systems such as increased heating requirements from retrofitting high wattage lighting with lower wattage LED lighting. The following tables provide a summary of the EWEMs evaluated and the simulation results showing projected use per building type, subtotal for all buildings by type, total for all buildings, and the projected reduction in consumption.

Note that EEM #1 thru 3 was not modeled, but rather was the result of lighting calculations based on an inventory of common area and site lighting. Modeling was not necessary as consumption for lighting is included in the owner-paid utilities.

ENERGY MODEL ASSUMPTIONS

The following assumptions were made in building the building energy model:

An approximation was made on the following based on observations during the site visit and plan drawings

- Local Vegetation/shading
- Interior conditions and HVAC set points
- Air infiltration goals
- Building orientation (should rotate the model to 4 compass points and average the modeled usage).
- Lighting loads W/SF
- Plug loads W/SF
- Schedules (lighting, plug loads)
- HVAC equipment types and efficiencies
- Economizers and heat recovery
- Water heating systems
- Specialty Systems
- Renewable energy systems

6.0 SIGNATURES OF PARTICIPATING PROFESSIONALS

AEI Consultants performed this ASHRAE Level II Energy Audit for the Property located at Property Address, City, County County, State, in conformance with the scope and limitations of ASHRAE *Procedures for Commercial Building Energy Audits, Second Edition*, ANSI/ASHRAE/ACCA Standard 211-2018, *Standard for Commercial Building Energy Audits*.

Prepared By:
Project Manager

Reviewed By:
Vice President

APPENDIX B

SUPPORTING DOCUMENTATION

ASHRAE Equipment Life Expectancy chart

ASHRAE is the industry organization that sets the standards and guidelines for most all HVAC-R equipment.
For additional info about ASHRAE the website is www.ashrae.org .

Equipment Item	Median Years	Equipment Item	Median Years	Equipment Item	Median Years
Air conditioners		Air terminals		Air-cooled condensers	20
Window unit	10	Diffusers, grilles, and registers	27	Evaporative condensers	20
Residential single or Split Package	15	Induction and fan coil units	20	Insulation	
Commercial through-the wall	15	VAV and double-duct boxes	20	Molded Blanket	20 24
Water-cooled package	15	Air washers	17	Pumps	
Heat Pumps		Ductwork	30	Base-mounted	20
Residential air-to-air	15	Dampers	20	Pipe-mounted	10
Commercial air-to-air	15	Fans		Sump and well	10
Commercial water-to-air	19	Centrifugal	25	Condensate	15
Roof-top air conditioners		Axial	20	Reciprocating engines	20
Single-zone	15	Propeller	15	Steam turbines	30
Multi-zone	15	Ventilating roof-mounted	20	Electric motors	18
Boilers, hot water (steam)		Coils		Motor starters	17
Steel water-tube	24 (30)	DX, water, or steam	20	Electric transformers	30
Steel fire-tube	25 (25)	Electric	15	Controls	
Cast iron	35 (30)	Heat Exchangers		Pneumatic	20
Electric	15	Shell-and-tube	24	Electric	16
Burners	21	Reciprocating compressors	20	Electronic	15
Furnaces		Packaged chillers		Valve actuators	
Gas- or oil-fired	18	Reciprocating	20	Hydraulic	15
Unit heaters		Centrifugal	23	Pneumatic	20
Gas or electric	13	Absorption	23	Self-contained	10
Hot water or steam	20	Cooling towers			
Radiant Heaters		Galvanized metal	20		
Electric	10	Wood	20		
Hot water or steam	25	Ceramic	34		



Caution: Photovoltaic system performance predictions calculated by PVWatts® include many inherent assumptions and uncertainties and do not reflect variations between PV technologies nor site-specific characteristics except as represented by PVWatts® inputs. For example, PV modules with better performance are not differentiated within PVWatts® from lesser performing modules. Both NREL and private companies provide more sophisticated PV modeling tools (such as the System Advisor Model at //sam.nrel.gov) that allow for more precise and complex modeling of PV systems.

The expected range is based on 30 years of actual weather data at the given location and is intended to provide an indication of the variation you might see. For more information, please refer to this NREL report: The Error Report.

Disclaimer: The PVWatts® Model ("Model") is provided by the National Renewable Energy Laboratory ("NREL"), which is operated by the Alliance for Sustainable Energy, LLC ("Alliance") for the U.S. Department Of Energy ("DOE") and may be used for any purpose whatsoever.

The names DOE/NREL/ALLIANCE shall not be used in any representation, advertising, publicity or other manner whatsoever to endorse or promote any entity that adopts or uses the Model. DOE/NREL/ALLIANCE shall not provide any support, consulting, training or assistance of any kind with regard to the use of the Model or any updates, revisions or new versions of the Model.

YOU AGREE TO INDEMNIFY DOE/NREL/ALLIANCE, AND ITS AFFILIATES, OFFICERS, AGENTS, AND EMPLOYEES AGAINST ANY CLAIM OR DEMAND, INCLUDING REASONABLE ATTORNEYS' FEES, RELATED TO YOUR USE, RELIANCE, OR ADOPTION OF THE MODEL FOR ANY PURPOSE WHATSOEVER. THE MODEL IS PROVIDED BY DOE/NREL/ALLIANCE 'AS IS' AND ANY EXPRESS OR IMPLIED WARRANTIES, INCLUDING BUT NOT LIMITED TO THE IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE ARE EXPRESSLY DISCLAIMED. IN NO EVENT SHALL DOE/NREL/ALLIANCE BE LIABLE FOR ANY SPECIAL, INDIRECT OR CONSEQUENTIAL DAMAGES OR ANY DAMAGES WHATSOEVER, INCLUDING BUT NOT LIMITED TO CLAIMS ASSOCIATED WITH THE LOSS OF DATA OR PROFITS, WHICH MAY RESULT FROM ANY ACTION IN CONTRACT, NEGLIGENCE OR OTHER TORTIOUS CLAIM THAT ARISES OUT OF OR IN CONNECTION WITH THE USE OR PERFORMANCE OF THE MODEL.

The energy output range is based on analysis of 30 years of historical weather data, and is intended to provide an indication of the possible interannual variability in generation for a Fixed (open rack) PV system at this location.

RESULTS

50,315 kWh/Year*

System output may range from 47,830 to 52,147 kWh per year near this location.

Month	Solar Radiation (kWh / m ² / day)	AC Energy (kWh)
January	3.12	3,092
February	3.92	3,432
March	4.99	4,707
April	5.75	5,060
May	5.72	5,033
June	6.14	5,188
July	6.13	5,248
August	5.71	4,941
September	4.99	4,222
October	4.20	3,882
November	3.38	3,144
December	2.41	2,365
Annual	4.71	50,314

Location and Station Identification

Requested Location	wilmington, de
Weather Data Source	Lat, Lng: 39.93, -75.06 29 mi
Latitude	39.93° N
Longitude	75.06° W

PV System Specifications

DC System Size	35 kW
Module Type	Standard
Array Type	Fixed (open rack)
System Losses	8%
Array Tilt	20°
Array Azimuth	180°
DC to AC Size Ratio	1.2
Inverter Efficiency	96%
Ground Coverage Ratio	0.4
Albedo	From weather file
Bifacial	No (0)
Monthly Irradiance Loss	Jan Feb Mar Apr May June 0% 0% 0% 0% 0% 0%
	July Aug Sept Oct Nov Dec 0% 0% 0% 0% 0% 0%

Performance Metrics

DC Capacity Factor**16.4%**

File Edit View Mode Tools Help

Project & Site **Building Shell** Internal Loads Water-Side HVAC Air-Side HVAC Utility & Economics

Actions


- Building Creation Wizard
- Energy Efficiency Measure Wizard
- Simulate Building Performance
- Perform Compliance Analysis
- Review Simulation Results View
- Review Compliance Analysis Report

2-D Geometry 3-D Geometry Spreadsheet Summary


Color Legend

- Exterior Walls
- Interior Walls
- Roofs
- Underground Walls
- Exterior Floors
- Interior Floors
- Ceilings
- Underground Floors
- Windows

Electric Consumption (kWh)



Gas Consumption (Btu)



- Area Lighting
- Exterior Usage
- Water Heating
- Refrigeration
- Task Lighting
- Pumps & Aux.
- Ht Pump Supp.
- Heat Rejection
- Misc. Equipment
- Ventilation Fans
- Space Heating
- Space Cooling

Electric Consumption (kWh x000)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	103.1	95.2	106.3	103.7	170.3	209.7	248.9	243.1	180.0	142.6	107.2	104.1	1,814.5
Heat Reject.	0.4	0.4	0.8	1.0	3.6	5.3	6.8	6.3	4.2	2.5	1.1	0.6	33.1
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	-	-	-	-	-	-	-	-	-	-	-	-	-
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	-	-	-	-	-	-	-	-	-	-	-	-	-
Vent. Fans	38.9	35.6	40.4	38.2	40.7	40.2	40.4	42.0	39.0	39.8	37.8	38.7	471.8
Pumps & Aux.	47.5	42.7	47.0	45.2	47.6	46.8	48.3	48.6	46.2	47.1	45.1	46.7	558.8
Ext. Usage	9.3	7.2	7.9	7.7	5.5	5.3	5.5	8.9	8.6	8.9	9.0	9.3	93.3
Misc. Equip.	140.9	131.2	152.6	139.7	148.7	146.8	141.7	152.6	139.7	144.8	138.9	141.6	1,719.4
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	129.1	122.1	145.4	129.7	139.9	139.3	130.2	145.4	129.5	134.6	128.5	130.2	1,603.9
Total	469.3	434.4	500.4	465.3	556.4	593.5	621.9	646.9	547.2	520.4	467.7	471.2	6,294.7

Gas Consumption (Btu x000,000,000)

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Space Cool	-	-	-	-	-	-	-	-	-	-	-	-	-
Heat Reject.	-	-	-	-	-	-	-	-	-	-	-	-	-
Refrigeration	-	-	-	-	-	-	-	-	-	-	-	-	-
Space Heat	2.24	1.92	1.92	1.71	1.41	1.08	1.05	1.07	1.22	1.59	1.84	2.09	19.13
HP Supp.	-	-	-	-	-	-	-	-	-	-	-	-	-
Hot Water	0.02	0.02	0.03	0.03	0.03	0.02	0.02	0.02	0.02	0.02	0.02	0.02	0.28
Vent. Fans	-	-	-	-	-	-	-	-	-	-	-	-	-
Pumps & Aux.	-	-	-	-	-	-	-	-	-	-	-	-	-
Ext. Usage	-	-	-	-	-	-	-	-	-	-	-	-	-
Misc. Equip.	-	-	-	-	-	-	-	-	-	-	-	-	-
Task Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Area Lights	-	-	-	-	-	-	-	-	-	-	-	-	-
Total	2.27	1.95	1.95	1.73	1.43	1.10	1.07	1.09	1.24	1.61	1.86	2.11	19.41

ABBREVIATIONS AND ACRONYMS

AC	Air Conditioning	kBTU	Kilo-British Thermal Unit
AEI	AEI Consultants	kGal	Kilogallons
ALTA	American Land Title Association	kW	Kilowatt
APN	Assessor's Parcel Number	kWh	Kilowatt hour
ASHRAE	American Society of Heating, Refrigerating and Air-Conditioning Engineers	LED	Light Emitting Diode
BTU	British Thermal Unit	M	Model
CH	Clubhouse	MBH	1,000 BTUs/hour
DHW	Domestic Hot Water	O	Occupied
ECM	Energy Conservation Measure	OFC	Office
EEM	Energy Efficiency Measures	OSHA	Occupational Safety and Health Administration
EUI	Energy Use Intensity	PCA	Property Condition Assessment
EUL	Estimated Useful Life	PCR	Property Condition Report
EWEM	Energy and Water Efficiency Measures	ROI	Return On Investment
F	Fahrenheit	RP	Responsible Party
FCU	Fan Coil Unit	SEDI	Statement of Energy Design Intent
Gal	Gallon	SF	Square Footage/Square Feet
GFA	Gross Floor Area	SIR	Savings to Investment Ratio
GPF	Gallons Per Flush	SP	Subject Property
GPM	Gallons Per Minute	SEP	Statement of Energy Performance
HUD	Department of Housing and Urban Development	V	Vacant
HVAC	Heating, Ventilation and Air Conditioning	□AR	Zoning Analysis Report

RESOLUTION

NOW, THEREFORE BE IT RESOLVED that the following Budget Amendment for the EGLE Grant revenue and expenditures is authorized:

	INCREASE (DECREASE)
GENERAL FUND	
REVENUES	
State Grant (101-000.00-540.100)	100,000
TOTAL REVENUES	<u>\$ 100,000</u>
APPROPRIATIONS	
Other Services and Charges (101-265.00-816.074)	100,000
TOTAL APPROPRIATIONS	<u>\$ 100,000</u>
Net Increase (Decrease) to Fund Balance	<u><u>\$ -</u></u>

I hereby certify that the foregoing is a true and complete copy of a resolution adopted by the City Council of the City of Novi at a regular meeting held on March 25, 2025

Cortney Hanson
City Clerk