CITY OF NOVI CITY COUNCIL NOVEMBER 17, 2025



SUBJECT:

Consideration of tentative approval of The Grove PRO to rezone from Office Service Technology to Low Density Multiple Family with a Planned Rezoning Overlay. The applicant is proposing to develop a 232-unit multiple-family townhome development.

SUBMITTING DEPARTMENT: Community Development, Planning

KEY HIGHLIGHTS:

- Rezoning 62 acres of vacant land at 12 Mile and Meadowbrook Roads to RM-1.
- The applicant is proposing to develop a 232-unit townhome development.
- Council's initial consideration of the PRO was on December 16, 2024; the plans have since been modified to reduce the number of units by over 200 and the number of deviations requested and enhance the benefits to the community at large.
- The project design represents a high-quality community with a focus on connectivity, preservation of a significant amount of wetland and woodland areas and exceeding open space requirements.
- All of the units will be for-sale homes, and a majority can accommodate a primary bedroom on the main floor to promote aging-in-place.
- Planning Commission recommended approval of the PRO Plan on October 8, 2025.

BACKGROUND INFORMATION:

The petitioner is requesting a Zoning Map Amendment for approximately 62 acres of property on the south side of Twelve Mile Road, east of Meadowbrook Road (Section 13). The applicant is proposing to rezone property from Office Service Technology (OST) to Low Density Multiple Family (RM-1) using the City's Planned Rezoning Overlay (PRO) option.

The recently adopted Master Plan identifies this property and those around it in purple as General Mixed Use. The area to the east is Public/Quasi-Public, and north of 12 Mile is Public Park, Community Commercial, and Single Family.

The subject parcel and all parcels surrounding it are zoned Office Service Technology (OST), which reflects the historic development pattern of this area. To the west of the property are office buildings and vacant parcels, and one residential home. The parcel to the south is Meadowbrook Corporate Park office buildings and preserved common area. To the east is a large MDOT-owned parcel with the Ingersol Regional Detention Basin and Ingersol Creek. North of Twelve Mile are the Beacon Hill Trailhead park, the future Beacon Hill retail area, and the future Armenian Church and Cultural Center.

The formal PRO Concept Plan proposes a 232-unit multiple-family townhome development, which was reduced from 438 on their original plan. The applicant has also revised the request to rezone the property to RM-1 Low Density Multiple Family. All of the units are now for-sale townhome units, with over 50% of those having a primary bedroom on the ground level to accommodate aging-in-place. The development consists of four "villages" of homes: The Meadows (67 attached units in 14 buildings), The Vistas (68 attached units in 15 buildings), The Woods (36 attached units in 8 buildings) and The Pointe (61 attached units in 12 buildings). There is also a central park area with amenities, including a pickleball court and a playground park, with an option to locate a clubhouse in that area if determined to be desired in the future. A couple of different designs are provided for the clubhouse depending on size of building selected.

The development is accessed by two entrances off Meadowbrook Road, and one from 12 Mile Road. The stormwater plan shows an interconnected system with 6 detention ponds of various sizes, along with the existing wetland system.

As described in the Wetland Review, each of the delineated wetlands on the site meet the criteria of providing wildlife habitat as well as flood and storm control. Wetland review notes that the proposed development appears to result in a total permanent wetland impact area of 1.44 acres out of the total 9.64 acres present on site (about 15% impact). The full requirement for mitigation is proposed to be provided on-site, as well as the mitigation required for the future development of the "Trinity Parcel."

For woodlands the plan appears to remove about 73% of the regulated trees on the woodland survey. Approximately 250 credits are proposed to be planted on-site, with the remaining credits to be paid into the Tree Fund.

The façade materials have been revised and now the proposed buildings are in full compliance with the standards. In addition, the level of detail and overall character of the designs qualify as an enhancement of the area beyond what could be required by the ordinance, which is in line with the intent of the PRO Ordinance.

The recently adopted Master Plan designates this area as General Mixed Use (GMX). This new category is meant to provide a high degree of flexibility in development, with a site-specific master plan to guide development. "Properties within this designated land use category can also utilize the PUD (Planned Unit Development Option) as a development tool to provide a variety of uses within an approved master plan development." Since the City has not adopted a Planned Unit Development ordinance at this time, the Planned Rezoning Overlay represents the closest option available to achieve the intended vision (the PRO is a form of Planned Unit Development, though more limited than the new Master Plan contemplates).

Some of the possible detriments of the proposal we identified include questions of compatibility and buffering from the adjacent uses that will remain OST. Being adjacent to a residential development will require additional setbacks and possible use restrictions, which can be an added burden to adjacent non-residential landowners, but that would primarily be an issue to the south and the Trinity Parcel, which are not separated by a thoroughfare. The applicant has proposed a berm and dense landscaping along both borders, which will provide screening buffers. The area to the east of the property will remain undeveloped, as it is an MDOT stormwater and wetland mitigation site.

The undisturbed woodland and wetland areas on the site and surrounding properties would allow the proposed use to remain relatively secluded from the commercial properties, as well as provide natural spaces contiguous with adjacent preserved areas, which is beneficial for natural habitat. The remaining undeveloped properties in the area that could develop under the OST zoning district are not likely to cause significantly greater conflicts with residential use on this site, since they are located on the other side of Meadowbrook Road.

Residential development is likely to result in *smaller* wetland and woodland impacts compared to an OST development due to the typical size of buildings and parking needs. OST permitted uses include offices, research & development, data processing, and hotels, which all have a larger footprint and greater surface parking demands than the RM-1 use proposed. The Traffic study notes that the number of residential units would result in fewer vehicle trips compared to an OST development, including during peak hours.

Staff supports the requested rezoning with the stated benefits, conditions, and deviations listed. There are conditions proposed that are more strict or limiting than the RM-1 standards and are found to have an overall benefit to the public. The list of identified benefits of rezoning appears to outweigh the anticipated detriments of introducing residential use to this section of Meadowbrook Road. The number of deviations has been reduced from 16 to 7 as listed in the suggested motion, with each being supported by staff.

The PRO Conditions offered by the applicant that are proposed to establish an overall benefit to the public include:

- A one-acre park area, accessible to residents and the general public, with pedestrian and bike rest stop area, at the northeast corner of the site along 12 Mile Road.
- A one-mile loop Grove nature area trail, accessible to residents and the public, that extends from the newly created park area along the east property line of the Property, providing scenic views of the adjacent 30-acre natural wetland area as well as natural features of the Property.
- In order to address the impact of additional use of Beacon Hill Park by the new residents and planned access and interconnectivity for Novi residents and Grove Nature Trail, Developer agrees to provide the City with \$25,000 to be used by the City at its discretion, for Beacon Hill Park improvements, art, services and/or maintenance.
- Constructing over 700 feet of 10-foot-wide pathway gap on the south side of 12
 Mile Road to create a connection from the existing bike path, located along the
 east side of Meadowbrook Road, and the new sidewalk being constructed with
 The Grove.
- Relocating the SMART bus stop to the east and enhancing the area with landscaping and seating along 12 Mile Road, which is supported by SMART. Additional bike parking has also been added for a total of 8 spaces.
- Approximately 1/3 of the property will be open space with most of the units abutting or overlooking open space and nature areas which significantly exceeds the Ordinance requirement for usable open.

- Consistent with Novi's mobility plans, construct an 8-foot wide shared-use public pathway within The Grove to provide pedestrian and bicycle connectivity between Meadowbrook Road and 12 Mile Road.
- Proposed conservation easements protecting approximately 10 acres of woodland and woodland replacement areas and 15.5 acres of wetland and wetland mitigation areas, which represents over 47% of the property and could not be required under typical development conditions.
- Decrease in density from what would be permissible in the RM-1 zoning district (4.2 units per acre proposed, up to 7.3 units per acre permitted).
- Dedicate right-of-way (60-foot width) along the entire Meadowbrook Road frontage, a total land area of about 2.5 acres.
- As well as additional overall benefits as listed in the suggested motion.

The full list of proposed conditions to be included in the PRO Agreement is included in the suggested motion.

PLANNING COMMISSION

The Planning Commission held a Public Hearing on the formal PRO Plan on October 8, 2025 and recommended approval to the City Council. Comments made at that time are reflected in the meeting minutes included in this packet.

CITY COUNCIL ACTION

If the City Council is inclined to approve the rezoning request with PRO at this time, the City Council's motion would be to direct the City Attorney to prepare a PRO Agreement with specified PRO Conditions. Once completed, the PRO Agreement will return to Council for final approval.

RECOMMENDED ACTION:

Note 3-part motion A-C.


Tentative indication that Council **may approve** the request of Ivanhoe Companies for The Grove JZ24-31with Zoning Map Amendment 18.745, to rezone from Office Service Technology (OST) to Low Density Multiple Family (RM-1), subject to a Planned Rezoning Overlay (PRO) Agreement, and corresponding PRO Concept Plan, and direction to the City Attorney to prepare the PRO Agreement including items A through C:

- A. All deviations from the ordinance requirements shall be identified and included in PRO Agreement, including:
 - 1. A Zoning Ordinance deviation from Section 3.1.7.D to reduce the building setbacks from 75 feet to 50 feet along the north, east, and south property lines, as sufficient screening appears to be proposed.
 - 2. A Zoning Ordinance deviation from Sec. 3.8.2.D to revise the required orientation of the buildings from a minimum of 45 degrees in certain locations. This allows for a more uniform site layout with all of the units backing up to open space/wooded areas.


- 3. A Zoning Ordinance deviation from Sec 3.8.2.H to reduce the building separation distance from the calculated formula as shown on the Building Separation Table on Sheet SP-3.6 of the PRO Plan. This deviation enables the layout of this project to fit within the available space while minimizing wetland and woodland impacts.
- 4. A Zoning Ordinance deviation from Section 5.10 allows for perpendicular parking on the major drives. This deviation is requested due to the impracticality of providing a minor road (defined as less than 600 feet in length) given the site constraints (woodlands, wetlands, and property configuration). Perpendicular parking for guests is proposed on four Major Drives (Simi Drive, Beckham Drive, Elle Parkway, and Ari Crest) in several locations, where driveways are also proposed. The parking spaces will not cause any more disruption on the roadway than cars that will be backing out of the driveways.
- 5. A Zoning Ordinance deviation from Section 5.10 to allow on-street parking on curves with less than a 230-foot centerline radius. The deviation is supported as the parking spaces will not cause any more disruption on the roadway than cars that will be backing out of the driveways.
- 6. A landscape deviation from Section 5.5.3.A.ii to not provide a 4-foot, 6-inch to 6-foot-high landscape berm on a proposed RM-1 district adjacent to an OST district on the east and south side. This deviation is supported because of topography and the provision of dense landscaping along both property lines.
- 7. A landscape deviation from Section 5.5.3.B.ii for the required greenbelt berm and plantings along 12 Mile and Meadowbrook Road due to the existing natural areas to be preserved, and a heavily landscaped detention basin.
- B. The following conditions shall be requirements of the PRO Agreement:
 - 1. Preservation of approximately 10 acres of City regulated woodlands and woodland replacements in a conservation easement.
 - 2. Preservation of approximately 15.5 acres of City regulated wetlands and wetland mitigation areas in a conservation easement.
 - 3. Removal of invasive species within the existing wetlands on site.
 - 4. Density shall not exceed 4.2 dwelling units per acre (More limiting than the dwelling units per acre allowed in the RM-1 District).
 - 5. Providing the community amenities shown in the PRO Plan.
 - 6. As an option, a clubhouse could be placed where the pickleball court and playscape are currently shown. The design of the clubhouse would need to meet Façade ordinance requirements at the time of site plan approval.
 - 7. Dedication of 1,650 linear feet of Right of Way on Meadowbrook Road.
 - 8. Building height will be limited to 30 feet, which is more limiting than the 35 feet permitted in the RM-1 District.
 - 9. The traffic improvements as shown on the PRO Plan.


- 10. If pickleball court(s) are proposed at the time of Preliminary Site Plan submittal, a noise impact statement shall be submitted showing that the activity, with any noise mitigation measures required, will comply with the City's Performance Standards.
- 11. Sustainable design features will include:
 - a. Pre-wired garages for one 240-volt EV charger.
 - b. All appliances used within the development must be EnergyStar-rated or applicable equivalent standards.
 - c. All applicable plumbing fixtures shall be WaterSense labeled or applicable equivalent standard.
 - d. Building material on the exterior façade of a majority of the exterior elevations are energy-efficient, durable, and low maintenance, including brick and composite siding.
 - e. Use of energy-efficient glass/glazing.
 - f. Use of energy-efficient insulation materials.
 - g. Offer a tankless water heater option.
 - h. Install smart scheduling technology for sprinklers.
 - Multi-modal non-motorized pathway network and infrastructure as shown on the PRO plan that reduces emissions and promotes pedestrian connectivity with bike/pedestrian friendly streets, and bicycle parking in units throughout the site.
 - j. Benches will be made with recycled materials will be used throughout the open space areas.
- C. This motion is made because, depending on finalization of an appropriate PRO Agreement, the proposed use of the PRO and RM-1 zoning district can be a reasonable alternative to the General Mixed Use with a Planned Unit Development recommended in the Future Land Use Map, and fulfills the intent of the Master Plan for Land Use, and because of the resulting benefits including:
 - A one-acre park area, accessible to residents and the general public, with pedestrian and bike rest stop area, at the northeast corner of the site along 12 Mile Road. The applicant states a public access easement will be placed over the park area.
 - 2. A one-mile loop Grove nature area trail, accessible to residents and the general public, that extends from the newly created park area described above, along the east property line of the Property, providing scenic views of the adjacent 30-acre natural wetland area as well as natural features of the Property. The applicant states a public access easement will be placed over the trail area.
 - 3. In order to address the impact of additional use of Beacon Hill Park by the new residents and planned access and interconnectivity for Novi residents and Grove Nature Trail, Developer agrees to provide the City with \$25,000 to be used by the City at its discretion, for Beacon Hill Park improvements, art, services and/or maintenance. Enhancements of the public trailhead would benefit the overall community.

- 4. Consistent with Novi's mobility plans, over 700 feet of 10-foot-wide pathway/sidewalk, off-site on the south side of 12 Mile Road to create a connection from the existing bike path, located along the east side of Meadowbrook Road, and the new sidewalk being constructed with The Grove. The provision of this missing sidewalk segment enhances connectivity of the project area and benefits the public.
- 5. Relocating the SMART bus stop to the east and enhancing the area with landscaping and seating along 12 Mile Road, which is supported by SMART. Additional bike parking has also been added for a total of 8 spaces. Maintenance and public access agreements would likely be required. This would be considered a benefit to the public.
- 6. Approximately 1/3 of the property will be open space with most of the units abutting or overlooking open space and nature areas (1.65 acres usable open space required, 5.97 acres proposed). Exceeding the Ordinance requirement for usable open space qualifies as an enhancement that could not otherwise be required.
- 7. Consistent with Novi's mobility plans, construct an 8-foot wide shared-use pathway within The Grove to provide pedestrian and bicycle connectivity between Meadowbrook Road and 12 Mile Road. The applicant states a public access easement will be placed over the pathway, so the pathway would be considered a benefit to the public at large.
- 8. Proposed conservation easements protecting approximately 10 acres of woodland and woodland replacement areas and 15.5 acres of wetland and wetland mitigation areas. The provision of conservation easements to protect the natural features, which represents over 47% of the property, is considered an enhancement that will benefit the public at large.
- 9. Decrease in density from what would be permissible in the RM-1 zoning district (4.2 units per acre proposed, up to 7.3 units per acre permitted), which is a site-specific limitation that is more strict than would otherwise apply to the zoning district and is considered an enhancement of the project.
- 10. Dedicate right-of-way (60-foot width) along the entire Meadowbrook Road frontage, an approximate length of 2,166 feet. The total land area to be dedicated is approximately 2.5 acres, which is a benefit in the interest of the public.
- 11. The Façade review notes that the design of the buildings meet or exceed the requirements of the Façade Ordinance, and the high level of character and attention to detail represents an enhancement of the project that would be unlikely in the absence of a PRO.
- 12. The benefits to the City from the proposed multiple family development as proposed outweigh the detriments.



JZ24-31 THE GROVE LOCATION





Legend

Subject Area



City of Novi

Dept. of Community Development City Hall / Civic Center 45175 W Ten Mile Rd Novi, MI 48375 cityofnovi.org

Map Author: Lindsay Bell Date: 9/9/24 Project: THE GROVE Version #: 1


0 120 240 480 720





1 inch = 542 feet

MAP INTERPRETATION NOTICE

Map information depicted is not intended to replace or substitute for any official or primary source. This map was intended to meet National Map Accuracy Standards and use the most recent, accurate sources available to the people of the City of Novi. Boundary measurements and area calculations are approximate and should not be construed as survey measurements performed by a licensed Michigan Surveyor as defined in Michigan Public Act 132 of 1970 as amended. Please contact the City GIS Manager to confirm source and accuracy information related to this map.









Woodlands

Wetlands




City of Novi
Dept. of Community Development
Novi City Hall
45175 Ten Mile Rd Novi, MI 48375 cityofnovi.org

0.15 Miles

Map Author: Lindsay Bell Date: 9/22/25 Project: The Grove Version #: 1



Map information depicted is not intended to replace or substitute for any official or primary source. This map was intended to meet National Map Accuracy Standards and use the most recent, accurate sources available to the people of the City of Novi. Boundary measurements and area calculations are approximate and should not be construed as survey measurements performed by a licensed Michigan Surveyor as defined in Michigan Public Act 132 of 1970 as amended. Please contact the City GIS Manager to confirm source and accuracy information related to this map.



PLANNED REZONING OVERLAY (PRO) PLAN

NOVI, MICHIGAN

DEVELOPER:

IVANHOE COMPANIES 6689 ORCHARD LAKE ROAD, SUITE 314 WEST BLOOMFIELD, MI 48322 GARY SHAPIRO



CIVIL ENGINEER:

ZEIMET-WOZNIAK AND ASSOCIATES, INC. 55800 GRAND RIVER AVE SUITE 100 NEW HUDSON, MICHIGAN 48165 P: (248) 437-5099 www.zeimetwozniak.com ANDY WOZNIAK

ALLEN DESIGN 557 CARPENTER NORTHVILLE, MICHIGAN 48167 P: (248) 467-4668 JIM ALLEN, RLA

LANDSCAPE ARCHITECT: WETLAND/WOODLAND CONSULTANT:

BARR ENGINEERING 3005 BOARDWALK DR. SUITE 100 ANN ARBOR, MICHIGAN 48108 P: (734) 922-4414 FRAN THOMPSON

ARCHITECT:

T.R.-DESIGN GROUP, LLC 6001 N ADAMS RD STE 202 BLOOMFIELD HILLS MI 48304 (248) 792-3256 JASON (J.R.) RUTHIG, AIA

PLANNER:

CINCAR CONSULTING GROUP, LLC 17199 N. LAUREL PARK DRIVE, SUITE 204 LIVONIA, MI 48152 (248) 867-8942 BRAD STRADER

(96) GRAND RIVER AVE LOCATION MAP

NOT TO SCALE

SITE

Sheet Index

COVER SHEET
OVERALL EXISTING CONDITIONS
OVERALL STIEF HAN
SITE HAN
SITE HAN
SITE HAN
PAYING NOTIS AND DETAILS
OPEN SPACE PLAN
PHILL E BINSTETS HAN
FIRE THERNING PLAN
FIRE THERNING PLAN
OVERALL GRADING PLAN
FIRE DEVELOPMENT DRAINAGE PLAN
FIRE DEVELOPMENT DRAINAGE PLAN
STORMWATER MANAGEMENT CALCULATIONS
STORMWATER MANAGEMENT CHALLELLE STORMS
STORMWATER MANAGEMENT CHALLELLE STORMS STORMWATER MANAGEMENT DETAILS OVERALL UTILITY PLAN UTILITY PLAN UTILITY PLAN BOUNDARY SURVEY BOUNDARY SURVEY BOUNDARY SURVEY BOUNDARY SURVEY BOUNDARY SURVEY WETLAND SURVEY WETLAND IMPACT PLAN TOPOGRAPHIC & TREE SURVEY SOUL BORINGS SOIL BORINGS

GREENBELT AND ENTRY

WOODLAND PLAN WOODLAND PLAN WOODLAND PLAN TREE LIST TREE LIST TREE LIST TREE LIST TREE LIST

ARCHITECTURE PLANS:

THE VISTAS
A1 OF 3 FLOOR PLAN
A2 OF 3 FLOOR PLAN
A3 OF 3 ELEVATIONS

A1 OF 2 FLOOR PLAN A2 OF 2 ELEVATIONS

THE WOODS
A1 OF 3 FLOOR PLAN
A2 OF 3 FLOOR PLAN
A3 OF 3 ELEVATIONS

THE POINTE
A1 OF 3 FLOOR PLAN
A2 OF 3 FLOOR PLAN
A3 OF 3 ELEVATIONS

OPTIONAL CLUBHOUSE

DE CONTRACTOS SHALL BE RESPONSIBLE FOR ANY AND ALL DAMAGE TO EXSTING UNDERGROUND UTILITES CAUSED BY HIS OPERATION, WHITE HAS TO FESTION OF THE HOUSE BY HIS OPERATION, WHITE HAS TO FESTION OF THE HOUSE BY HIS OPERATION, WHITE HAS THE HE STATE HAS THE HE STATE HE WAS THE HE WAS AND CONSISTENCY WHITE HAS AND CONSISTENCY WHITE HAS AND CONSISTENCY WHITE HAS AND CONSISTENCY WHITE HAS AND CONTRACTOR. WHITE HAS AND CONTRACTOR WHI

ALL WORK SHALL CONFORM TO THE CITY OF NOW'S CURRENT STANDARDS AND SPECIFICATIONS.
CALL MISS DIG (1-800-647-7344 / 1-800-MISS DIG) A MINIMUM OF 72 HOURS PRICE TO THE START OF
CONSTRUCTION.
THE CONTRACTOR SHALL BE RESPONSIBLE FOR ANY AND ALL DAMAGE TO EXISTING UNDERGROUND UTILITIES CAUSED
BY HIS GEFERATIONS.





PROJECT SPONSOR: 6689 ORCHARD LAKE ROAD, SUITE 314 WEST BLOOMFIELD, MI 48322 (248) 626-611

WETLAND PLANS: W-1 EXISTING CONDITIONS W-2 WETLAND IMPACT PLAN W-3 WETLAND SECTIONS W-4 WETLAND SECTIONS

LANDSCAPE PLANS:

GREENBELT AND ENTRY

12 MIE PARK AND OPEN SPACE
GREENBELT AND ENTRY
PROPOSED BUFFERS
DETENTION PONDS
DETENTION PONDS
DETENTION PONDS
TYPING ALS

TYPICALS AMENITY PLAN LANDSCAPE DETAILS WOODLAND PLAN

THE MEADOWS

C1 OF 3 OPTION 1 C2 OF 3 OPTION 2 C3 OF 3 OPTIONS 3 AND 4

THREE FULL WORKING DAYS BEFORE YOU DIG, CALL THE MISS DIG SYSTEM IVANHOE COMPANIES

COVER SHEET THE GROVE NOVI, MICHIGAN

DATE 1/14/24	SCALE HOR: 1" = 150" VER: 1" = N/A
DESIGNED BY SRB	JOB NO. 22149
DRAWN 6Y DAB	SHEET SP-1

THESE PLANS ARE THE PROPERTY OF ZEIMET-WOZNIAK & ASSOCIATES, INC. NO CONSTRUCTION STAKING OR CONSTRUCTION INSPECTION OR CONSTRUCTIVE USE OF THESE PLANS SHALL BE MADE BY ANYONE WITHOUT THE WRITTEN AUTHORIZATION BELOW.

AUTHORIZATION BY:

ZEIMET-WOZNIAK & ASSOCIATES, INC. SHALL NOT BE RESPONSIBLE FOR MEANS, METHODS, NOT BE RESPONSIBLE FOR MEANS, METHODS, OF CONSTRUCTION, NOR FOR SAFETY ON THE JOB SITE, NOR SHALL ZEIMET-WOZNIAK & ASSOCIATES, NO. BE RESPONSIBLE FOR THE CONTRACTOR'S FAILURE TO CARRY OUT THE WORK IN ACCORDANCE WITH THE CONTRACT DOCUMENTS.

THE CONTRACTOR SHALL INDEMNIFY AND SAVE HARMLESS THE OWNER AND ENGINEER FROM ALL LIABILITIES FOR INJUNY TO PERSONS, OR DAMAGE TO OR LOSS OF PROPERTY, OR ANY OTHER LOSS, COST OR EXPENSE, AS A RESULT OF THE ACTIONS OF THE CONTRACTOR, HIS EMPLOYEES, AGENTS, OR SUBCONTRACTORS.

ALL CONTRACTORS SHALL NAME ZEIMET-WOZNIAK & ASSOCIATES, INC. AS ADDITIONALLY INSURED ON ALL INSURANCE POLICIES.

THE LOCATION AND ELEVATION OF EXISTING UNDERGROUND UTILITIES. SHOWN ON THESE DRAWINGS UNDERGROUND UTILITIES. SHOWN ON THE STRAWINGS UNDERGROUND UTILITIES. SHOWN ON THE STRAWING SHOWN OF THE STRAWING SHOWN OF THE STRAWING SHOWN OF THE STRAY OF THE STRAY

FIRE DEPARTMENT NOTES


- JIER DURATIMENT SOIDS.


 I WATER MAND AND FRE HYDRANTS SHALL BE INSTALLED AND OPERATIONAL. PRIOR TO ANY COMBISTRILE MATERIAL IS BROUGHT ON-SITE (FC 2015 3312.1).
 ALL NEW MAILTHAMY RESIDENTIAL BUILDANGS SHALL BE NUMBERED WITH A COMMITTED STATE OF THE ST

- LANE IS 14.


 6. PROPOSED BUILDINGS DO NOT HAVE FIRE SUPPRESSION SYSTEMS.


ZEIMET W DZNIAK




















CITY	Buil	DING	SEPAF	NOTEAS	TABLE

SPACE BETWEEN	HA	Ha	LA	La	REQUIRED	PROPOSED
BUILDINGS	(FEET)	(FEET)	(FEET)	(FEET)	SPACING (FEET)	
1-2	27.2	27.2	59.3	73.5	40.3	30.82
2-3	27.2	27.2	CORNER	CORNER	34.6	120.10
3-4	27.2	27.2	71	71	41.8	25.34
4-5	27.2	27.2	71	71	41,8	25.34
5-6	27.2	27.2	CORNER	CORNER	34.6	176.52
6-22	27.2	27.2	68.2	71	41.3	113.36
7-8	27.2	27.2	39.7	45.3	32.3	175.56
7-15	27.2	27.2	66	71	41.0	94.11
9-10	27.2	27.2	63.9	71	40,6	31,31
9-13	27.2	27.2	120.7	117.7	57.9	76.99
9-14	27.2	27.2	33.4	26.1	28.1	30.40
10-11	27.2	27.2	50.5	53.8	35.5	30.08
10-12	27.2	27.2	96.9	77.2	47.2	62.91
11-12	27.2	27.2	16.9	11.8	22.9	31.14
12-13	27.2	27.2	71	71	41.8	25,59
13-14	27.2	27.2	18	18	24.1	30,45
15-16	27.2		CORNER		34.6	30.00
16-17	27.2	27.2	71	71	41.8	25.00
17-18	27.2	27.2	58.1	46	35.5	25.00
19-20	27.2	27.2	71	71	41.8	25.00
20-21	27.2	27.2	45.1	22.9	29.5	32.32
21-22	27.2	27.2	31.8	60.4	33.5	39.38
23-24	27.2	27.2	56.4	56.5	37.0	26.11
24-25	27.2	27.2	61.2	48.8	36.5	25,39
25-26	27.2	27.2	60.7	40.9	35.1	25.53
26-27	27.2	27.2	71	71	41.8	25.33
27-28	27.2	27.2	66.3	61.1	39.4	25.79
28-19	27.2	27.2	CORNER	CORNER	34.6	152.70
29-30	27.2	27.2	38.7	37	30.8	25.33
30-31	27.2	27.2	68.9	49.5	37.9	30.00
31-32	27.2	27.2	49.8	40	33.1	29.03
32-33	27.2	27.2	41	60.8	35.1	25.83
33-39	27.2	27.2	CORNER	CORNER	34.6	26.32
34-35	27.2	27.2		CORNER	34.6	34.64
34-36	27.2	27.2	78.4	102.7	48.3	52.26
34-37	27.2	27.2		CORNER	34,6	62.75
34-38	27.2	27.2	62	10.5	30.2	37.33
35-36	27.2	27.2	59	70.9	39.8	32.19
36-37	27.2	27.2	CORNER	CORNER	34.6	33.05
37-38	27.2	27.2	71	70,3	41,7	30,70
39-40	27.2	27.2	71	71	41.8	25.04
40-41	27.2	27.2	58.9	47.6	35.9	26.18
41-42	27.2	27.2	65.6	51.9	37.7	25.05
42-43	27.2	27.2	42.5	46.7	33.0	25.23
43-44	27.2	27.2	64.9	47	36.8	25.67
45-46	27.2	27.2	71	71	41.8	27.77
45-49	27.2	27.2	71	71	41.8	30,10
46-47	27.2	27.2		CORNER	34.6	34.32
47-48	27.2	27.2	25.1	20.4	25.7	30.08
47-49	27.2	27.2	78.9	83.9	45.3	89.38
48-49	27.2	27.2	44.9	35.2	31.5	31.38
50-51	27.2	27.2	71	71	41.8	25.00

* THE MANIMUM REQUIRED SPACING FOR 2 BUILDINGS ACROSSTHE PREVATERCAD FROM BIGH ON THE WOULD REQUIRE ASSEMBLION OF A (MOST ASSIMILATION OF A MOST AND A (MOCOSTONING PARTH ACCONTRACTOR).

** THE BUILDINGS ACROSS FROM ISO OTHER ALONG THE PREVATER CADE HAVE AMMINIMUM SEPARATION OF ASS (MISSIAMISOON) AND TAS (WOCOST FORT).

ISSUED FOR	DATE	ISSUED FOR	DATE	ISSUED FOR	DATE	ISSUED FOR	DATE	ISSUED FOR	DATE
SUBMITTAL	7/26/24								
PRO SUBMITTAL	7/09/25								
PRO SUBMITTAL	8/22/25								







PROJECT SPONSOR: IVANHOE COMPANIES
6689 ORCHARD LAKE ROAD, SUITE 314
WEST BLOOMFIELD, MI 48322 (248) 626-6114

BUILDING SEPAR	ATION PLAN
THE GR	OVE
NOVA MICH	HCAN

DATE 1/14/24	SCALE HOR: 1" = 100" VER: 1" = N/A
DESIGNED BY SRB	JOB NO. 22149
DRAWN BY	SHEET SP-3.6

































LEGAL DESCRIPTIONS PER TITLE COMMITMENT:

EVUIDIT "

THE LAND REFERRED TO IN THIS SEARCH IS DESCRIBED AS FOLLOWS: CITY OF NOVI, COUNTY OF OAKLAND, STATE OF

PARCEL 1

PART OF THE NORTHWEST 1/4 OF SECTION 13, TOWN 1 NORTH, RANGE & EAST, DESCRIBED AS:

BECOMING AT A POINT DISTANT EAST SHALES PEET AND SOUTH OF DEGREES 24 MINUTES 30 SECONDS WEST 95.18 FEET FROM

BECOMES AN ENWINES 30 SECONDS WEST 301.85 FEET; THENCE NORTH

BE DEGREES 44 MINUTES 30 SECONDS WEST 301.85 FEET; THENCE NORTH

BE DEGREES 44 MINUTES 30 SECONDS WEST 301.85 FEET; THENCE NORTH 20 EXCRESS 26 MINUTES 30 SECONDS SEAT 318.55

FEET, THENCE NORTH 46 DEGREES 38 MINUTES 40 SECONDS EAST 71.70 FEET; THENCE SOUTH 89 DEGREES 38 MINUTES 40 SECONDS EAST 29.41 FEET TO THE POINT OF BECOMES 18.51

SECONDS EAST 29.41 FEET TO THE POINT OF BECONDS 18.51

FEET, THENCE NORTH 46 DEGREES 30 MINUTES 40 SECONDS PART 30 SECONDS SEAT 31.70 FEET; THENCE SOUTH 89 DEGREES 30 MINUTES 40 SECONDS EAST 71.70 FEET; THENCE SOUTH 89 DEGREES 30 MINUTES 40 SECONDS EAST 71.70 FEET; THENCE SOUTH 89 DEGREES 30 MINUTES 40 SECONDS EAST 71.70 FEET; THENCE SOUTH 89 DEGREES 30 MINUTES 40 SECONDS EAST 71.70 FEET; THENCE SOUTH 89 DEGREES 30 MINUTES 40 SECONDS EAST 71.70 FEET; THENCE SOUTH 89 DEGREES 30 MINUTES 40 SECONDS EAST 71.70 FEET; THENCE SOUTH 89 DEGREES 30 MINUTES 40 SECONDS EAST 71.70 FEET; THENCE SOUTH 89 DEGREES 30 MINUTES 40 SECONDS EAST 71.70 FEET; THENCE SOUTH 89 DEGREES 30 MINUTES 40 SECONDS EAST 71.70 FEET; THENCE SOUTH 89 DEGREES 30 MINUTES 40 SECONDS EAST 71.70 FEET; THENCE SOUTH 89 DEGREES 30 MINUTES 40 SECONDS EAST 71.70 FEET; THENCE SOUTH 89 DEGREES 30 MINUTES 40 SECONDS EAST 71.70 FEET; THENCE SOUTH 89 DEGREES 30 MINUTES 40 SECONDS EAST 71.70 FEET; THENCE SOUTH 89 DEGREES 30 MINUTES 40 SECONDS EAST 71.70 FEET; THENCE SOUTH 89 DEGREES 30 MINUTES 40 SECONDS EAST 71.70 FEET; THENCE SOUTH 89 DEGREES 30 MINUTES 40 SECONDS EAST 71.70 FEET; THENCE SOUTH 89 DEGREES 30 MINUTES 40 SECONDS EAST 71.70 FEET; THENCE SOUTH 89 DEGREES 30 MINUTES 40 SECONDS EAST 71.70 FEET; THENCE SOUTH 89 DEGREES 30 MINUTES 40 SECONDS EAST 71.70 FEET; THENCE MINUTES 50 SECONDS EAST 71.70 FEET; THENCE SOUTH 80 SECONDS EAST 71.70 FEET; THENCE SOUTH 89 SECONDS EAST 71.

DARCEL S

PART OF THE NORTHWEST 1/4 OF SECTION 13, TOWN 1 MORTH, RANGE & EAST, DESCRIBED AS: BEGINNING AT A POINT DISTANT EAST 888.10 FEET MOR DOUGH 0.2 DEGREES 23 MINUTES OS SECONDS WEST 100.33 FEET FROM THE NORTHWEST SECTION COMMER, THENCE SOUTH 0.2 EXPRESS 23 MINUTES OS SECONDS WEST 501.81 FEET, THENCE EAST 565.41 FEET, THENCE SOUTH SECONDS SECONDS SECONDS SECONDS WEST SECONDS S

PARCEL :

PART OF THE NORTHWEST 1/4 OF SECTION 13, TOWN 1 NORTH, RANGE 8 EAST, DESCRIBED AS:
COMMENCING AT THE WEST 1/4 COPIEZ OF SAD SECTION 13, THENCE NORTH 02 DEGREES 30 MINUTES OF SECONDS EAST
COMMENCENCY OF THE WEST 1/4 COPIEZ OF SAD SECTION 13, THENCE NORTH 02 DEGREES 10 MINUTES OF SECONDS EAST
CROWNING, THENCE NORTH 02 DEGREES 20 MINUTES OF SECONDS EAST 2007 OF TEST ALONG THE MEST LINE OF SAD SECTION
13 AND THE CENTRELINE OF MADOWRROOK ROAD, THENCE SOUTH 80 DEGREES 19 MINUTES OF SECONDS EAST 2008.70 FEET,
14 FINE SOUTH 02 DEGREES 20 MINUTES OF SECONDS SET 2008.70 FEET (RECORDED AS SOUTH) 01 DEGREES 30 MINUTES 3
SECONDS WEST 2008.70 FEET), THENCE NORTH 80 DEGREES 19 MINUTES OF SECONDS WEST 2008.70 FEET (RECORDED AS NORTH 90 DEGREES) 10 MINUTES 30 SECONDS WEST 2008.70 FEET (RECORDED AS NORTH 90 DEGREES) 10 MINUTES 30 SECONDS WEST 2008.70 FEET (RECORDED AS NORTH 90 DEGREES) 10 MINUTES 30 SECONDS WEST 2008.70 FEET (RECORDED AS NORTH 90 DEGREES) 10 MINUTES 30 SECONDS WEST 2008.70 FEET (RECORDED AS NORTH 90 DEGREES) 11 MINUTES 30 SECONDS WEST 2008.70 FEET (RECORDED AS NORTH 90 DEGREES) 11 MINUTES 30 SECONDS WEST 2008.70 FEET (RECORDED AS NORTH 90 DEGREES) 11 MINUTES 30 SECONDS WEST 2008.70 FEET (RECORDED AS NORTH 90 DEGREES) 11 MINUTES 30 SECONDS WEST 2008.70 FEET (RECORDED AS NORTH 90 DEGREES) 11 MINUTES 30 SECONDS WEST 2008.70 FEET (RECORDED AS NORTH 90 DEGREES) 11 MINUTES 30 SECONDS WEST 2008.70 FEET (RECORDED AS NORTH 90 DEGREES) 11 MINUTES 30 SECONDS WEST 2008.70 FEET (RECORDED AS NORTH 90 DEGREES) 11 MINUTES 30 SECONDS WEST 2008.70 FEET (RECORDED AS NORTH 90 DEGREES) 11 MINUTES 30 SECONDS WEST 2008.70 FEET (RECORDED AS NORTH 90 DEGREES) 11 MINUTES 30 SECONDS WEST 2008.70 FEET (RECORDED AS NORTH 90 DEGREES) 11 MINUTES 30 SECONDS WEST 2008.70 FEET (RECORDED AS NORTH 90 DEGREES) 11 MINUTES 30 SECONDS WEST 2008.70 FEET (RECORDED AS NORTH 90 DEGREES) 11 MINUTES 30 SECONDS WEST 2008.70 FEET (RECORDED AS NORTH 90 DEGREES) 11 MINUTES 30 SECONDS WEST 2008.70 FEET (RECORDED AS NORTH 90 DEGREES) 11 MINUTES 30 SECONDS WEST 20

PARCEL 4

PART OF THE WEST 1/2 OF THE NORTHWISTS 1/4 OF SECTION 13, TOWN 1 MORTH, RANCE B EAST, DESCRIBED ASCOMMENCING AT THE WEST 1/4 CORRESS OF SAID SECTION 13, THEIRC MORTH OR DESCRIBES AS MINUTES OS SECONOS WEST
329.22 FEFT ALONG THE WEST LINE OF SAID SECTION 13, AND THE CONTERINE OF MEADOWRROOK ROAD TO THE POINT OF
DESCRIBES AS WAS ASSOCIATED SECONOS ASST SCALE FEET ALONG THE WEST LINE OF SAID SECTION
OF SECONOS AS SOUTH 89 DEGREES 11 MINUTES 40 SECONOS EAST 208.70 FEET; THEIRCE NORTH 02 DEGREES 28 MINUTES
SOUTH 89 DEGREES 19 MINUTES AS SECONOS EAST 108.70 FEET; THEIRCE NORTH 02 DEGREES 28 MINUTES
SOUTH 89 DEGREES 19 MINUTES OF SECONOS EAST 178.40 FEET (RECORRED AS SOUTH 89 DEGREES 28 MINUTES
SOUTH 89 DEGREES 19 MINUTES OF SECONOS EAST 178.40 FEET (RECORRED AS SOUTH 89 DEGREES 19 MINUTES AS
SECONOS WEST 332.62 FEET; THEIRCE MORTH 89 DEGREES 19 MINUTES AS
SECONOS WEST 332.62 FEET; THEIRCE NORTH 89 DEGREES 14 MINUTES AS SECONOS WEST 138.465 FEET (RECORRED AS SOUTH 89 DEGREES AND MINUTES AS

PARCEL 5

PAGE THE NORTHWEST 1/4 OF SCOTION 13, TWW 1 HORTH, RANGE 8 EST, GSORBED AS:

PAGE DEFINED AS THE NORTHWEST 1/4 OF SCOTION 13, TWW 1 HORTH, RANGE 8 EST, GSORBED AS:

PAGE DEFINED AS THE NORTHWEST LIKE OF SAU SCOTION 13, AND THE CENTERLINE OF WEADOWRROOK ROAD TO THE FORM TO TESCHORE SOUTH 80 DEGREES 29 MINUTES OF SCOTIONS EAST 138,274 FEET THENCE SOUTH 00 DEGREES 29 MINUTES OF SCOTIONS EAST 138,274 FEET THENCE SOUTH 00 DEGREES 29 MINUTES AS SOUTH 02 DEGREES 19 MINUTES AS SOUTH 03 DEGREED 18 MINUTES AS SOUTH 03 DEGREED 18 MINUTES AS SOUTH 05 DEGREED 18 MINUTES AS SOUTH 05 DEGREES 19 MINUTES AS SOUTH 05 DEGREED 18 MINUTES AS SOUTH 05 DEGREES 19 MINUTES AS SOUTH 05 DEGREED 18 MINUTES AS SOUTH 05 DEGREES 19 MI

PARCEL 6

PART OF THE NORTHWEST 1/4 OF SECTION 13, TOWN 1 NORTH, RANGE & EAST, DESCRIBED AS BECHNING AT A POINT DISTANT SOUTH OF DECREES 25 MAINTES OS SECONOS MAST 609-04 FEET FROM THE NORTHWEST SECTION CORREC, THONG SOUTH 80 DECREES 44 MAINTES AS SECONOS EAST 1379-04 FEET, THONG SOUTH 02 DECREES 10 NORTH 02 DECREES 26 MAINTES OF SECONOS EAST 102-04 FEET, THONG SOUTH 80 ECREES 44 MAINTES OS SECONOS EAST 200,00 FEET, THONG MORTH 02 DECREES 26 MAINTES OF SECONOS EAST 100,00 FEET, THONG MORTH 80 DECREES 44 DOINT OF SECONOS EAST 100,00 FEET, THONG MORTH 02 DECREES 26 MAINTES OF SECONOS EAST 100,00 FEET, THONG MORTH 80 DECREES 46

PARCEL 7

PART OF THE NORTHWEST 1/4 OF SECTION 13, TOWN 1 NORTH, RANGE & EAST, DESCRIED AS: BEGINNING AT A POINT DESTANT SOUTH OF LEGENESS & MINUTES SO SECONDS WEST 988-56 FEET FROM THE NORTHWEST SECTION CORNER, THENSE SOUTH OF DECREESS AS MINUTES SO SECONDS DAYS 1980.00 FEET, THENSE SOUTH OF DECREES AS NORTH OF DECREESS AS MINUTES OF SECONDS EAST 3202 FEET TO THE POINT OF BECOMING SWEST 1980.00 FEET, THENSE

PARCEL

THE NORTH 158.00 FEET OF THE NORTH 1/2 OF THE SOUTH 1/2 OF THE WEST 1/2 OF THE NORTHWEST 1/4 OF SECTION 13, TOWN 1 NORTH, RANGE 8 EAST.

PARCEL

THE SOUTH 189.00 FEET OF THE NORTH 347.00 FEET OF THE NORTH 1/2 OF THE SOUTH 1/2 OF THE WEST 1/2 OF THE NORTHWEST 1/4, SECTION 13, TOWN 1 NORTH, RANGE 8 EAST.

PARCEL

PART OF THE KORTHHEST 1/4 OF SECTION 13, TOWN 1 KROTH, PANCE & LEST, DESCRIBED AS:

OMMERICHING AT THE KORTHHEST CORRECT OF SAID SECTION 15, THICKS SUITH OF DECREES 26 MINUTES DO SECONDS WEST
720.04 FEET ALONG THE WEST LINE OF SAID SECTION 13, AND THE CENTERLINE OF MEADOWRROOK ROAD, TO THE POINT OF
ECONOMICH, THENCE SOUTH BY DECREES 44 MINUTES AS SECONDS EAST DROAD FEET. THENCE SOUTH OF DECREES 44 MINUTES AS SECONDS EAST DROAD FEET. THENCE SOUTH OF DECREES 44 MINUTES AS SECONDS EAST TO BROOM THE WEST LINE OF SAID SECTION 13, AND THE
CENTERLINE OF SAID MEADOWRROOK ORNOOT TO THE POINT OF BEGINNION.

PARCEL

PART OF THE NORTHWEST 1/4 OF SECTION 13, TOWN 1 NORTH, RANGE E LAST, DESCRIPED AS BEGINNING AT A POINT DISTANT EAST 103.46 FEET AND SOUTH 02 DEGREES 21 MAINTES 30 SECONDS WEST 105.47 FEET FROM THE NORTHWEST SECTION CONNECT, THOUSE SOUTH 90 EDURES 08 MINUTES AND SECONDS EAST 344.46 FEET, THENSE 24.46 FEET, THENSE ORTH 02 DEGREES 21 MAINTES AND SECONDS EAST SE22 FEET TO THE POINT OF BECOMMISS. SHEET 34.46 FEET, THENSE NORTH 02 DEGREES 21 MAINTES AND SECONDS EAST SE22 FEET TO THE POINT OF BECOMMISS. SHEET

PARCEL 12

PART OF THE NORTHWEST 1/4 OF SECTION 13, TOWN 1 NORTH, RANGE 8 FAST, DESCRIBES AS.

BECHNING AT A PONN DISTANT AST 88-81 FEET AND SOUTH 02 DECREES 23 MINUTES OS SECONDS WEST 100.33 FEET FROM THE NORTHWEST SECTION CORNERS, MEDIC SOUTH 80 BECKNESS, 08 MINUTES, 03 SCONDS EAST 344,75 FEET THENCE WEST ASSESSED. THE NORTHWEST SECTION CORNERS, MEDIC SOUTH 50 BECKNESS, 05 MINUTES, 05 SECONDS EAST 344,75 FEET THENCE CORT OF CORNERS, SOUTH 50 SECONDS EAST 344,81 FEET TO THE POINT OF BECOMING.

EXCEPTIONS:

- EASEMENT GRANTED TO THE CITY OF NOVI FOR PUBLIC UTILITIES AND HIGHWAY PURPOSES RECORDED IN LIBER 7082, PAGE 484, OAKLAND COUNTY RECORDS, AS PERTAINS TO PARCEL 4. SHOWN.
- 2. EASEMENT GRANTED TO THE CITY OF NOVI FOR PUBLIC UTILITIES AND HIGHWAY PURPOSES RECORDED IN
- EASEMENT GRANTED TO THE CITY OF NOVI FOR PUBLIC UTILITIES AND HIGHWAY PURPOSES RECORDED IN LIBER 7082, PAGE 488, OAKLAND COUNTY RECORDS, AS PERTAINS TO PARCEL 5 [PARCEL 10]. SHOWN.
- LIBER 7082, PAGE 480, VARIAND COUNTY RECORDS, AS PERTAINS TO PARCEL S [PARCEL 10] SHOWN.

 LIBER 7082, PAGE 502, OAKLAND COUNTY RECORDS, AS PERTAINS TO PARCEL 5. SHOWN.
- EASEMENT GRANTED TO THE CITY OF NOVI FOR PUBLIC UTILITIES AND HIGHWAY PURPOSES RECORDED IN LIBER 7082, PAGE 504, OAKLAND COUNTY RECORDS, AS PERTAINS TO PARCELS 7, 8 AND 9. SHOWN.
- EASEMENT GRANTED TO THE CITY OF NOVI FOR PUBLIC UTILITIES AND HIGHWAY PURPOSES RECORDED IN LIBER 7092, PAGE 530, OAKLAND COUNTY RECORDS. AS PERTAINS TO PARCEL 1, SHOWN.
- EASEMENT GRANTED TO THE CITY OF NOVI FOR PUBLIC UTILITIES AND HIGHWAY PURPOSES RECORDED IN LIBER 7082, PAGE 557, OAKLAND COUNTY RECORDS, AS PERTAINS TO PARCEL 1. SHOWN.
- 8. EASEMENT GRANTED TO THE CITY OF NOVI FOR PUBLIC UTILITIES AND HIGHWAY PURPOSES RECORDED IN LIBER 7082, PAGE 560, OAKLAND COUNTY RECORDS, AS PERTAINS TO PARCEL 1. SHOWN.
- TERMS, CONDITIONS AND PROVISIONS CONTAINED IN, AND EASEMENT(S) CREATED BY, DECLARATION OF TAKING RECORDED IN LIBER 7217, PAGE 483, OAKLAND COUNTY RECORDS, AS PERTAINS TO PARCELS 3 THROUGH 10, BOTH INCLUSIVE. SHOWING
- 10. EASEMENT(S) CONTAINED IN AND/OR CREATED BY WARRANTY DEED RECORDED IN LIBER 11987, PAGE 63, AND RE-RECORDED IN LIBER 12016, PAGE 188, OAKLAND COUNTY RECORDS, AS PERTAINS TO PARCEL 1. SHOWN.
- EASEMENT(S) CONTAINED IN AND/OR CREATED BY WARRANTY DEED RECORDED IN LIBER 11987, PAGE 65, AND RE-RECORDED IN LIBER 12016, PAGE 161, OAKLAND COUNTY RECORDS, AS PERTAINS TO PARCEL 2. SHOWN.
- 12. SANITARY SEWER EASEMENT GRANTED TO THE CITY OF NOVI RECORDED IN LIBER 12054, PAGE 119, OAKLAND COUNTY RECORDS, AND THE TERMS, CONDITIONS AND PROVISIONS CONTAINED THEREIN, AS PERTAINS TO PARCEL 5. SHOWN. TEMPORARY CONSTRUCTION EASEMENT NOT SHOWN.
- 13. SANITARY SEWER EASEMENT GRANTED TO THE CITY OF NOVI RECORDED IN LIBER 12113, PAGE 46, OAKLAND COUNTY RECORDS, AS PERTAINS TO PARCEL 4. SHOWN. TEMPORARY CONSTRUCTION EASEMENT NOT SHOWN.
- SANITARY SEWER EASEMENT GRANTED TO THE CITY OF NOVI RECORDED IN LIBER 13492, PAGE 337, OAKLAND COUNTY RECORDS, AS PERTAINS TO PARCELS 11 AND 12. SHOWN: TEMPORARY CONSTRUCTION EASEMENT NOT SHOWN.
- DRAINAGE EASEMENT GRANTED TO THE CITY OF NOVI RECORDED IN LIBER 13528, PAGE 228, OAKLAND COUNTY RECORDS, AS PERTAINS TO PARCELS 11 AND 12. SHOWN. TEMPORARY CONSTRUCTION EASEMED
- DRAINAGE EASEMENT GRANTED TO THE CITY OF NOVI RECORDED IN LIBER 13637, PAGE 780, OAKLAND COUNTY RECORDS, AS PERTAINS TO PARCEL 2. SHOWN. TEMPORARY CONSTRUCTION EASEMENT NOT SHOWN.
- TERMS, CONDITIONS AND PROVISIONS CONTAINED IN TERMINATION AND RECIPROCAL PELEASE OF DEED RESTRICTION RECORDED IN LIBER 19888, ASCER 283, CANALAN COUNTY RECORDS, AS PERVAINS TO PARCEL 1 AND PARCELS 3 THROUGH 10. BLANKETS PARCELS 1, 2 3, 5, 7, 8, 9, 10, 12, AND A PORTION OF PARCEL II. NOTHING TO PLOY.
- EASEMENT GRANTED TO THE CITY OF NOVI FOR CONSTRUCTION, OPERATION AND MAINTENANCE OF WATER MAIN RECORDED IN LIBER 25672, PAGE 283, OAKLAND COUNTY RECORDS, AS PERTAINS TO ALL PARCELS. SHOWN. TEMPORARY CONSTRUCTION EASEMENT NOT SHOWN.
- TENES, CONDITIONS AND PREVISIONS CONTINUED IN, AND INSENSITIES OPERATE BY, BILL OF SALE FOR WHATE OUPPR'S SYSTEM PROPRIED IN USER'S 2672, PAGE 268. ANA MIO COLINY PROFINES AS PERTAINS TO PARCEL 1, PARCEL 3 AND PARCELS 5 THROUGH 10, BOTH INCLUSIVE. SHOWN, TEMPORARY CONSTRUCTION ASSEMBLY NOT SHOWN.
- SIDEWALK EASEMENT GRANTED TO THE CITY OF NOVI RECORDED IN LIBER 46087, PAGE 250, OAKLAND COUNTY RECORDS, AS PERTAINS TO PARCEL 10. SHOWN. TEMPORARY GRADING PERMIT NOT SHOWN.
- 21. SIDEWALK EASEMENT GRANTED TO THE CITY OF NOVI RECORDED IN LIBER 46087, PAGE 256, OAKLAND COUNTY RECORDS, AS PERTAINS TO PARCEL 6. SHOWN. TEMPORARY GRADING PERMIT NOT SHOWN.
- SIDEWALK EASEMENT GRANTED TO THE CITY OF NOVI RECORDED IN LIBER 46087, PAGE 262, OAKLAND COUNTY RECORDS, AS PERTAINS TO PARCEL 7. SHOWN. TEMPORARY GRADING PERMIT NOT SHOWN.
- SIDEWALK EASEMENT GRANTED TO THE CITY OF NOVI RECORDED IN LIBER 46087, PAGE 268, OAKLAND COUNTY RECORDS, AS PERTAINS TO PARCEL 8. SHOWN. TEMPORARY GRADING PERMIT NOT SHOWN.
- 24. SIDEWALK EASEMENT GRANTED TO THE CITY OF NOW RECORDED IN LIBER 46087, PAGE 274, OAKLAND COUNTY RECORDS, AS PERTAINS TO PARCEL 9. SHOWN, TEMPORARY GRADING PERMIT NOT SHOWN.
- SIDEWALK EASEMENT GRANTED TO THE CITY OF NOVI RECORDED IN LIBER 46087, PAGE 280, OAKLAND COUNTY RECORDS, AS PERTAINS TO PARCEL 5. SHOWN, TEMPORARY GRADING PERMIT NOT SHOWN.
- SIDEWALK EASEMENT GRANTED TO THE CITY OF NOVI RECORDED IN LIBER 46087, PAGE 286, OAKLAND COUNTY RECORDS, AS PERTAINS TO PARCEL 3. SHOWN. TEMPORARY GRADING PERMIT NOT SHOWN.
- SIDEWALK EASEMENT GRANTED TO THE CITY OF NOVI RECORDED IN LIBER 46087, PAGE 292, OAKLAND COUNTY RECORDS, AS PERTAINS TO PARCEL 4. SHOWN. TEMPORARY GRADING PERMIT NOT SHOWN.
- SIDEWALK EASEMENT GRANTED TO THE CITY OF NOVI RECORDED IN LIBER 48087, PAGE 298, OAKLAND COUNTY RECORDS, AS PERTAINS TO PARCEL 1. SHOWN. TEMPORARY GRADING PERMIT NOT SHOWN.
- ANY RIGHTS, TITLE, INTEREST IN OR CLAIMS THEREOF TO THAT PORTION OF THE LAND LYING WITHIN THE DRAIN CROSSING THE SUBJECT PROPERTY, AS PERTAINS TO PARCELS 4, 5 AND 9.
- RIGHTS OF THE PUBLIC AND OF ANY GOVERNMENTAL UNIT IN ANY PART OF THE LAND TAKEN, USED OR DEEDED FOR STREET, ROAD OR HIGHWAY PURPOSES.
- 31. RIGHTS OF TENANTS IN POSSESSION OR PURSUANT TO UNRECORDED LEASES.
- 32. PAYMENT OF TAXES:

PARCEL A LEGAL DESCRIPTION AS SURVEYED:

A PARCEL OF LAND LOCATED IN PART OF THE NORTHWEST 1/4 OF SECTION 13, TOWN 1 NORTH, RANGE 8 EAST, CITY OF NOW, OAKLAND COUNTY, MICHIGAN AND MORE PARTICULARLY DESCRIBED AS:

COMBINION OF THE WEST 1/4 CORRECT OF SAID SECTION 15, TRINCE 14, 0227/57 M. 1, 577.67 FEET ALONG THE SECT SECTION ULLE OF SECTION 13, ALSO SEND THE CONTRIBUTE OF DELACORPHIC RODG (MOST MOST) PROBLEM TO A TOWN THE ASSOCIATION OF THE ASSOCIATI

CONTAINS 337,297 SQUARE FEET (7.74 ACRES) MORE OR LESS, AND BEING SUBJECT TO ANY EASEMENTS AND/OR RESTRICTIONS OF RECORD

PARCEL B LEGAL DESCRIPTION AS SURVEYED:

A PARCEL OF LAND LOCATED IN PART OF THE NORTHWEST 1/4 OF SECTION 13, TOWN 1 NORTH, RANGE 8 EAST, CITY OF NOW, OAKLAND COUNTY, MICHIGAN AND MORE PARTICULARLY DESCRIBED AS:

COMMENCING AT THE MEST 1/4 CORNER OF SAID SECTION 13, THENCE N. 02213"4" W. 329.52 FEET ALONG THE WEST SECTION LINE OF SECTION 13, ALSO BEING THE CENTERLINE OF MELDOWEROX RODA (MIDT) WARES), TO THE POINT OF BECONNEYS, THENCE CONTINUING NUZ273"4" W. 148.15 FEET ALONG SAID WEST SECTION LINE DEPOKE N. 8072850" E. 4.5.15 MID ALONG SAID SECTION LINE DEPOKE N. 8072850" E. 4.5.15 MID ALONG SAID SECTION LINE DEPOKE N. 807273" W. 140.50 FEET ALONG SAID DESCRIBED LINE FINENCE N. 807273" E. 761.29 FEET THENCE N. 607273" E. 761.20 FEET THENCE N. 607273" E. 761.29 FEE

CONTAINS 2,693,340 SQUARE FEET (61.83 ACRES) MORE OR LESS, AND BEING SUBJECT TO ANY EASEMENTS AND/OR RESTRICTIONS OF RECORD.

OVERALL LEGAL DESCRIPTION (PARCEL A & PARCEL B) AS SURVEYED:

A PARCEL OF LAND LOCATED IN PART OF THE NORTHWEST 1/4 OF SECTION 13, TOWN 1 NORTH, RANGE 8 EAST, CITY OF NOW, OAKLAND COUNTY, MICHIGAN AND MORE PARTICULARLY DESCRIBED AS:

COMMENDING AT THE WEST 1/4 CORNER OF SAID SECTION 13, THENCE N. 022134* W. 329.52 FEET ALONG THE WEST SECTION LINE OF SECTION 13, ALSO BEING THE CENTERLINE OF MEADOWSROOK ROAD (WIDTH WREES). TO THE POINT OF BECOMING, THENCE CONTINUING NOZ2734* W 1464.51 FEET ALONG SAID WEST SECTION LINE INFORCE N. 8527830* E. 4.5.03

TOTAL PROPERTY OF THE PROPERTY OF THE SECTION OF THE SECTION LINE INFORMATION OF THE SECTION OF THE S

CONTAINS 3.030.638 SQUARE FEET (69.57 ACRES) MORE OR LESS. AND BEING SUBJECT TO ANY EASEMENTS AND /OR RESTRICTIONS OF RECORD.

SURVEY NOTES:

- 1. THE SURVEYED PROPERTY IS IN A FEDERALLY DESIGNATED FLOOD ZONE X, FIRM MAP No. 28125C0827F. EFFECTIVE DATE 9-29-2006. THE ABOVE FLOOD PLAIN DESIGNATION IS FOR INFORMATION ONLY AND IS BASED ON THE FIRM MAP LISTED ABOVE AVAILABLE ELECTRONICALLY FRON FEAR ON THE DATE OF THIS SURVEY. THIS SURVEYOR SALES NO LIBBILITY FOR THE CORRECTIONS OF THE CITED MAPS, IN ADDITION, HE ABOVE STATEMENT DOES NOT REPRESENT THIS SURVEYOR SERVING OF THE CITED MAPS. IN ADDITION, HE ABOVE STATEMENT DOES NOT REPRESENT THIS SURVEYOR SERVING OF THE CITED MAPS.
- 2. THE BEARINGS ARE BASED ON THE MICHIGAN STATE PLANE COORDINATE SYSTEM, SOUTH ZONE, INTERNATIONAL FOOT (NAD 83), AS OBSERVED ALONG THE WEST SECTION LINE OF SECTION 13, BEING N. 02'21'34" W.
- 3. THE LOCATION OF EXISTING UNDERGROUND UTILITIES ARE NOT SHOWN ON THIS SURVEY. NO GUARANTEE IS EITHER EXPRESSED OR IMPLIED AS TO THE COMPLETENESS OR ACCURACY THEREOF.
- . PARKING: SUBJECT PROPERTY IS VACANT.
- 5. PARCEL A CONTAINS 337,297 SQUARE FEET OR 7.74 ACRES OF LAND, MORE OR LESS. PARCEL B CONTAINS 2,693,340 SQUARE FEET OR 61.83 ACRES OF LAND, MORE OR LESS. OVERALL PARCEL CONTAINS 3,000,638 SQUARE FEET OR 68.57 ACRES OF LAND, MORE OR LESS.
- 6. AT TIME OF INSPECTION THERE WAS NO OBSERVED EVIDENCE OF CEMETERIES LOCATED ON SUBJECT PROPERTY.
- 7. HE SIE IS ZONED OST, OFFICE SERVICE TECHNIQUOY. SETBADISS FROM TO, SIE 69, PEAR 50.

 SETBADISS ARE USETBA COCORDING TO THE ZONING FORDINACE, SETBADIS ARE ARE SUBJECT TO INTERPRETATION OF FRONT, SIE AND REAR, VARIANCES AND VARIOUS PLANNING AND SIE PLUM APPROVALS, OUT THE APPROVANTE MANIQUAR, AUTHORITY CAN DETERMINE IF THE SURVEYED PROPERTY CONFORMS TO SETBACK REQUIREDRING. THE SURVEYED CONFORMS TO SETBACK REQUIREDRINGS THE SURVEYED AND THE SURVEYED PROPERTY CONFORMS TO SETBACK REQUIREDRINGS. THE SURVEYER CAN BE SURVEYED THAT LIGHTED THE SURVEYED PROPERTY OF THIS PROPERTY OF THIS GO AND THE SURVEYED THAT LIGHTED THAT LIGHTED THE SURVEYED THAT LIGHTED THAT LIG
- 8. THERE ARE NO CHANGES IN STREET RIGHT-OF-WAY KNOWN TO THIS SURVEYOR. THERE WAS ONGOING CONSTRUCTION WORK ALONG MEADOWBROOK ROAD AT THE TIME OF THIS SURVEY. PROPERTY EVIDENCE HAS BEEN FOUND BO FEET FROM THE CENTERLINE OF MEADOWBROOK ROAD.
- 9. THERE WAS NO OBSERVED EVIDENCE OF EARTHWORK, BUILDING CONSTRUCTION OR BUILDING ADDITIONS IN RECENT MONTHS ON DATE OF FIELD SURVEY. THERE WAS OBSERVED EVIDENCE OF UTILITY CONSTRUCTION WORK TAKING PLACE IN RECENT MONTHS AT THE INTERSECTION OF MEADOWBROOK ROAD AND THELVE MILE ROAD AND ALOUS MEADOWBROOK ROAD AT THE TITLE OF THIS SURVEY.
- 10. THE PROPERTY HAS ACCESS TO MEADOWBROOK ROAD BASED ON EXISTING ASPHALT PAVEMENT AND APRON OBSERVED IN THE FIELD (NOT SHOWN ON SURVEY), A PUBLIC ROAD, THERE IS VISIBLE EVIDENCE OF A GATED, INGRESS EGRESS ROAD, NEAR TWELVE MILE ROAD, ALONG THE EAST LINE OF THE MEST 1/2 OF THE NORTHWEST 1/4, (NOT SHOWN ON SURVEY).
- 11. THERE WAS NO OBSERVED EVIDENCE THAT THE SUBJECT SITE IS CURRENTLY BEING USED AS AN ACTIVE SOLID WASTE DUMP, SUMP OR SANITARY LANDFILL ON DATE OF PIELD SURVEY.
- 12. RECORD MEASUREMENTS SHOWN ON THE SURVEY ARE BASED ON THE PROVIDED TITLE WORK AS REFERENCED IN THE LEGAL DESCRIPTION PER TITLE COMMITMENT
- 13. SQUIPSERV RIGHT-OF-WAY LINE OF TRELEW MLE ROAD ESTABLISHED FROM MODT RIGHT-OF-WAY MAN SHEET NO. 230, File NO. 63.8-Fil. LAST REVISION DATE OF JUNE 2012.
 RECORDS SHOWN A 33 WINE PRESONETIVE RIGHT-OF-WAY FOR MEADUREON ROAD AND A 45 WINE DEDICATION RIGHT-OF-WAY FOR MEADOWNEDON ROAD. PLEASE RICH.
 THAT FOUND EVIDENCE HAS BEEN ESTABLISHED FOR A 60 FOOT RIGHT-OF-WAY (FILE) AND FOR MEADOWNEDON ROAD. NO RECORD WAS PROVIDED TO THE SURVEYOR STATING
 THAT THERE B A 60 FOOT WINE CITY 20 WIDTH) RIGHT-OF-WAY (FILE) AND MEADOWNEDON ROAD.

14. NO IRONS HAVE BEEN SET AT THIS TIME OF THIS SURVEY.

CERTIFICATION:

TO: MERCY HEALTH SERVICES, A MICHIGAN NONPROFIT CORPORATION, N/K/A TRINITY HEATH-MICHIGAN, A MICHIGAN NONPROFIT CORPORATION; IVANHOE COMPANIES; AND ATA NATIONAL TITLE GROUP:

I HEREBY CERTIFY THAT:
THIS DRAWNO REPRESENTS EXISTING CONDITIONS ON THE DATE OF THE FIELD
SURVEY. THE RELATIVE PRECISION OF THE CORNERS IDENTIFIED AND SHOWN ON THE
DRAWNO ARE WITHOUT MATS ACCEPTED BY THE PRACTICE OF PROFESSIONAL
SURVEYING. THE BOUNDARY FIELD WORK WAS COMPLETED ON DECEMBER 30, 2022.

12-30-2022 DATE

JUSTIN G. OSWALT
PROFESSIONAL SURVEYOR NO. 4001067109
JOSWALT@ZEIMETWOZNIAK.COM

THIS COPY OF THIS SURVEY IS NOT VALID UNLESS AN ORIGINAL SIGNATURE APPEARS ON ITS FACE.

ATA NATIONAL TITLE GROUP, TITLE INFORMATION REPORT, FILE NO. 63-22858774-SCM, DATED NOVEMBER 17, 2022

TWO DELLAR PROJECT SPONSOR:

BOUNDARY SURVEY

THE MORNATION REPORT, FLE NO. 63-22888774-SOL, DATED MONEMBER 17

BOUNDARY SURVEY

THE MORNATION REPORT, FLE NO. 63-22888774-SOL, DATED MONEMBER 17

THE GROUP, THE MORNATION REPORT, FLE NO. 63-22888774-SOL, DATED MONEMBER 17

THE GROUP, THE MORNATION REPORT, FLE NO. 63-22888774-SOL, DATED MONEMBER 17

THE GROUP, THE MORNATION REPORT, FLE NO. 63-22888774-SOL, DATED MONEMBER 17

THE GROUP, THE MORNATION REPORT, FLE NO. 63-22888774-SOL, DATED MONEMBER 17

THE GROUP, THE MORNATION REPORT, FLE NO. 63-22888774-SOL, DATED MONEMBER 17

THE GROUP, THE MORNATION REPORT, FLE NO. 63-22888774-SOL, DATED MONEMBER 17

THE GROUP, THE MORNATION REPORT, FLE NO. 63-22888774-SOL, DATED MONEMBER 17

THE GROUP, THE MORNATION REPORT, FLE NO. 63-22888774-SOL, DATED MONEMBER 17

THE GROUP, THE MORNATION REPORT, FLE NO. 63-22888774-SOL, DATED MONEMBER 17

THE GROUP, THE MORNATION REPORT, FLE NO. 63-22888774-SOL, DATED MONEMBER 17

THE GROUP THE GROUP THE MORNATION REPORT, FLE NO. 63-22888774-SOL, DATED MONEMBER 17

THE GROUP THE G

ISSUED FOR	DATE	ISSUED FOR	DATE	ISSUED FOR	DATE	ISSUED FOR	DATE	ISSUED FOR	DATE	ZEIMET WIEZN
BMITTAL	7/26/24									$\int_{1}^{\frac{1}{1}\frac{1}{1}\frac{1}{1}\frac{1}{1}} W_{k} \frac{\sqrt{2}\frac{1}{1}}{\sqrt{2}\frac{1}{2}\frac{1}{2}\frac{1}{2}}$
SUBMITTAL	7/09/25									Consulting Civil Engine
SUBMITTAL	8/22/25									55800 GRAND RIVER AVE., SÜITE NEW HUDSON, MICHIGAN 481 P: (248) 437-5099 F: (248) 437-5222 www.zei
UPDATE	9/12/25									







BOUNDARY SUR THE GROVE NOVI, MICHIGAN


1/14/24	SCALE HOR: 1" = N/A VER: 1" = N/A
DESIGNED BY SRB	JOB NO. 22149
DRAWN 6Y DAB	SHEET SP-7.3


JUSTIN OSWALT PROFESSIONAL SURVEYOR












Sheet No.



- After two weeks of herbicide application, the dead stalks should be cut and removed to encourage native plant material growth. If a mechanical method is
 used, equipment should be cleaned to prevent the spread of seed.

1. A visual inspection will be made during June - July. If phragmites is present, steps 1-3 above will be repeated

Notes:

Trees Shall be Planted no Closer than 10' to Sanitary Sewer, Utility Structures Including Hydraris and 5' from Utility Lines. Trees Shall be Planted 4' from Curbs.

Tree Shall not Be Planted within 4' of Property Lines.

Snow Shall be Deposted Aglacent to Drives and within the Curb Lawn. Any Damaged Trees Shall be Replaced as Needed. If Walks are Adjacent to the Street, Snow What but the Stored in Newly Islands or Lawn Polys Islands or Lawn Applications.














Sheet No.



ALLENDESIGN





Landscape Plan

Project:

The Grove Novi, Michigan

Prepared for:

Ivanhoe Companies 6689 Orchard Lake Road, Suite 314 West Bloomfield, Michigan 48322 248.626.6114

March 28 2024 July 26, 2024 July 9, 2025 September 12, 2025

Job Number:

21-054

Drawn By: Checked By:





Sheet No.

Multi-Family Trees - 244 Trees Provided

Notice:


Trees Shall be Planted no Closer than 10' to Sanitary Server, Utility
Structures including hydrants and 5' from Utility Lines. Trees Shall be
Planted 4' from Curbs.


Tree Shall not Be Planted within 4' of Property Lines.

Tree Shall not Be Planted within 4' of Property Lines.

The Shall not Be Planted within 4' of Property Lines.

The Shall not be Planted Agriculture to Divers an Weeting the Curb Linum. Any Shall not the Sh





Landscape Summary - This Sheet

12 Mile Road Street Lawn Total Street Frontage Less Drive Opening Net Street Frontage Trees Required Trees Provided 577 Lf. 104 Lf. 473 Lf. 13.5 Trees (473 / 35) 14 Trees (Remaining 4 Trees are Shown in Park) r trees provided
Greenbelt Plantlings
Total Street Frontage
Less Preservation Area
Drive Opening
Net Street Frontage
Canopy Trees Required
Canopy Trees Provided
Sub-Canopy Trees Provided
Macdowletock Da-2 577 Lf. 226 Lf. 60 Lf. 291 Lf. 8.3 Trees (291 / 35) 8 Trees 11.6 Trees (291 / 25) 12 Trees Meadowbrook Road

Meadowbrook Road Street Lawn Total Street Frontage Less Drive Opening Net Street Frontage Trees Required Trees Provided 850 l.f. 145 l.f. 705 l.f. 20.1 Trees (705 / 35) 20 Trees I rees Provided
Greenbelt Plantings
Total Street Frontage
Less Drive Opening
Less Preserved Frontage
Net Street Frontage
Canopy Trees Required
Canopy Trees Provided
Sub-Canopy Trees Prequired
Sub-Canopy Trees Provided

850 l.f. 60 l.f. 64 l.f. 790 l.f. 20.7 Trees (726 / 35) 21 Trees 29.0 Trees (726 / 25) 29 Trees

Potential Wetland Mitigation

tes:
Trees Shall be Planted no Closer than 10' to Sanitary Sewer, Utility
Structures Including Hydrants and 5' from Utility Lines. Trees Shall be
Planted 4' from Chuste within 4' of Property Lines.
Tree Shall not Be Planted within 4' of Property Lines.
Snow Shal be Deposited Adjacent to Orives and within the Curb Lawn. Any
Damaged Trees Shall be Replaced as Needed. It Walts are Adjacent to the
Steed, Snow Will be Storden i Neathy Islands or Lawn Any
Damaged Trees Shall be Replaced as Needed. It Walts are Adjacent to the
Steed, Snow Will be Storden in Neathy Islands or Lawn Areas.

Bench Detail, 11 Instances



Jameson 6' Recycled Plastic Bench Color - Brown Mounted on 4' x 8' Concrete Pad







Tree Protection Fencing

Grove Nature

Greenbelt and Entry

Project:

The Grove Novi, Michigan

Prepared for:

Ivanhoe Companies 6689 Orchard Lake Road, Suite 314 West Bloomfield, Michigan 48322 248.626.6114

Revision:	Issued:
Review	March 28, 2024
Revised	July 26, 2024
PRO Submission	July 9, 2025
Revised PRO Submission	September 12, 2025

Job Number: 21-054

Drawn By:

Checked By:

15' 30'



1"=30"

Sheet No.

12 Mile Road Park, Bus Stop and Open Space 12 Mile Road Park and Open Space
 Seating
 Bike Racks for 4 Bikes
 Bike Rest Stop Bus Stop
 Seating
 Bike Racks for 8 Bikes Rerennial Garden 25' Wetland Buffer
Wetland Buffer Seed Mix with Buffer
Tree Protection Fencing
Wetland Limits Overlook
 Crushed Limeston MDOT Natural Preservation Area Crushed Limestone Path Park Limits 24 Grove Nature Area Trail 29 Additional Overlook Benches Provided to the South







12 Mile Park, Bus Stop and Open Space

Project:

The Grove Novi, Michigan

Prepared for:

Ivanhoe Companies 6689 Orchard Lake Road, Suite 314 West Bloomfield, Michigan 48322 248.626.6114

Revision:	Issued:		
Review	March 28, 2024		
Revised	July 26, 2024		
PRO Submission	July 9, 2025		
Revised PRO Submission	September 12, 2025		

Job Number: 21-054


Drawn By: Checked By:






Sheet No.

Meadowbrook South Greenbelt



Meadowbrook South Greenbelt



Landscape Summary - This Sheet

Meadowbrook Road Street Lawn Total Street Frontage Less Drive Opening Net Street Frontage Trees Required Trees Provided 921 l.f. 104 l.f. 817 l.f. 23.3 Trees (817 / 35) 23 Trees Trees Provided
Greenbelt Plantings
Total Street Frontage
Less Preservation Area
Drive Opening
Net Street Frontage
Canopy Trees Required
Canopy Trees Prequired
Sub-Canopy Trees Prequired
Sub-Canopy Trees Provided 921 l.f. 510 l.f. 60 l.f. 351 l.f. 10.0 Trees (351 / 35) 10 Trees 14.0 Trees (351 / 25) 23 Trees

- Ides:
 Trees Shall be Planted no Closer than 10' to Sanitary Sewer, Utility
 Structures including Hydrants and 5' from Utility Lines. Trees Shall be
 Planted 4' from Cutility.
 Tree Shall not Be Planted tuttles.
 Tree Shall not Be planted adjacent to Drives and within the Cut Lawn. Any
 Damaged Trees Shall be Replaced as Needed. It Walks are Adjacent to the
 Street, Show will be Strider in Nearby Islands or Lawn Areas.







Greenbelt and Entry

Project:

The Grove Novi, Michigan

Prepared for:

Ivanhoe Companies 6689 Orchard Lake Road, Suite 314 West Bloomfield, Michigan 48322 248.626.6114

Revision:	Issued:	
Review	March 28, 2024	
Revised	July 26, 2024	
PRO Submission	July 9, 2025	
Revised PRO Submission	September 12, 2025	

Job Number:

21-054

Checked By: Drawn By:


15' 30'



1"=30"

Sheet No.

North Buffer



- Notice:
 Trees Shall be Planted or Closer than 10' to Sandary Server. Utility
 Structures including Hydrants and 5' from Utility Lines. Trees Shall be
 Planted 4' from Curbs.
 Trees Shall not Be Planted within 4' of Property Lines.
 The Shall not Be Planted within 4' of Property Lines.
 Snow Shall be Deposited Adjacent to three and within the Curb Lisen. Any
 Show Shall be Deposited Adjacent to three shall within the Curb Lisen. Any
 Street, Snow will be Stored in Nearby Islands or Lawn Areas.

ALLENDESIGN





Proposed Buffers

Project:

The Grove Novi, Michigan

Prepared for:

Ivanhoe Companies 6689 Orchard Lake Road, Suite 314 West Bloomfield, Michigan 48322 248.626.6114

Revision:	Issued:
Review	March 28, 2024
Revised	July 26, 2024
PRO Submission	July 9, 2025
Revised PRO Submission	September 12, 2025

Job Number: 21-054

Drawn By: Checked By:










Sheet No.

L-7


South Buffer



Pond A 28 Seed Mix Permanent Water Elev. 900.0

Pond C Stormwater Seed Mix Permanent Water Elev. 884.0

Pond B



Landscape Summary - This Sheet

Pond A
Detention Pond Plantings
10' from Water Elevation
Required Planting
Planting to be Provided
Pond Frontage for Trees
Trees Required
Trees Provided 982 l.f. 688 l.f. (70%) 695 l.f. (71%) 834' 23.8 Trees (834 / 35)

Pond B
Detention Pond Plantings
10' from Water Elevation
Required Planting
Planting Planting to be Provided
Pond Frontage for Trees
Trees Required
Trees Provided 493 l.f. 345 l.f. (70%) 355 l.f. (72%) 308' 8.8 Trees (308 / 35) 15 Trees

Pond C
Detention Pond Plantings
10' from Water Elevation
Required Planting
Planting Planting to be Provided
Pond Frontage for Trees
Trees Required
Trees Provided 613 l.f. 429 l.f. (70%) 433 l.f. (71%) 422' 12.0 Trees (422 / 35) 19 Trees

- Notes:

 Trees Shall be Planted no Closer than 10' to Sanitary Sever, Utility Structures including Hydrants and 5' from Utility Lines. Trees Shall be Planted 4' from Culties United.

 Tree Shall not Be Planted with of corp. Lines. Trees Shall not Be Planted with a Corp. Shall not Be Planted with a Corp. Lines.

 Tree Shall not Be Planted with 6' of Plopping Lines.

 Tree Shall not Be Planted with 6' of Planted within the Cult Laun. Any Damaged Trees Shall be Reglaced as Needed. If Wilds are Adjacent to the Street Shall within for Class Pleasa.

Storm Water Seed Mix





53,092 s.f. Total Area

34.2 lbs. per Acre Application Rate 41.7 lbs. of Detention Seed Mix Required 3"-6" of Topsoil with 20%-30% Compost Shall be Placed in this Area.

Note:
Contractor Shall Provide Proof of Seed to be Used in the Form of an Invoice or Photo of the Seed Bag to rmeader@cityofnovi.org for Approval Prior to Installation. If an Unacceptable Seed Mix is Used, the City Reserves the Right to Destroy the Plants and Re-seed with and Acceptable Mix at the Developer's Expense.







Detention Ponds

Project:

The Grove Novi, Michigan

Prepared for:

Ivanhoe Companies 6689 Orchard Lake Road, Suite 314 West Bloomfield, Michigan 48322 248.626.6114

Revision:	Issued:		
Review	March 28, 2024		
Revised	July 26, 2024		
PRO Submission	July 9, 2025		
Revised PRO Revision	September 12, 20		

Job Number: 21-054

Checked By: Drawn By:











Sheet No.

Pond D 1000 1000 Seed Mix Permanent Water Elev. 896.0

Pond E



Pond F



Landscape Summary - This Sheet

Pond D
Detention Pond Plantings
10' from Water Elevation
Required Planting
Planting to be Provided
Pond Frontage for Trees
Trees Required
Trees Provided 607 l.f. 425 l.f. (70%) 433 l.f. (71%) 344' 9.8 Trees (344 / 35) 15 Trees

Pond E
Pond E
Detention Pond Plantings
10' from Water Elevation
Required Planting
Planting to be Provided
Pond Frontage for Trees
Trees Required
Trees Provided 384 l.f. 269 l.f. (70%) 288 l.f. (75%) 267' 7.6 Trees (267 / 35) 10 Trees

Pond F

Pond F

Detention Pond Plantings
10' from Water Elevation
Required Planting
Planting to be Provided
Pond Frontage for Trees
Trees Required
Trees Provided 719 l.f. 503 l.f. (70%) 518 l.f. (72%) 667' 19.1 Trees (667 / 35) 30 Trees

Notes:

* Times Shall be Planted no Closer than 10' to Sanzhary Sever, Utility

* Times Shall be Planted no Closer than 10' to Sanzhary Sever, Utility

* Times Shall not be Planted of them. On the Planted of Reno Line Shall be Planted of them. On the Shall not be Planted of them to the Shall not be Planted of them. On the Shall not Be Planted on them of the Shall not Be Planted on the Shall not be Shall not Shall be Rejalaced as Needed. If Vitals are Adjacent to the Street Chosen the Street of Needed Shall be Rejalaced as Needed. If Vitals are Adjacent to the Street Chosen the Street of Needed Shall not or Lam Areas.







Detention Ponds

Project:

The Grove Novi, Michigan

Prepared for:

Ivanhoe Companies 6689 Orchard Lake Road, Suite 314 West Bloomfield, Michigan 48322 248.626.6114

Revision:	Issued:	
Review	March 28, 2024	
Revised	July 26, 2024	
PRO Submission	July 9, 2025	
Revised PRO Submission	September 12, 202	

Job Number: 21-054


Drawn By: Checked By:









Sheet No.



The Vistas - 5 Unit



The Meadows 4 Unit





ALLENDESIGN

Unit Typicals

Project:

The Grove Novi, Michigan

Prepared for:

Ivanhoe Companies 6689 Orchard Lake Road, Suite 314 West Bloomfield, Michigan 48322 248.626.6114

Revision:	Issued:
Review	March 28, 2024
Revised	July 26, 2024
PRO Submission	July 9, 2025
Revised PRO Submission	September 12, 2025



Drawn By: Checked By:

ca	jca		




Sheet No.




The Meadows 5 Unit



The Meadows 6 Unit



The Pointe and Woods 3 Unit




The Woods and Pointe 4 Unit


999

000

88



The Woods and Pointe 5 Unit



Unit Frontage Summary

Office Frontage Suffilliary				
Building Type	Building Length	Required Landscape (35%)	Landscape Provided	Waiver Required
The Vistas, 4 Unit	108.7'	37.8'	43.7'	0
The Vistas, 5 Unit	138.7'	48.5'	57.5'	0
The Meadows, 4 Unit	96.7'	33.8'	39.7**	0
The Meadows, 5 Unit	120.7'	42.3'	47.5**	0
The Meadows, 6 Unit	144.7'	50.6"	55.2**	0
The Woods and Pointe, 3	Unit 90.7'	31.7"	42.0'	0
The Woods and Pointe, 4	Unit 120.7'	42.2'	55.7'	0
The Woods and Pointe, 5	Unit 150.7'	52.7"	68.0'	0

*Note: Plantings Along the Building Sides that will be Visible from the Street are Included in the Provided Frontage Landscaping

- Notes for all Residential Envelopes:

 1. Unit mix, size, and location are representative and may vary within the building envelope. Each building envelope will accommodate 3 6 units.

 Building envelope deight may increase in some locations to a building envelope unit. All minimum setback requirements will be maintained.

 3. Decks or pations may extend a maximum of 10 bepond the building envelope into the perimeter, side to side, and side to rear setback.

 4. Minimum Building Width; 2-2.

 4. Minimum Building Width; 2-2.

 5. All units will have 2-or 3 bedooms.


 7. Minimum Driveway Length is 20' from Sidewalks.

© 2025 Allen Design L.L.C.


L-10

1"=40"

Park / Recreation Area



Clubhouse Option



Landscape Summary - Clubhouse Option


Foundation Landscaping Building Perimeter Less Doors Net Perimeter Landscape Area Required Landscape Area Provided 214 l.f. 12 l.f. 202 l.f. 1,616 s.f. (202 x 8) 1,862 s.f.

Notes:

1. The Location and Design of Amenities are Conceptual and Subject to Change.

2. All Landscape Requirements Shall be Provided.

Optional Clubhouse Area



Note for Optional Clubhouse Area:

1. The Clubhouse / Pool are optional and may not be built. The size and location of clubhouse / pool shown within the buildable envelop is representative of what may be built and is subject to change.

ALLENDESIGN





Amenity Plan

Project:

The Grove Novi, Michigan

Prepared for:

Ivanhoe Companies 6689 Orchard Lake Road, Suite 314 West Bloomfield, Michigan 48322 248.626.6114

Revision:	Issued:		
Review	March 28, 2024		
Revised	July 26, 2024		
PRO Submission	July 9, 2025		
Revised PRO Submission	September 12, 2025		

Job Number: 21-054


Drawn By: Checked By:








Sheet No.



DECIDUOUS TREE PLANTING DETAIL




MULTI-STEM TREE PLANTING DETAIL



NOTE: ORIENT STAKING/GUYING TO PREVAILIE WINDS, EXCEPT ON SLOPES GREATER THAN 3:1 ORIENT TO SLOPE. : IT STAKINGIGLIVING TO PREVAILING USE SAME STAKING/GUYING ORIENTATION FOR ALL PLANTS WITHIN


STAKING/GUYING LOCATION




GUYING DETAIL

STAKING DETAIL


TREE STAKING DETAIL




EVERGREEN TREE PLANTING DETAIL



TRANSFORMER SCREENING DETAIL



PERENNIAL PLANTING DETAIL



HORIZONTAL SCALE: 1"=10"

NOTE: TREE SHALL BEAR SAME RELATION TO FINISH GRADE AS IT BORE ORIGINALLY OR SLIGHTLY HIGHER THAN FINISH GRADE UP TO 4" ABOVE GRADE, IF DIRECTED BY LANDSCAPE ARCHITECT FOR HEAVY CLAY SOIL AREAS.

PRUNE ONLY DEAD OR BROKEN

SHREDDED HARDWOOD BARK. NATURAL IN COLOR. PULL BACK 3" FROM TRUNK. REMOVE ALL TAGS, STRING, PLASTICS AND OTHER MATERIALS THAT ARE PLANTING MIXTURE: UNSIGHTLY OR COULD CAUSE AMEND SOILS PER SITE CONDITIONS GIRDLING. AND REQUIREMENTS OF THE PLANT MATERIAL. MOUND EARTH TO FORM SAUCE REMOVE COLLAR OF ALL FIBER POTS. POTS SHALL BE CUT TO_ PROVIDE FOR ROOT GROWTH. REMOVE ALL NONO CONTAINERS COMPLETELY

REMOVE ALL
NON-BIODEGRADABLE MATERIALS
COMPLETELY FROM THE
ROOTBALL. FOLD DOWN BURLAP FROM TOP # OF THE ROOTBALL

MULCH 3" DEPTH WITH

SCARIFY SUBGRADE AND PLANTING PIT SIDES. RECOMPACT BASE OF TO 4"

SHRUB PLANTING DETAIL

LANDSCAPE NOTES

- All plants shall be north Midwest American region grown, No. 1 grade plant materials, and shall be true to name, free from physical damage and wind burn.

 Plants shall be full, well-branched, and in healthy vigorous growing condition.

- Professional to the III, were criterious, and in nearby opposition growing. Primish shall be wastered before and after planting is complete. All trees must be staked, feelitized and mulached and shall be quaranteed to exhibit a normal growth cycle for all seath to (2) full years following. Only approval.

 All materials are conforme to the guidelines established in the most secent. All the conformed to the guidelines established in the most secent. Provide dean backfill soil, using material stockpied on also. Soil shall be accessed and need only destine, foreign material, and stone. The provides of t

- 8. Amended planting mix shall consist of 17s screened topoult, 17s sand and 15d compost, mixed well and spread to the depth as indicated in planting details. 15d compost, mixed well and spread to the depth as indicated in planting details. 15d compost, mixed and spread to 15d composition of the planting set of the planting best of the planting best of the planting best of the planting best of the planting planting best of the planting set of the planting best of the planting planting best of the planting set of the planting planting best of the planting set of the planting planting best of the planting set of the planting planting best of the planting set of the planting planting set of the planti

CITY OF NOVI NOTES

- All indicacys isstined shall be backfilled with a sand minuter to facilitate drainage.

 All proposed tendercape islands shall be curbed.

 All proposed tendercape islands shall be curbed.

 All proposed tendercape islands shall be carbed.

 All proposed tendercape islands shall be distributed an infirman of 10 firms after hydradt, and control tendercape the shall be planted an infirman of 10 firms after hydradt, and control tendercape the shall be planted and instituted to the proposed tendercape the shall be planted and instituted and instituted and instituted and instituted and instituted and instituted the shall be planted and instituted to the shall be planted and instituted and institu
- proposed valids.

 In the proposed valids by parting best shall be mushed with streeteds bardwood bark spread to intermine depth of "A libam hars there what have as 4 dismeter citized of shreeted bardwood valids "A way from truth. All personal, annual and ground cover beds shall receive 2" of ant colored bard much as incidented on the plant list. Much or but the libam colored bard much as incidented bardwood valids and colored bardwood valids and colored bardwood valids and colored bardwood valids and colored bardwood valids of the libam colored bardwood valids of the libam colored bardwood valids and the libam colored bardwood valid

NOTES: THE APPROXIMATE DATE OF INSTALLATION FOR THE PROPOSED LANDSCAPE WILL BE MARCH 15 AND NOVEMBER 15.

THE SITE WILL BE MAINTAINED BY THE DEVELOPER IN ACCORDANCE WITH THE STANDARDS SET FORTH IN THE CITY OF NOVI ZONING ORDINANCE. THIS INCLUDES WEEDING AND WATERING AS REGISSER BY

PLANT MATERIALS SHALL BE GUARANTEED FOR 2 YEARS AND SHALL BE MAINTAINED IN ACCORDANCE WITH CITY ORDINANCES. WARRANTY PERIOD BEGINS AT THE TIME OF CITY APPROVAL. WATERING AS NECESSARY SHALL OCCUR DURING THIS WARRANTY PERIOD.

ANY SUBSTITUTIONS MUST BE SUBMITTED IN WRITING AND APPROVED BY THE CITY

ALLENDESIGN





Landscape Details

Project:

The Grove Novi. Michigan

Prepared for:

Ivanhoe Companies 6689 Orchard Lake Road, Suite 314 West Bloomfield, Michigan 48322 248 626 6114

Revision:	Issued:
Review	March 28, 2024
Revised	July 26, 2024
DDO Cataviralia	1.1.0.0005

Job Number:

21-054

Drawn By: Checked By:

Sheet No

what's helow

L-12

© 2025 Allen Design L.L.C.



Key

Bold Trees to be Removed

See Sheet L-15 - L-19 for Tree List

ALLENDESIGN



Woodland Plan

Project:

The Grove Novi, Michigan

Prepared for:

Ivanhoe Companies 6689 Orchard Lake Road, Suite 314 West Bloomfield, Michigan 48322 248.626.6114

evision:	Issued:					
- delene	March 20 2					

Job Number:

Drawn By: Checked By:





Sheet No.

Matchline Sheet L-12 Tree Protection Fencing See Sheet L-20 Wetland Mitigation Matchline Sheet L-14

Key
Bold Trees to be Removed
See Sheet L-15 - L-19 for Tree List

ALLENDESIGN LAND PLANNING / LAND SCAPE ARCHITECTURE

t. 248.467.4e

800



Title

Woodland Plan

Project:

The Grove Novi, Michigan

Prepared for:

Ivanhoe Companies 6689 Orchard Lake Road, Suite 314 West Bloomfield, Michigan 48322 248.626.6114

Revision: Issued:

Revised PRO Submission Revised PRO Submissi

March 28, 2024 July 26, 2024 July 9, 2025 ission September 12, 2025

Job Number:

21-054

Drawn By:

Checked By:





No.

Sheet No.

L-14

Г





557 Carper Northville, Michigan 48 e. jca®wideopenwest.c t. 248.467.4



Sea



Title:

Woodland Plan

Project:

The Grove Novi, Michigan

Prepared for:

Ivanhoe Companies 6689 Orchard Lake Road, Suite 314 West Bloomfield, Michigan 48322 243.626.6114

Revision:	Issued:				
Review	March 28, 2024				
Revised	July 26, 2024				
PRO Submission	July 9, 2025				
Revised PRO Submission	September 12, 2025				

Job Number:

. .

Drawn By: Checked By:







Sheet No.

L-15

Know what's below.

Required Mutti-Stem Tag Scientific Name Common Name Dia. Condition Status Replacement Replacement Credits	Required Multi-Stern Tag Scientific Name Common Name Dia. Condition Status Replacement Replacement Credits	Required Multi-Stem Tag Scientific Name Common Name Dia. Condition Status Replacement Replacement Credits	Required Multi-Stern Tan Scientific Name Common Name Dia Condition Status Registerent Replacement Condits
1 Ukrus americane American ekn 12 Fair Save 2 Americanum Red maple 9 Fair Save 3 Aprovibrum Red maple 9 Fair Save	160 Pinus sylvestris Scots pine 10 Fair Remove 1 161 Ulmus americana American elm 17 Fair Romove 2	320 Populus delitoides Elestem cottomacod 11 Fair Save 331 Populus delitoides Elestem cottomacod 8 Fair Save 322 Populus delitoides Elestem cottomacod 8 Fair Save	737 Robinia prosudencecia Black loculot 18 Fair Remove 2 738 Robinia gasudoscuccia Black loculot 9 Fair Remove 1
3 Aperindrum Redinaple 9 Fair Save 4 Aperingundo Boxelder 10 Fair Save	162 Aper-pubruso Red maple 14 Fair Remove 2 163 Aper-pubruso Red maple 18 Fair Remove 2	322 Populos deltoides Eastern cottonwood 16 Fair Sawe 323 Malar pumile Common apple 10.10.11 Fair Exempt	739 Pourus serotina Black cherry 8 Fair Remove 1 740 Robinia praeudoscapia Black locust 10 Fair Remove 1
5 Frankos pennsylvanica Green ash 12 Good Save 6 Acer secchanum Sugar maple 10 Good Remove 1	164 Acervatrum Red maple 9,15 Fair Remove 3 165 Pranus sercina Black cherry 15 Fair Remove 2	324 Pices ables Norway spruce 13,16 Fair Exempt 325 Acer secchanteum Silver maple 35 Good Exempt	741 Robinia pseudocacia Black locust 13 Fair Remove 2 742 Robinia pseudocacia Black locust 14 Fair Remove 2
Flashing persoywaring - Green ab. 12 Good Else	166 Pinus sylvestris Soots pine 29 Fair Remove 3 167 Pratus sercins Black cherry 13 Fair Remove 2	326 Pinus sylvestris Soots pine 9 Fair Exempt 327 Pinus sylvestris Soots pine 11 Fair Exempt	743 Acer regundo Boxelder 11 Fair Remove 1 744 Robinia payodecacia Black locust 13 Fair Remove 2
9 Pinus sylvestris Scots pine 9 Fair Remove 1 10 Acer seccharum Sugar maple 11 Good Remove 1	168 Pinus sylvestris Scots pine 8 Fair Remove 1 169 Pinus sylvestris Scots pine 8 Fair Remove 1	326 Pinus sylvestris Scots pine 8 Fair Exempt 329 Pinus sylvestris Scots pine 9 Fair Exempt	745 Robinia pseudoscacia: Black locust 15 Fair Remove 2 746 Prozus serotina Black cherry 12 Fair Remove 2
11 Pinus sylvestris Scots pine 8 Fair Remove 1 12 Pinus sylvestris Scots pine 9 Good Remove 1	170 Phonos serolina Black cherry 9 Fair Remove 1 171 Phonos serolina Black cherry 15 Fair Remove 2	230 Pinus sylvestris Scots pine 6 Fair Exempt 233 Pinus sylvestris Scots pine 8 Fair Exempt	747 Rebinia psiaudoscaccia Black locust 10 Fair Remove 1 748 Alcer regundo Boxelder 12 Fair Remove 2
1	102 Auto-Outor Instrument 103 Fall Instrument 2 Instrument	334 Pinus sylvestris Scots pine 7 Fair Exempt 335 Pinus sylvestris Scots pine 8 Fair Exempt	749 Robinia preudoscacia: Black locust 10 Fair Remove 1 750 Robinia pseudoscacia: Black locust 14 Fair Remove 2
10 Acer obtuse Red magie 8 Fair Remove 1 16 Acer obtuse Red magie 15 Fair Remove 2	174 Insular pureus Common appeal 9,11 Pair Institute 1 175 Pinus sylvestris Soots pine 12 Fair Remove 2	336 Populus delfoides Esistem cottonwood 12 Peir Ecempt 337 Populus delfoides Esistem cottonwood 7 Peir Ecempt	751 Acer regundo Bosolder 9 Pair Remove 1 752 Robinia pseudoacacia Black locust 12 Fair Remove 2
17 Paus gyapestis Sodis pine 8 Fair Betrooe 1	177 Photos parcins Black cherry 9 Fair Remove 1	330 Approximation Red maple 35 Fair Exempt	753 Protoria passobucació Black locust 11 Fair Remove 1 754 Protoria passobucació Black locust 11 Fair Remove 1
20 Acur nature Red maple 12 Fair Remove 2 21 Province perceion Standard plants 14 Good Parrows 1	179 Aper-valuer Red maple 37 Fair Remove 4	341 Popular deltoides Eastern cottonwood 10 Feir Save	756 Robina praeudoscaria Black locust 13 Fair Remove 2
A continued of the co	181 Acervature Red maple 20 Feir Remove 2 182 (Arms armerises American etc. 9 Feir Remove 1	343 Populus delicidas Esistem cottonwood 9 Fair Saws	758 Robinia praedoscala: Black locuat. 12 Pair Remove. 2
20 Pavas pylanistos Sosto pine 22 Okod Berricoe 3	163 Aperiodrum Redinagle 6,8 Fair Remove 1 184 Aperiodrum Redinagle 12 Fair Remove 2	345 Populya delizioles Esselem cottomesco 8 Fair Sawe 346 Provide delizioles Esselem cottomesco 9 Fair Sawe	750 Robbie previouscele Black locust 16 Fair Remove 2 751 Britinia resorbanancia Black locust 13 Fair Remove 2
26 Pinus strobus Eastern white pine 31 Excellent Remove 4 27 Pinus serbina Black charry 8 Fair Remove 1	165 Pinus sylvestris Scots pine 11 Fair Remove 1 166 Pinus sylvestris Scots pine 11 Fair Remove 1	347 Populos delicades Eastern cottonwood 11 Fair Save 348 Malar rumila Common acres 11 Pon Events	702 Robinia pseudocacia: Black locust 12 Fair Remove 2 703 Britania mandriamania: Black locust 12 Fair Remove 2
28 Ulmus americane American eln 8 Fair Remove 1 29 Juniperus virginiane Eastern red cedar 11 Good Save	167 Aper appriation Silver maple 14 Good Remove 2 168 Aper raphur Red maple 12 Fair Remove 2	349 Carya condiformia Bitternut hickory 8 Fair Exempt 350 Programias Nasyany project 7 Fair Exempt	764 Robinia posudoscacia Black locust 12,13 Fair Remove 4 765 Aurr.negundo Bossidair 11 Fair Remove 1
30 Pransus sentrina Black chemy 10 Good Remove 1 31 Pransus sentrina Black chemy 6 Fair Exempt	189 Pinus sylvestris Scots pine 8 Fair Remove 1 190 Pinus sylvestris Scots pine 12 Fair Remove 2	301 Acer subrum Red magin 60 Feir Remove 4 352 Piose ables Noneay space 15 Feir Exempt	766 Robinia pseudocacia Black locust 14 Fair Remove 2 767 Robinia pseudocacia Black locust 11 Fair Remove 1
32 Ulmus americana American elm 9 Good Remove 1 30 Pracus sercina Black cherry 10 Fair Remove 1	191 Pinus sylvestris Scots pine 11 Fair Remove 1 192 Pinus sylvestris Scots pine 9 Fair Remove 1	363 Acervatrum Red maple 15,16 Fair Exempt 354 Acervatrum Red maple 16 Fair Exempt	768 Robinia pseudoscacie Black locust 13 Fair Remove 2 769 Robinia pseudoscacie Black locust 12 Fair Remove 2
34 Pinus sylvestris Scots pine 12 Good Remove 2 35 Piucus sercina Black cherry 10 Good Remove 1	193 Pinus sylvestris Scots pine 9 Fair Remove 1 194 Pinus sylvestris Scots pine 11 Fair Remove 1	365 Junipenus virginiane Eastern red cedar 17 Feir Exempt 356 Junipenus virginiane Eastern red cedar 17 Feir Exempt	770 Sassafras albidum Sassafras 14 Fair Remove 2 771 Sassafras albidum Sassafras 17 Fair Remove 2
36 Malus pumile Common apple 8,8 Fair Remove 2 37 Pinus sylvestris Scotis pine 8 Good Remove 1	156 Phose sylvestris Scots price 9 Pair Horrows 1 156 Phose sylvestris Scots price 11 Fair Remove 1	357 Juniperus virginiane Ealstern red cedar 8 Fair Exempt 358 Juniperus virginiane Eastern red cedar 9 Fair Exempt	772 Robinia preudoscacia: Black locust 12 Fair Remove 2 773 Robinia pseudoscacia: Black locust 9 Fair Remove 1
38 Prunus serchina Black chemy 7 Good Exempt 39 Junipenus virginiana Eastern red cedar 9 Good Remove 1	197 Acertabrace Red maple 15 Pair Remove 2 198 Acertabrace Red maple 7,15 Fair Remove 2	359 Juniperse virginiane Elektern nid cedar 8 Feir Exempt 360 Picea ables Norway spruce 20 Feir Exempt	774 Robinia pasudoacacia Black locust 10 Fair Remove 1 775 Robinia pasudoacacia Black locust 13 Fair Remove 2
20	200 Pinus sylvestris Soots pine 8 Fair Romove 1	361 Robins psychococol Black locust 20 Fair Exempt 362 Uhrus americane American elm 24 Good Remove 3 203 Acre socchartore Silver maple 26 Poor Remove 3	776 Robina pasudancacia Black locust 14 Fair Remove 2 777 Robina pasudancacia Black locust 8 Fair Remove 1
43 Acur sacchasum Sugar maple 10 Good Remove 1	202 Pinus sylvastris Scots pine 14 Fair Remove 2	363 Aper sacongresser state maps 26 Poor Hermone 3 364 Pinus sylvestris Scots pine 8 Fair Exempt	770 Acer regundo sicosoer 11 Fair Fernove 1 779 Robinia praeudoscacia: Black locust 17 Fair Remove 2
45 Pinus sylvestris Scots pine 9 Very Poor Exempt 60 (Save appairage Sympton also 9 Good Persons 1	204 Prince services Black cherry 7,12 Feir Remove 2 205 Prince services Control one 46 Entry Prince 2	300 Pinus sylvestris Scots prie 7 Feir Evernot 300 Jumpeus vigniane Eastern red cadar 9 Feir Remove 1	760 Aper regundo Boonder 9 Fair Hernove 1 761 Robbits possobucacius Black locust 16 Fair Remove 2 760 Aper Remove 2
47 Phone section Black cherry 13 Fair Remove 2 48 Phone section Black cherry 11 Fair Remove 1	205 Junipense virginiane Eastern red cedar 8 Fair Remove 1 207 Physic supervise South rine 11 Fair Remove 1	306 Popular delicioles Esseten coltonwood 26 Fair Remove 3	763 Robinia posociocacia Black locust 17 Fair Remove 2 764 Ace secundo Brackles Brackles 10 Est Dannes 1
49 Aper secologister Silver maple 12 Good Remove 2 50 Aper secologister Silver maple 8 Feb Remove 1	200 Physic sylvestris Scots pine 9 Very Poor Exempt 209 Physic sylvestris Scots pine 10 Good Remove 1	370 Rhamus catherine Common buckform 7,6 Feir Exempt 371 Rhamus patherine Common buckform 7,2 Feir Exempt	785 Robbig preparation Stack locust 19 Fair Remove 2 786 Robbig anauchanancia Black locust 19 Fair Remove 2
51 Salivarrygdaloides Peachleaf willow 19 Poor Save 52 Ultrus americana American elm 14 Good Save	210 Pinus sylvestris Scots pine 8 Good Remove 1 211 Pinus sylvestris Scots pine 9 Good Remove 1	372 Junipens viginiane Eastern red cedar 13 Fair Remove 2 373 Junipens viginiane Eastern red cedar 12 Fair Remove 2	787 Acernegundo Boxelder 9 Fair Remove 1 788 Britania mandramania Black Install
20 Minus amenium	212 Pinus sylvestris Scots pine 10 Good Remove 1 213 Pinus sylvestris Scots pine 9 Fair Remove 1	374 Ultrus americana American elm 9,9 Fair Remove 3 375 Robinia geoudoscacia Black locust 10 Fair Save	789 Acur regundo Bossider 8 Fair Remove 1 790 Robinia gasudoscania: Black locust 12 Fair Remove 2
55 Pinus sylvestris Scots pine 14 Good Remove 2 56 Junipens viginiane Eastern red cedar 8 Good Remove 1	214 Pinus sylvestris Soots pine 8 Fair Remove 1 215 Pinus sylvestris Soots pine 11 Good Remove 1	378 Robinia pseudoacacia Black locust 10 Fair Save 382 Robinia pseudoacacia Black locust 14 Fair Save	791 Acer platanoides Norway maple 10,10,12 Fair Remove 4 792 Populas deltoides Eastern cottonwood 10 Fair Remove 1
57 Pinus sylvestris Scots pine 9 Good Remove 1 50 Pinus sylvestris Scots pine 10,11 Good Remove 3	216 Ulinius americana American elin 8 Good Remove 1 217 Pinus sylvestis Scots pine 11 Good Remove 1	383 Poblinia pseudoacacia Black looust 12 Fair Save 389 Robinia pseudoacacia Black looust 10 Fair Save	763 Ulrinus pumila Siberian elm 9 Fair Remove 1 794 Ulrinus pumila Siberian elm 8 Fair Remove 1
59 Phosa sylvestris Scots pine 8 Fair Remove 1 60 Junipens viginiare Eastern red cedar 11 Good Remove 1	218 Pinsa sylvestria Scots pine 9 Good Romove 1 219 Piusus seccina Black cherry 8 Fair Remove 1	350 Robinia pseudoacacia Black locust 10 Fair Save 391 Robinia pseudoacacia Black locust 9 Fair Save	765 Uhrsus purella Siberian elm 10 Fair Remove 1 796 Uhrsus americanse American elm 8 Fair Remove 1
61 Ultrus americana American elm 9 Fair Remove 1 62 Ultrus americana American elm 9 Fair Remove 1	220 Pinus sylvestris Scots pine 15 Good Remove 2 221 Pinus sylvestris Scots pine 14 Poor Remove 2	302 Poblinia pseudoacacia Black looust 9 Fair Save 388 Robinia pseudoacacia Black looust 10 Fair Save	707 Popular deltaidas Eastern cottonwood 10 Fair Remove 1 766 Acer regundo Boxelder 11 Fair Remove 1
63 Aper-rubrum Red maple 14 Fair Remove 2 64 Phonos serotina Black cherry 8 Fair Remove 1	222 Phose sylventris Scote pine 15 Pair Remove 2 223 Juglans rigna Black walnut 11 Good Remove 1	364 Robinia pseudoacacia Black locust 12 Fair Save 366 Robinia pseudoacacia Black locust 12 Fair Save	759 Robins pseudoscacia Black locust 11 Fair Remove 1 800 Ultrus americana American elm 10 Fair Remove 1
68 Pinus sylvestris Scots pine 8 Good Remove 1	226 Junipense virginiane Eastern red cedar 13 Feir Remove 2	366 Robinia pseudosceole Black locust 10,11 Fair Sawe 367 Robinia pseudosciache Black locust 17 Fair Sawe	801 Acer negundo Boselder B Fair Remove 1 802 Populas detestas Esistem cottonwood 23 Fair Remove 3
67 Priss sylvestris Scots prie 7 Good Exempt 60 Priss sylvestris Scots pine 7 Fair Exempt	220 Prints sylvestris Social pine 10 Fair Remove 1 227 Prints sylvestris Social pine 11 Fair Remove 1	366 Acer regundo Boxelder 15 Fair Save 350 Robinia presudoscacia Black locust 10 Fair Remove 1	809 Robinia pasudoscacia Black locust 15 Fair Remove 2 804 Robinia pasudoscacia Black locust 12 Fair Remove 2
70 Pinus sylvestris Scote pine 13 Good Remove 2	229 Phase sylventris Soote pine 12 Good Remove 1 230 Disse sylventris Soote pine 11 Good Remove 1	410 Mooning posucocacion Statis South 11 Feir Save 555 Popular deficioles Eastern cottonwood 9 Fair Save	800 Hoticina possoporacia Black charry 9 Fair Remove 1
72 Phase sylvestris Scote prine 11 Good Remove 1	231 Acer sacchartour Sher maple 14 Good Remove 2	500 Missus atha White mutterny 50 Feir Save 557 Acer rubrum Red maple 15,16,23 Feir Save	60 Polytria pseudocacia Black locust 15 Fair Remove 2 60 Robinia pseudocacia Black locust 16 Fair Remove 2
74 Pinus sylvestris Scots pine 10,11,11 Fair Remove 4	223 Acer seconsum Sugar mode 13 Good Remove 2 234 Photos section Black charry 10,13 Poor Remove 3	559 Aperiodoxo Red maple 19 Fair Save	810 Robinia posudoscacio Black locusti 11 Fair Remove 1
76 Ulmus americana American elm 9 Fair Remove 1 77 Ulmus americana American elm 8 Fair Remove 1	235 Pinus sylvestris Scots pine 8 Poor Remove 1 235 Pinus sylvestris Scots pine 8 Poor Remove 1	565 Populos delicides Eastern cottonwood 9 Fair Save	812 Ultrus americana American elm 8 Fair Remove 1
78 Junipenos viginiane Eastern red cedar 9 Good Remove 1 79 Juainos nicro Black valnut 13 Good Remove 2	237 Pranus serorina Black cherry 9 Fair Remove 1 238 April serorina Silver maple 10 Good Remove 1	644 Acertatrum Red maple 28 Fair Save	814 Robinia pseudocacia: Black locust 13 Fair Remove 2
80 Juglans nigra Black walnut 21 Good Remove 3 81 Juglans nigra Black walnut 9 Fair Remove 1	239 Aper saccharisum Silver maple 10,12 Fair Remove 3 240 Aper saccharisum Silver maple 9,9,12 Good Remove 4	646 Aperication Red maple 12 Fair Save 647 Aperication Red maple 8 Fair Save	816 Robinia preudoscanie Black locust 13 Fair Remove 2 817 Robinia preudoscanie Black locust 13 Fair Remove 2
62 Populos deltoides Eastern cottonwood 33 Good Remove 4 63 Aper saccharison Silver maple 6.9 Fair Remove 1	241 Pinus sylvastris Scots pine 9 Good Remove 1 242 Pinus sylvastris Scots pine 15 Fair Remove 2	648 Acer satrum Red maple 15 Fair Save 649 Acer satrum Red maple 10,15 Fair Save	818 Ulmos americane American elm 12 Fair Remove 2 819 Robinia pseudopopole Black locust 16 Fair Remove 2
64 Populus deltaides Eastern cottonwood 14 Fair Ramove 2 65 Junipens viginiane Eastern red cedar 11 Fair Remove 1	243 Pinus sylvastris Scots pine 11 Good Remove 1 244 Pinus sylvastris Scots pine 10 Fair Remove 1	650 Acur subruro Red maple 10,10,13 Fair Save 656 Ulmus americana American elm 11 Fair Save	830 Robinia praeudoscacia: Black locust 15 Fair Remove 2 821 Robinia pseudoscacia: Black locust 14 Fair Remove 2
86 Populus deltoides Eastern cottonwood 22 Fair Remove 3 87 Populus deltoides Eastern cottonwood 41 Fair Remove 4	245 Title americana Balaiswood 5,9 Good Remove 1 246 Acer saccharum Sugar maple 8 Good Remove 1	657 Mahs punils Common apple 8 Fair Save 658 Acer regundo Boxelder 11 Fair Save	822 Robinia presudencia: Black locust 14 Fair Remove 2 823 Robinia presudencia: Black locust 13 Fair Remove 2
66 Populus dell'oides Elisatem cottonwood 21 Fair Remove 3 69 Populus dell'oides Eastern cottonwood 12 Fair Remove 2	247 Pristue sectine Black cherry 8 Fair Remove 1 248 Pinus sylvestris Scots pine 11 Good Remove 1	659 Saliv arrygdaloides Peachleaf willow 7,0,8 Fair Saws 660 Saliv arrygdaloides Peachleaf willow 22 Fair Save	834 Robinia pseudoscacio Black locust 9 Fair Remove 1 835 Robinia pseudoscacio Black locust 9 Fair Remove 1
90 Acer obtuse Red maple 24 Fair Remove 3 91 Popular deltroides Einstern cottonwood 22 Fair Remove 3	289 Pinus sylvestris Soots pine 9 Good Remove 1 250 Acur aucchanture Silver maple 8,14,17 Good Remove 5	661 Populus deltoides Eastern cottonwood 23 Fair Save 652 Acer regundo Boxelder 11 Fair Save	826 Robinia pseudoscacia: Black locust 9 Fair Remove 1 827 Robinia pseudoscacia: Black locust 9 Fair Remove 1
62 Acer ashum Helimape 6,12,14 Fair Hemove 6 93 Populus deltoides Esistem cottonwood 23 Fair Remove 3	251 Plants serons Black cherry 11,15 Good Herrove 4 252 Plant sylvestris Scots prie 11 Feir Remove 1	963 Populus deltoides Eastern optronwood 25 Fair Save 954 Populus deltoides Eastern optronwood 27 Fair Save	828 Robinia pseudoacacia: Black locust 13 Fair Remove 2 839 Acerneguedo Boxelder 11 Fair Remove 1
96 Ulmus americana Americanelm 8 Fair Remove 1	254 Phase stroubs Eastern white pine 15 Good Remove 2 254 Phase stroubs Eastern white pine 15 Good Remove 2 256 Phase constitution of the pine 15 Good Remove 2	665 Populos deticidos Estatem cottomwood 17 Fair Save 665 Unicus americana American elim 11 Fair Save	800 Acer regundo Boxescer 9 Fair Herrove 1 831 Robins posudocacia Black locust 10 Fair Remove 1
97 Populos delicides Eastern cottonwood 18 Fair Remove 2 98 Porsilos delicides Eastern cottonwood 16 Fair Remove 2	256 Phinas sylventria Scota pine 10 Fair Remove 1 257 Phinas sylventria Scota pine 10 Count Remove 1	10	823 Robinia posuplencacia Black locust 14 Fair Remove 2
99 Populos deficides Eastern cottonwood 18 Fair Remove 2 150 Physic sulvestria Scots pine 8 Fair Remove 1	258 Phus sylvestris Scots pine 10 Good Remove 1 259 Phus stratus Eastern white pine 15 Good Remove 2	672 Robinia posudoscolo Black locust 11 Fair Remove 1	835 Robinia posudoscocio Black locust 11 Poor Remove 1
101 Populus delfoides Eastern cottonwood 16 Fair Save 102 Populus delfoides Eastern cottonwood 20 Good Save	260 Pinus sylvestris Scots pine 15 Good Remove 2 251 Pinus sylvestris Scots pine 9 Fair Remove 1	674 Robina pseudoacacia Black looust 10 Fair Remove 1 675 Robina pseudoacacia Black locust 12 Fair Remove 2	837 Acer sacchanism Silver maple 40 Fair Remove 4 838 Robins associational Black locat 8 Fair Remove 1
103 Aper saccharison Silver maple 12 Fair Save 104 Populys delicides Eastern cottonwood 16 Fair Save	262 Pinus sylvestris Scots pine 9 Fair Remove 1 263 Quercus rubra Red cask 19 Fair Remove 2	676 Robinia pseudoacacia Black locust 10 Fair Remove 1 677 Robinia pseudoacacia Black locust 8,10 Fair Remove 3	859 Robinia pseudoscania Black locust 8 Fair Remove 1 840 Robinia pseudoscania Black locust 13 Fair Remove 2
105 Ulmus americana American elm 8 Fair Save 106 Acer saccharisum Silver maple 8 Poor Save	264 Pinus sylvastris Soots pine 13 Fair Remove 2 265 Prusus serolina Black cherry 12,14 Fair Remove 4	678 Poblinia pseudoacacia Black looust 9 Fair Remove 1 679 Robinia pseudoacacia Black looust 21 Fair Remove 3	841 Pronue serotina Black cherry 10 Fair Remove 1 842 Robinia pseudoscapia Black locust 6,9 Fair Remove 1
107 Juniperus viginiane Eastern red cedar 12 Good Remove 2 108 Acer saccharison Silver maple 11 Good Remove 1	288 Phatus serotina Black cherry 8,10 Fair Remove 3 267 Phatus serotina Black cherry 14 Fair Remove 2	680 Acer regundo Boxelder 12 Fair Remove 2 681 Robinia pseudoacacia Black locust 14,18 Fair Remove 4	843 Rebinia praeudoscacia Black locust 10 Fair Remove 1 844 Robinia pseudoscacia Black locust 11 Fair Remove 1
109 Junipense utginisse Eastern riid cedar 14 Good Ramow 2 110 Pinus sylvestris Scoto pine 11 Fair Remove 1	288 Aper-subrustre Red maple 7,12 Pair Remove 2 289 Ultrus americana American elm 8 Fair Remove 1	682 Robinia pasudoscacia Black loculit 12 Fair Remove 2 683 Acer regundo Boxelder 13 Fair Remove 2	846 Robinia preudoscacia: Black locust 12 Poor Remove 2 846 Robinia pseudoscacia: Black locust 12 Fair Remove 2
112 Pinus sylvestris Scots pine 9 Fair Remove 1	271 Pinus syriestris Soots pine 8 Fair Remove 1	685 Ulmus americana American elm 6,13 Poor Remove 2	848 Pounus serotina Black cherry 11 Fair Remove 1
114 Acur secharam Sugar maple 11 Good Remove 1 115 (Sayur appellance American Am 9 Calc Persons 1	273 Phisa sylvastris Sorte pine 12 Fair Remove 2 274 Discus sylvastris Sorte pine 14 Fair Remove 2	687 Pobinia preudonacia Black locust 13,13 Poor Remove 4	850 Protein proceduración Black locust 14 Fair Remove 2
Automate appears	1	680 Physical servicins Black cherry 8 Feir Remove 1	852 Robbia pasudoscola Black locust 9 Fair Remove 1 852 Robbia pasudoscola Black locust 9 Fair Remove 1
118 Aper aucchardson Silver maple 7,9 Febr Save 119 Populos delfordes Eastern cottonwood 34 Poor Romove 4	277 Administration Silver maple 5,9 Good Save 278 Uhrsus americana American ohn 5,9 Good Save	691 Robinia preudoscania Black locust 19 Fair Remove 2 692 Robinia resustranzania Black locust 12 Fair Romove 2	554 Robinia presodenciale Black locust 14 Fair Remove 2 555 Robinia resodenciale Black locust 15 Fair Remove 2
120 Ulmus americana American elm 12 Fair Remove 2 121 Possios deltrades Esistem cottonwood 22 Fair Remove 3	279 Aper seponantum Silver maple 10 Good Save 280 Aper seponantum Silver maple 5.6 Good Exempt	600 Robins pseudoscola Black locust 13 Fair Remove 2 604 Brokes resultanguage Plant locust 12 Fair Remove 2	855 Robinia presidenzacia: Black locust: 15 Fair Remove 2 857 Britisha mandriannania: Black locust: 15 Fair Remove 2
122 Aren secchanisum Silver maple 8 Good Remove 1 123 Populius deltroides Eastern cottonwood 19 Good Save	281 Populus deltoides Eastern cottonwood 19 Good Remove 2 262 Pinus sylvestris Soota pine 10 Good Remove 1	065 Jugiono rigra Black welnut 12 Feir Remove 2 066 Ultrus americana American elm 12 Feir Burrow 2	650 Robinia presidenzacia: Black locust 14 Fair Remove 2 659 Robinia gasodoscacia: Black locust 13 Fair Perrove 2
124 Populos deltoides Eastern cottonwood 24 Good Save 125 Pinus sylvestris Scota pine 9 Fair Remove 1	283 Ulmus americana American elm 9 Poor Save 284 Ulmus americana American elm 10 Good Ramove 1	697 Robinia pseudoscacia Black locust 12 Fair Remove 2 698 Robinia pseudoscacia Black locust 12 Fair Remove 2	860 Robina pseudocacie Black locust 12 Fair Remove 2 851 Robina pseudocacie Black locust 10 Fair Remove 1
126 Acer saccharisum Silver maple 13 Good Save 127 Pinus sylvestris Scots pine 10 Fair Remove 1	285 Pinus sylvestris Scots pine 10 Good Remove 1 285 Pinus sylvestris Scots pine 10 Fair Remove 1	669 Robinia pseudoacacia Black looust 12 Fair Remove 2 700 Robinia pseudoacacia Black looust 13 Fair Remove 2	862 Robinia pseudoscacie Black locust 11 Fair Remove 1 863 Robinia pseudoscacie Black locust 12 Fair Remove 2
128 Pinus sylvestris Scots pine 8 Fair Remove 1 129 Pinus sylvestris Scots pine 11 Fair Remove 1	287 Junipenus viginiane Eastern red cedar 9 Good Remove 1 288 Pinus sylvestris Goots pine 19 Good Remove 2	701 Robinia pseudoacacia Black looust 11 Fair Remove 1 702 Robinia pseudoacacia Black looust 15 Fair Remove 2	864 Robinia pseudoacacie Black locust 12 Fair Remove 2 865 Robinia pseudoacacie Black locust 11 Fair Remove 1
100 Privat splentis 100 cities 9 Privat Person 1	289 Pinus sylvestris Scots pine 9 Good Remove 1 250 Pinus sylvestris Scots pine 10 Fair Remove 1	703 Robinia pseudoacacia Black looust 8 Fair Remove 1 704 Robinia pseudoacacia Black looust 10 Fair Remove 1	866 Rebinia pseudoacacia Black locust 9 Fair Remove 1 867 Robinia pseudoacacia Black locust 11 Fair Remove 1
132 Acur saccharosen Biller maple 10 Good Remove 1 133 Poursus serotina Black cherry 8 Fair Remove 1	201 Phosi sylvestris Scots pine 8 Good Remove 1 252 Phosi sylvestris Scots pine 12 Fair Remove 2	706 Ulmus pumbla Biberian elm 20 Feir Remove 2 706 Robinia pseudoacacia Black loous1 19 Feir Remove 2	868 Robinia gasudeacacia Black locusi 13 Fair Remove 2 869 Robinia pseudeacacia Black locust 11 Fair Remove 1
136 Pinus sylvestris Scots pine 8 Good Remove 1	204 Prince seventy successfully 9 Pair Normow 1 294 Prince sylvestris Soots pine 15 Fair Remove 2	707 Ukraus purtula Siberian elm 24 Fair Remove 3 708 Robinia pseudoacacia Black locust 18 Fair Remove 2	870 Robinia presidenzacia: Black locust 11 Fair Remove 1 871 Robinia pseudoacacia: Black locust 12 Fair Remove 2
137 Prince visiting Scote pine 12 Feir Sale 139 (visiting Scote pine 2 Feir Sale	256 Prices sylvatric Scots pine 9 Fair Remove 1	The Jugains right black wainst 8 Feir Remove 1 710 Jugains right Black wainst 8 Feir Save	The content of the
150	256 Prints sylvanists Scots pine 8 Fair Remove 1 259 Prints sylvanists Scots pine 8 Fair Remove 1 259 Prints sylvanists Scots pine 12 Gard Persona 2	712 Approximate Black Walful 9 Feb 5999 712 Approximate Booklet 8,14,19 Feb 6999 713 Approximate Booklet 8,14,19 Feb 6999 714 Approximate 9999 715 Feb 6999	erin museum proposecutur oldisk 80085 11 Half Hellinde 1 875 Robeira praesobecutari Black locust 12 Half Remove 2 878 Oldiska praesobecutari Black locust 0 Earl 7000000000000000000000000000000000000
141 Ultrus americans American elm 11 Feir Sews 142 Acer sacchariser Silver nacio 1528 Poor Rave	300 Pinus sylvestris Scots pitre 8 Good Remove 1 300 Populary detroides Eastern controvaced 14 Fair Remove 2	717 Robinia passahanania Black torust 15 Feir Sawa 718 Robinia passahanania Black torust 13 Feir Sawa	## 1577 Acer regundo Bosider 19 Fair Remove 2 ### 27 Acer regundo Bosider 19 Fair Remove 2 ####################################
All Author authorized Conference Page	200 Priva sylvents 200 priva 2 Fall Remote 1	719 Physic section Black therry 12 Fair Saw 720 Physic section Black therry 10 Physic Save	879 Robinia presudenzania Black locust 10 Fair Remove 1
145 Pinus sylvestris Scots pine 9 Fair Remove 1 146 Pinus sylvestris Scots pine 10 Good Remove 1	305 Populos deltodes Eastern cotronwood 15 Fair Saws 306 Pinus sylvastra Sooti pine 8 Fair Exempt	721 Umus americane American elm 10 Fair Save 722 Pinus sylvastris Scots pine 11 Fair Remove 1	279 Riskon generalization 10 Fair Remove 1 281 Riskon generalization 10 Fair Remove 1 281 Riskon generalization Risk koost 12 Fair Remove 2 281 Riskon generalization Risk koost 13 Fair Remove 2 282 Riskon generalization Risk koost 13 Fair Remove 2 283 Riskon generalization Risk koost 13 Fair Remove 2 284 Riskon generalization Risk koost 15 Fair Remove 2 285 Riskon generalization Risk koost 15 Fair Remove 2 286 Riskon generalization Risk koost 15 Fair Remove 2 287 Riskon generalization Risk koost 15 Fair Remove 2 288 Riskon generalization Risk koost 15 Fair Remove 2 289 Riskon generalization Risk koost 15 Fair Remove 2 280 Riskon generalization Risk koost 15 Fair Remove 2 280 Riskon generalization Risk koost 15 Fair Remove 2 280 Riskon generalization Risk koost 15 Fair Remove 2 280 Riskon generalization Risk koost Risk k
147 Pinus sylvestris Scots pine 8 Fair Remove 1 146 Pinus sylvestris Scots pine 11 Good Remove 1	307 Ultrus atranicana American elm 6 Fair Save 306 Populus delitridas Elastem cottomezod 10 Fair Save	722 Phasa ayimatha Sooks prie 11 Fair Remove 1 720 Phasas sercina Black cherry 14 Fair Remove 2 724 Acer natrure Red majoi 2, 72 Fair Remove 3	863 Robinia pseudoscacia Black locust 13 Fair Remove 2 884 Robinia pseudoscacia Black locust 15 Fair Remove 2
149 Pinus sylvestris Scots pine 10 Good Remove 1 150 Prusus serctina Black cherry 8 Fair Remove 1	309 Populos deltoides Eastern cottonwood 12 Fair Save 310 Populos deltoides Eastern cottonwood 13 Fair Save	726 Robins pseudoacacia Black louist 15 Fair Remove 2 726 Make purelle Common apple 7,8,12 Fair Remove 3	885 Robinia pseudoscocia Black locust 16 Fair Remove 2 885 Robinia pseudoscocia Black locust 12 Fair Remove 2
150 Possul section	311 Pinus sylveshis Scots pine 4,9 Fair Exempt 312 Pinus sylveshis Scots pine 8 Fair Exempt	727 Maha purnia Common apple 8.8.10 Fair Remove 4 720 Maha purnia Common apple 6.9 Fair Save	887 Robinia pseudoacacie Black locust 11 Fair Remove 1 888 Robinia pseudoacacie Black locust 14 Fair Remove 2
To 7 Phose sylvestris Scots pine 11 Good Remove 1 154 Pinus sylvestris Scots pine 11 Good Remove 1	313 Acer subrure Red maple 10 Fair Save 314 Acer subrure Red maple 7 Fair Save	Material Content	889 Robinia pseudoscacia Black locust 11 Fair Remove 1 860 Robinia pseudoscacia Black locust 13 Fair Remove 2
Column		Section Company	1966
158 Pinus sylvanis Soots pine 10 Good Remove 1 159 Pinus sylvanis Soots pine 10 Good Remove 1 150 Pinus sylvanis Soots pine 9 Entry Burrow 1	417 Pagean versionary Listent COSTONADOS 12 File Date 318 Populas detaides Eastern cottonados 12 File Save 319 Populas relatividas Estatem cottonados 24 File Save	736 Acer regulado Baceldor 11 Fair Remove 1	esu reconse presopercació islack locuet 16 Pair Remove 2 894 Robinia pseudocació Black locust 14 Fair Remove 2
The contract of the contract o		The register programmer (MRM Model) P.M. P.	THE PROPERTY OF THE PROPERTY O





Sea



Title:

Tree List

Project:

The Grove Novi, Michigan

Prepared for:

Ivanhoe Companies 6689 Orchard Lake Road, Suite 314 West Bloomfield, Michigan 48322 248.626.6114

Revision:	Issued:
Review	March 28, 2024
Revised	July 26, 2024
PRO Submission	July 9, 2025
Revised PRO SUbmission	September 12, 2025

Job Number:

21-054

Drawn By: Checked By:



Sheet No.

Required Multi-Stem	Required Multi-Stem	Required Multi-Stem	Required Multi-Stem
185 Policia poscionecia Black locust 9 Fair Remove 1 MIZ Princia poscionecia Black locust 10 Fair Remove 1	Tag Scientific Name Common Name Dis Condition Status represent represent Credits 1879 FUND PROFESSION STATES A CONTROL 1997 1997 1997 1997 1997 1997 1997 199	Tag Searchife Name Common Name One Confident State State September September One September	Top District Name Control Name District Name Distric
887 Riskinia pseudokasasia Black kosasi 10 Fair Romove 1 888 Riskinia pseudokasasia Black kosasi 10 Fair Romove 1 880 Azervadurum Red magis 17 Fair Romove 2	1981 Ulmus americana American elm 8 Fair Remove 1 1992 Ulmus americana American elm 10 Fair Remova 1	2007 Applies region Bits settled 10 Could Remove 1 Could Remove 2 Could	2997 Uhrus americana American etm 10 Fair Bernove 1 2998 Americana Visitriana Eighten red ceder 12 Fair Bernove 2
900 Robinia pseudoacacia Black locust 11 Fair Remove 1 901 Jugiero nigra Black walnut 16 Fair Remove 2	1963 Ulmus americana American elm 11 Peor Romove 1 1964 Aper saccharison Silver maple 23 Good Romove 3	2699 Jugians rigra Black walnut 11 Good Remove 1 2600 Jugians rigra Black walnut 25 Good Remove 3	2999 Populos deficidos Eastern cottonacod 25 Fair Save 3000 Populos deficidos Eastern cottonacod 24 Fair Save
960 Pickha persolikoskia Black Mount 11 Fall Berrone 1 601 Aughen ngoru Black Mount 11 Fall Berrone 2 600 Phisso seritoria Black Charry 56 Fall Berrone 2 600 Phisso seritoria Black Charry 56 Fall Berrone 2 600 Phisso seritoria Charles Charry 60 Fall Berrone 2 600 Phisso seritoria Charles Charles 60 Phisso Series 60 Phisso Serie	1985 Acur seccharison Silver maple 19 Good Remove 2 1996 Rhomous catherise Common buckthorn 9 Fair Exempt	2681 Juglans rigna Black walnut 9 Feir Remove 1 2662 Juglans rigna Black walnut 16 Feir Remove 2	3250 Acervatrure Red maple 13,31 Fair Remove 7 4200 Pinus sylvestris Scots pine 10 Good Remove 1
904 Urrus americana American etm 10 Poor Formove 1 905 Urrus americana American etm 7,6 Feir Formove 1	1987 United americanse American elm 13 Poor Romow 2 1988 Prunus sercrina Black cherry 11 Good Romow 1	2883 Jugians nigra Black walnut 10 Good Pormove 1 2694 Jugians nigra Black walnut 11 Good Remove 1	4239 Pinus sylvestris Scots pine 10 Fair Remove 1 4240 Pinus sylvestris Scots pine 8 Fair Remove 1
10	1999 Acer regundo Boxelder 16 Dead Exempt 1990 Juglians rigna Black walnut 9 Good Ramova 1	2665 Pinus sylvestris Sosta pine 7 Feir Exempt 2666 Augilans rigna Black wahrut 17 Feir Romove 2	4241 Pinus sylvestris Scots pine 10 Good Remove 1 4242 Pinus sylvestris Scots pine 9 Fair Remove 1
900 Umus americano American elm 10 Fair Romove 1 900 Umus americano American elm 10 Fair Romove 1 900 Umus americano American elm 11 Fair Romove 1	1997 Pyrus communic Cultilated pass 12 Pair Remove 2	2867 Augitans rigina Black welnut 19 Feir Remove 2 2888 Urruss americane American elm 8 Feir Remove 1	4243 Phus sylvestris Scots pine 14 Fair Remove 2 4244 Phusus aerotha Black cherry 11 Fair Remove 1
1910 Unitrus amonoscipe Amonoscine ethn 1 + Pair Postrove 1	1994 Malus pumilar Common apple 10 Fair Remove 1	2009 Junipensi segmano Elastem red cedar 10 Feir Fermove 1 2010 Procus seccina Black cherry 12 Feir Remove 2	4265 Jungeros wygnania Ealstern red cedar 11 Good Hernine 1 4266 Jungerus wygniana Elastern red cedar 12 Good Remove 2
913 Acer other Red magie 11 Fair Remove 1 914 Phones section Black there 9 Fair Remove 1	1998 Agiana niya Black walnut 7 Fair Exempt 1997 Phasas section Black there 14.14 Fair Remove 4	2017 Proficial posudocacial Black looust 9 Febr Remove 1 2017 Polyman sulmantar Scott plans 16 Febr Remove 2	4246 Procus percins Black cherry 13,14 Fair Remove 4 4290 Procus percins Black cherry 11,16 Fair Remove 4
915 Phonus serotina Black cherry 11 Fair Remove 1 916 Acer negando Boselder 13,15 Fair Remove 4	1998 Photos serotina Black cherry 11 Fair Remove 1 1999 Robinia pseudoscapia Black locust 10 Fair Remove 1	2674 Acer secchanism Silver maple 13 Good Remove 2 2673 Acer secchanism Silver maple 42 Good Remove 4	4250 Photos sercina Black charry 8 Fair Remove 1 4251 Acer secchasum Suzar made 15 Good Remove 2
15 France Section 15 France 15 F	2000 Potivisia presorbaccacia Black locust 11 Fair Permove 1 2003 Acer robrano Red magile 22 Fair Exempt	2676 Phonos sercina Black charry 10 Fair Remove 1 2677 Umus americana American elm 9 Good Remove 1	4252 Junipros viginiane Existem red ceder 10 Good Remove 1 4253 Junipros viginiane Existem red ceder 10 Good Remove 1
919 Pobinia pseudoacacia Black locust 18 Fair Remove 2 920 Robinia pseudoacacia Black locust 9 Fair Remove 1	2004 Phasus sersina Black cherry 8,24 Fair Remove 4 2005 Anijornas viginiana Eastern red cedar 15 Good Remove 2	2678 Acer seccharum Suger mepte 16 Good Remove 2 2679 Robinia pseudoacacia Black looust 9 Fair Remove 1	4254 Juniperus vigoriana Esettem red cedar 13 Good Remove 2 4255 Pinus sylvestrio Scotts pine 8 Fair Remove 1
	2006 Procus serctina Black cherry 9 Poor Remove 1 2007 Procus serctina Black cherry 11 Poor Remove 1	2000 Robinia pseudoscacia Black locust 10 Fair Remove 1 2681 Robinia pseudoscacia Black locust 15 Good Remove 2	Column C
923 Fotorisi pasuchacacia Black locust 17 Fair Remove 2 924 Fotorisi pasuchacacia Black locust 17 Fair Remove 2	2008 Profits pseudoscada Black locust 13,14 Pair Remove 4	2002 Robinia pasudoscacia Black looust 14 Fair Remove 2 2003 Prunus serona Black chemy 15 Fair Remove 2	4200 Pinus sylvectris Scotts pine 9 Very Poor Exempt 4200 Jumperus wigniane Eastern red ceder 10 Good Remove 1
905 Pictorina posedocacacia Black locust 13 Fair Remove 2 907 Riccinia posedocacacia Black locust 15 Fair Remove 2	2311 Robinia posubaccacia Black locust 9 Fair Remove 1	2004 Hotoma posucocacia Black soust 11 Feir Hormove 1 2005 Pobinia posucocacia Black locust 11,12 Feir Berrove 3	4200 Prince synderins scoop pine 14 Good Hemove 2 4201 Proces sentition Black cherry 7 Fair Exempt
207 Richard procincious color Richard Indicated 15 Fair Richard Indicated 2 Richard Indicated 2 Richard Indicated Richard Indicated 2 Richard Indicated Richard Indicated 15 Fair Richard Indicated 2 Richard Indicated Richard Indicated 15 Fair Richard Indicated 2 Richard Indicated Richard Indica	2313 Robins pseudococia Black losust 16 Fair Remove 2 2316 Robins pseudococia Black losust 11 Fair Remove 1	2007 Robins pseudoscapile Black locust 10 Febr Remove 1 2008 Printer assertance Reset Remove 1	4203 Juniperus Wighlans Eastern red cedar 12 Good Remove 2 4294 Physic reference 12 Good Remove 2
930 Robinia poeudoacecie Black locust 14 Fair Remove 2 931 Acertubrato Red maple 11 Fair Remove 1	2315 Acer saccharinum Silver maple 36 Fair Remove 4 2316 Pobinia pseudoscacia Black locust 26 Fair Remove 3	2009 Robins psychocock Black locust 10 Feb Remove 1 2000 Robins psychocock Black locust 10 Feb Remove 1	4265 Pinus sylvestrio Scoto pine 10 Good Remove 1 4266 Pinus sylvestrio Scoto pine 9 Fair Remove 1
802 Phanus serotina Black cherry 8 Fair Remove 1 903 Phanus serotina Black cherry 11 Fair Remove 1	2317 Ulmus americana American elm 9 Feir Romow 1 2318 Aper-saccharinum Silver maple 10,12 Feir Romow 3	2891 Robinia posudoacacia Black locust 10 Fair Remove 1 2892 Robinia posudoacacia Black locust 14 Fair Remove 2	4267 Pinus sylvestris Soots pine 9 Fair Remove 1 4260 Pinus sylvestris Soots pine 9 Fair Remove 1
934 Robinia pseudosciacia Black locusi 17 Fair Remove 2 935 Robinia pseudoscala Black locust 19 Fair Remove 2	2319 Phonos serctina Black cherry 19 Poor Remove 2 2320 Juglans rigna Black walnut 25 Fair Remove 3	2693 Ulmus pumila Siberian elm 10 Fair Remove 1 2694 Populus delfoides Eastern cottonwood 13 Good Remove 2	4269 Pinus sylvestria Scots pine 13 Good Remove 2 4270 Plunus serctina Black otherry 11 Fair Remove 1
936 Pobinia pasudoacacia Black locust 14 Fair Remove 2 937 Robinia pasudoacacia Black locust 14 Fair Remove 2	2321 Ulmus americana American elm 11 Poor Remove 1 2322 Prunus sercrina Black charry 21 Fair Remove 3	2005 Populus delitrides Eastern cottonwood 9 Feir Remove 1 2006 Populus delitrides Eastern cottonwood 9 Feir Remove 1	4271 Arriperus virginiana Esetem red cedar 13 Good Remove 2 4272 Pinus sylvestris Scots pine 11 Good Remove 1
930 Pochrisi posuchacacia Black locust 12 Fair Remove 2	2224 Phono section Black therry 11 Very Hoor Exempt 2224 Phono section Black therry 8 Fair Parmow 1	2007 Populari delfoides Elestem cottonwood 9 Feir Remove 1 2008 Ulmus americana American etm 8 Feir Remove 1	4273 Urtus attendans American elim 11 Good Remove 1 4274 Prunus serctina Black cherry 10 Fair Remove 1
200 Pickers preschoolscale Black hourt 12 Fair Perrore 2	2205 Jugaine nigra Black walnut 9 Good Remove 1	2000 Ulraza amandania Amandani dhi 8 Fair Morriova 1 2700 Robinia pasudoadacia Black locusti 13 Fair Berrova 2	4275 Priss sylvestris Scots pine 14 Good Remove 2 4276 Priss sylvestris Scots pine 14 Good Remove 2
943 Policinia presochancenia Black locust 13 Fair Pernove 2 944 Policinia presochancenia Black locust 12 Fair Pernove 2	2328 Popula delicides Eastern outconwood 9 Fair Remove 1 2329 Popular delicides Eastern outconwood 11 Eastern Parrows 1	2017 Planta certifica Black cherry 5,7 Pair Remove 1	4270 Phose sylventris Scotts pine 9 State Persone 1 4270 Phose sylventris Scotts pine 10 Fair Remove 1
45.1 Rubriss periodicinazion Black Josept 1.5 Fair Parricon 2	2330 Ulrus americana American elm 10 Fair Remove 1 2331 Plusus securitos Black cherry 14 Fair Remove 2	2879 Piccus professor Black cherry 8.9 Febr Remove 3	4281 Juniperus wightiens Eastern red ceder 10 Fair Remove 1 4292 Program servicina Blank charge 12 Fair Remove 2
948 Acer obnaro Red maple 20 Fair Remove 2 949 Acer negando Boselder 20 Fair Remove 2	2332 Ulmus americana American elm 9 Fair Remove 1 2333 Ulmus americana American elm 9 Fair Remove 1	2881 Pinus sylvestris Soets pine 11 Fair Remove 1 2862 Physic peoples Illiack cherry 9 Fair Remove 1	4283 Plunus serctina Black sherry 8 Fair Remove 1 4284 Plnus selestrins Scotts sine 11 Good Remove 1
160 Autor Ampropriate Autor Service Au	2004 Policia pseudoscuola Black locust 9 Pair Pernove 1 2005 Jugliaro rigna Black walnut 10 Fair Remove 1	2883 Ampenos viginiano Eistem red cedar 12 Good Remove 2 2894 Phos sylvestris Soots pine 10 Good Exempt	4295 Juniperos virginiane Esistem red cedar 10 Good Remove 1 4296 Pinus silvestris Scotts pline 9 Fair Remove 1
952 Robinia pasudoacacia Black locust 14 Fair Remove 2 953 Pranus serotina Black cherry 8 Fair Remove 1	2336 Frankrus emericana White ash 10 Fair Remove 1 2337 Azur regundo Boselder 8 Fair Remove 1	2001 Ulmus americana American elm 12,12 Feir Remove 3 2002 Frannos pennsylvanica Green ash 10 Feir Remove 1	4287 Pinus sylvestris Scots pine 14 Good Remove 2 4289 Prozus serctina Black sheny 10 Fair Remove 1
954 Phonus secolina Black cherry 11 Fair Remove 1 955 Ulmus americana American etm 16 Fair Remove 2	2338 Robinia pseudoaceania Black locust 11 Fair Remove 1 2339 Robinia pseudoaceania Black locust 12 Fair Remove 2	2000 Acertabrato Red maple 22 Fair Remove 3 2004 Acertabrato Red maple 19 Fair Remove 2	4209 Pinus sylvestris Scots pine 8 Fair Remove 1 4290 Pinus sylvestris Scots pine 12 Good Remove 2
160 Protes entrollo Black cherry 12 Fair Brenoe 2	2340 Robinia pseudoanacia Black locust 10 Fair Romove 1 2341 Azer sacchantson Silver maple 9 Fair Romove 1	2885 Ulmus americana American elm 8 Fair Remove 1 2896 Ulmus americana American elm 8 Poor Remove 1	4291 Juniperus Wighlans Eastern red cedar 9 Good Remove 1 4202 Acer ascchasum Sugar maple 8 Good Remove 1
986 Hooma possocococo Black Noust 19 Feir Hormore 2 950 Phus sylventris Scots pine 12 Feir Remove 2	2342 Uhrusi amendansi Amendan elm 9 Peir Remove 1 2343 Robinia posudoacada Black losust 19 Fair Remove 2	2897 Pinus sylvestris Soets pine 9 Fair Remove 1 2009 Pinus sylvestris Soets pine 11 Fair Remove 1	4293 Juniperus Wiginiana Eastern red cedar 10 Good Remove 1 4294 Acernatriatro Ped maple 16 Pair Remove 2
962 Anthropyriso Bastern red cedar 9 Fair Remove 1	2346 Urrus americana American elim 17 Good Romove 2	2000 Phus sylvestris Soots pine 9 Feir Normove 1 2000 Phus sylvestris Soots pine 14 Feir Remove 2	426 Urrus americano American em 9 Fair Hemove 1 4296 Urrus americano American elm 8 Good Remove 1
984 Robinia possidiocasila Black locust 13 Fair Remove 2 987 Ultrur amprisona American altra 10 Enir Remove 1	2947 Polynia prosochonacia Ellack locust 13 Fair Pormore 2 2949 Polynia prosochonacia Ellack locust 15 Fair Pormore 1	2802 Robins pseudoacacia Black losust 9 Fair Remove 1	420 Prius sylvestris Scots pine 11 Fair Remove 1
966 Sassafras athibure Sassafras 9 Fair Remove 1 967 Robins assafrascolis Black locust 13 Fair Remove 2	2349 Ulmus americana American elm 8 Fair Remove 1 2350 Strinia assorbanación Risch Invast 50 Paur Remove 1	2504 Polyinia posocionacinia Black locust 9 Feir Save	4300 Phonos secretina Black otherty 8 Fair Remove 1
968 Potivital pseudobacacia Black locust 16 Fair Remove 2 969 Prunus percritos Black cherry 10 Fair Remove 1	2351 Richinia posudoscacia Black locust 8 Fair Remove 1 2352 Richinia pasudoscacia Black locust 10 Fair Remove 1	2008 Ulmus americana American elm 11 Feir Romove 1 2007 Ulmus americana American elm 12 Feir Romove 2	4302 Frazinas americana White ash 11 Poor Remove 1 4303 Prius sylvestris Soots sine 8 Fair Remove 1
202 Decision arrows 1	2050 Robinia posudoacacia Black locust 10 Fair Remove 1 2054 Phos sylvestris Scots pine 10 Fair Remove 1	2008 Ulmus americane American elm 10 Fair Remove 1 2009 Ulmus americane American elm 9 Fair Remove 1	4304 Pinux sylvestris Scots pine 9 Pair Remove 1 4305 Pinus sylvestris Scots pine 13 Good Remove 2
972 Robinia pseudoscacia Black locust 11 Fair Remove 1 973 Robinia pseudoscacia Black locust 9 Fair Remove 1	2355 Robinia pseudoanacia Black locust 9 Fair Remove 1 2355 Ulmus americana American elm 10 Fair Remove 1	2910 Robinia pseudoacacia Black locust 10 Fair Save 2911 Ulmus americana American elm 8 Fair Save	4306 Pinus sylvestris Scots pine 13 Fair Remove 2 4307 Acer subrure Red maple 9,10 Fair Remove 3
10	2357 Ulmus americana American elm 10 Poor Remove 1 2358 Robinia pseudoacacia Black losust 7,10 Fair Remove 1	2012 Ultrus americana American elm 8 Feir Save 2013 Robins pseudoscacia Black locust 13 Feir Save	4308 Pinus sylvestris Scots pine 8 Fair Remove 1 4309 Pinus sylvestris Scots pine 11 fair Remove 1
976 Pranus sercina Black cherry 11 Fair Remove 1 977 Pinus sylveschis Goots pline 13 Fair Remove 2	2359 Robinsa pseudoacacia Black locust 6,9 Fair Remove 1 2390 Robinsa pseudoacacia Black locust 9 Fair Remove 1	2914 Ulmus americana American elm 8 Feir Save 2915 Pinus sylvestris Gods pine 8 Feir Save	4310 Pinus sylvestris Scots pine 9 Fair Remove 1 4311 Pinus sylvestris Scots pine 11 Fair Remove 1
978 Acer accoharum Sugar mopte 8 Fair Remove 1 979 Prunus serofina Black cherry 13 Fair Remove 2	2001 Robinia pseudoscacia Black losust II,8 Fair Remove 2 2002 Robinia pseudoscacia Black locust 12 Fair Remove 2	2016 Pinus sylvestris Scots pine 8 Fair Save 2017 Pinus sylvestris Scots pine 8 Fair Save	4512 Pinus sylvestris Scots pine 12 Fair Remove 2 4313 Pinus sylvestris Scots pine 11 Fair Remove 1
981 Phanus sercina Black cherry 8,10,11 Fair Remove 4	2863 Hooma proviocacioni Balan Nobel 13 Fair Hermore 2 2364 Urrus americana American elim 14 Fair Remove 2	2018 Phosis sylvestris Scots pine 10 Peir Sawe 2019 Pinus sylvestris Scots pine 9 Fair Sawe	4314 Junpenus wigmans Etailorn red ceder 11 Peir Memove 1 4315 Pinus sylvectris Scots pine 14 Fair Remove 2
1861 Passas sectival Black charry 8.10,11 Fair Romone 4	2365 Petronia posociocacacia Black locust 10 Fair Remove 1	2021 Prince syretems Scott pine 10 Fair Save	4310 Final systems access pine 10 Fair Remove 1 4317 Acer regundo Boxelder 10 Poor Remove 1
985 Phon sylventris Scots pine 25 Good Remove 3	2368 Robinia pseudoacacia Black losust 9 Fair Remove 1 2799 Robinia pseudoacacia Black losust 8 Fair Remove 1	2923 Prinzi sylventria Scota pine 8 Feir Sene 2924 (Brinzi sylventria Scota pine 8 Feir Sene	4319 Quercus velocitios Black cela 11 Fair Remove 1 4300 Dissa refusción Quercus ellas 12 Dair Banque 2
967 Phus sylvectris Society pine 12 Fair Remove 2 968 Aper sportnam Super mode 23 Fair Save	2370 Potrinia presobazacia: Black locust 7,12 Fair Remove 2 2371 April supplementation Silver mode 8 Fair Remove 1	2825 Ukrus americane American elm 11 Feir Save 2909 Pinns sulentris South nine 8 Feir Save	4321 Pinus sylventris Scots pine 16 Fair Remove 2 4322 Pousse secretina Blank interes 10 Fair Remove 1
See Make surviva German again 7 Pale Same See Privacy Sprinders Goods Sprinders Sprinders Sprinders Sprinders Goods Sprinders	2372 Potrina pseudoscacia Black locust 12 Fair Parriow 2 2373 Potrina pseudoscacia Black locust 10 Fair Perriow 1	2027 Pinus sylvestris Scots pine 8 Feir Save 2021 Pinus sylvestris Scots pine 7 Feir Save	4323 Secontre ablicion Sessattes 8 Fair Remove 1 4324 Pransa septina Black cherry 9 Fair Remove 1
200 Papico activates Same and microword 15 Fe	2374 Robinia pseudoscacia Black locust 10 Fair Remove 1 2375 Robinia pseudoscacia Black locust 12 Fair Remove 2	2929 Ulmus americano American elm 10 Feir Sove 2920 Ulmus americano American elm 13 Feir Sovo	4325 Pinus sylvestris Soots pine 10 Fair Remove 1 4326 Jungseus virginians Eleptern red cedar 10 Fair Remove 1
965 Pinus sylvestris Scots pine 14 Fair Remove 2 994 Juniperus virginiano Eastern red cedar 13 Good Save	2376 Robinio pseudoaceole Black locust 11 Fair Remove 1 2377 Robinio pseudoaceole Black locust 12 Fair Remove 2	2931 Ulmus americana American elm 9 Feir Save 2932 Ulmus americana American elm 9 Feir Save	4327 Juniperus virginiana Eastern red cedar 9 Fair Remove 1 4328 Juniperus virginiana Eastern red cedar 10 Fair Remove 1
986 Phosus sercitiva Black cherry 11 Fair Remove 1 986 Phos sylvestris Souls pine 10,11 Fair Remove 3	2378 Acer regundo Boselder 16 Fair Save 2379 Acer regundo Boselder 12,16 Fair Save	2003 Photos section Black cherry 8 Feir Save 2004 Photos sections Black cherry 9 Feir Save	4339 Juniperus viginiana Esestem red ceder 10 Fair Remove 1 4300 Pinus sylvestris Scots pine 8,14 Fair Remove 3
900 Procus arceros suack cherry 12 Par Formove 2 996 Ulrous americana American elm 9 Fair Remove 1	2381 Malais jurniti Common apple 9,8.8 Very Poor Save 2382 Acer regundo Boxelder 7,9.9 Fair Save	2009 Procue sercicus Black chemy 12 Fair Saws 2008 Acer rotrure Red maple 13 Fair Save	4331 Acervatrate Ped maple 25 Fair Remove 3 4332 Acervatrate Ped maple 10 Fair Remove 1
1000 Ultrus americana Americana den 11 Fair Ramore 1 1923 Pinus sujentius Souts sine 8 Fair Romore 1	2003 Activityphoto Boselder 15 Febr Same 2004 Activityphoto Boselder 8 Febr Same 2007 Activityphoto Boselder 6.0 Earl Bernom 1	2007 Umus amendana Amendan em 15 Feir Romove 2 2008 Acer regundo Boselder 9 Feir Save	4333 Jangaros viginario Esperimies cesar 10 Fair Remove 1 4334 Pinza sylvanistis Scotta pine 14 Fair Remove 2 4305 Discus sylvanistis Scotta pine 11 Fair Remove 1
1924 Phast sylvestrist Scots pine 8 Fair Remove 1 1925 Amiranos viceiriano Esatem red cedar 10 Fair Remove 1	2388 Make purelle Common apple 5,8 Very Poor Excempt 2997 Tills amendman Bassaccot 51 Enir Persons 1	2000 Acer regundo Docelder 9,12 Fair Saws 2001 Maio cumido Oceanos anale 7,16 Sair	4506 Prints sylvestris Scots pine 12 Fair Remove 2 4506 Prints sylvestris Scots pine 12 Fair Remove 2
1924 Privat sylvation Scale prec A Fair Permone 1 1925 Apropose organistic Easierine et coder 10 Fair Permone 1 1927 Private sentrius Salek Arleny 1 Fair Permone 1 1927 Private sentrius Salek Arleny 1 Fair Permone 1 1928 Apropose organistic Easierine coder 13 Fair Permone 2 1929 Apronatorius Permone 1 Fair Permone 2 1920 Apronatorius Permone 1 Fair Permone 2 1920 Permone codathical Commandatation 8 Fair Permone 2 1921 Permone codathical Commandatation 8 Fair Permone 2 1922 Permone 1 Permone 1 Permone 1 1923 Permone codathical Permone 1 Permone 1 1924 Permone 1 Permone 1 Permone 1 1925 Permone 1 Permone 1 Permone 1 1924 Permone 1 Permone 1 Permone 1 1924 Permone 1 Permone 1 Permone 1 Permone 1 1924 Permone 1 Permone 1 Permone 1 Permone 1 1924 Permone 1	2388 Acur regundo Boselder 8 Fair Remove 1 2389 don regundo Boselder 10 Fair Save	2942 Ulrus americana American elm 9 Good Save 2943 Parano servicios Blank chemo 9 Good Barrone 1	4330 Pinus sylventris Scots pine 12 Fair Remove 2 4330 Unran amarinana American after 8 Fair Remove 1
1928 Junipenus viginiano Eastern red cedar 13 Fair Remove 2 1929 Acertubrato Red maple 10 Fair Remove 1	2001 Populus delicades Eastern cottonwood 13 Fair Romow 2 2002 Ultrus americana American shn 10 Fair Romow 1	2944 Ulmus americana American elm 16 Good Remove 2 2945 Phonus promina Illiack cherry 14 Good Remove 2	4340 Planus sercina Black sherry 10 Fair Remove 1 4341 Ann secchanium Sher made 14 Good Remove 2
1900 Rhammus cathartico Common buelathorn 8 Fair Exempt 1901 Juniperus virginiano Eastern red cedar 10 Fair Remove 1	2003 Ulmus americana American elm 9 Fair Remove 1 2004 Ulmus americana American elm 8 Fair Remove 1	2946 Acer solvure Red maple 28 Fair Save 2947 Pharmus catherice Common buckthorn 8 Fair Save	4342 Pinus sylvestris Scots pine 14 Good Remove 2 4343 Pinus sylvestris Scots pine 6,7 Fair Exempt
1932 Acer outrore Red maple 12,25 Fair Remove 5 1933 Populos dell'oxides Eastern cottonwood 10 Fair Remove 1	2605 Populus delfoides Eastern osttonweed 9 Fair Save 2605 Populus delfoides Eastern osttonweed 9 Fair Save	2948 - Jugians nigra Black walnut 7 Good Exempt 2949 Prunus serotina Black chemy 9 Very Poor Exempt	4344 Acer sacruer Red maple 13 Fair Remove 2 4345 Acer sacchanium Silver maple 7,10,11 Fair Remove 3
100 Private privates Private private Private Private private Private private Private private Private Private private Private private Private private Private Private private Private private Private private Private Private private Private private Private private Private Private private Private private Private private Private Private private Private private Private private Private Private private Private private Private private Private Private private Private Private private Private private Private private Private private Private private Pri	2607 Populos delfoides Eastern cottonweed 11 Fair Save 2008 Populos delfoides Eastern cottonweed 14 Fair Save	2800 Juniperos virginiano Eastern red cedar 8 Fair Remove 1 2861 Frankos pomoyivanica Green ash 9 Paar Remove 1	4546 Popular deltoides Eleaters cottonwood 13 Fair Remove 2 4547 Acer saccharinom Silver maple 9 Fair Remove 1
1907 Acur sabuse Red maple 8 Fair Remove 1	2009 Popular defrades Eastern cottonwood 9 Peir Save 2010 Popular defrades Eastern cottonwood 11 Fair Save	2852 Plucus seccine Black cherry 8 Fair Remove 1 2953 Acur saccharoser Silver maple 11 Fair Remove 1	4340 Acer seccharum Sugar maple 16 Good Remove 2 4340 Amperia wigmane Eastern red ceder 11 Good Remove 1
1977 Alex Auders American 1	2011 Populus dell'oxides Eastern cottonwood 12 Fair Sawe 2012 Populus dell'oxides Eastern cottonwood 20 Fair Sawe	2954 Ulrica americana American elm 8 Fair Remove 1 2955 Ulrica americana American elm 10 Good Remove 1	4300 Acer seccharum Sugar maple 7,22 Good Remove 3 4351 Acer seccharum Sugar maple 12 Good Remove 2
1941 Possus sercitina Black cherry 9 Fair Bernove 1 1942 Urrusi americana American elm 8 Fair Remove 1	2014 Popular delitrioles Eastern coltrovand 9 Fair Save	2807 Umus americane American elm 9 Good Remove 1	4303 Juganin Agra Bases warus 6 Good Remove 1 4303 Aler seccharum Sugar maple 19 Good Remove 2
1943 Phonus recritice Black cherry 10 Feir Remove 1 1944 Phonus recritice Black cherry 10 Feir Remove 1	2010 Popular delicates Eastern continuence 13 Fair Sawe 2017 Popular delicates Eastern continuence 13 Fair Sawe 2017 Popular delicates 2 Basel Sawe	2869 Pranus seccins Black cherry 8 Fair Remove 1 2869 Pranus seccins Black cherry 8 Fair Remove 1 2860 Age resolutions Silve models 8 Fair Remove 1	4355 United americans American dem 5 Pair Exempt 4355 United americans American dem 5,8 Pair Exempt 4358 United american Black welfort 21 Good Barrows 3
1945 Applies rigra Black select 5 Fair Remove 1 1946 Ambreus statistics Bastern red cedar 5 Fair Remove 1	2018 Umus americana American elm 12 Fair Save	2961 Acer sacchardore Silver maple 13 Fair Remove 2 2962 Ultrur amaricana Americana de 14 Esir Berrous 2	4357 Jugitars rigina Black walnut 14 Good Remove 2
1947 Ulmus americane American elm 12 Fair Romove 2 1948 Junipenya viginione Eastern red cedar 11 Fair Remove 1	2620 Umus americane American elm 10 Fair Save 2621 Posulus delinides Eastern coltonwood 10 Fair Save	2983 Acer seccharison Silver maple 8,9 Good Remove 3 2984 Ultrara amaricana Americana dan 8 Feir Remove 1	4559 Acer saccharinori Silver maple 8,11 Fair Remove 3 4360 Junios nico Black valous 9 Good Remove 1
1949 Ampense viginiane Eastern red ceder 10 Fair Remove 1 1950 Ampense viginiane Eastern red ceder 8 Fair Remove 1	2622 Populas deltroides Eastern cottonwood 13 Fair Save 2623 Populas deltroides Eastern cottonwood 11 Fair Save	2005 Acur succhansur Silver maple 14,14 Good Remove 4 2006 Robinia posudoacania Black koust 10 Fair Remove 1	4381 Jugians nigns Black wates 12 Good Remove 2 4362 Jugians nigns Black wates 9 Good Remove 1
1942 Unit a ministrate	2624 Populus deltoides Eastern cottonwood 11 Good Saws 2625 Populus deltoides Eastern cottonwood 10 Good Remove 1	2967 Procus sercina Black cherry 8 Fair Remove 1 2968 Ulmus americane American elm 8 Fair Remove 1	4363 Juljann njora Black wehut 22 Good Remove 3 4384 Uhrusa americana American elm 12 Fair Remove 2
1953 Acer subruro Red maple 10 Fair Remove 1 1954 Ulmus americana American elm 9 Fair Remove 1	2029 Juniperus viginiane Eastern red cedar 8 Fair Remove 1 2630 Acur subruco Red maple 8 Fair Remove 1	2869 Planus serotina Black cherry 10 Fair Remove 1 2970 Robinia pseudoscacia Black locust 14 Fair Remove 2	4365 Jugiore nigro Black walnut 16 Good Remove 2 4388 Urrous americana American alm 8 Poor Remove 1
1956 Chruz armiscana Armiscan de 9 Pair Parrona 1950 Applica (1970 197	1000	The second column	
1967 Pinca sprindris Soots pine 12 Poor Remove 2 1960 Pincus sercitins Black cherry 8 Fair Remove 1 1960 Pincus sercitins Black cherry 9,10 Fair Remove 3	2033 Ampenia viginiana Bastern red cedar 7 Fair Exempt 2034 Ampenia viginiana Bastern red cedar 8 Good Remove 1	29/3 Intracerus catharica Common buckflorer 11 Fair Exempt 29/4 Urcus americana American elm 9 Fair Bernove 1	4389 Horous serctina Black charry 8 Fair Remove 1 4370 Pinus sylvectris Scotts plane 21 Good Remove 3
1960 Prince offential Description 8 Fair Remove 1 1961 Prince offential Society place 8 Fair Remove 1 1961 Diver industrial Society place 11 East Remove	2000 France systematics Scotts prine 13 Fear Ramove 2 2008 Acertativity Red maple 5,8 Fear Ramove 1	2010 Limite americane American etm 9 Good Remove 1 2016 Pussus secons Black cherry 23 Fair Remove 3	4-371 Lecture accenticates American elen 13 Pair Remove 2 4372 Jeropeura virginianus Eiselem red ceder 8 Good Remove 1
1920 Pursus sentirols Billion 1920 Paris Pursus 3	2031 Acer regundo Boselder 9 Very Poor Exempt 2039 Pourus sercina Black cherry 9 Fair Remove 1	2017 Finus systems Scots pine 11 Fair Remove 2018 Phus systems Scots pine 3 Fair Remove 1	441 Outstanderschein Americanis der 3 Good Parrows 1 442 August 2014 Steine 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
1963 Prisous eventors seator cerery o Pair Hormove 1 1964 Prisou aylvestria Scots pine 11 Fair Remove 1 1965 Populos delicolesis Eastern cottonwood 16,17 Fair Remove 5	2039 Aceruscoharum Sugar mople 16 Fair Permove 2 2840 Jugales nigna Black wahrut 14 Fair Permove 2 2841 Judges nigra Black wahrut 10 Fair Permove 1	2000 Acer-obstero Red maple 13 Fair Remove 2 2000 Acer-obstero Red maple 13 Fair Remove 2 2001 Dougla personal Dilak change 6.8 Each Remove 1	4-370 Finus sylvestris Scots pine 8 Fair Memove 1 4376 Finus sylvestris Scots pine 8 Good Remove 1 4377 Finus sylvestris Scots pine 1 Good Remove 1
1968 Ultrus americane American elm 11 Feir Borrove 1 1967 Ultrus americane American elm 11 Feir Borrove 1	2842 Agricon rignia Black restruct 19 Cond Remove 1 2942 Agricon rignia Estate red cedar 10 Cond Remove 1	2002 Arriponto deginano Essisten red cedar 10,11 Feir Remove 3 2003 Arriponto deginano Essisten red cedar 10,11 Feir Remove 3 2003 Poutos certifica Plate chemy 54 15 Feir Remove 4	4378 Prints sylventris Scots pine 11 Fair Remove 1 4379 Prints sylventris Scots pine 17 Fair Remove 1
1969 Amberos viginiane Eastern red cedar 10,12 Fair Remove 3 1969 Prunus sercina Black charry 11 Fair Remove 1	2644 Aughen nigra Black welnut 10 Fair Remove 1 2645 Aughen nigra Black welnut 13 Fair Remove 2	2864 Amiperon viginiane Eastern red cedar 9 Feir Remove 1 2865 Amisena viginiane Eastern red cedar 10 Feir Remove 1	4360 Pinus sylveotris Scots pine 10 Pair Remove 1 4361 Pinus sylveotris Scots pine 9 Pair Remove 1
1970 Acer subsure Red maple 32 Fair Remove 4 1971 Acer succharitorn Silver maple 19 Good Parsove 2	Applied Propried Applied Applied Propried A	2996 Guercus miscrosopia Barcok 9 Fair Remove 1 2007 Physica sercifus Black cherry 12 Fair Remove 2	Coop February Coop Feb
	2848 Jugitare nigro Black walnut 10 Fair Remove 1 2649 Uhrus americana American elm 0 Fair Remove 1	2009 Acer cepundo Baselder 9 Fair Remove 1	4384 Acerushrum Red maple 13 Fair Remove 2 4385 Pinus sylvestris Scotts place 15 Fair Remove 2
1974 Juniperus virginiano Eastern red oedar 7 Fair Exempt 1975 Pinus sylvestris Soots pine 9 Fair Remove 1	2650 Juglans rigna Black walnut 11 Good Romove 1 2651 Juglans rigna Black walnut 10 Fair Remove 1	2000 Junipensa virgimiane Eastern red cedar 14 Fair Remove 2 2991 Jugitans nigra Black walnut 11 Fair Remove 1	4388 Acervahrum Red maple 11,12 Fair Remove 3 4387 Acervahrum Red maple 9 Fair Remove 1
March Marc	Column C	Section Commonweal	
rerv ====== opvelsors Godes pare to ear Remove 1	доон индиали лідги — Black welnut — 6 — Fair — Remove — 1	2009 History resolves Goale pline 11 Fair Remove 1	4-seu i-mas sysveotris Goots pline 13 Pair Remove 2





Sea



Title

Tree List

Project:

The Grove Novi, Michigan

Prepared for:

Ivanhoe Companies 6689 Orchard Lake Road, Suite 314 West Bloomfield, Michigan 48322 248.626.6114

Revision:	Issued:
Review	March 28, 2024
Revised	July 26, 2024
PRO Submission	July 9, 2025
Revised PRO Submission	September 12, 2025

Job Number:

21-054

Drawn By: Checked By:



Sheet No.

L-17

© 2025 Allen Design L.L.C.

		Required Multi-Stem	Required Multi-Stem	Required Multi-Stem	Required Multi-Germ
Tag Scientific Name Common 4391 Phas sylvestris Scots pine	on Name Dia. Condition w 13 Good	Status Replacement Replacement Credits Remove 2	Tag Scientific Name Common Name Dis Condition Status Replacement Replacement Credits 4002 Place ables Noncey space 12 Fair Remove 2	Tag Scientific Name Common Name Dia. Condition Status Replacement Replacement Credits 4711 Propos services Black (New 8 Cred Cents	Tag Scientific Name Common Name Dia. Condition Status Replacement Replacement Credits ### Condition of the Condition Status Replacement Replacement Credits
Type Characteristics Control of C	erry 8 Fair ne 9 Good	Remove 1	Column	2012 Agents reput Black sealed 1 0.00d Coeff 2	4871 Junipena vigniana Eastern red cedar 9 Good Remove 1
4394 Ultrus americana American e 4395 Aper serribasan Supar meni	relm 9 Good	Remove 1	Good Price Price	Column	4873 Process percentage Black charry 7,9 Fair Remove 1
4356 Pinus sylvestris Scots pine	w 17 Good	Rimove 2	4557 Pinus sylvestris Scota pine 19 Fair Remove 2	4716 Pinus sylvestris Gods pine 9 Pair Credit 2	4875 Pinus sylvestris Scota pine 13 Good Remove 2
4397 Untus amendana Amendan e 4398 Aper saccharitum Silver maple	1690 12 G000 ple 9 Fair	Remove 1	4009 Prisos restricios Hed prife 13 Fair Remove 2 4009 Prisos sylvestris Goots prine 12 Fair Remove 2	4717 Pisus sylvestris Sooti pine 8 Fair Exempt 4718 Jugitne rigra Black walnut 7,8,8 Good Exempt	4876 Pinus sylvestris Scotts pine 8 Fair Remove 1 4877 Pinus sylvestris Scotts pine 8 Fair Remove 1
4000 Pinus sylvestris Scots pine	pre 9 Good ne 18 Good	Remove 1	4060 Phose abies Norway sprace 14 Fair Remove 2 4061 Pinus sylvestris Scots pine 17 Fair Remove 2	4719 Pisus sylvestris Soots pine 8 Good Exempt 4720 Acer regundo Boxelder 10 Good Exempt	4678 Pinus sylvestris Scotts pine 8 Fair Remove 1 4079 Pinus sylvestris Scotts pine 11 Good Remove 1
4401 Robinia pseudoacacia Black locus 4402 Robinia pseudoacacia Black locus	rust 8 Good rust 8 Good	Save Save	4562 Pinas sylvestris Scota pine 12 Fair Remove 2 4563 Pinas resitosa Red pine 14 Fair Remove 2	4721 Juglane nigra Black walnut 9,9 Good Exempt 4722 Pinus sylvashris Scotia pine 7 Good Exempt	4890 Juniperos virginians Eastern red cedar 13 Good Remove 2 4891 Juniperos virginians Eastern red cedar 9 Fair Remove 1
4403 Robinia pseudoacacia Black locus 4404 Prunus serotina Black chem	sust 9 Fair erry 10 Fair	Save Save	4564 Pinus sylvestris Scote pine 11 Fair Remove 1 4565 Pinus sylvestris Scote pine 15 Fair Remove 2	4723 Pinus sylvestris Soots pine 9 Pair Exempt 4724 Pinus sylvestris Soots pine 11 Fair Exempt	4882 Pinus sylvestris Scota pine 9 Good Remove 1 4883 Pinus sylvestris Scota pine 9 Good Remove 1
4405 Pinus sylvestris Scots pine 4406 Pinus sylvestris Scots pine	w 9 Good ne 8 Fair	Save Save	4565 Pinus sylvestris Scots pine 10 Fair Remove 1 4567 Pinus sylvestris Scots pine 9 Fair Remove 1	4725 Prisos sylvestris Scots pine 8 Fair Exempt 4726 Prisos sylvestris Scots pine 10 Fair Exempt	4894 Pinus sylvestris Scots pine 7 Fair Exempt 4995 Pinus sylvestris Scots pine 12 Cond. Remove 2
4407 Pinus sylvestris Scots pine 4408 Juniperus virginiane Eastern red	ne 7 Fair red cedar 8 Fair	Save Save	4500 Pinus sylvestris Soots pine 13 Fair Remove 2 4900 Aprillutur Red maple 17 Fair Remove 2	4727 Prisos sylvestris Scots pine 8 Fair Exempt 4729 Prisos sylvestris Scots pine 9 Fair Exempt	4806 Pinus sylvestris Scots pine 9 Poor Remove 1 4907 Anna sylvestris Rijer marke 10 10 11 Fair Remove 4
Acre accinent Superior Superio	rust 9 Good	Save	4570 Pinus strobus Eastern white pine 9 Fair Remove 1	4729 Pinus sylvestris Scots pine 9 Good Exempt	4668 Pinus sylvestris Soots pine 10 Fair Remove 1
4411 Pinus sylvestris Scots pine	e 9 Good	Save	4572 Pinus resinosa Red pine 12 Fair Remove 2	4731 Pinus sylvestris Soots pine 9 Good Exempt	4600 Prinus sylvestris Scots pine 13 Good Remove 2
4413 Pinus sylvestris Scots pine	w 7 Good	Sine	457.4 Pinus resinosa Red pine 9 Fair Remove 1	4732 Pinus sylvestris Scots prei 9 Good Exempt 4733 Pinus sylvestris Scots pine 8 Good Exempt	4891 Juniperus wiginiana Elastem red cedar 9 Good Remove 1 4892 Juniperus wiginiana Elastem red cedar 9 Good Remove 1
4415 Robins pseudoscacia Black locus	ust 8 Fair	Remove 1	4579 Aperiustrum Red maple 22 Fair Remove 3	4734 Pinus sylvestris Scots pine 9 Good Exempt 4735 Pinus sylvestris Scots pine 8 Fair Exempt	4860 Proces erotina Black cherry 8 Pair Remove 1 4894 Junipens Wightans Eastern red cedar 8 Good Remove 1
4415 Private preventional British Story 4417 Private privations South Story 4417 Stakes pursuits 4419 Private privations South Story 4419 Private privations South Stakes 4419 Private privations South Stakes 4410 Private defendable South Stakes 4421 Private defendable South Stakes 4421 Private defendable South Stakes 4422 Private defendable South Stakes 4424 Private defendable South Stakes 4425 Private defendable South Stakes 4426 Private defendable South Stakes 4427 Private defendable South Stakes 4428 Private defendable South Stakes 4429 Private defendable South Stakes 4429 Private defendable South Stakes 4429 Private defendable South Stakes 4420 Private defendable South Stakes 4421 Private defendable South Stakes 4422 Private defendable South Stakes 4423 Private defendable South Stakes 4424 Private South Stakes 4425 Private defendable South Stakes 4425 Private South Stakes 4425 Private South Stakes 4426 Private South Stakes 4426 Private South Stakes 4426 Private South Stakes 4427 Private South Stakes 4427 Private South Stakes 4427 Private South Stakes 4427 Private South Stakes 4428 Private South Stakes 4428 Private South Stakes 4428 Private South Stakes 4429 Private South Stakes 4429 Private Stakes 4420 Private South Stakes 4420 Private South Stakes 4421 Private Stakes 4421 Private Stakes 4422 Private Stakes 4423 Private Stakes 4424 Private Stakes 4424 Private Stakes 4424 Private Stakes 4425 Private Stakes 4426 Private Stakes 4426 Private Stakes 4426 Private Stakes 4426 Private Stakes 4427 Private Stakes 4427 Private Stakes 4428 Private Stakes 4428 Private Stakes 4428 Private Stakes 4428 Private Stakes 4429 Private Stakes 4429 Private Stakes 4429 Private Stakes 4420 Private S	ne 8 Good apple 7,8 Poor	Remove 1	45/7 Priss syriestris Scots pine 14 Fair Remove 2 45/78 Priss syriestris Scots pine 11 Fair Remove 1	4736 Jugitine signe Black walnut 12 Very Poor Exempt 4737 Pinus sylvastris Soots pine 9 Good Exempt	4865 Pinus sylvestris Scotts pine 13 Good Save 4856 Utraus americana American elim 9 Pair Save
4418 Pinus sylvestris Scots pine 4419 Juniperus virginiane Eastern red	ne 17 Good ned cedar 8 Good	Save Save	4579 Pinus strobus Eastern white pine 14 Fair Remove 2 4580 Pinus strobus Eastern white pine 12 Fair Remove 2	4739 Juglans njera Black walnut 11 Good Exempt 4739 Pinus sylwatris Soots pine 10 Good Exempt	4867 Ultrus americana American elm 8 Fair Save 4868 Acer sacchantum Silver maple 9 Good Save
4421 Populus deltoides Eastern oot 4402 Ulmus americana American e	oottonwood 31,35 Fair nelm 20 Fair	Remove 9 Save	4561 Pinus sylvestris Scots pine 8 Fair Remove 1 4562 Pinus sylvestris Scots pine 10 Fair Remove 1	4740 Pinus sylveshis Soots pine 10 Good Exempt 4741 Pinus sylveshis Soots pine 10 Pair Exempt	4899 Populus deltoides Eastern cottonecci 8 Fair Save 4900 Populus deltoides Eastern cottonecci 14 Fair Save
4423 Populus defroides Eastern cot 4424 Populus defroides Eastern cot	cottonwood 15 Fair	Exempt Exempt	4583 Pinus sylvestris Scots pine 18 Fair Remove 2 4594 Pinus shine Norway source 9 Fair Remove 1	4742 Pinus sylvestris Soots pine 8 Fair Exempt 4743 Pinus sylvestris Scots pine 9 Fair Exempt	4501 Popular delicates Eastern cottonwood 18 Good Save 4507 Popular delicates Eastern cottonwood 10 Dair Save
4425 Populus delfoides Eastern cot 4426 Populus delfoides Eastern cot	cottonwood 12 Fair	Exempt Exempt	4685 Phase sylventres Soote pine 19 Feir Remove 2 4696 Audison ninos Black wolnut 11 Good Remove 1	4744 Prisos sylventris Scots pine 8 Fair Exempt 4765 Prisos sylventris Scots pine 9 Fair Exempt	4503 Popular deltoides Einstern cottonwood 13 Good Sinve
4427 Populus deltoides Eastern cot	cottonwood 9 Fair	Exempt	4267 Acer secoharum Sugar maple 12 Good Remow 2	4746 Jugians rigns Black walnut 10,10 Good Exempt	4605 Salix arraystalothes Peachled villow 13 Good Saw
4430 Plose ables Norway spr	prace 13 Fair	Exempl Exempl	4569 Phus should Eastern white pine 15 Fair Remove 2	4748 Juphen nigra Black wahrut 9 Good Save	400 Actar sectmental Crief higher 11 0000 February 2 4607 Pinus sylvestris Scots pine 14 Good Remove 2
4432 Populus deltoides Eastern cot	ottonwood 8 Fair	Exempt	4591 Pinus sylvestris Scots pine 10 Fair Remove 1	4750 Ulmus americana American elm 14 Poor Remove 2	4909 Junipeos Wighlano Eastern red cedar 10 Good Remove 1
4434 Populus deltoides Eastern oot	ottorwood 10 Fair	Exempt	4032 Pinus strolus Eastern white pine 23 Fair Remove 3	4752 Aper regundo Boselder 10 Fair Remove 1 4752 Aper regundo Boselder 11 Fair Remove 1	4910 Pinus sylvestris Scota pine 11 Pair Remove 1 4911 Pinus sylvestris Scota pine 10 Good Remove 1
4435 Populus deltoides Eastern oot 4436 Populus deltoides Eastern oot	ottorwood 10 Fair ottorwood 14 Fair	Exempt Exempt	4594 Pinus sylvestris Scots pine 10 Pair Remove 1 4595 Picea ables Norway spruce 12 Fair Remove 2	4753 Pinus sylvestris Scots pine 12 Fair Remove 2 4754 Junipeus viginiane Eastern red cedar 9 Fair Remove 1	4912 Pinus sylvestris Scots pine 9 Good Remove 1 4913 Pinus sylvestris Scots pine 8 Good Remove 1
4437 Populus deltoides Eastern cot 4439 Quercus alba White oak	coltonwood 12 Fair k 12 Fair	Exempt Exempt	4595 Pinus sylvestris Scots pine 11 Fair Remove 1 4597 Pinus sylvestris Scots pine 9 Fair Remove 1	4795 Pinus sylvestris Scota pine 15 Fair Ramove 2 4796 Procus section Black charry 8 Fair Ramove 1	4914 Populus defoides Eastern cottonwood 21 Good Remove 3 4915 Populus defoides Eastern cottonwood 22 Good Remove 3
4439 Quercus alba White cak 4440 Populus deltoides Eastern oot	k 8,12 Fair oottonwood 12 Fair	Exempt Exempt	4598 Pinus resinosa Red pine 12 Fair Remove 2 4592 Pinus resinosa Red pine 11 Fair Remove 1	4757 Robinia pseudoscala Black locust 12 Pair Sawa 4709 Ulmus americana American elm 10 Fair Remove 1	4916 Populos delfoldes Eastern cottonwood 15 Fair Remove 2 4917 Phosos sentina Black charry 12 Fair Remove 2
4441 Populos deltoides Eastern cot 4442 Populos deltoides Eastern cot	oottonwood 15 Fair oottonwood 12 Fair	Exempt Exempt	4600 Pices ables Norway spruce 13 Fair Remove 2 4601 Pinus sylveshis Scots pine 10 Fair Remove 1	4739 Pinus sylvestris Scots pine 12 Pair Remove 2 4790 Junicenza vicinitate Eastern red cedar 9 Pair Remove 1	4919 Junipens wiginians Eastern red ceder 12 Good Remove 2 4919 Junipens wiginians Eastern red ceder 10 Good Remove 1
4443 Populus delfoides Eastern out 4444 Pinus sylvestris Soots pine	cottonwood 8 Fair w 9.10 Fair	Exempt Exempt	4602 Pinus sylvestris Scots pine 12 Fair Remove 2 4600 Pinus sylvestris Scots pine 8 Fair Remove 1	4761 Product servicing Black cherry 10,11 Poor Remove 3 4762 Conference Plant waters 11 February 1	4900 Junipens Viginiane Eastern red cedar 13 Good Save
4445 Pinus sylvestris Scots pine	te 9 Fair	Exempt Could 2	4604 Pinus sylvastris Scots pine 13 Fair Remove 2	4763 Pinus sylvestris Scats pine 11,12 Fair Remove 3	4502 Unica americana American elm 8 Fair Save
4447 Populos fremulaides Quaking as	aspen 11 Fair	Credit 2	4606 Pinus resirous Red pine 11 Fair Remove 1	4765 Pinus sylvestris Scots pine 9 Fair Remove 1	4624 Juniperus Wighnane Eastern red cedar 10 Good Remove 1
4449 Populos tremultidas Qualring as	aspen 9 Fair	Credit 2	4600 Pinus sylveshis Scots pine 17 Fair Remove 2	4767 Make purnis Common apple 5,7,7 Pair Exempt	4500 Priss sylvestris Scots pine 9 Fair Hemove 1 4509 Priss sylvestris Scots pine 11 Good Remove 1
4451 Populus fremulaides Quaking as	aspen 8 Fair	Credit 2	4610 Pinus stratus Eastern white pine 14 Fair Remove 2	4790 Pinus sylvestris Soots pine 14 Fair Remove 2 4790 Pinus sylvestris Soots pine 14 Fair Remove 2	4927 Prince sylvesims 8005 pine 10 Good Helmove 1 4600 Populius deltoides Eastern cottonwood 15 Pair Remove 2
4453 Populus fremulaides Quaking as	aspen 8 Fair aspen 8 Fair	Credit 2	4611 Phosa syrvastris Scots prile 14 Fair Hornove 2 4612 Pinus strotus Eastern white pine 12 Fair Remove 2	4770 Pinus sylvestris Scots pine 15 Fair Remove 2 4771 Junipenus virginiana Essatem ned cedar 9 Fair Remove 1	4009 Pinus sylvestris Scots pine 10 Good Remove 1 4600 Pinus sylvestris Scots pine 9 Good Remove 1
4454 Populus tremulaides Quaking as 4455 Malus purnila Common as	aspen 10 Fair apple 6,7,8 Fair	Credit 2 Credit 2	4613 Pinsa sylvestria Scota pine 12 Fair Remove 2 4614 Picea ables Norway spruce 9 Poor Remove 1	4772 Pinus sylvestris Soots pine 15 Fair Remove 2 4773 Pinus sylvestris Soots pine 12 Fair Remove 2	4601 Acur saccharinum Silver maple 9 Good Remove 1 4602 Acur saccharinum Silver maple 13 Good Remove 2
4456 Populus deltoides Eastern oot 4457 Pinus sylvestris Soots pine	oottonwood 18 Fair ne 8 Fair	Save Credit 2	4615 Pinus sylvestris Scots pine 10 Fair Remove 1 4616 Pinus sylvestris Scots pine 10 Fair Remove 1	4774 Robinia pseudoacacia Black locust 12 Fair Save 4775 Make purole Common apple 9.9 Fair Remove 3	4503 Pinus sylvestris Scala pine 15 Good Remove 2 4504 Pinus sylvestris Scota pine 12 Const. Remove 2
4458 Matu purnia Common ap 4459 Pinus strotus Fasters wh	apple 16 Fair shife-pine 22 Fair	Credit 3	4617 Pices ables Norway spruce 7 Fair Exempt 4618 Pices ables Norway spruce 11 Fair Remove 1	4776 Utrus americana American etn 12 Fair Bave 4777 Poblida nesudnospila Start Insust 19 Fair Barrow 2	4505 Pinus sylvestris Scate pine 9 Good Remove 1
4460 Pinus sylvestris Scots pine 4461 Pinus strolus Fasters whi	w 9 Fair white sine 11 Fair	Sine Sine	4619 Pices ables Norway spruce 16 Fair Remove 2 4600 Press ables Norway spruce 14 Fair Remove 2	4778 Make purele Common apple 8,11 Feir Save	4937 Pinus sylvestris Boots pine 8 Good Remove 1
4462 Malus purelle Common ap	apple 12,13 Fair	Exempt	4621 Piosa ables Norway sprace 13 Fair Remove 2	4790 Junipens viginiane Eastern red cedar 7 Fair Exempt	4609 Juniperus Wiginiana Eastern red cedar 8 Good Remove 1
4464 Pyrus calleryana Callery pea	ear 11 Fair	Exempt	4623 Picea ables Norway sprace 10 Fair Remove 1	4702 Pourus sercitine Diack cherry 9 Pair Remove 1	4941 Junipens viginiana Eastern red cedar 11 Good Remove 1
4466 Populos delfoides Eastern cot	cottonwood 11 Fair	Save	4605 Pinus atrabus Eastern white pine 11 Fair Remove 1	4783 Phosa systems Scots pine 14 Fair Hornove 2 4784 Phosas serotina Black cherry 10 Fair Remove 1	4942 Pinus sylveptris Scotts pline 14 Good Remove 2 4943 Populius delitorales Elektern cottonwood 11 Good Remove 1
4469 Populus delfoides Eastern oct	ottorwood 10 Fair	Exempt	4635 Phose sylvestris Scots prile 8 Fair Remove 1 4637 Pices ables Norway spruce 16 Fair Remove 2	4785 Phursus serotina Black charty 8,9,10 Fair Hornove 4 4786 Pinus sylvestris Scots pine 15 Fair Remove 2	4946 Pinus sylvestris Scotts pine 9 Pair Remove 1 4946 Acer ascchantom Silver maple 6,9,11 Good Remove 3
4489 Populos deltoides Eastern cot 4470 Populos deltoides Eastern cot	ottorwood 10 Fair ottorwood 11 Fair	Exempt Exempt	4628 Pices ables Norway spruce 10 Fair Remove 1 4629 Pinus atrobus Eastern white pine 13 Fair Remove 2	4787 Utrus americana American elm 11 Feir Seva 4789 Aceristrum Redinaple 10 Feir Remove 1	4946 Pinus sylvestris Scots pine 10 Good Remove 1 4947 Protest serotina Black cherry 8 Good Remove 1
4471 Pinus sylvestris Scots pine 4472 Ulmus americana American e	w d Fair nelm 10 Fair	Exempt Credit 2	4600 Pinus strobus Eastern white pine 9 Fair Remove 1 4631 Pinus strobus Eastern white pine 14 Fair Remove 2	4789 Acer-rubruro Red maple 9 Fair Save 4790 Juniperus virginiane Eastern red cedar 8 Fair Save	4948 Acer secchanism Siler maple 5,7,8 Fair Remove 1 4949 Pinus sylvestris Scots pine 10 Good Remove 2
1997 1998 1999	le 15 Fair 18 Fair	Exempt Exempt	4632 Pinus atrobus Eastern white pine 15 Fair Remove 2 4633 Pinus strobus Eastern white pine 11 Fair Remove 1	Column	4960 Pinus sylvestris Scots pine 9 Fair Remove 1 4951 Pinus sylvestris Scots pine 10 Good Remove 1
4475 Populus fremulaides Quaking as 4476 Pinus sylvestris Scots pine	aspen 10 Fair w 9 Fair	Exempt Exempt	4634 Pinus atrobus Eastern white pine 17 Fair Remove 2 4635 Pinus resinosa Red pine 10 Fair Remove 1	4790 Acer rubrum Red maple 9 Fair Save 4794 Umus amendana American etm 9 Fair Save	4952 Pinus sylvasmis Scots pine 17 Good Remove 2 4953 Literary arrangement American site 8 Fair Rem
4477 Pinus sylvestris Scots pine 4478 Augiere plans Black weins	ne 11 Fair Inut 12 Fair	Exempt Exempt	4636 Pinus resinous Red pine 15 Fair Remove 2	4795 Acer saccharum Sugar maple 13 Good Save 4795 Dinne subsector Social rates 14 Fish Decrees 2	4554 Popular delicates Eintern cottonwood 17 Good Saw 4555 April processor State (1995) 25 Good Saw
4479 Aper subrure Red maple 4480 Pinus subreshis Scots pine	ie 16 Poor w 8 Fair	Exempt Exempt	4638 Pinus restrora Red pine 12 Fair Remove 2 4699 Provide harmatrista Cublish Science 9 Const. Remove 1	4797 Juglans nigra Black watrut 14 Fair Remove 2 4798 Physic subsector Scott nigra 11 Fair Person 1	4505 Aper secchanium Silver maple 9,11 Good Save
4481 Pinus sylvestris Scots pine 4487 Pinus sylvestris Scots pine	te 10 Fair	Exempt	4640 Pinus sylvestris Scots pine 9 Good Exempt	4799 Pisus sylvestris Soots pine 10,13 Fair Remove 3	4600 Acer secchanium Silver maple 11,11 Good Remove 3
4463 Pharmus cathartics Common bu	buckthorn 8 Fair	Exempt	4642 Pinus resinosa Red pine 9 Fair Remove 1	4801 Ulmus americana American elm 10 Feir Remove 1	4950 Junipens Wighland Eastern red cedar 11 Good Remove 1
4465 Juglans rigns Black walnu	frut 12 Fair	Exempt	4644 Pinus sylvestris Scots pine 10 Fair Remove 1	4800 Juplans rigns Disck valual 15 Fair Remove 2	4901 Prince sylvestris Scota pine 13 Good Formore 2 4902 Pinus sylvestris Scota pine 7 Pair Exempt
4467 Juglans rigra Black walnu	inut 11 Fair	Exempt	4940 Pinus resinosa Red pine 8 Fair Remove 1	4604 Mookina pasuooacucus Elack looust 14 Fair Hemove 2 4605 Juniperus virginiane Elastem red cedar 19 Fair Remove 2	4963 Pinus sylvestris Scotts pine 8 Good Remove 1 4964 Pinus sylvestris Scotts pine 8 Fair Remove 1
4489 Pinus sylvestris Scots pine 4489 Pinus sylvestris Scots pine	ne 10 Fair ne 9 Fair	Exempt	4647 Pinus strobus Eastern white pine 17 Fair Remove 2 4648 Pices ables Norway spruce 8 Fair Remove 1	4806 Robinia pseudoacacia Black locust 11 Fair Remove 1 4807 Jugilans rigra - Black walnut 11 Fair Remove 1	4903 Pinus sylvestris Scots pine 9 Pair Remove 1 4968 Pinus sylvestris Scots pine 14 Good Remove 2
4490 Prunus serctina Black cheri 4491 Saliv arrygdaloides Peachleaf v	erry 11 Poor dwillow 7,9,10 Fair	Exempt	4649 Pices ables Norway spruce 9 Fair Remove 1 4650 Pices ables Norway spruce 15 Fair Remove 2	4608 Juniperus virginiane Eastern red cedar 10 Fair Remove 1 4609 Juniperus virginiane Eastern red cedar 13 Fair Remove 2	4967 Acer spocharkum Sher maple 12 Good Remove 2 4968 Acer spocharkum Sher maple 11,11 Good Remove 3
4462 Pinus sylvestris Scots pine 4463 Pinus sylvestris Scots pine	ne 9 Pair ne 10 Good	Exempt Exempt	4651 Picea ables Norway spruce 12 Fair Remove 2 4652 Picea ables Norway spruce 15 Fair Remove 2	4810 Ulmus americana American alm 11 Fair Remove 1 4811 Pronus serotina Black cherry 9 Fair Remove 1	4969 Pinus sylvestris Scots pine 9 Fair Remove 1 4970 Pinus sylvestris Scots pine 9 Good Remove 1
4494 Pinus sylvestris Scots pine 4495 Pinus sylvestris Scots pine	ne 10 Fair ne 10 Good	Exempt Exempt	4663 Pinus sylvestris Scots pine 10 Fair Remove 1 4654 Pinus sylvestris Scots pine 8 Fair Exempt	4812 Procus section Black cherry 10 Fair Remove 1 4813 Pinus sylvestris Scots pine 10 Fair Remove 1	4971 Pinus sylvestris Scots pine 17 Good Remove 2 4972 Utrus greecopsy American etn 0 Fair Remove 1
4466 Pinus sylvestris Scots pine 4467 Pinus sylvestris Scots pine	w 8 Fair w 8 Fair	Exempt Exempt	4605 Pinus sylvestris Scots pine 8 Fair Exempt 4656 Matus pumila Common apple 10 Fair Exempt	4814 Phonos servina Black cherry 8,8 Fair Remove 2 4815 Pinus sylvestris Scotts pine 9,11 Fair Remove 3	4973 Make purelle Common apple 8 Good Remove 1 4974 Postus sentina Black sherry 11 Good Remove 1
4499 Pinus sylvestris Scots pine 4499 Juglans nigra Black walni 4500 Acer negundo Boxelder	ne 8 Good Inut 8 Good	Exempt Exempt	4667 Ulmus americana American elm 7 Fair Exempt 4668 Populos tremuloides Qualring aspen 10 Fair Save	4816 Pinus sylvestris Soots pine 20 Fair Remove 2 4817 Pinus sylvestris Soots pine 12 Fair Remove 2	4075 Pinus sylvestris Scots pine 16 Good Remove 2 4676 Pinus sylvestris Scots pine 14 Good Remove 2
4500 Aper regundo Boxelder 4501 Postus sercina Black cherr	7,10,11 Fair env 7 Fair	Remove 3 Eventor	4009 Salivanyphaloides Peachinal willow 15 Fair Save 4990 Province definition Fastern communication 41 Fair Save	4818 Pinus sylvestris Scots pine 9 Fair Save	4977 Popular delicates Eastern cottonwood 21 Good Save
4502 Prunus serorina Black chem 4500 Pinus strobus Eastern wh	erry 9 Fair shite pine 16 Fair	Remove 1 Remove 2	4661 Fracing pennsylvanica Green ash 9 Fair Save	4620 Photos servina Black theny 13 Fair Remove 2	4679 Populus delicates Eastern cottonwood 18 Good Save
4504 Pinus strobus Eastern whi 4505 Pinus restrosa Red pine	white pine 12 Fair 11 Fair	Remove 2 Remove 1	4663 Richina pseudoacacia Black locust 11 Fair Save	4622 Jugher nigra Black walnut 8 Fair Saws 4622 Approximation Shar marks 14 Good Saws	4661 Populios detoides Eastern cottonwood 12 Poor Save
4506 Pinus resinosa Red pine	9 Fair	Remove 1	4665 Robinia pseudoacacia Black koust 11 Fair Save	4604 Acer seccharitum Silver maple 13 Good Remove 2	4963 Populos deltoides Eastern cottonwood 9 Poor Save
4508 Ploas ables Norway spr 4509 Plant stocker Casters wh	priore 10 Fair	Remove 1	4667 Rockinia pseudoanacia Black locust 11 Fair Save	4628 Phonos sections Black cherry 8 Poor Remove 1	4666 Populus deficiales Eastern cottonwood 17 Fair Save
4510 Pinus strobus Eastern wh	ahite pine 12 Fair	Remove 2	4889 Phos sylvestre Scots pine 13 Good Save	4627 Priss sylvestris Scots pine 9 Good Remove 1 4628 Pinus sylvestris Scots pine 9 Good Remove 1	4696 Populius deltoides Eastern cottonwood 22 Good Save 4667 Populius deltoides Eastern cottonwood 21 Fair Save
4512 Aper rubruro Red maple	ie 17 Fair	Remove 2	46/0 Prins syretins Soots pine 12 Good Save 46/1 Prunus serctina Black charry 12 Good Save	4629 Photos serona Black cherry 13 Pool Horrove 2 4630 Photos serolina Black cherry 9 Pair Remove 1	4668 Populus deltoides Eastern cottonwood 13 Poor Save 4669 Populus deltoides Eastern cottonwood 13 Fair Save
4513 Pinus atrobus Eastern wh 4514 Pinus resirosa Red pine	efite prie 24 Fair 9 Fair	Remove 1	4672 Junipens virginiane Eastern red cedar 8 Good Save 4673 Pinus sylvestris Scota pine 19 Good Save	4831 Ulmus americana American elm 10 Good Remove 1 4832 Pinus sylvestris Sosts pine 12 Fair Remove 2	4990 Populus deltoides Eastern cottonwood 19 Fair Save 4991 Populus deltoides Dastern cottonwood 29 Good Save
4515 Pinus sylvestris Scots pine 4516 Pinus sylvestris Scots pine	w 9 Fair ne 11 Fair	Remove 1 Remove 1	4674 Pinus sylvestris Scots pine 9 Good Exempt 4675 Pinus sylvestris Scots pine 10 Fair Exempt	4633 Ulmus americana American elm 14 Good Remove 2 4694 Pinus sylvestris Sosts pine 9 Fair Remove 1	4992 Populus deltoides Eastern cottonwood 9 Poor Save 4993 Populus deltoides Eastern cottonwood 12 Poor Save
4517 Pinus sylvestris Scots pine 4518 Pinus strobus Eastern whi	w 12 Fair white pine 15 Fair	Remove 2 Remove 2	4676 Pinus sylvestris Scots pine 8 Fair Exempt 4677 Robinia psyudopopia Black locust 11 Good Exempt	4605 Pinus sylvestris Scots pine 7 Fair Exempt 4606 Pinus sylvestris Scots pine 8 Fair Remove 1	4694 Populius delitrories Eastern cottonwood 11 Poor Save 4695 Populius delitrories Eastern cottonwood 14 Fair Save
4519 Pinus sylvestris Scots pine 4520 Pinus sylvestris Scots pine	w 12 Fair no 8 Fair	Remove 2 Remove 1	4678 Robinia pasudoscania Black locust 8 Good Exempt 4679 Pribinia pasudoscania Black locust 7 Good Exempt	4607 Procus sections Black cherry 11 Fair Remove 1 4609 Procus subsection Scotts rice 11 Fair Remove 1	4506 Salix arrayctalcides: Peachland willow 10,15,16 Fair Save
4521 Pinus strobus Eastern whi 4522 Pinus sylvestris Scotts pine	white pine 18 Fair ne 13 Fair	Remove 2 Remove 2	4800 Phase sylventris Scots pine 8 Good Exempt 4801 Phase sylventris Scots pine 9 Good Exempt	4039 Plays sylvestris Scots pine 11 Fair Remove 1 4900 Plays sylvestris Black charty 8 10 19 Fair Brance 5	4500 Popular delicides Eastern cottonwood 11 Poor Save
December 2015 Continue of the Continue of	nielm 12 Fair w 15 Fair	Remove 2 Remove 2	Column	GROSS Fig. GROSS GROSS	Manufaction
4525 Pinus resinosa Red pine	8 Fair	Remove 1	4694 Robinia pseudoscacia Black locust 0.9 Good Exempt	4843 Prunus serctina Black cherry 11,12 Fair Remove 3	6002 Aperiushum Red maple 18 Fair Remove 2
4527 Pinus resinosa Red pine	8 Fair	Remove 1	4696 Robinia pseudoacacia Black locust 12 Good Exempt	4845 Prantus serctina Black cherry 9 Fair Remove 1	6004 Aper saccharitori Siner maple 12 Good Remove 2
4629 Pinus sylvestris Scots pine	w 11 Fair	Remove 1	4689 Pinus sylvestris Scots pine 9 Good Exempt	4947 Juniprous kiginiane Eastern red cedar 8 Good Remove 1	6008 Populas deficides Eastern cottonwood 12 Fair Save
4631 Ulmus americana American e	nelm 19 Fair	Remove 2	4600 Phus sylvestris Scots pine 8 Good Exempt	4949 Pinus sylestris Scots pire 6,8 Fair Remove 1	COLU Propulys detroates luxetem coltonwood 30 Good Sare 6008 Acur nature Red maple 9 Fair Remove 1
4533 Piose ables Norvey spr	pruce 12 Febr	Remove 2	4692 Phus sylvestris Sods pine 7 Fair Exempt	NOV PLET ASSETS HES TRADE 1 First sylvestris Scots pine 22 Very Poor Exempt	6484 Hnius systems is cotte pine 12 Fair Remove 2 6010 Popular delitridas Eastern cottonwood 22 Good Save
4535 Pinus resinosa Red pine	10 Fair	Remove 1	4004 Pinus sylvestris Scots pine 9 Good Exempt	Accus united amendana Amendani em is Very Poor Exempt 48CO Pinus sylvestris Scots pine 11 Fair Remove 1	
4537 Pices ables Norway spr	pruce 12 Fair	Remove 2	eoso i-rinus sylvestris Scotii pine 8 Poor Exempt 4696 Robiniy pseudoscotie Black looust 9,11,13 Good Exempt	4004 Princis gylestrins Soots pine 10 Very Poor Exempt 4005 Pinus sylestrins Soots pine 8 Fair Remove 1	eutra Propulsa districidas Eastern cottonivoda 10,31 Fair Save 6014 Ultrius arcericans American elm 8 Fair Save
4030 Pices ables Norway spr 4539 Pices ables Norway spr	pruce 13 Pair pruce 14 Fair	Remove 2	4607 Pinus sylvestris Scots pine 7 Good Exempt 4698 Robinia pseudoacacia Black looust 14 Good Exempt	4886 Alexi seccharum Sugar maple 13 Good Remove 2 4867 Pinus sylvestris Soots pine 13 Dead Exempt	
4040 Plose ables Norway spr 4541 Pinus sylvestris Scots pine	pruce 11 Fair re 9 Fair	Remove 1	4659 Pinus sylvestris Scota pine 8 Good Exempt 4700 Pinus sylvestris Scots pine 9 Good Exempt	4850 Phanus securins Black cherry 8,9 Fair Remove 3 4850 Phasa sylvestrins Soots pine 7 Fair Exempt	6017 Acer seccharum Sugar misple 10 Good Remove 1 6018 Acer seccharum Sugar misple 8 Good Remove 1
4504 Poos abies Nonway got 4505 Phus reshroots Red pine 4509 Phus reshroots Red pine 4507 Ploos abies Nonway spi 4509 Poos abies Nonway spi 4509 Poos abies Nonway spi 4509 Poos abies Nonway spi 4504 Phus othobies Essensi	white pine 18 Fair ipruce 18 Fair	Remove 2 Remove 2	4701 Pinus sylvestris Scots pine 8 Good Remove 1 4702 Pinus sylvestris Scots pine 8 Good Exempt	4860 Pinus sylvestris Sosts pine 8 Fair Remove 1 4861 Prunus sentrina Black cherry 12 Good Remove 2	6019 Pinus sylveotris Scota pine 10 Fair Remove 1 6000 Pinus sylveotris Scota pine 9 Fair Remove 1
4544 Pices ables Norway spr 4545 Pices ables Norway spr	pruce 11 Fair pruce 12 Fair	Remove 1 Remove 2	4703 Pinus sylvestris Soots pine 8 Good Exempt 4704 Pinus sylvestris Soots pine 14 Good Remove 2	4802 Alon secohanoum Silver maple 20 Good Remove 2 4863 Phous sylvestris Soots pine 11 Good Remove 1	6021 Pinus sylvectris Scots pine 8 Fair Remove 1 6022 Pinus sylvectris Scots pine 10 Fair Remove 1
4546 Pices ables Norway spr 4547 Pices ables Norway spr	pruce 11 Fair pruce 14 Fair	Remove 1 Remove 2	4705 Pinus sylvestris Scots pine 10 Good Exempt 4708 Pinus sylvestris Scots pine 10 Good Exempt	4864 Jugians oigna Black welnut 22 Excellent Remove 3 4865 Jugians nigna Black welnut 9 Good Remove 1	
August A	19	Second	Column	The content of the	April
4550 Pices ables Norway spr 4551 Pices ables Norway spr	pruce 9 Fair pruce 18 Fair	Remove 1 Remove 2	4709 Robinia pseudoacacia Black locust 18 Good Exempt 4710 Pinus sylvestris Scots pine 8 Good Exempt	4889 Juglans nigra Black walnut 21 Good Remove 3 4869 Juglans nigra Black walnut 18 Good Remove 2	6027 Ultrus americana American elm 9 Fair Remove 1 6028 Prius sviveptris Scots pine 9 Fair Remove 1
					•





Sea



Title:

Tree List

Project:

The Grove Novi, Michigan

Prepared for:

Ivanhoe Companies 6689 Orchard Lake Road, Suite 314 West Bloomfield, Michigan 48322 248.626.6114

Revision:	Issued:
Review	March 28, 2024
Revised	July 26, 2024
PRO Submission	July 9, 2025
Revised PRO Submission	September 12, 2025

Job Number:

21-054

Drawn By: Checked By:



Sheet No.

1100 LIST			
Required Mutti-Chorn Tag Scientific Name Common Name Dia. Condition Status Reptacement Reptacement Credits	Required Multi-Zitem Tag Scientific Name Common Name Dia. Condition Status Replacement Replacement Credits	Required Multi-Glore Tag Scientific Name Common Name Dia. Condition Status Replacement Replacement Condition	Required Multi-Stern
13g Scientific Name Common name Uss. Condition Salas responsively represented to condition (Condition Salas Represented represented to condition Salas Represented represented to condition (Condition Salas Represented represented to condition Salas Represented represented to condition (Condition Salas Represented represented to condition Salas Represented represented to condition (Condition Salas Represented represented to condition Salas Represented represented to condition (Condition Salas Represented represented to condition Salas Represented repitation represented represented represented represented represen		CMR Title amenicana Bassaccid 11 Fair Remove	Tag Scientific Name Common Name Dia. Condition Status Reprocement respiscement Credits 6209 Procus serctina Black chery 10 Fair Remove
6000 Pinus sylvestris Scots pine 9 Fair Save 6001 Pinus sylvestris Scots pine 15 Fair Save	6191 Pinus strobus Eastern white pine 14 Fair Remove 2 6192 Pinus sylvestris Scots pine 12 Fair Remove 2	6960 Carya conditionnis Bittemut hickory 11 Fair Remove 1 6351 Tilla emericana Basevocad 19 Fair Remove 2	6510 Ostrya viginiana Hop-hombeam 8 Fair Remove 1 6511 Tila americana Bassanani 20 Good Bassana 2
1000 Trian symbols	6193 Pinus sylvestris Scots pine 10 Good Remove 1	SZIZ Tale americana Barrocca 8 Fair Barrocca 1	6512 Jugians rigns Black welrus 10 Feir Remove 1
6004 Photos sercrine Black cherry 10,11 Fair Save	6195 Phonos serctina Black cherry 15,16 Fair Remove 4	6354 Tille americana Basswood 21,23,34 Poor Remove 10	6514 Carpa confitorms Bitternat hickery 10 Pair Save
6005 Junipenos virginiano Eastern red cedar 9 Fair Save 6006 Judiano nigro Black walnut 9 Fair Save	6196 Aper seccharitum Silver maple 8,13,17 Good Remove 5 6197 Aper seccharitum Silver maple 11 Good Remove 1	6365 Tille-americana Basswood 18 Good Remove 2 6398 Tille-americana Basswood 9 Good Remove 1	6515 Carya condiformis Bitternut hickory 11.13 Fair Save 6516 Carya condiformis Bitternut hickory 8 Fair Save
	1512 Privat Applicate 150 Private 150 Private		6517 Title americana Basswood 12 Good Save
5009 Aperiushuro Redinage 8 Fair Sawe	6200 Pinus strobus Eastern white pine 19 Good Remove 2		6519 Carya conditornia Biliteraut hickary 11 Good Save
6040 Acer saccharum Sugar maple 9 Good Sake 6041 Ulmus americana American elm 8 Fair Sake	6001 Malus purella Common apple 8 Fair Remove 1 6002 Phasa selventria Soota pine 8 Good Remove 1	6360 Juglans rigna Black walnut 18 Good Remove 2 6361 Querous alba White cals 8.6 Fair Remove 2	6520 Carya confiformis Bitternat hickory 9 Good Save 6521 Carya confirmin Bitternat hickory 10 Ear. Remove 1
6042 Apertubrum Red maple 14 Fair Save		GRZ Carya conditionals Bitternut hickory 8 Good Remove 1	6522 Ontrya viginiana Hop-hombeam 7,8,8 Good Remove 2
6044 Populus deltoides Eastern cottonwood 28 Feir Saws	6205 Ulmus americana American elm 12 Good Remove 2	6384 Titis americana Basswood 21 Good Remove 3	6523 Carya conditionns Editernat hickory 12,15,19 Good Remove 6
6045 Uhrus americana American elm 10 Fair Save 6046 Possus serotina Black cherry 15 Fair Save	6207 Ulmus americana American eth 11 Good Remove 1	Agricol Agri	6525 Carya conditional Billiteral hickory B Good Remove I 6508 Ontre significant Handron 7 Fair Frances
1002 First synthetis 100 First 100	6200 Pinus sylvestris Scots pine 12 Good Remove 2 6200 Pinus sylvestris Scots pine 9 Fair Remove 1	6367 Tile americana Bassaccot 23 Good Remove 3 6298 Tile americana Bassaccot 21 Good Remove 3	6527 Quarcus rubra Red oak 11 Good Remove 1
6049 Robinia posudoscacia Black locust 11 Fair Sawe	6210 Pinus sylvestris Scots pine 10 Fair Remove 1	5598 Tale americane Sales and 21 Good Remove 3	6529 Ultrus attendans American elin 10 Pair Remove 1
6050 Popular fremulaides Guelang sepen 8 Feir Sawe 6051 Popular fremulaides Guelang sepen 9 Poor Sawe	6212 Pinus sylvestris Scots pine 9 Good Remove 1	6371 Ulmus americana American elm 12 Good Remove 2	6530 Quercus alba White oak 31 Good Remove 4 6531 Cetya wiginiana Hop-hombeam 8.9 Good Remove 3
6052 Pinus sylvestris Scots pine 11 Fair Romove 1 6053 Pinus sylvestris Scots pine 12 Fair Remove 2	6214 Pinus sylvestris Scots pine 14 Good Remove 2	CST2 Customs native Rep3 eaix 17 Fair Retrove 2	6632 Carya confiformis Bittarnat hickory 13 Good Save 6533 Changur after White only 14 Good Save
6054 Pinus sylventris Scots pine 11 Feir Remove 1	6215 Promos serotina Black cherry 9 Good Remove 1 6216 Provi sulvestris Scots pine 13 Fair Remove 2	6374 Ultrus americana American elm 9 Fair Remove 1 6775 (volume nives Black select 19 Fair Perrosa 2	6534 Juglans nigra Black walnut 21 Good Remove 3
6056 Pinus sylvestris Scots pine 10 Poor Remove 1	6217 Pissa sylvestris Scota pine 10 Fair Remove 1	6378 Litrus americana American elm 13 Good Remove 2	6536 Aperingundo Boolder 12,13 Feir Save
6057 Pinus sylvestris Sceta pine 11 Good Remove 1 6058 Pixous serotina Black cherry 0.11 Fair Remove 3	6219 Pinus sylvestris Scots pine 12 Good Remove 2	6379 Ultrau ammouree Ammoureer in 13 Good Nerrow 2 GST7 Julgelen signs – Black welmst 15 Good Remove 2 6370 Jugalens regna – Black welmst 11 Filir Remove 1	6537 Juglians nigra Black walnut 9 Fair Save 6538 Juglians nigra Black walnut 12 Good Save
6060 Ulmus americana American elm 10 Fair Remove 1 6060 Poucus serritos Black chemy 10 Fair Remove 1	6221 Pinus sylvestris Scots pine 11 Dead Exempt 6221 Pinus sylvestris Scots pine 7 Poor Exempt		6509 Carya coniformia Bitterrut hickory 14 Good Save
6061 Prome servina Black cherry 10 Very Poor Exempt	6222 Rhamnus cathartics Common buckthorn 8 Fair Exempt 6223 Pinus sulventra Scota pine 14 Good Remove 2	6381 Juglans rigra Black walnut 11 Good Remove 1 6382 Tillia americana Blackword 9.12 Good Remove 3	6641 Juglans rigra Black walnut 7 Poor Save
6063 Pinus sylvestris Scots pine 9 Fair Remove 1	6224 Pinus sylvestris Scots pine 12 Good Remove 2	6989 Juglans rigra Black walnut 20 Good Remove 2	6942 Units amendana Amendan em 9 Fair Save 6543 Applan nigra Black walnut 20 Good Save
6064 Pinus sylvashtis Scots pine 17 Fair Remove 2 6065 Aper subnum Red masle 9.13 Fair Remove 3	6226 Pinus sylvestris Soots pine 8 Poor Remove 1	6384 Juglans rigna Black watrut 15 Good Remove 2 6385 Juglans rigna Black watrut 8 Fair Remove 1	6544 Carya confformis Bilterrut hickory 8 Good Save
6066 Pinus sylvestria Scots pine 9 Feir Remove 1	6227 Pinus sylvestris Scoti pine 9 Good Remove 1 6228 Pinus sylvestris Scoti pine 14 Good Remove 2	6386 Jugiana nigra Black walnut 10 Fair Remove 1 6397 Anna serritanam Banar mante 8 Ven Poer France	6546 Jugliere nigra Black welnut 10 Good Sawe
6000 Pinus sylvestris Gools pine 10 Fair Remove 1	6029 Ulmus americana American elm 9 Fair Remove 1 6720 Anni americana Sunta maria 11 Fair Barrosa 1		6547 Ultrus americans American elim 7 Pair Essempt 6540 Quercus rubre Red ook 14 Good Remove 2
6009 Pinus sylvestris Gods pine 8 Fair Remove 1 6000 Pinus sylvestris Gods pine 11 Good Remove 1	6231 Ulmus americane American elm 15 Good Remove 2	Column C	6549 Ulmus americana American elm 9 Good Remove 1
6071 Priss sylvestris Scots pine 19 Good Remove 2	6232 Pinus strobus Eastern white pine 13 Good Remove 2 6233 Pinus xylvestris Scots pine 9 Fair Remove 1	6391 Carya cordifornis Bitterrut hickory 10 Fair Remove 1 6302 Jupiters niona Black resinut 20 Fair Remove 2	6551 Urrus americana American elm 9 Fair Remove
6073 Pinus sylvestris Scots pine 8 Good Remove 1	6234 Quercus rubra Red oak 14 Good Remove 2 6235 Possus serptina Black cherry 11 Good Remove 1	6393 Acer saccharum Sugar maple 11 Good Remove 1 6394 Tille americana Biography 19 Fine Burrows 2	6003 Carya condiformia Bilternut hickery 13,14 Good Remove 4
6075 Pinus sylvestris Gods pine 10 Feir Remove 1	6236 Ulmus americana American elm 10 Good Remove 1	6385 Prunus sercina Black cherry 11 Fair Remove 1	6554 Quercus rubre Red oak 11 Good Remove 1 6555 Quercus rubre Red oak 20 Good Remove 2
6076 Acertabrary Red maple 10 Fair Remove 1	6238 Pinus sylvestris Scots pine 11 Fair Remove 1	6307 Acur succharum Sugar maple 7,7 Fair Exempt	6566 Juglans rigns Black welnut 12 Good Remove 2
6078 Phus sylvestris Scots pine 10 Fair Remove 1	6240 Ulmus americana American elm 9 Good Remove 1	6399 Cana osrafornia Bitterrut hickon 9 Good Remove 1	6558 Juplins rigns Black walnut 8 Fair Remove 1
Manufaction	Authors on the content of the cont	Column	ebodi Jugians ngra Black walnut 17 Good Remove 2 6560 Jugians nigra Black walnut 18 Good Remove 2
6081 Pinus sylvestris Scots pine 10 Dead Exempt 6062 Pinus sylvestris Scots pine 19 Good Remove 1	6243 Acer seccharum Sugar maple 13 Good Remove 2	6401 Jugliere regna Black velorist 20 Good Retrove 2	6561 Agénis nigra Black weinut 6 Fair Remove 1 6562 Plous submittés Soots nine 9.11 Fair Remove 1
6003 Pinus sylvestris Scots pine 9 Fair Remove 1	624 Tille americana Basswood 8 Good Remove 1	6403 Acer saccharum Sugar maple 9 Good Remove 1 6404 Acer saccharum Sugar maple 8 Good Remove 1	6563 Press rights Black pine 12 Very Poor Exempt
6005 Aper supplies the maple 11 Good Remove 1	6246 Populos delfoides Eastern cottonwood 19 Good Remove 2 6247 Umus americana American elm 14 Good Remove 2	5605 Jugiste rigid Slack select 1 0cod Remove 1	6564 Acer acchance Sugar maple 8 Good Remove 1 6565 Applans nigra Black wateut 12 Pair Remove 2
6088 Pinus sylvestris Scots pine 12 Good Remove 2 6087 Pinus sylvestris Scots pine 11 Fair Remove 1	6048 Acer seconarum Sugar maple 10 Poor Remove 1	9407 Juglans nigra Black walnut 8 Good Remove 1	6566 Arer saccharum Sugar maple 11 Good Remove 1 6567 Judines nicro Black valnut 13 Good Remove 2
6008 Pinus sylvestris Scots pine 8 Feir Remove 1	6250 Acer saccharum Sugar maple 14 Good Rerrove 2	6409 Ulmus americana American elm 9 Fair Remove 1	6568 Juglians nigra Black welnut 18 Good Remove 2
6090 Acer succhartum Silver maple 9,10,14 Good Remove 5	6251 Pinus sylvestris Scots pine 10 Poor Remove 1 6252 Pinus sylvestris Scots pine 13 Fair Remove 2	October 1999 State sealed 9 Cloud Berrore 1	6570 Jugians rigns Black wateut 14 Fair Hemove 2 6570 Jugians rigns Black wateut 14 Fair Sawe
6091 Pricing services Black cherry 8 Fair Remove 1 6092 Prices sylvestris Soots pine 17 Good Remove 2	6253 Aper seconarum Sugar maple 8 Fair Remove 1	6412 Title amenicana Basswood 21 Fair Remove 3	6571 Carya condiformis Bitternut hickory 10 Fair Save 6572 Judices signs Black valeut 11 Fair Save
6003 Quercus rubra Red oak 18 Good Remove 2	6255 Tills americana Basswood 12 Good Remove 2	6414 Querous rubras Red oak 17 Good Remove 2	6573 Acernatrum Red maple 39 Very Poor Save
6005 Pranse servina Black cherry 8 Fair Remove 1	CDS Aper seconatum Sugar mapre 9,10 Feir Hornove 3 CDS7 Populiya delfoldes Elestem cottonwood 18 Good Remove 2	6415 Quercus rubra Red oak 11 Good Remove 1 6416 Quercus rubra Red oak 14 Good Remove 2	6575 Agians rigns Black walnut 11 Pair Save
6097 Procus section Black cherry 11 Fair Remove 1	6059 Populos deltoidos Eastern cottonwood 17 Good Remove 2 6059 Anni sannharum Sugar manie 8 Good Remove 1	Geol	6576 Uhrus americano American elim 9 Fair Save 6577 Cana confiornis Bilterrut hickory 14 Fair Save
6008 Acervatrum Red maple 9,10,13 Fair Remove 4 6009 Popula services Black cherry 16 Fair Remove 2	6090 Acer seconarum Sugar maple 15 Good Remove 2	6419 Aper saccharum Sugar maple 9 Fair Remove 1	6578 Aperiushiser Red maple 16 Fair Save
Description Compared Compar	6082 Pinus sylvestris Scots pine 16 Fair Remove 2		6580 Acuraturum Red maple 11,12,12 Fair Save
6101 Priss sylvestris Soots pine 8 Fair Remove 1 6102 Priss sylvestris Soots pine 9 Fair Remove 1	6083 Acer saccharum Sugar maple 7 Fair Exempt 6094 Judians norus Black walnut 8 Fair Remove 1	6423 Jugiters right Black walnut B Fair Remove 1 6424 Jugiters rives Black walnut 15 Cond Remove 2	6581 Juglans nigra Black welnut 10 Fair Save 6582 Populus homuloides Qualking Assen 7 Fair Save
6103 Pinus sylvestris Scots pine 8 Fair Remove 1 6104 Pinus sylvestris Scots pine 8 Fair Remove 1	COSS Aper secolatum Sugar maple 11 Fair Remove 1	5425 Tille americana Basswood 11 Good Remove 1	6583 Juglians nigra Black walnut 14 Fair Save
6105 Pinus sylvestris Scots pine 8 Fair Remove 1	6267 Poscus section Black therry 9,9 Fair Remove 3	6427 Populis deltoides Eastern autonwood 12 Good Remove 2	6585 Auginer rigra Black walnut 9 Pair Saw
6107 Pinus sylvestris Gools pine 11 Fair Remove 1	CDB Guarcus varutina Black oak 13 Fair Homove 2 CDB Populus deltoides Eastern cultonwood 17 Fair Remove 2	6428 Juglans nigra Black walnut 12 Fair Remove 2 6429 Cana confitomis Bittemut hickory 10 Fair Remove 1	6267 Aperiushum Red maple 30 Fair Save
6108 Pinus sylvestris Scots pine 14 Good Remove 2 6109 Pinus sylvestris Scots pine 10 Fair Remove 1	6270 Ulmus americana American elm 13 Fair Remove 2 6271 Tille americana Bassacod 9 Fair Remove 1	6430 Ultrus americana American elm 15 Fair Save 6431 Uniform nives Black united 12 Fair Save	6588 Ulmus americans American elim 10 Fair Save 6589 Populus deltoides Exetern cottonwood 17 Fair Save
6110 Pinus sylvestris Scots pine 10 Good Remove 1	6272 Tillia americana Basswood 9 Fair Remove 1	6432 Juglans rigna Black walnut 13 Fair Bave	6500 Juglans nigra Black welnut 19 Good Remove 2
6112 Pinus sylvestris Scots pine 11 Fair Remove 1	6274 Title americana Basswood 9 Fair Remove 1	6434 Juglans rigna Black watnut 9 Fair Save	6562 Jugians rigns Black walnut 14 Good Save
6113 Pinus sylvestris Scots pine 14 Good Remove 2 6114 Pinus sylvestris Scots pine 14 Fair Remove 2	6275 Title americana Basevood 11 Fair Remove 1 6276 Populos detroides Eastern cottonwood 17 Fair Remove 2	6634 Juglaine regra Black welvart 9 Fair Sove 6405 Juglaine regra Black welvart 10 Fair Sove 6408 Juglaine regra Black welvart 15 Fair Sove 6407 Tital americana Separacot 3 Fair Sove	6593 Acer saccharinum Silver maple 15 Very Peor Save 6594 Populus hympololes Qualding Arcen 11 Good Save
6115 Prantis servina Black theny 19 Good Remove 2 6116 Prantis selection Scott pine 15 Good Person 2	6277 Umus amenicana American elm 9 Fair Remove 1	6437 Tilia americana Basswood 13 Fair Save	6505 Popular Nerrulandas Qualitrig Aspen 12 Good Save
6117 Process services Black cherry 9 Feir Remove 1	6279 Aper-physics Red maple 12 Fair Remove 2	GSUB Julgates reput Stack seekest 15 Fair Stack	6597 Popular freculation Qualing Aspen 10 Good Remove 1
6118 Prius sylvestris Scots pine 10 Dead Exempt 6119 Prius sylvestris Scots pine 12 Good Remove 2	C200 Ulmus americane American elm 8 Fair Remove 1 C201 Ulmus americane American elm 8 Fair Remove 1	6440 Populus deltoides Eastern cottonwood 11 Fair Remove 1 6441 Quercus velutina Black calk 12 Fair Remove 2	6568 Populis frontionas Quaking Aspen 8 Good Remove 1 6569 Populis serctina Black chery 13 Good Remove 2
6120 Pinus sylvestris Scots pine 16 Good Remove 2 6121 Pinus sylvestris Scots pine 10 Good Remove 1	6092 Aper-subrum Red maple 12 Fair Remove 2 6090 Aper-subrum Red maple 10 Fair Remove 1	6442 Populus detoides Eastern cottonwood 8 Fair Remove 1 6440 Tills arrestings Resourced 8 Fair State	6600 Prorus sercina Black charry 7,11 Poor Remove 1
6122 Pinus sylvestris Scots pine 11 Good Remove 1	6094 Junipensi viginiane Eastern red cedar 10 Fair Remove 1	6444 Populos deltoides Eastern cottonwood 14 Fair Remove 2	6802 Malus purelia Common apple 7,9 Feir Remove 1
6124 Pinus sylvestris Scots pine 11 Good Remove 1	6288 Pinus sylvastris Scota pine 13 Fair Remove 2	648 Aper secchanism Silver maple 12 Fair Save	6000 Planus section Black chery 8 Pair Remove 1
6126 Priss sylvestris Soots pine 13 Good Remove 2 6126 Priss sylvestris Soots pine 9 Feir Remove 1	6287 Pinus sylvestris Scots pine 8 Fair Hemove 1 6288 Jupians rigna Black watnut 12 Fair Remove 2	6447 Aper sapphantsum Silver maple 11 Fair Save 6448 Title americana Bissavood 12 Fair Save	6605 Crategor spp. Hawthom spp. 8 Fair Remove 1 6606 Quercus rubra Red ook 15 Good Remove 2
6127 Pinus sylvestris Scots pine 10 Good Remove 1 6128 Pinus sylvestris Scots pine 13 Fair Remove 2	6299 Pinus sylvestris Scots pine 12 Fair Remove 2 6290 Pinus sylvestris Scots pine 15 Poor Remove 2	646 Jugians rigra Black walnut 18 Fair Save 6450 Guerra ratha Bat nak 15 Fair Ruse	6807 Province sections Black charry 13 Good Remove 2 6609 Divince section Black charry 13 Ear. Remove 2
6129 Pinus sylvestris Scots pine 11 Good Remove 1	6291 Acer obnum Red maple 9 Fair Remove 1 6292 Minus americana American alm 11 Fair Ruse	6451 Tile americana Bassavod 12 Fair Save	6009 Carya condiformia Bilthernat hickory 12 Good Remove 2
6131 Pinus sylvestris Scots pine 8 Poor Remove 1	6293 Pinus sylvestris Soots pine 19 Fair Remove 2	6453 Carga cordifornis Bitterrut hickory 10,11 Fair Save	6611 Procus sercina Black chery 10 Poor Remove 1
	6296 Ulmus americana American elm 8 Fair Save	6454 Quarcus rubna Red oak 22 Fair Save 6455 Populos delfoides Eastern cottonwood 11 Fair Remove 1	6812 Ulrous americans American elim 8 Fair Remove 1 6613 Cana conflormis Bitterrut hickory 14 Good Remove 2
6134 Pinsa sylvestria Scota pine 13 Fair Remove 2 6135 Acer saccharinam Silver maple 17 Good Remove 2	6287 Ulmus americana American elm 11 Pair Save 6287 Ulmus americana American elm 9 Fair Save	6405 Populus détroides Eastern cottonword 11 Fair Remove 1 6498 Querous nuture Red calk 16 Fair Remove 2 6407 Tillo annotation Bassancod 9 Fair Remove 1	6814 Tita americana Basswood 17 Good Remove 2 6815 Tita americana Resowand 16 Good Remove 2
6136 Phus sylvestris Scots pine 10 Good Remove 1	6098 Populos deltadas Eastern cottonwood 22 Fair Save 6099 April subnum Red matrie 19 Fair Save	6458 Querous rubra Redicals 9,11 Fair Remove 3 6459 Querous abra White calc 9 Fair Perrous 4	6616 Prome serctina Black cherry B Pair Remove
100 100	6300 Popular fremulation Qualiting septin 8,15 Fair Save 6201 Popular fremulation Qualiting septin 11 Fair Save		6610 Pronus serctina Black cherry 13 Good Remove 2
6140 Acervaturo Red maple 10 Fair Remove 1	6302 Promos serctine Black cherry 12 Feir Sees	6462 Aper seccharum Suger miprie 14 Feir Sewe	6619 Priss sylvestris Scots pine 8 Pair Remove 1 6620 Acer saccharinon Silver maple 5,13 Good Remove 2
6141 Pinus sylvestris Soots pine 8 Fair Remove 1 6142 Pinus sylvestris Soots pine 10 Fair Remove 1	6303 Umus amendana Amendan em 10 Fair Remove 1 6304 Azur subsure Red maple 30 Fair Remove 4	6463 Quercus rubra Redicak 11 Fair Save 6464 Quercus rubra Redicak 10 Fair Save	6621 Pinus sylvestris Scots pine 8 Pair Remove 1 6622 Cana confidence Rithment Indiana 10 Canal Remove 1
6143 Aperiushum Redimple 8 Fair Remove 1	6305 Frankus pernsylvanica Green ash 10 Fair Remove 1 6308 Prassus sentitiva Black chemy 8 Fair Save	Motion M	6023 Populus del'oides Eastern cottonwood 15 Good Remove 2
6145 Pinus sylvestris Soots pine 10 Fair Remove 1	6307 Ulmus americana American elm 10 Fair Save	6467 Quercus rubra Redioak 24 Fair Remove 3	6625 Populos frencicios Qualing Aspen 11 Good Save
6146 Ultrus americana American elm 12 Feir Remove 2 6147 Pinus sylvestris Soots pine 10 Feir Remove 1	6309 Frankous permoylvanica Green ash 8 Fair Remove 1	6469 Querous rubria Red oak 9 Fair Remove 1	6036 Populis herculoides Quaking Aspen 9 Dead Save 6627 Populis herculoides Quaking Aspen 8 Good Remove 1
1014 Philos pyreants	6310 Populus deltoides Eisstem cottonwood 11 Pair Remove 1 6311 Juglans nigra Black walnut 14 Fair Remove 2	6470 Quercus alba White calk 13,13 Fair Remove 4 6471 Ulrus americana American elm 15 Fair Remove 2	6628 Popular hamulaides Qualiting Aspen 7 Good Exempt
6100 Amperus virginiano Eastern red cedar 8 Fair Remove 1	6312 Ultrus americana American elm 13 Fair Remove 2 6313 Junites cinna Black velout 17 Fair Remove 2	6472 Querous abus White oak 13 Feir Remove 2 6473 Querous abus White oak 16 Feir Remove 2	6630 Tile emericana Basswood 10,11,12 Fair Save
6101 Priss sylvestris Soots pine 8 Fair Remove 1 6152 Priss sylvestris Soots pine 9 Fair Remove 1	6314 Quercus alba White oak 8 Fair Remove 1	6611 United amenisation	6631 Quercus rubre Red oak 14 Pair Save 6632 Quercus velutina Black oak 21 Fair Save
6163 Pinus sylvestris Soots pine 7 Fair Exempt 6154 Prunus syrofina Black charry 12 Fair Ramove 2	6316 Aperiustrum Red maple 8 Fair Remove 1	6476 Quercus alba White oak 7 Fair Save	6633 Jugians nigra Black wainut B Pair Save 6634 Juniora nigra Black wainut 24 Fair Save
100	100 Private private 100 Privat	6470 Ouerous abus White oak 7 Fair Siee 6477 Ouerous ndrain Red oak 13 Poor Remove 2 6479 Ouerous ndrain Red oak 8 Fair Remove 1 6479 Ouerous ndrain Red oak 8 Fair Remove 1	Column
6157 Pinus sylvestris Soots pine 9 Fair Remove 1	6019 Tilla americana Basswood 12 Fair Remove 2 6000 Tilla americana Basswood 15 Fair Remove 2	6479 Querous rudra Redicals 10 Fair Save 6490 Arm supplements 9.15 Fair Save	8637 Popular delicides Eastern cottonwood 6 Fair Save
6159 Acer subrure Red maple 8 Fair Remove 1	6321 Ulmus pumila Siberian elm 11 Fair Remove 1		6638 Populus delfoldes Eastern cottonwood 16 Fair Save 6639 Populus delfoldes Eastern cottonwood 13 Fair Save
6160 Pinus sylvestris Scots pine 15 Fair Remove 2 6161 Pinus atrobus Eastern white pine 13 Good Remove 2	6323 Title americana Basswood 10 Fair Remove 1	two.c Lovercos vestina Black cak 12 Fair Remove 2 6483 Quercos vestina Black cak 15 Fair Remove 2	6640 Populos delfoides Eastern cottonwood 0 Fair Save
6162 Pranus sercina Black cherry 10,13,13 Fair Remove 5	6324 Title americana Basswood 15 Fair Remove 2 6325 Title americana Basswood 11 Fair Remove 1	6494 Quercus rubra Red oak 15 Fair Remove 2 6495 Quercus velutina Black cak 13 Fair Remove 2	6642 Juglans nigra Black wainut 29 Good Save
6164 Pinus sylvestris Scots pine 9 Fair Remove 1	6006 Procus percins Black cherry 10 Fair Remove 1 6007 Tills anyelingan Resounced 8 Fair Percent	5690 Cultural natural Fleet ass 10 Fleet Restronce 1	6643 Jugishii nigrii Black walnut 9 Good Sawe 6644 Jugisho nigrii Black walnut 10 Good Remove 1
6165 Acer subsure Red maple 12 Fair Remove 2 6168 Pinus sylvestris Scots pine 13 Fair Remove 2	6328 Jugilana nigra Black walnut 18 Fair Remove 2	6488 Quercus velulina Black celc 15,28 Feir Sawe	6545 Jupines rigns Black welnut 9 Fair Remove 1 6846 Jupines rigns Black welnut 13 Good Saw
6169 Pinus sylvestris Souts pine 15 Fair Remove 2	escar i na americana Basswood 12 Fair Remove 2 6300 Tilla americana Basswood 12 Fair Remove 2	6400 Quercus velutres Black celc 8 Feir Remove 1 6400 Tilly emericana Basswood 9 Feir Remove 1	6647 Juglans nigra Black walnut 8 Very Poor Exempt
6171 Phos sylvestris Soots pine 15 Fair Remove 2	6331 Title americana Basswood 8 Fair Remove 1 6332 Title americana Basswood 10 Fair Remove 1	6491 Querous velutina Black colc 13 Fair Remove 2 5492 Querous rubre Red calk 15 Fair Remove 2	соно зираля луги Black wainst 9 Good Memowi 1 6649 Jugiano nigra Black wainst 9 Fair Remove 1
6172 Acer subsum Red maple 14 Fair Remove 2 6173 Acer seccharum Sugar maple 13 Good Remove 2	6333 Tilia americana Basswood 9 Fair Remove	6403 Quercus rubra Red calk 3 Fair Remove 1	6650 Quercus rubra Redicali 8 Fair Remove 1 6651 Quoling ritina Black walnut 9 Good Remove 1
6174 Aper secolarum Sugar maple 8 Good Remove 1	6335 Querous alba White oak 10 Fair Remove 1	6496 Tillia americana Basswood 10 Fair Remove 1	6652 Juglans rigra Black walnut 9 Fair Remove 1
6176 Pinus sylvestris Soets pine 14 Good Remove 2	6337 Procus section Black cherry 12 Fair Remove 1	6495 Jugisne nigna Black welnut 21 Fair Remove 3 6497 Ulmus amaricana American elm 8 Fair Remove 1	6654 Acer sacchanium Silver maple 12,33 Fair Save
0177 Prince syrvestris Scots pine 10 Good Remove 1 6178 Prince sylvestris Scots pine 10 Good Remove 1	COS Title americana Basswood 15 Fair Remove 2 6009 Title americana Rasswood 12 Fair Remove 2	5490 Title americana Basswood 14,14 Fair Remove 4	6605 Jugistre nigra Black walnut 9 Fair Save 6696 Jugistre nigra Black walnut 10 Fair Save
6179 Pinus sylvestris Scots pine 8 Good Remove 1 6190 Pinus sylvestris Scots pine 13 Good Remove 2	CHO Tile americana Basswood 11 Fair Remove 1	5000 Table annexional Bassancott 14,14 Fair Bernove 4	6667 Juglans nigra Black walnut 11 Good Remove 1
6181 Pinus sylvestris Soots pine 13 Fair Remove 2	6341 Titu americana Basswood 11 Fair Remove 1 6342 Titu americana Basswood 12 Fair Remove 2	6601 Propulos deltraides Eastern cottonwood 9 Poor Exempt 6502 Cargo conditionals Bildemut hickory 19 Fair Remove 2	6669 Tilla americana Basswood 13 Good Remove 2
one, inner 5 Gods pine 8 Paor Remove 1 6183 Pinus strolus Eastern white pine 19 Excellent Remove 2	6943 Populos fremuloides Quaking Aspen 12 Fair Remove 2 6944 Tilly americana Bassaccod 16 Fair Remove 2	6503 Tillia americana Basswood 15 Good Remove 2	6600 Jugions rigna Black walnut 16 Fair Remove 2 6661 Tika americana Basswood 13 Good Remove 2
6194 Phos sylvestris Soots pine 12 Fair Remove 2 6195 Phos sylvestris Soots pine 9 Good Remove 1	Comparison	Column	6602 Title emericana Basswood 10 Good Remove 1
1	Product Prod	Column	Company
6188 Phus sylveshis Soots pine 8 Fair Remove 1	6340 Procus section Black cherry 12 Fair Remove 2	6500 Guerous rubre Red ask 20 Fair Remove 2	occo insiamencami Basswood 16 Good Remow 2 6666 Ostrja viginiana Hophombean 13 Good Remow 2
ones increase Eastern white pine 5 Good Remove 1			6667 Carya conditornis Bitterrut hickory 16,17 Good Remove 4





Sea



Title:

Tree List

Project:

The Grove Novi, Michigan

Prepared for:

Ivanhoe Companies 6689 Orchard Lake Road, Suite 314 West Bloomfield, Michigan 48322 248.626.6114

Revision:	Issued:
Review	March 28, 2024
Revised	July 26, 2024
PRO Submission	July 9, 2025
Revised PRO Submission	September 12, 2025

Job Number:

21-054

Drawn By: Checked By:



Sheet No.

						Required	Multi-Stem Replacement	Credits	_						Required Replacement	Multi-Stem Replacement	
Tag	Selentific Name Juppins right Carps conditions Tills american Carps conditions Tills american	Black walrut	19	Fair	Remove	Repiscement 2	Reprocement	Credits	Tag 6627	Jugans rigra	Disck weinst	10	Fair	on Status Remove	Repiscement	Reprocement	Credits
6669 6670	Carya cordiformis Tilia americana	Bitternut hickory Basswood	10	Good Good	Remove	2			6828 6829	Angeler angeles See empediation Access angeles Access angeles Access angeles Access angeles Access angeles Access angeles Access	Black walnut Peachlest willow	14 18 14 22 15 10 15 10 15 25 23 29 23 3 29 20 13	Good	Remove	2 2		
6671	Cerya considernia Tilia americana	Basewood Bitternut hickory Basewood	18 20 11 9	Good Good Good Good	Remove Remove Remove Remove	2 1			SCHOOL	Selly metaudase Aper secobasisum	Colosions will will be a continued to the continued to the colosion of the col	14	Fair Good Good Fair Good Fair Very Po Fair Fair Fair	Source Sou			
6672 6673 6674	Tille americana (unines pioce	Basswood Basswood Black walnut	9	Good	Remove	1			6802	Populus delfoides	Eastern cottonwood	15	Good	Save			
6675	Jugians nigra	Black walnut	7		Exempt				6834	Aper secoharitum	Silver maple	15	Good	Save			
6676 6676 6677 6678 6879	Tita americana Tita americana	Black walnut Basswood Basswood Basswood Basswood	111 9 144 18 115 144 15 15 15 15 15 15 15 15 15 15 15 15 15	Good Good Excellent Excellent Fair Good	Exercity	1			6636	Aper seconarisum	Silver maple	10	Very Po	or Save			
6678 6879	Tika americana Tika americana	Basswood Basswood	14	Excellent Excellent	Remove	2 2			6837 6838	Aper seccharitum Aper seccharitum	Silver maple Silver maple	15	Fair	Save			
6680	Title americana Cana confitemis	Basiswood Basiswan tidooy Basiswan tidooy Silver majde Black walnut Bilack walnut Black walnut B	11	Fair Good	Remove	1 2			6839	Aper succharitum	Silver maple Silver monte	25 23	Fair	Save			
6681 6682 6683 6684 6685 6686 6687 6288 6689 6280 6681	This amendment of the control of the	Silver maple	13	Good Fair Good Good Fair Fair Fair Fair Fair Good Good Good Fair Good Good Good Excellent Good Good Excellent Good Good Fair Good Good Fair Good Good Fair Good Good Fair Good Good Fair Good Good Good Good Fair Good Good Good Good Good Good Good Goo	Remove	2			6841	Aper secoharitum	Silver maple	29	Good Good Fair Fair Fair	Save			
6684	Jugians nigra	Black walnut	8	Good	Remove	1			6843	Aper seconarisum	Silver maple	9	Fair	Save			
6685 6886	Carya cordiformis Juglans nigra	Bitternut hickory Black walnut	10	Good Fair	Remove	1			6844 6845	Aper seccharitum Aper seccharitum	Silver maple Silver maple	20	Fair	Save			
6667 6668	Jugians nigra Jugians nigra	Black walnut Black walnut	9 8	Fair	Remove	1			6847	Aper secoharitum Aper secoharitum	Silver maple Silver maple	13 8.13	Good	Save Save			
6689	Jugians nigra	Black walnut	14	Very Poor	Exempt				5040	Aper rubrum	Red maple	8,13 25 19 7	Good Fair Fair Fair Fair	Save			
6691 6662	Jugians nigra	Black walnut	16	Fair	Remove	2			6860	Aper seccharinum	Silver maple	7	Fair	Save			
6693	Jugians nigra	Bitternat hickory Black wahnut	12	Fair	Remove	2			6852	Juglana nigra Carya cordifornis	Black watnut Bitternut hickory	21 9 225 8 23 10 18 16 22 19 18 14 17 12 16 10 15 11 12 27 8 8 10 10 10 11 10 10 10 10 10 10 10 10 10	Good	Save			
6603 6604 6606 6606 6607 6608 6700 6701 6702	Jugians nigra Jugians nigra	Black walnut Black walnut	19	Good	Remove	2 2			6853	Juglans nigra	Black websit	22	Good Fair Fair Good Fair Fair Fair	Save			
6696 6697	Juglans nigra	Black walnut Black walnut	16	Good	Remove	2 2			6655	Saliv arrygdaloides	Peachleaf willow	8	Good	Save			
6698	Jugians nigra	Black walnut	12	Fair	Remove	2			6657	Ulmus americana	American elm	10	Fair	Save			
6700	Jugians nigra	Black walnut	12	Good	Remove	2			6859	Poblinia pasudoacacia Juglans nigra	Black locust Black walnut	18	Fair	Save			
6702	Jugians nigra Tilia americana	Black walnut Basswood	16	Excellent	Remove	2			6861	Robinia pseudoacacia Ulmus americana	Stack locust American elm	22 19	Fair Pair Fair Fair Fair Fair Fair Fair Fair F	Save Save			
6703	Jugians nigra	Black walnut Black walnut	11	Good	Remove	1			6862	Robinia pseudoacacia	Black locust	18	Fair	Save			
6704 6705 6706 6707 6708	Jugians nigra	Black walnut	10	Good	Remove	1			6864	Quercus velutina	Black oak	17	Fair	Save			
6707	Jugians nigra	Black walnut	9	Good	Remove	1			6866	Prunus serotina	Red maple Black cherry	12	Very Po	or Save			
6709	Jugians nigra Jugians nigra	Black welnut	8	Good Good Good Good Good Fair	Remove	1			6868	Carya cordiformis Quarcus alba	The analysis of the second of	15	Good	Solve Solve			
6709 6710 6711 6712 6713	Jugiana nigra Jugiana nigra	Black walnut Black walnut	9	Good Good Fair Fair	Remove	1			6869	Aper secoharitum	Silver mople Silver monte	31	Good	Save			
6712	Jugiana nigra	Black walnut Black walnut	9	Good	Remove	1			6871	Acer secoharisum	Silver maple	27	Poor	Save			
6714	Jugians nigra	Black walnut	10	Fair	Remove	1			6873	Aper succharitum	Silver maple	8	Fair	Save			
6715 6716	Jugians nigra	Easton Cottlewood Black works. The State work of	9	Good Fair Fair Fair Good Good Fair Fair Good Poor	Remove	1			6875	Aper secoharitum Aper secoharitum	Silver maple Silver maple	10 22	Fair	Save			
6717	Juglans nigra Juglans nigra	Black walnut Black walnut	11	Fair	Remove	1			6876	Aper secoharitum	Silver maple	11	Fair	Save			
6719	Jugiana nigra	Black walnut	9	Fair	Remove	1			6878	Aper secoharisum	Silver maple	17	Fair Fair Poor Fair Fair Fair Fair Fair Fair Good Fair Fair	Save			
6721	Jugiana nigra	Black walnut	10 8 8 11 14 10 16	Good	Remove	-			6880	Aper seccharitum Aper seccharitum	Silver maple Silver maple	29,25	Poor	Save			
6722 6723	Jugians nigra Jugians nigra	Black walnut Black walnut	11	Fair Fair	Remove	1			6882	Aper secoharitum	Silver mople Silver monte	19	Fair Fair	Save			
6724	Jugians nigra	Black weinut	14	Good	Remove	2			6883	Aper secoharitum	Silver maple	15	Fair	Save			
6726	Jugians nigra	Black walnut	16	Good	Remove	2			6885	Aper seccharitum	Silver maple Silver maple	12	Good	Save			
6728	Populus hierufoldes	Quaking aspen	10,13	Fair	Save		4		6886 6887	Aper seccharitum Aper seccharitum	Silver maple Silver maple	12	Fair	Save Save			
6712 6720 6721 6722 6724 6726 6726 6726 6726 6726 6731 6731 6732 6736 6736 6736	Jugann right and Jugann	Bitternut hickory Bitternut hickory	13,13 10 12 15,17 31 13 13 11 9 10 9 11 11 11 11 12 9	Good Fair Fair Fair Fair Fair Fair Good Good Good Good Good Good	Remove Save Save Save Save				6000	Ulmus americana	American elm	22 11 20 17 29,35 14 19 15 15 15 15 12 22 12 14 12 18 15 19 11 19 10 10 10 10 10 10 10 10 10 10 10 10 10	Fair Fair Fair Fair Fair Fair Fair Fair	Save Sa			
6731	Quercus rubre	Red oak	31	Fair	Save	-			6890	Aper seconarism	Silver maple	18	Fair	Save			
6733	Tilia americana	Basswood	13	Fair	Remove Remove Save Remove Remove	2 2			6891 6892	Aper seccharitum Aper seccharitum	Silver maple Silver maple	15 19	Fair	Save			
6734 6735	Coercus robre Ulmus americane	Red oak American eim	9	Fair	Remove	1			6894	Aper saccharitum	Silver mople Silver monle	15	Fair Fair	Save			
6736	Jugians nigra	Black walnut	10	Good		1			6895	Aper secoharitum	Silver maple	13	Fair	Save			
6738 6739 6740 6741 6742	Jugians nigra	Black walnut	11	Good	Remove Remove Remove Remove Remove Save	1			6897	Aper seconamium Aper seconamium	Silver maple Silver maple	13	Good	Save			
6740	Jugians nigra Jugians nigra	Black walnut	11	Good	Remove	1			6898	Aper succharitum	Silver maple Silver maple	13	Fair Good	Save			
6741	Juglans nigra Juglans nigra	Black walnut Black walnut	12	Good	Remove	1 2			6500	Aper saccharitum	Silver maple	23	Poor	Save			
6743	Jugiana nigra	Black walnut	9	Fair Fair	Save				6902	Aper seconstrum	Silver maple	33	Good	Save			
6745	Jugians nigra	Black walnut	8	Good	Save				6903 6904	Acer seccharitum Ulmus americana	Silver maple American elm	11	Poor Fair Good Good Poor Fair	Save Save			
6746 6747	Jugians nigra Jugians nigra	Black walnut Black walnut	8	Poor	Remove	1			6905	Aper succharitum	Silver maple	24	Fair	Save			
6743 6744 6745 6746 6746 6747 6748	Juglans nigra	Black walnut	12	Fair	Exempt Save Remo	2			6907	Aper saccharitum	Silver maple	16,21 12 13 13 13 13 8 9 23 23 24 22 25 15 15 15 15 15 15 15 15 17 18 18 19 21 11 11 11 11 11 11 12 13 13 14 15 15 16 17 17 18 18 18 18 18 18 18 18 18 18 18 18 18	Fair Poor Good Fair Good	Save			
6750 6751 6752	Littus attericans	American elm	9	Fair	Remove	1			6909	Aper seconarium Aper seconarium	Silver maple Silver maple	15	Fair	Save			
6752 6753	Litrus americans	American elm	8	Fair	Remove	-			6910 6911	Aper seccharitum Aper seccharitum	Silver maple Silver maple	21	Good	Save Save			
6753 6754	Jugians nigra Jugians nigra	Black walnut Black walnut	21 12 13 21 12 9	Fair	Remove	3 2			6912	Aper succharitum	Silver maple	18	Good Good Fair Good Poor	Save			
6754 6755 6756 6757 6758 6759	Jugians nigra	Black walnut	13	Fair	Remove	2			6914	Aper secoharitum	Silver maple	17	Good	Save			
6757	Jugians nigra	Black walnut	12	Fair	Remove	2			6915 6916	Aper seccharitum Aper seccharitum	Silver maple Silver maple	18 15	Poor Fair Fair	Save Save			
6759	Jugians nigra	Black walnut		Fair	Remove	1			6917 6918	Aper seccharitum	Silver maple Silver maple	19	Fair	Save Save			
6760 6761	Populius deltoides Judians nicre	Eastern cottonwood Black walnut	12	Fair Fair	Remove	2 2			6919	Aper saccharitum	Silver maple	11,17	Fair Fair Fair Fair Fair	Save			
6762 6763 6764 6765	Ulmus americana	American elm	14	Fair	Remove	2 2			6921	Aper secoharitum	Silver maple	23	Fair	Save			
6764	Jugians nigra	Black walnut	11	Poor	Remove	1			6623	Aper seconarium Aper seconarium	Silver maple Silver maple	28	Fair	Save			
6766	Jugians nigra Jugians nigra	Black walnut	10	Fair	Remove	1			6624	Aper secoharisum	Silver maple Silver maple	8 34 42 36 9	Fair Fair Fair	Save			
6766 6767 6768 6769 6770	Juglans nigra Juglans nigra	Black walnut Black walnut	11	Fair	Remove	1			6926	Aper saccharitum	Silver maple	42	Fair	Save			
6769 6770	Juglans nigra Providus deltridas	Black walnut Fastern cottonwood	8	Fair Fair	Remove	1			6525	Ostya kiginiasa	Hop-hombeam	9	Good	Save			
6771	Populus deltoides	Eastern cottonwood	8	Fair	Remove	1			6930	Prunus serotina	Silver maple Silver maple Silver maple Silver maple Silver maple Silver maple Hop-hombeam Hop-hombeam Hop-hombeam Black cherry Hop-hombeam Sittemut hickory Hop-hombeam Silver maple	9 10 13 18	Good Fair Good Good Fair Fair	Save Save Save Save Save Save Save Save			
6773	Populus deltoides	Eastern cottonwood	9	Fair	Remove	1			6632	Canya sirginiana Canya cordiformia	Hop-hombeum Bitterrut hickory	13 18	Good	Save Save			
6775	Populus deltoides Populus deltoides	Eastern cottonwood Eastern cottonwood	10	Fair	Remove	1			6503	Ostya signiara	Hop-hombeum Films month	9	Fair	Save			
6776	Ultrus americans Ponulus detoides	American elm Fastem cottonwood	10	Fair	Remove	1			6905	Aper saccharitum	Silver maple	9	Fair	Save			
6772 6773 6774 6775 6776 6777 6778 6779 6780 6781	Judgers riggs of the Control of the	American et m. Service de la constitución de la con	9 12 14 14 15 11 12 20 10 10 10 10 10 10 10 10 10 10 10 10 10		Remove Remove Remove Remove Remove Remove Remove Remove Remove Remove Remove Remove Remove Remove Remove	1			6020 6020 6020 6020 6020 6020 6020 6020	Ace el economiento de la composición del la composición de la composición del la compos	Solve migde	9 10 9 16 15 7,15 19 10 10	Fair Fair Fair Fair Good Fair Fair Good Fair Fair Fair Fair Fair Fair Fair Fair	Sixue			
6780	Jugians nigra	Black wainst	22	Fair	Remove	i			6639	Aper secoharisum Aper secoharisum	Silver maple Silver maple	16 15	Fair Good	Save Save			
6781 6782	Jugians nigra	Black walnut	10	Fair	Remove	2 2			6940 6941	Aper secoharitum Aper secoharitum	Silver maple Silver maple	7,15	Fair Fair	Save			
6783 6784	Quercus velutina Quercus velutina	Black oak Black oak	20 10	Fair Fair	Remove Re	2			6942	Aper secoharitum	Silver maple	15	Good	Save			
6784 6785 6786 6787	Juglans nigra Juglans nigra	Black walnut Black walnut	17	Fair Fair	Remove	2			6944	Acer secoharitum	Silver maple	10	Fair	Save			
6787	Popular defodes	Eastern cottonwood	10	Fair	Remove	1			6946 6946	Aper secoharisum Aper secoharisum	Silver maple Silver maple	25 11,18,5 10 10 7,12 14 20 9 14 9 10 20 12 17 24 17 24 17 21 21 19	Fair 8 Fair	Save			
6788 6789 6790 6791 6792	Ulmus americana	American elm	10	Fair	Remove	1			5047 5949	Aper saccharitum	Silver maple Silver maple	10	Poor Good Good Good Fair Fair	Save			
6790 6791	Jugians nigra Jugians nigra	Black walnut Black walnut	20 10	Fair Fair	Remove	2 1			6949	Aper secoharitum	Silver maple	7,12	Good	Save			
6792 6793	Jugians nigra	Black weinut	14	Fair	Remove	2			6951	Juglans rigna Aper saccharinum	Silver maple	20	Fair	Save			
6794	Jugians nigra	Black walnut	9	Fair	Remove	1			6962	Aper succharitum	Silver maple Silver monle	9	Fair	Save			
6796	Jugians nigra	Black walnut	10	Fair	Remove	1			6064	Aper saccharitum	Silver maple	9	Good Good Fair Good	Save			
6797 6798	Juglans nigra Juglans nigra	Black walnut Black walnut	8	Fair	Remove	1			6956	Aper secoharitum	Silver maple	20	Good	Save			
6794 6795 6796 6797 6798 6799 6801 6801 6802 6803	Jugians nigra	Slack walnut Black walnut	9	Fair	Remove	1 2			6958	Aper secoharisum	American em Silver maple	17	Good	Save			
6801	Jugians nigra	Black walnut	8	Pair Fair Fair Fair Fair Fair Fair Good Good Good Good Good Good Good Goo	Remove	1			6969	Aper suppharitum Aper suppharitum	Silver maple Silver maple	24 17	Fair Fair Good Good	Save			
6803	Populus deltoides Juglans nigra	Black walnut	10 13 13	Fair	Remove	2			6961	Aper saccharitum	Silver mople	21	Good	Save			
5804 6805	Juglans nigra Juglans nigra	Black walnut Black walnut	13	Fair Fair	Remove	2 1			6963	Acer secoharisum	Silver maple	19	Fair 5 Fair	Save			
6805 6806 6807 6808 6809	Jugians nigra	Black walnut Black walnut	9 10 8	Fair Fair	Remove Remove Remove Remove Remove	1			6965	Acer seccharisum Acer seccharisum	oriver maple Silver maple	19 9,14,1 20 9 10,17 9,22 11 10	Good	Save Save			
6608	Jugians nigra	Black walnut	9	Good	Remove	1			6967	Aper saccharitum Aper saccharitum	Silver maple Silver maple	10,17	Good Poor Fair Fair Fair Fair	Save			
6809 6810	Jugians nigra Jugians nigra	Black walnut Black walnut	10	Par Good	Remove	1			6968	Aper saccharitum	Silver maple	9,22	Fair	Save			
6810 6811 6812 6813 6814 6815	Jugians nigra Jugians nigra	Black walnut Black walnut	10 10 13 10 9 18 8	Good	Remove Remove Save Remove Remove Remove	1			6970	Ulmus americana	American elm	10	Fair	Save			
6813	Jugiana nigra	Black walnut Black walnut	10	Good	Remove	1			6972	Salix amygdaloides	American elm Peachleaf willow		Good	Save Save Save Save Save			
5815	Jugians nigra	Black walnut Black walnut	18	Good	Remove	2			6973 6974	Populus deltroides Salix annyoda/oides	Eastern cottonwood Peachleaf willow	13	Good	Save			
6816 6817	Jugians rigna Jugians rigna	Black walnut	8	Good Fair	Remove	1			6975	Jugians nigra	Black welnut	19	Good	Save			
6818 6819	Juglans nigra Juglans nigra	Black walnut Black walnut	9	Good	Remove	1			6976 6977 6978 6979	Aper secoharitum	Silver maple	10 13 8 19 23 18 13 34	Fair Good Good Fair Good Fair Fair Good	Save Save Save			
6816 6817 6818 6819 6820 6821	Ulmus americana	American elm	8	Good Good Good Good	Remove	1			6978 6979	Carya condiformia Juglans nigra	Black welnut Armedican eim Armedican eim Peachlest willow Black welnut Black welnut Black welnut Black welnut Black welnut Black welnut Black welnut Black welnut	13 34	Fair Good				
6802	Jugiana nigra	Black walnut	16	Good	Remove	2					Health Ratings, 9th Ed		T	otal Regulated Trees	2783	399	
6802 6803 6804 6805 6805	Jugians nigra Jugians nigra Jugians nigra Umus americana Jugians nigra Jugians nigra Jugians nigra Pipulus deltridas Pinus sylvestris Jugians nigra	Black wahrut Black wahrut	11 16 13 38 9	Good Good Good Poor Good	Remove Remove Remove Remove Remove Remove Remove Remove Remove Remove Remove	4				. ,	and the second s		10	otal Multi-Stem Trees Credits		-24	35
6825 6826	Fraus sylvestris Jugians nigra	Scots pine Black walnut	9	Poor Good	Remove	1											

Status Key

Tree will be saved Tree is located outside of a woodland area and will be saved. Grading Occurs within the Critical Root Zone. Tree Will Remain but Counted as Removed. Trees to be Removed for Potential Wetland Mitigation Tree is located in a regulated woodland and will be removed.

Tree is dead or located outside of a woodland area.


Woodland Summary

Total Trees
Less Non - Regulated Trees:
Non-Regulated Trees
Net Regulated Trees
Regulated Trees Removed 82 Trees 2,775 Regulated Trees 2,019 Trees

| Replacement Required | Trees 8"- 11" | 1,126 Trees | 1"- 20" | 1715 trees x 2= | 1,430 Trees | 17- 20" | 59 trees x 2= | 177 Frees 30" | 41 trees x 4= | 177 Frees 30" | 41 trees x 4= | 177 Frees 30" | 41 trees x 4= | 177 Frees 30" | 41 trees x 4= | 177 Frees 30" | 50 Frees | 389 Frees | 177 Frees 30" | 177 | 177 Free

Tree Fence Installation and Removal \$67,140 (11,190 l.f. x \$6 l.f.)

Tree Protection Fencing



- I differ Person Vision Change Seven Seven Spill Selb I headed on Departs Selb Ingline. Unless Manufacture of Experts Selb Ingline Selb







Title:

Tree List

Project:

The Grove Novi, Michigan

Prepared for:

Ivanhoe Companies 6689 Orchard Lake Road, Suite 314 West Bloomfield, Michigan 48322 248.626.6114

Revision:	Issued:				
Review	March 28, 2024				
Revised	July 26, 2024				
PRO Submission	Junly 9, 2025				
Revised PRO Submission	September 12, 2025				

Job Number:

21-054


Drawn By: Checked By:




Sheet No.


L-20

© 2025 Allen Design L.L.C.












REAR ELEVATION MATERIAL QUANTITY:
BRICK VENERS = 675 50.FT, = 56%
COMPOSITE SIDING / MOOD TRIM = 1835 50.FT, = 44%





-ALL RENDERING AND ELEVATIONS ARE ARTISTIC IN NATURE AND SUBLECT TO CHANCE. REPER TO CIVIL AND LANDSCAPE PLANS FOR BUILDING LATOUT. MATERIAL COLORS ARE REPRESENTATIONAL OF MANUFACTURED PRODUCT.

BUILDING CONFIGURATIONS MAY WARY BETWEEN 3,45,46 UNIT BUILDINGS

4-PLEX RIGHT ELEVATION

RIGHT ELEVATION MATERIAL QUANTITY: BRICK / STONE VENER: = 44T SQFT; = 618 COMPOSITE SIDNE / HOOD TRIM = 7TI SQFT; = 34%




LEFT ELEVATION MATERIAL QUANTITY: BRICK / STONE YENER: 4 4TI SQFT. + 61% COMPOSITE SIDNIS / WOOD TRIM + TIT SQFT. + 34%





Ivanhoe Companies The Grove - Novi, Michigan Village #2 - The Meadows

Drwn: B.H. Chkd: J.R.							
08/22/25 Permit Set:	NOT FOR CONSTRUCTION						
Review Set: 08/22/25	Final Set:	Revisions:					
22072							

A2 of 2








4-PLEX RIGHT ELEVATION

RIGHT ELEVATION MATERIAL QUANTITY: BRICK / STONE VENER = 625 SQFT; = 536 COMPOSITE SIDNS / MODD TRIM = 562 SQFT; = 476



Review Sec. 07/15/75
Final Sec. NOT POR CONSTR
Revisione: 08/22/25 Added Biol


Drwn: C.M. | Chkd:


Ivanhoe Companies The Grove - Novi, Michigan Village #3 - The Woods

23073


A3 of 3

© Copyright 2004 TR-Dusign Group,










REAR ELEVATION MATERIAL QUANTITY: BRICK VENEER = 881 50,FT. = 18% COMPOSITE SIDING / WOOD TRIM = 244 50,FT. = 22%








4-PLEX FRONT ELEVATION

FRONT ELEVATION MATERIAL QUANTITY: BRICK / STONE VENEER = III4 SQ.FT. = 74% COMPOSITE SIDING / WOOD TRIM = 384 SQ.FT. = 26%



Drwn: S.C. | Chkd:

23073

A3 of 3



RIGHT ELEVATION MATERIAL QUANTITY: BRICK / STONE YENEER = TOI SQ.FT. = 46% COMPOSITE SIDING / WOOD TRIM = TSI SQ.FT. = 52%




LEFT ELEVATION MATERIAL QUANTITY: BRICK / STONE VENEER = 100 SQ.FT. = 47% COMPOSITE SIDING / WOOD TRIM = 181 SQ.FT. = 53%

METAL ACCENT ROOF
ASTHALT SERVICES

COMPOSITE VERTICAL SIDNA
BNICK

CYTERINA KASTING

CLUBHOUSE ELEVATION - OPT. I



CLUBHOUSE FLOOR PLAN - OPT. I

SQUARE FOOTAGE 4025 SQUARE FEET




23073 ph Number

C2 of 3



CLUBHOUSE ELEVATION - OPT. 2




CLUBHOUSE FLOOR PLAN - OPT. 2

<u> </u>	<u> </u>
	SQUARE FOOTAGE 1/- 1,930 SQUARE FEET

Drwn: C.M. | Chkd:



CLUBHOUSE ELEVATION - OPT. 3




CLUBHOUSE FLOOR PLAN - OPT. 3






CLUBHOUSE ELEVATION - OPT. 4



CLUBHOUSE FLOOR PLAN - OPT. 4

SQUARE FOOTAGE 1/- 620 SQUARE FEET





6689 Orchard Lake Rd. - #314 West Bloomfield, MI 48323 248-626-6114 (office) 248-626-6104 (fax)

GARY SHAPIRO gshapiro@ivanhoecompanies.com

September 30, 2025

Via Email

Lindsay Bell, Senior Planner City of Novi 45175 Ten Mile Road Novi, Michigan 48375

Re:Application for Rezoning to RM-1 with Planned Rezoning Overlay for the Grove Southeast Corner of 12 Mile Road and Meadowbrook Road

Dear Lindsay:

I am submitting this updated letter in support of the ongoing application of the Ivanhoe Companies' ("Ivanhoe") to rezone to RM-1 with a planned rezoning overlay (PRO) twelve parcels of land located at the southeast corner of 12 Mile Rd. and Meadowbrook Rd. (the "Project" or the "Grove"). This letter is inclusive of the information provided in my prior letters of July 9 and August 26, with all information updated to reflect further revisions to public benefits and other review items discussed with Planning Staff. This letter and the enclosed Executive Summary outlines Ivanhoe's vision for the Project, developed after substantial planning and analysis over several years of study and after participating in public hearings before the Planning Commission and City Council. It is intended as the project narrative describing the proposed rezoning and addressing the PRO eligibility requirements.

Ivanhoe has revised its original concept plans based on input from the City Council and City Staff and our own design refinements. Some of the key changes following the City's mostly positive reaction include a substantial reduction in density, the conversion of all rental units to for-sale units, changing the rezoning from RM-2 to RM-1, materially reduced the requested deviations, added more public benefits and added substantially more units with first floor master bedrooms to appeal to seniors.

A. Project Summary and Procedural Background

Ivanhoe entered into a Purchase Agreement with Trinity Health-Michigan ("Trinity") on November 18, 2022, for the purchase of approximately 69.65 acres (the "Grove Property") of the land owned by Trinity south of 12 Mile Road and east of Meadowbrook Road. Trinity would retain approximately 7.8 acres of land at the intersection of Meadowbrook and 12 Mile Road for future business development (the "Trinity Retained Parcel"). All of the property is zoned OST (office, service, technology). The Grove Property, however, contains extensive wetlands and woodlands, which makes it less desirable and not practicable or usable for OST development. The property is most suitable, however, for residential development that better preserves and takes advantage of the natural features of the site. The location and condition of the Property are ideal for the creation of a desirable residential living environment with much less traffic than an OST development in close proximity to many recreational amenities and some of the finest commercial shopping districts in Oakland County.

Before creating any concept design plans, Ivanhoe conducted a great deal of investigation and studies, including wetland and woodland investigations, topographic and drainage surveys, traffic studies, community impact statements and multiple market studies. A full tree survey was undertaken, and wetlands were marked and surveyed and agreed to by the City's outside wetland consultant. The market studies, prepared by outside professionals (CBRE, Chesapeake Group, etc.), demonstrated both the need for additional multi-family residential and the lack of demand for OST uses at this location. With this information in hand, the design process began. The objective was to create an integrated, mixed use residential development with multiple housing types and options, all connected by recreational amenities and preserved natural features.

On April 19, 2024, Ivanhoe submitted to the City a pre-application package that included a concept plan and comprehensive supporting documents. On May 7, 2024, Ivanhoe received a comprehensive written response from all key City Departments setting forth comments and observations regarding the proposal. Also on May 7, 2024, Ivanhoe participated in a pre-application meeting with City Staff. At the time, we proposed a rezoning to RM-2 with a planned rezoning overlay. The plan depicted four distinct villages of multi-family residential homes. The Grove Project contemplated a total of 430 residences, which included rental and for-sale units, along with extensive preserved open space, recreational amenities and public benefits.

After receiving and incorporating Staff input from the pre-application meeting, Ivanhoe submitted its formal application for rezoning to RM-2 with PRO on or about August 12, 2024. Extensive supporting material was included, which is best summarized by the cover letter narrative we submitted with the application dated August 12, 2024, and the letter from Brad Strader, our municipal planning consultant from C2G Consulting dated August 12, 2024. Both letters are included again in **Appendix 1** because they support in detail the basis for this rezoning.

The material was reviewed by the City planning staff, engineering department, traffic engineer and landscape architect. Another "Planning Review Center Report" dated September 11, 2024, was prepared by the City in response to our application. Ivanhoe prepared a comprehensive response which was submitted to the City on or about October 7, 2024. The Planning Commission held a public hearing on October 24, 2024, at which time Ivanhoe and its team presented a comprehensive power point presentation of the Grove Project.

The City Council also held a public hearing on the Project on December 16, 2024. (See, e.g., City Community Development Summary for the meeting given to City Council by its Professional Staff, attached as **Appendix 2**.) Ivanhoe again made a comprehensive presentation to City Council in support of the Project. The City Council and members of the public provided their observations and comments.

The reaction was very favorable. No member of the public appeared to express any opposition to the Project. There was general agreement that the proposed residential use was a good alternative use for the Property. The plans have now been revised to address various comments and direction given by both the Planning Commission and City Council, including for, among other things, more mitigation of unregulated, small pockets of wetlands, reduction in density, use of enhanced and more expensive building materials, include all attached garages, the desire for more units targeting senior living and for more expansive public benefits.

B. The Revised Grove Rezoning Request and Preliminary Site Plan

Continuing our collaborative process, Ivanhoe has materially revised the plans for the Grove in a manner that addresses each of the comments received from the Planning Commission and City

Council. We have also continued to monitor and evaluate market conditions so that the Project will be both successful and an important asset to the community. The key material changes made to the plans are summarized as follows:

- 1. Reduction in Density. The density had been materially reduced from 438 residential units to 232 residential units. In fact, this has allowed us to seek a rezoning to RM-1 rather than the higher density RM-2 classification. The overall density is now only 4.2 units per acre. Even under the RM-1 classification, approximately 400 residential units could have been designed for the Property. Although traffic was not an issue for the 438-unit plan (which was already less than an OST development on the Property), this reduced density will materially decrease the traffic generated even further.
- 2. For Sale Housing Units and Product Diversity. The revised plan continues the concept of interconnected residential villages containing diverse housing options and architectural details, but we are now proposing that all the units be for sale products rather than rental housing.
- 3. Enhanced Design and Building Materials. We had 2 different architectural firms design the original buildings to provide unique designs and architectural diversity, but the building materials did not comply with the City's ordinances, and we were seeking a variance for the building material deviations. The designs have been modified to comply with all the building material and other City Ordinance design requirements, and a variance is no longer requested.
- **4. Senior Living Options**. The City Council asked that we consider providing more housing suitable for seniors and ageing in place. In this regard, we have now included over 50% of the units which can accommodate first floor primary suites suitable for senior or age in place living opportunities.
- **5. Wetland Mitigation and Open Space.** The plans have been modified to provide all the wetland preservation and mitigation requested by the City's wetland consultant. Usable open space areas now consist of approximately 8.6 acres, more than the amount required by City Ordinances.
- **6. Enhanced Public Benefits.** At the suggestion of City Council and discussions with City Staff thereafter, we included more public benefits and modified other benefits (see Public Benefits Plan Sheet SP-3.5). The Project benefits now include:
 - **a.** 12 Mile Road Park and Open Space. An approximate one-acre park area and open space, accessible to residents and the general public, with pedestrian and bike rest stop area, at the northeast corner of the site along 12 Mile Road;
 - b. Grove Nature Area Trail. A one-mile loop Grove nature area trail, accessible to residents and the public, that extends from the newly created 12 Mile Road park area described above, along the east property line of the Property, providing scenic views of the adjacent 30-acre natural wetland area as well as natural features on the Property;
 - c. <u>Beacon Hill Park Improvements</u>. In order to address the impact of additional use of Beacon Hill Park by the new residents and the planned access and interconnectivity for Novi residents to use the 12 Mile Road Park and Grove Nature

- Trail, Developer agrees to provide the City with \$25,000 to be used by the City at its discretion, for Beacon Hill Park improvements, including landscaping, art, new seating, and other services and/or maintenance.
- d. <u>Novi Off-Site Pathway</u>. Consistent with Novi's mobility plans, over 700 feet of 10' wide pathway/sidewalk, off-site on the south side of 12 Mile Rd. to create a connection from the existing Beacon Hill Park and parking lot to the Grove 12 Mile Road Park and open space and the new connectivity sidewalk described below;
- e. New Novi Public Bus Stop. Construct a new "Coverage Stop" bus stop in accordance with the SMART Bus Stop Design Manuel, dated January 2025. This bus stop is supported by SMART, and will include adjacent seating, bike racks, and a perennial garden along 12 Mile Road to provide transportation options for the entire Novi community;
- **f.** <u>Increase Usable Open Space</u>. Increase useable open space by over 260% from the required 1.65 acres to 5.97 acres. Total open space is approximately 1/3 of the property;
- g. Novi Connectivity Sidewalk. Construct a new 8' wide sidewalk along the arterial road within The Grove to provide pedestrian and bike connectivity between Meadowbrook Road and 12 Mile Road, which will allow pedestrians and bikers to bypass the corner business property and allow easier access to the 12 Mile Road Park and Nature Trail. This is an objective of the City of Novi's 2023 Active Mobility Plan;
- h. <u>Dedication of Woodland and Wetland Conservation Areas</u>. Protect approximately 10.2 acres of 10 separate Woodlands and Woodland replacement areas and approximately 15.6 acres of 10 separate Wetlands and Wetland Mitigation areas with conservation easements. The combined conservation easements will ensure that over 47% of the property remains untouched for future generations;
- i. <u>Decreased Density</u>. Decrease density from 7.3 units per acre, which is the maximum allowed for three-bedroom units in the now proposed RM-1 zoning district criteria, to 4.23 units per acre. This provides the opportunity to increase open space and decrease wetland and woodland impact; and
- j. <u>Meadowbrook Road Right-of-Way Dedication</u>. Dedicate right-of-way along the entire Meadowbrook Road frontage (2,166 feet). The total land area to be dedicated is approximately 2.5 acres.
- 7. Material Reduction in Deviations. In its last submission, Ivanhoe requested 16 deviations, many of which were are deviations routinely approved by the City over the last several years for other projects, as discussed and reflected in the City Staff reviews previously mentioned. Without focusing on an objection to any specific deviation, one or more members of City Council expressed a generalized concern about the number of deviations requested. Several of these deviations were already supported by Staff in the prior review letters. As discussed in more detail in **Appendix 3**, the number of requested deviations has been cut in half and is now limited to 7 in total.

- 8. Compliance with Master Plan. The Project is also fully consistent with the City's new Master Plan adopted by the Planning Commission on June 25, 2025. The new Future Land Use Map places the Trinity Property in a new general mixed-use classification, which is characterized as the most flexible classification available. The planned uses now specifically include multi-family residential use. Thus, the development of the Trinity property for both multi-family residential and other business uses on the Trinity Retained Parcel, is fully consistent with the Master Plan and the planning objectives contained therein and will achieve a true mixed-use development on the Trinity Property.
- **9. Attached Garages**. In the original plan some of the rental, multi-family units were served by separate carports rather than garages. Now, each residential unit has a two-carattached garage prepped for charging stations and bike rack/storage.

C. Additional Project Narrative

Although this information was largely presented in the previous submissions, we wanted to reiterate some additional points in support of the RM-1 rezoning with PRO. As previously stated, the Trinity Property, which totals about 78 acres, is close to a variety of offices, retail, recreation, entertainment and residential land uses. To the north, across 12 Mile Rd., there are residential enclaves, with planned commercial uses, plus the MSU Tollgate Farms, and a City of Novi trailhead and park developed and deeded to the City by Ivanhoe as part of the Beacon Hill mixed-use project. There is an older office/type building on the southwest corner of 12 Mile Road and Meadowbrook. Twelve Oaks Mall and Twelve Mile Crossing at Fountain Walk are located a short distance to the west along 12 Mile Road. A substantial amount of office/commercial is located to the east; across M-5. Adjacent to the south is a small office park and then the I-96/M-5 interchanges. The entire eastern boundary of the Property abuts approximately 32 acres of MDOT right-of-way adjacent to the M-5 expressway, which is an undeveloped natural area containing wetlands and woodlands.

The Property has scattered small wetlands throughout, in which invasive species are present. The location, topography, and natural features present development challenges which is why it remains one of the larger pieces of undeveloped properties left in the City, particularly considering the size and configuration of buildings typically developed for OST uses. These environmental challenges also provide opportunities to create something unique, impactful and synergistic with the key nearby, large-scale retail shopping areas in the City of Novi.

With both current and future City planning objectives in mind, Ivanhoe spent months developing multiple iterations of potential development plans for the Property. We believe that the revised preliminary site plan submitted and illustrated in the enclosed materials satisfies the key City objectives and presents an exciting modern, mixed residential development and reflects current and future market trends. The natural features and constraints on the Property and the nature of nearby uses guided the design of the development plan.

The overall Property development is divided into two parts—Parcel A is the portion of the land that will be retained by Trinity and is targeted for business development as described further below; and Parcel B, which will be developed by Ivanhoe as a unique master-planned residential community containing four (4) villages integrated with parks, woodlands and other natural features, with multiple housing types, now providing substantially more first floor master bedroom homes for seniors. The Grove is intended to provide a range of flexible housing options catering to diverse, multi-generational residents, ranging from younger residents, families and older residents to age in the community.

There are three key factors that drive this development. First, the size of the Property offers the opportunity to provide diverse, but integrated housing options. Second, the isolated location of the Property and the natural features on and around the site are ideal and attractive for a successful residential project. Moreover, the entire west side of the property—over 2,200 hundred feet—abuts the M-5 right-of-way which will remain undeveloped. That MDOT-controlled property contains wetlands, woodlands, and storm drainage features. A pathway with observation areas on the Property adjacent to the MDOT wetland mitigation conservation easement will allow residents and the general public to appreciate the natural area. The Grove will include a non-motorized system that connects to pathways along the roads that will provide easy and direct access to MSU's Tollgate Farms and the Beacon Hill Park access trail.

An equally important consideration is the proximity to some of the premiere shopping areas in Oakland County—Twelve Oaks Mall, Fountain Walk and Novi Town Center. The stress on brick-and-mortar stores is well documented. Many shopping malls around the country and in Michigan are failing and some have closed (such as Lakeside Mall in Sterling Heights). Oversaturation of commercial lands and loss of on-site sales means that new residential areas are needed to support the retailers and restaurants. The Grove is perfectly positioned to provide easy access to these shopping districts. The residents would benefit from easily accessible retail and commercial services, and the commercial business would benefit from the additional customers living in close proximity.

The Preliminary Site Plan for the Grove calls for four residential villages all interconnected and governed by common themes of high quality and compatible designs and an open-space park area available for recreational use. The proposed *density has been reduced from 438 units proposed in the concept plan to 232 units*, all of which are for-sale condominium units with 2-car attached garages. A majority of the units are ranches or units with first floor primary bedrooms suitable for senior residents.

The Villages are tied together by an extensive pathway system and recreational and natural amenities, including an approximate 1.37 acre central gathering park, pocket parks, a nature area, pickleball court, playground and a designated Grove Park recreation area. Ivanhoe has also included an optional recreation plan that includes a clubhouse and pool, in the event it is later determined that such amenities would be desired by the residents. In total there are approximately 40 acres of green space with extensive internal sidewalks and walking and hiking trails. Almost all of the residences will abut or overlook open space areas.

Finally, consistent with the City's objectives and goals for sustainable development and Ivanhoe's own development philosophy, the Project will include numerous sustainable design features, such as: EV charging; numerous bike racks and bike storage space; use of native vegetation and strategically placed canopy trees; applicable plumbing fixtures shall be Water Sense labeled or equivalent standard; use of energy efficient exterior building materials, glass/glazing and insulation; installing smart scheduling technology for water use; and LED exterior lighting.

D. Trinity Parcel A Development

While there is no specific use now proposed for Parcel A at the southeast corner of 12 Mile Rd. and Meadowbrook Rd., Parcel A has been included in all the due diligence and planning analysis for the overall Property. The potential uses for Parcel A as reflected in the new Master Plan general mixed-use classification of the property, include without limitation, corporate headquarters and offices, healthcare facilities for Trinity, commercial, high-tech research and office, high-end health club, hotel and other mixed uses. The residential development has been

carefully situated to provide appropriate setbacks and screening for future business uses and to be compatible with them. Ivanhoe's consultants undertook a complete wetland analysis of Parcel and Ivanhoe has provided land for wetland mitigation on Parcel B (the Grove) in order to enhance the development potential of Parcel A. With an appropriate plan in place and synergistic uses, Ivanhoe and Trinity anticipate that Trinity Parcel A will attract development that would be an asset for the City and integrate and enhance the development or redevelopment of nearby properties.

E. Next Steps and Conclusion

To summarize, the proposed RM-1 rezoning with PRO will satisfy, among other things, the following objectives and conditions:

- 1. It will permit the development of multigenerational housing options in unique villages, in a single integrated development with vehicular and pedestrian connections serving diverse populations in close proximity to the City's extensive commercial corridors and served by public transportation, which will also benefit those commercial shopping areas;
- 2. It specifically addresses the City's desire and demand for housing suitable for seniors and aging in place;
- 3. Because of the challenging topographical, wetland and woodland conditions, the Property is less suitable for an OST development. Such a development would have an extensive adverse impact on the natural features, while a carefully designed residential project would preserve and enhance the natural features for the use and enjoyment of the residents;
- 4. It provides the ability to view an extensive preserved wetland/woodland system owned by MOOT and other adjacent preserved natural areas;
- 5. It will create substantially less traffic congestion than an OST development and, with the density restrictions stated below, less traffic than a traditional RM-2 development as previously proposed and further reduced in half again under RM-1 zoning limited to 232 units:
- 6. The prior proposal under the RM-2 zoning would permit approximately 1,235 two-bedroom residences or 926 three-bedroom residences. The revised proposed rezoning to RM-1 would reduce substantially the allowable density to approximately 400 units, the PRO plan under RM-1 zoning presented here is further limited to only 232 units;
- 7. All of the wetlands, which are generally small in size, are full of invasive species. Under the PRO, Ivanhoe will remove invasive species and upgrade the wetland features as to both function and aesthetics. We have revised the plan to allow for more upland land to increase mitigation per Novi's review;
- 8. The Grove's 40 acres of strategically located green space, combined with the adjacent MDOT property to the east (34 acres) and land included in a conservation easement to the south (around 6 acres abutting The Grove), create 80 acres of contiguous natural wildlife habitat;
- 9. The design of the Villages will be integrated, consistent, and complimentary including high quality and diverse materials. It is designed through setbacks, buffering, and connectivity to be supportive of, and compatible with, a commercial development at the retained Trinity Property;

- 10. An extensive list of sustainable design features as to both structures and landscape features will be included in the proposed PRO; and
- 11. Numerous public benefits including extensive pathways, park areas, public bus stop, increased open space, decreased density, diverse housing options, and conservation easements, will be provided.

Thank you for considering all this information and we look forward to continuing to work collaboratively with the City to make this development a reality.

Sincerely,

The Ivanhoe Companies

Gary Shapiro

Enclosures

cc: Barb McBeth

Alan M. Greene Andy Wozniak Brad Strader

APPENDIX 1

Via E-Mail and Hand Delivery



Barb McBeth - City Planner City of Novi 45175 Ten Mile Road Novi, Michigan 48375

August 12, 2024

RE: Application for Rezoning to RM-2 with Planned Rezoning Overlay for The Grove--Northeast Corner of 12 Mile Rd. and Meadowbrook Rd.

Dear Barb:

I am submitting this letter and the enclosed application and supporting information in connection with the Ivanhoe Companies' ("Ivanhoe")¹ proposed rezoning to RM-2 with a planned rezoning overlay (PRO) for 12 parcels of land located at the southeast corner of 12 Mile Rd. and Meadowbrook Rd. (the "Project" or the "Grove"). This letter outlines some project background and Ivanhoe and its design team's vision for the Project, developed after substantial planning and analysis over several years of study. It is intended as the project narrative describing the proposed rezoning and addressing the PRO eligibility requirements. The Presentation Booklet that accompanies the application provides visual depictions of the matters described in this narrative.

As you may recall, we had our concept plan meeting for the Project on December 14, 2023. We then submitted comprehensive materials for the pre-application review required by the Zoning Ordinance. The current revised plans and supporting materials also address the comments in the various City staff and department review letters and reflect the collaborative process we have embarked on with the City.

A. <u>Description of the Property and Background.</u>

The subject property (the "Property") consists of approximately 62 acres and has frontage along both 12 Mile and Meadowbrook Roads. The property is currently zoned OST (Office Service Technology) and is owned by Trinity Health-Michigan ("Trinity"). Ivanhoe entered into an agreement with Trinity in November 2022 to acquire approximately 62 acres of the nearly 70 acres of land owned by Trinity. While Trinity is retaining ownership of approximately 8 acres at the corner of 12 Mile and Middlebelt Roads, Ivanhoe has included that land in its development due diligence, planning and design work, including with respect to woodlands, wetlands and connectivity, so that any future development of that land could be integrated into the whole at the appropriate time.

¹ The Ivanhoe Companies, working with a diverse development team of community planners, designers and engineers, are creative community developers and have developed over 100 residential communities in Oakland, Wayne, Washtenaw and Livingston Counties. In the last decade we have specialized in unique sites in suburban infill locations in developed or partially developed areas to meet growing residential housing needs. We are proud of our reputation as environmentally sensitive developers and are the only three-time winner of the Michigan Society of Planning Officials award for best new project design.

The Property is close to a variety of offices, retail, recreation, entertainment and residential land uses. To the north, across 12 Mile Rd., there are residential enclaves, with planned commercial uses, plus the MSU Tollgate Farms, and a City of Novi trailhead and park developed and deeded to the City by Ivanhoe as part of the Beacon Hill mixed-use project. There is an older office/type building on the southwest corner of 12 Mile Road and Meadowbrook. Twelve Oaks Mall and Twelve Mile Crossing at Fountain Walk are located a short distance to the west along 12 Mile Road. A substantial amount of office/commercial is located to the east; across M-5 Adjacent to the south is a small office park and then the I-96/M-5 interchanges. The entire eastern boundary of the Property abuts approximately 32 acres of MDOT right-of-way adjacent to the M-5 expressway, which is an undeveloped natural area containing wetlands and woodlands.

The Property has scattered small wetlands throughout, in which invasive species are present. The location, topography, and natural features present development challenges which is why it remains one of the larger pieces of undeveloped properties left in the City, particularly considering the size and configuration of buildings typically developed for OST uses. As explained in more detail in the accompanying materials, there are sufficient and more suitable areas available for OST development. These environmental challenges also provide opportunities to create something unique, impactful and synergistic with the key nearby, large-scale retail shopping areas in the City—Twelve Oaks Mall, Fountain Walk and Novi Town Center.

With both current and potential future City planning objectives in mind, Ivanhoe spent months developing multiple iterations of potential development plans for the Property. We believe that the plan described below and illustrated in the enclosed materials satisfies the key City objectives and presents an exciting modern, mixed-use development and reflects current and future market trends. The natural features and constraints on the Property and the nature of nearby uses guided the design of the development plan.

B. The Grove PRO Development Plan—A Multi-Generational Destination Community

The overall Property development is divided into two parts—Parcel A is the portion of the land that will be retained by Trinity and is targeted for business development as described further below; and Parcel B, which will be developed by Ivanhoe as a unique master-planned residential community containing four (4) villages integrated with parks, woodlands and other natural features, with multiple housing types, including a mixture of for sale and rental housing options. The Grove is intended to provide a full range of flexible housing options catering to diverse, multi-generational residents, ranging from younger residents and families to active seniors.

Per the Master Plan "A variety of housing options will welcome younger residents and families as well as older residents to age in the community." The corresponding objective is to "Attract new residents to the city by providing a full range of quality housing opportunities that meet the housing needs of all demographic groups including but not limited to singles, couples, first time home buyers, families and the elderly." The plan for The Grove is guided by these Master Plan objectives and will be a unique multigenerational community.

There are three key factors that drive this development. First, the size of the property offers the opportunity to provide diverse, but integrated housing options. Second, the isolated location of the Property and the natural features on and around the site are ideal and attractive for a successful residential project. Moreover, the entire west side of the property—over 2,200 hundred feet—abuts the M/5 right-of-way which will remain undeveloped. That MDOT-controlled property contains wetlands, woodlands, and storm drainage features. A pathway with observation areas on the Property adjacent to the MDOT wetland mitigation conservation easement will allow residents to appreciate the natural area. The Grove will include a non-motorized system that connects to pathways along the roads that will provide easy and direct access to MSU's Tollgate Farms and the Beacon Hill Park access trail, which was developed by Ivanhoe as part of the Beacon Hill mixed-use project on the north side of 12 Mile Road.

An equally important consideration is the proximity to some of the premiere shopping areas in Oakland County—Twelve Oaks Mall, Fountain Walk and Novi Town Center. The stress on brick and mortar stores is well documented. Many shopping malls around the country and in Michigan are failing and some have closed (such as Lakeside Mall in Sterling Heights). Oversaturation of commercial lands and loss of on-site sales means that new residential areas are needed to support the retailers and restaurants. The Grove is perfectly positioned to provide easy access to these shopping districts. In fact, Twelve Oaks would be less than a mile walk or bike ride from the project along a bike path fronting the Property. The residents would benefit from easily accessible retail and commercial services, and the commercial business would benefit from the additional customers living in close proximity.

The Concept Plan for the Grove calls for four distinct villages all interconnected and governed by common themes of high quality and compatible designs. Two of the villages—the Woods and the Pointe—are targeted for condominiums. The other two villages—the Vistas and Meadows—can be offered for sale or rent depending on the market and demand. Current plans envision homes with flex space for home office or library use, 2 or 3 bedrooms, and 2.5 baths. The quality and nature of the design and development of these units would make them suitable for sale, either initially or as a later conversion. Thus, the Grove has the ultimate flexibility to address multiple housing targets within an interconnected project, responsive to market conditions, and fully consistent with both the current and proposed new Master Plan housing objectives.

The Villages are tied together by an extensive pathway system and recreational and natural amenities, including an approximate 5.5 acre central gathering park, pocket parks, a nature area, clubhouse and pool facilities, pickleball courts and a dog park. In total there are approximately 39 acres of green space with extensive internal sidewalks and walking and hiking trails.

Additionally, our traffic engineers at Fleis & VandenBrink, compared the number of expected trips in the peak hours for a typical office use with the number of trips expected with the residential use. A typical OST development, for example, would generate far more traffic during an average weekday versus the proposed residential development. Peak hour traffic differences are even more dramatic. The traffic benefits could be even greater if people walk or bike ride to nearby retail and restaurants in the area.

Finally, consistent with the City's objectives and goals for sustainable development and Ivanhoe's own development philosophy, the Project will include numerous sustainable design features, such as: EV charging stations; numerous bike racks and bike storage space; use of native vegetation and strategically placed canopy trees; applicable plumbing fixtures shall be Water Sense labeled or equivalent standard; use of energy efficient exterior building materials, glass/glazing and insulation; installing smart scheduling technology for water use; and LED exterior lighting.

C. <u>Trinity Parcel A Development</u>.

While there is no specific use now proposed for Parcel A at the southeast corner of 12 Mile Rd. and Meadowbrook Rd., Parcel A has been included in all the due diligence and planning analysis for the overall Property. The potential uses for Parcel A include without limitation, corporate headquarters and offices, healthcare facilities for Trinity, commercial, high-tech research and office, high-end health club, hotel and other mixed uses. The residential villages have been carefully situated to provide appropriate setbacks and screening for future business uses and to be compatible with them. With an appropriate plan in place and synergistic uses, Ivanhoe and Trinity anticipate that Trinity Parcel A will attract business uses that would be an asset for the City and integrate and enhance the development or redevelopment of nearby properties.

D. <u>Next Steps—Rezoning to RM-2 with PRO Development Approval.</u>

As the City knows, it currently has limited zoning tools available to accomplish the alternative and mixeduse approach envisioned for the Property. The City has two multiple family zoning classifications. Both ordinances are not targeted for development of the multiple housing options within a single development. The RM-1 density is insufficient for the development, while the RM-2 provides greater density than proposed. Therefore Ivanhoe is proposing a rezoning of approximately 62 acres of the property to the RM-2 zoning district with a PRO (planned rezoning overlay) similar to the procedure used for the development of the Beacon Hill project across 12 Mile Road from the Grove, which included single-family housing, a public park dedicated to the City and future commercial/retail development. The conditions and circumstances supporting the PRO include at least the following:

- 1. It will permit the development of multiple housing options in a single integrated development with vehicular and pedestrian connections serving diverse populations in close proximity to the City's extensive commercial corridors, which will also benefit those commercial shopping areas;
- 2. Because of the challenging topographical, wetlands and woodlands conditions, the Property is less suitable for an OST development. Such a development would have an extensive adverse impact on the natural features, while a carefully designed residential project would preserve and enhance the natural features for use and enjoyment of the residents;
- 3. It provides the ability to view an extensive preserved wetland/woodland system owned by MDOT and other adjacent preserved natural areas;
- 4. It will create substantially less traffic congestion than an OST development and, with the density restriction stated below, less traffic than a traditional RM-2 development;
- 5. Although the RM-2 zoning would permit approximately 1,235 two-bedroom residences or 926 three-bedroom residences, the proposed PRO would limit the density to only 438 residences;
- 6. All of the wetlands, which are generally small in size, are full of invasive species. Under the PRO Ivanhoe will remove invasive species and upgrade the wetland features as to both function and aesthetics;
- 7. The Grove's 39 acres of strategically located green space, combined with the adjacent MDOT property to the east (34 acres) and land included in a conservation easement to the south (around 6 acres abutting The Grove), create 80 acres of contiguous natural wildlife habitat;
- 8. Extensive pathways, view features and recreational and exercise amenities will be included, including 4 places of interest for general public use along the main roads;
- 9. An extensive list of sustainable design features as to both structures and landscape features will be included in the proposed PRO; and
- 10. The design of the Villages will be integrated, consistent and complimentary and will include high quality and diverse materials.

E. Conclusion.

Ivanhoe is very excited about this new development and expects it to be a successful and unique place-making destination for living within the community, and an asset to the City.

Sincerely,

Gary Snapiro

Ivanhoe Companies

cc: Lindsay Bell (via email: lbell@cityofnovi.org)

Brad Strader (via email: Brad.Strader@itsc2q.com)

Andy Wozniak (via email: awozniak@zeimetwozniak.com)

Alan M. Greene (via email: agreene@dykema.com)



August 12, 2024

City of Novi Attn: City of Novi Planning Commission 45175 Ten Mile Road Novi, Michigan 48375

Re: The Grove Proposed Rezoning and PRO Concept Plan - Planning Recommendation

Dear Planning Commissioners,

I have been working with the Ivanhoe team on The Grove project for around two years. I have been involved in the design and development of many of the materials that have been submitted. This letter supports why I believe, as an experienced professional planner, the Commission should approve the rezoning using the Planned Rezoning Overlay (PRO) process.

The PRO option allows a conditional rezoning, to be used when a site and project has something unique where the typical zoning standards do not apply. That is certainly true for this site. The property contains large, forested wetlands that can be integrated into the design, but does require deviations that allow the buildings and parking to be clustered, rather than spread throughout the site in a more traditional layout.

This letter begins with a few statements about my professional experience and expertise. This is followed by a summary of all the benefits that the project will provide that may not otherwise be possible within the existing zoning district.

My Qualifications

As some of you may know, I am a Planning Consultant with over 40 years of experience. I was President of a planning firm (LSL Planning) that worked for more than 50 communities in Michigan, plus projects in many other states. My municipal clients included Farmington, Farmington Hills, Northville Township and Wixom. I was also selected by the City of Novi to assist with some special zoning districts.

Throughout my career I have often been selected as an instructor on planning, zoning, and transportation related topics. For around 15 years, I was the instructor for the annual Oakland County Planning and Economic Development Department, which was attended by some Novi Planning Commissioners.

I have spent most of my career working for the public sector. Because of my strong relationships with cities in Oakland County, and my reputation, I must be very selective when working for developers. I have been working with Ivanhoe for about 25 years, including two prior projects in the City of Novi. I enjoy working with the Ivanhoe team because they study the site and surrounding area as well as take the time to explore options and develop innovative designs. Several of the projects I have done with Ivanhoe have won awards from the Michigan Association of Planning (MAP), along with other organizations.



I currently work for Cincar Consulting Group (C2G) as the Planning Director. At C2G, we partner with clients and communities to collaboratively create great spaces to live, work, and play. While we work mostly for public agencies, we also carefully select to work with top quality developers like Ivanhoe.

Before I joined C2G a year ago, I worked at MKSK. MKSK is a talented landscape architecture and design firm with award-winning projects throughout the Eastern United States. Haley Wolfe and Brian Kinzelman (former CEO) at MKSK have, like me, been involved in this project for over two years. We all support this project due to the integration of development with the environment, and to help meet the need for more attainable housing with all the locational attributes outlined below. Some of the features we helped create include elements that turn this into a special place – parks and amenities, non-motorized pathways, sustainability features, convenient access to a new SMART stop and more.

Cincar Consulting Group and MKSK worked with the rest of this creative team of landscape architects, planners, architects, designers, engineers and others to develop a cohesive proposal.

Why Multiple-Family instead of Office Service Technology (OST)?

The team has been working with Ivanhoe for around two years on this project. The general sequencing of the project is outlined below.

Ivanhoe has been working with the owner, Trinity Health, to explore development options for several years. Even when the office market was robust, this site remained vacant. There are just too many natural resource obstacles to develop this site with office buildings and their required parking. Ivanhoe and Trinity consulted with CBRE, one of the top experts in office developments in SE Michigan. CBRE confirmed that the OST market was soft for the Property, due to overall lack of demand and the site's imposing environmental features.

Trinity will retain ownership of the corner parcel, believing that could be a visible, landmark location for an office or other more intense business or commercial development in the future. They wanted to ensure that development on the Ivanhoe section would be compatible with whatever may occur on the corner parcel in the future.

Then Ivanhoe explored different use options for the site. Gary Shapiro from Ivanhoe personally attended several meetings with the City's subcommittee working to update the City's Master Plan. The experienced Project Manager from Becket-Rader noted that a flexible approach was needed for our site in terms of use and design (defined as a potential Mixed Use or "MXD"). I believe the Ivanhoe proposal is consistent with the approach offered by the City's planning consultant.

Ivanhoe reached out to various market consultants to define what type of use would be appropriate for this location. Those market consultants reached the same conclusion:, low-rise multiple-family that preserves much of the site as open space and wetlands. The market consultants noted that housing was needed to attract younger professionals, and to retain 2nd generation Novi residents, who are not yet ready to purchase a home but want to live in Novi.

Two creative residential architects were engaged to design buildings that would be unique in the market and provide timeless design. Hobbs & Black from Ann Arbor designed the buildings in the Meadows and the Woodlands. Preliminary renderings are featured in the booklet. TR Architects was engaged to

People Centric | Client Focused | Community Minded



design buildings in The Woods and The Point. Using two acclaimed architects helps ensure that the Villages have a distinct character while retaining an overall consistent design theme.

As the site evaluation and housing design were merged, Ivanhoe's team developed a master-planned, multiple-family community containing different villages, providing a mixture of unit types. The residential villages are integrated through a series of non-motorized connections, with a large open space park, pocket parks, woodland corridors and other natural features. Per the City's Master Plan, an objective is to "Attract new residents to the city by providing a full range of quality housing opportunities that meet the housing needs..." In response, The Grove will target young professionals and families (generation X, Y, Z) providing a variety of housing options that will meet the goals of the Master Plan.

What the PRO Zoning Provides

The attractive features on the site, especially the wetland corridors, make it very difficult to construct buildings and parking using the zoning standards developed for a flat featureless piece of land. The City's Zoning Ordinance allows a PRO to be used in situations where a more creative design approach is needed. This allows "deviations" from the typical setback and spacing standards, to allow a design that fits the site conditions. The City also requires that the project "benefit" the City.

We have reviewed the City's Zoning Ordnance and the PRO criteria. You will see in our materials those criteria and how we address them, a listing of the many benefits this project provides, and support for the deviations requested. Many of these benefits, shown below, would not otherwise be possible for this site as currently zoned, or for a project without the requested deviations:

- 1. Benefit to the commercial development in the area: The project is near a variety of offices, retail, recreation, entertainment, and residential land uses. For example, the property is located within easy biking or driving distance to Twelve Oaks Mall and Twelve Mile Crossing at Fountain Walk. Residential will also support the planned commercial across 12 Mile (part of the Ivanhoe mixed use project) and businesses on the other side of M-5.
- 2. Meets the housing needs in the City: The project promotes high quality standards for residential uses compatible with the surrounding area of the City. Given the size of the property, there is an opportunity to provide a wide range of flexible housing options that are also integrated into the site.
- 3. Sustainable development: The Grove is also consistent with the City's objectives and goals for sustainable development. This project's close proximity to nearby commercial areas can also help reduce the reliance on vehicles and promote more walking and biking to surrounding areas. The Project will include numerous sustainable design features that will create positive community impacts, including EV charging stations, bike racks and bike storage, native vegetation, energy efficient exterior building materials, amongst other sustainable design aspects.
- 4. Less traffic impacts than OST: The traffic impact study shows that a typical OST development office park (which would be permitted under the current zoning) would generate more traffic than the proposed residential development. Additionally, peak hour traffic differences show that development under the OST zoning would be more than four times traffic associated with The Grove development.

People Centric | Client Focused | Community Minded



5. Consistent with the "Walkable Novi" Plan and the City's new Mobility Plan: The Grove development will be walkable and interconnected into the regional non-motorized network. Meadowbrook Pathway connects adjacent to our site at Meadowbrook and 12 Mile Road which then connects to the Michigan Air Line Trail, M-5 Metro Trail as well as the I-275 Metro Trail. There will be connections to a new bus stop for residents to connect to SMART's Route 740 along 12 Mile Road.

Internally, the development has three miles of internal pathways and sidewalks. These pathways provide connections to the regional non-motorized system plus the 5.5-acre central gathering park, pocket parks, a nature area, clubhouse and pool facilities, pickleball courts and a dog park.

In summary, and on behalf of the entire design team, we believe the Grove development is a perfect application of the City's PRO zoning. We have all spent considerable time exploring options for the layout of the homes, circulation, parking, a comprehensive non-motorized system, and a series of amenities to set this project apart from other multiple-family developments in the City.

We hope after you review the plans, that you will agree. We look forward to meeting with you to hear your comments.

Respectfully Submitted,

Brad Strader, AICP, PTP

Planning Director

Cincar Consulting Group

APPENDIX 2



CITY OF NOVI CITY COUNCIL DECEMBER 16, 2024

SUBJECT:

Initial review of eligibility of The Grove, to rezone property at the southeast corner of Twelve Mile Road and Meadowbrook Road to High-Density Multiple Family with a Planned Rezoning Overlay.

SUBMITTING DEPARTMENT: Community Development – Planning Division

KEY HIGHLIGHTS:

- Rezoning 62 acres on Meadowbrook Road to allow a 438-unit multi-generational development with attached townhomes and apartments and open space amenities.
- Former agricultural site contains regulated woodlands and an extensive system of wetland areas.
- Proposed PRO Conditions include four pedestrian seating areas along Meadowbrook and Twelve Mile, and off-site 10-foot-wide pathway along Twelve Mile, which the applicant indicates are in the public interest.
- Planning Commission reviewed the Initial PRO Plan and provided feedback on October 30, 2024.

BACKGROUND INFORMATION:

The applicant is requesting a Zoning Map Amendment for approximately 62 acres of property on the south side of Twelve Mile Road, east of Meadowbrook Road (Section 13). The applicant is proposing to rezone the property from Office Service Technology (OST) to High-Density Multiple Family (RM-2) using the City's Planned Rezoning Overlay (PRO) option.

The current zoning of the property is OST – Office Service Technology. The properties to the east, west and south are also zoned OST. The area to the north is B-3 General Business and RA Residential Acreage.

The Future Land Use Map identifies this property and those around it in blue as Office, R&D and Technology, which is consistent with the current zoning. The area to the north is single family and community commercial.

The natural features map shows there are significant wetland and woodland areas on this property as well as to the east and south. The tree and wetland surveys provided by the applicant confirm these features.

The applicant is proposing to utilize the Planned Rezoning Overlay to rezone the property to RM-2 High Density Multiple Family. The initial PRO plan shows four "villages" offering different types of residential units. The Vistas are 3-bedroom townhome units – a total of 49 units in 3-story buildings. The Woods and The Point are 2-story townhome buildings with a total of 133 units, each with three bedrooms. The Meadows are residential apartment buildings with a total of 256 units. These would offer a mix of studio, 1-bedroom and 2-bedroom units. There is also a clubhouse building and central park area with amenities, including an outdoor pool, pickleball courts, a playground and a dog park.

The development is accessed by two entrances off Meadowbrook Road, and one from Twelve Mile Road.

Rezoning to the RM-2 category would permit the use proposed, however the multifamily zoning is not in compliance with the current Master Plan designation as Office Research Development and Technology. The current update to the Master Plan is under review, and the land use designation for this area may change.

The conditions in the interest of the public offered by the applicant include:

- Four "focal areas" two along Meadowbrook and two along Twelve Mile, which would be publicly available from the sidewalk. These are small seating areas with landscaping. One of these could serve as a bus stop for the new SMART service along Twelve Mile.
- 2. Construction of a 10-foot pathway on Twelve Mile on the Trinity site adjacent (off-site)
- 3. A corner feature at the southeast corner of Meadowbrook and Twelve Mile.
- 4. The usable open space and general open space significantly exceeds the requirements of the Ordinance.
- 5. Other conditions as listed in the Summary of Conditions section below.

Staff thinks that given the size of the development proposed, additional benefits to the public could be considered to off-set the detrimental impacts of the project.

As described in the Wetland Review, each of the delineated wetlands on the site meet the criteria of providing wildlife habitat as well as flood and storm control. Wetland review notes that the proposed development appears to result in a total permanent wetland impact area of 1.71 acres out of the total 9.64 acres present on site (about 18% impact). Approximately 1.4 acres of on-site mitigation area is noted on the plan, which is not likely to meet the full requirement for mitigation. The City has determined that all wetlands on the site are regulated, and therefore the wetland impacts, and mitigation calculation requirements should be updated accordingly on future submittals.

For woodlands, the plan appears to remove about 75% of the regulated trees on the woodland survey.

As noted in the Façade Review, the façade materials proposed do not conform to the Ordinance requirements. The building designs show extensive use of "luxury" vinyl siding, which is not permitted. Most of the building facades do not meet the 30% minimum brick requirement. The façade materials should be reconsidered to bring the units into substantial compliance.

Some other issues identified include questions of compatibility and buffering from the adjacent uses that will remain OST. Being adjacent to a residential development can require additional setbacks or other restrictions, which can be an added burden to surrounding non-residential landowners, however this would primarily be an issue to the south, but that parcel is largely developed. Dense landscaping is proposed in that area to provide buffering.

A residential development may result in smaller wetland and woodland impacts compared to an OST development due to the typical size of buildings and parking needs. OST-permitted uses include offices, research & development, data processing, and hotels, which all typically have a larger footprint than the RM-2 uses proposed. The Traffic study notes that the number of residential units proposed would likely result in fewer daily vehicle trips compared to an OST development, but there is a net increase during peak hours.

PRO ORDINANCE

The PRO option creates a "floating district" with a conceptual plan attached to the rezoning of a parcel. As part of the PRO, the underlying zoning is proposed to be changed and the applicant enters into a PRO agreement with the City, whereby the City and the applicant agree to a conceptual plan for development of the site. Following final approval of the PRO concept plan, conditions for the development, and a PRO agreement, the applicant will submit for Preliminary and Final Site Plan approval under standard site plan review procedures. The PRO runs with the land (unless terminated), so future owners, successors, or assignees are bound by the terms of the agreement, absent modification by the City of Novi. If the development has not begun within two (2) years, the rezoning and PRO concept plan expires, and the agreement becomes void.

City Council adopted revisions to the Planned Rezoning Overlay ordinance. Under the terms of the new ordinance, the Planning Commission does <u>not</u> make a formal recommendation to City Council after the first public hearing. Instead, the initial review is an opportunity for the members of the Planning Commission, and then City Council, to hear public comment, and to review and comment on whether the project meets the requirements of eligibility for Planned Rezoning Overlay proposal. Section 7.13.2.B.ii states:

In order to be eligible for the proposal and review of a rezoning with PRO, an applicant must propose a rezoning of property to a new zoning district

classification, and must, as part of such proposal, propose clearly-identified site-specific conditions relating to the proposed improvements that,

- (1) are in material respects, more strict or limiting than the regulations that would apply to the land under the proposed new zoning district, including such regulations or conditions as set forth in Subsection C below; and
- (2) constitute an overall benefit to the public that outweighs any material detriments or that could not otherwise be accomplished without the proposed rezoning.

(See chart at the end of this motion sheet for example conditions from Subsection C)

Ultimately, the applicant will have the burden of demonstrating that the following requirements and standards are met by the PRO Plan, Conditions, and PRO Agreement:

- a. The PRO accomplishes the integration of the proposed land development project with the characteristics of the project area in such a manner that results in an enhancement of the project area as compared to the existing zoning that would be unlikely to be achieved, or would not be assured, in the absence of the use of a PRO.
- b. Sufficient conditions have been included on and in the PRO Plan and the PRO Agreement such that the City Council concludes, in its discretion, that, as compared to the existing zoning and considering the site-specific land use proposed by the applicant, it would be in the public interest to grant the rezoning with PRO. In determining whether approval of a proposed application would be in the public interest, the benefits which would reasonably be expected to accrue from the proposal shall be balanced against, and be found to clearly outweigh the reasonably foreseeable detriments thereof, taking into consideration reasonably accepted planning, engineering, environmental and other principles, as presented to the City Council, following recommendation by the Planning Commission, and also taking into consideration the special knowledge and understanding of the City by the City Council and Planning Commission.

In other words, an applicant needs to establish that its proposed project can integrate with the other development in the area, that it results in an enhancement of the project area as compared to the existing zoning, one that couldn't happen without the rezoning and the PRO, and that it would be in the public interest.

After this initial round of comments by the public bodies, the applicant may choose to make any changes, additions or deletions to the proposal based on the feedback received. The applicant will then submit their formalized PRO Plan, which will be reviewed by City staff and consultants. The project would then be scheduled for a 2nd public hearing before Planning Commission. Following the 2nd public hearing the Planning Commission will make a recommendation on the project to City Council. City Council would then consider the rezoning with PRO, and if it determines it may approve it, would direct the City Attorney to work with the applicant on a PRO Agreement. Once completed, that final PRO Agreement would go back to Council for final determination.

PLANNING COMMISSION

The Planning Commission held a Public Hearing on October 30, 2024, to review and make comments on the proposal's eligibility for using the Planned Rezoning Overlay option. Comments made at that time are reflected in the meeting minutes included in this packet, and summarized here:

- Commissioners stated they were concerned about changing the character of this area from Office Service Technology to more residential, especially since it isn't in line with the 2016 Master Plan.
- Commissioners thought the layout was thoughtfully designed to take into account the wetland areas.
- Commissioners thought the facades should be brought into compliance with the Façade Ordinance.
- Commissioners reiterated that additional public benefits would be needed to justify the PRO.
- Commissioners liked the look of the amenities within the development.
- Commissioners stated that providing the type of housing that would benefit the underserved senior housing market could be a public benefit to consider.

SUMMARY OF CONDITIONS OFFERED

Below is a summary of possible conditions from applicant, or staff and consultant's review letters that may be considered to meet the standard of <u>clearly identified site-specific</u> conditions that are more strict or limiting than the regulations that would apply to the land under the proposed new zoning district:

- 1. Preservation of City regulated woodlands
- 2. Preservation of City regulated wetlands
- 3. Density shall not exceed 8.0 dwelling units per acre (More limiting than the dwelling units per acre allowed in the RM-2 District)
- 4. Providing the community amenities shown in the PRO Plan, including the provision of 11 acres of usable open space, which significantly exceeds the requirement of about 2 acres.
- 5. Design and construction of an off-site 10-foot multi-use pathway on the adjacent property retained by Trinity (approximately 730 linear feet).
- 6. Dedication of 1,652 linear feet of Right of Way along Meadowbrook Road.
- 7. Building height will be limited to 41 feet.
- 8. Exceeding landscaping requirements, such as in the use of native species.
- 9. Improvements or other measures to improve traffic congestion or vehicular movement with regard to existing conditions or conditions anticipated to result from the development.
- 10. Creation or preservation of public or private parkland or open space.
- 11. Completion of a project recommended in the 2023 Active Mobility Plan in the nearby area.

Below is a summary of conditions that may be considered to reach the conclusion that, as compared to the existing zoning and considering the site-specific land use proposed

by the applicant, it is in the public interest to grant the rezoning with PRO <u>(taken from the applicant's narrative)</u>:

Open Space and Parks – The Project design and layout is intended to create a "Placemaking" destination. These benefits will provide the City and its residents with great views, open space, pathways available to the public and, linked with the adjacent MDOT preserve, a large open space for wildlife habitat.

- 1. Over 1/3 of the site will be open space.
- 2. The open space includes "pocket parks" and an internal "Central" park community gathering area with many amenities (pool, clubhouse, Pickleball courts, picnic areas, playground, and a dog park).
- 3. Landscaping will focus on the use of native Michigan vegetation.
- 4. Setbacks, buffering and connectivity to support the eventual development of the corner parcel.
- 5. Views along Meadowbrook and 12 Mile Roads will have four places of interest, with extensive tree envelopes, benches and other amenities. Almost 50% of the frontage along those streets will be open space. The developer would be responsible for maintaining these amenities.
- 6. Preserves wetland and woodland corridors by mingling development into pockets. This is in contrast to development of OST uses that likely would have greater disruption of the natural features. Major wetlands will be preserved through a Conservation Easement.

Housing – Housing demand has changed. To address the market trends and need for more choices, we will offer multi-generational housing, geared toward young professionals and those looking for a more maintenance-free lifestyle.

- 1. Converts a long vacant OST parcel into a type of development that the public needs.
- 2. A more "attainable" housing cost compared to other options prevalent in the City.
- 3. Attractive, flexible housing types townhomes, residential flats, designed for rent, sale or conversion to condominiums.

Mobility and Transportation – Connections to the Regional Pathways and the various internal non-motorized connections are consistent with "Walkable Novi" and the City's new Mobility Plan.

- Combining 12 parcels, which could be developed with individual access points, into one unified destination with just two access points. There are two access points on Meadowbrook, and one on 12 Mile Road. The retained Trinity parcel at the corner would likely have at least two access points as well.
- 2. Connections to a new bus stop for residents of the area for SMART's Route 740 along 12 Mile Road. **Would a bus shelter be provided?**
- 3. An integrated pathway system that links to the regional non-motorized system along 12 Mile and Meadowbrook Roads, that connects to the Michigan Air Line Trail, M-5 and I-275 systems.
- 4. Our internal non-motorized system includes sidewalks, pathways, compacted limestone and natural hiking trails. We are providing a wider, 10-foot wide, circular pathway system in the area where we believe the demand will be highest.

- 5. Significant reductions in traffic compared to development of the site with typical OST uses (as noted in the Community Impact Statement and Traffic Impact Study).
- 6. Additional right-of-way will be dedicated along the Meadowbrook Road frontage.

DEVIATIONS

The proposed PRO Concept Plan includes the following ordinance deviation requests (Note these are based on the Initial PRO Plan, with Staff comments in bold):

- 1. **Building Setbacks** (Sec 3.1.7.D): A Zoning Ordinance deviation is requested to reduce the building setbacks from 75 feet to 50 feet along the east, west and south property lines. The applicant indicates the property to the east will not be developed as it is the MDOT wetland and stormwater natural area, so the reduced setback will not impact this property. The applicant states that much of the property to the south is in a conservation easement, and a berm with landscaping for additional screening is proposed. The conservation easement area is not in the area adjacent to the proposed homes. On the western side, the applicant states the 50-foot setback is consistent with existing developments along Meadowbrook, and that Trinity Health has endorsed the design of the site, including the setbacks. The setbacks from the Trinity Health parcel observe a 75-foot setback as is required. Most of the existing buildings along this segment of Meadowbrook are set back more than 70 feet from the road rightof-way. The only building setback that is less than 70 feet is the University of Detroit Mercy building, which is approximately 30 feet from Meadowbrook ROW.
- 2. Parking Setback (Sec 3.1.7.D): A Zoning Ordinance deviation is requested to reduce the parking setback from 75 feet to 50 feet along the west property lines. The deviation is requested as it is similar to other developments along Meadowbrook Road, and ample landscaping will provide a screening buffer. Parking areas along Meadowbrook Road are in the 30-to-50-foot range for setbacks. There is only one location on the proposed plan with parking this close to the road, and it is shown to be covered by a carport structure.
- 3. Total Number of Rooms (Sec. 3.8.1.A): A Zoning Ordinance deviation is requested to allow a greater number of rooms than the RM-2 District permits for buildings less than 4-stories (1,389 rooms proposed, 1,195 permitted). The applicant states while the proposed number of rooms exceeds the number allowed, the proposed density for each unit type is less than the allowed density, and the proposed unit mix is consistent with current market conditions and demand. The RM-2 district allows a greater number of rooms for buildings 4 stories or taller, with corresponding higher units. This deviation has been permitted previously, as the overall density permitted by the district is not exceeded.
- 4. **<u>Building Length</u>** (Sec. 3.8.2.C): The maximum building length in The Meadows is 216 feet, which exceeds the allowed length of 180 feet. The applicant states that the buildings are smaller than most modern multi-family buildings of this

- type. Architectural details like changes in building materials, as well as over a third of the front façade of the building being landscaped, there is visual interest that helps to break up the bulk of the building.
- 5. <u>Building Orientation (Sec. 3.8.2.D):</u> A Zoning Ordinance deviation is requested to revise the required orientation of the buildings from a minimum of 45 degrees in certain locations. This allows for a more uniform site layout with all of the units backing up to open space/wooded areas. All buildings are either parallel or perpendicular to property lines abutting non-residential districts. This deviation has been requested and granted for many residential projects in the City in the last 5 years.
- 6. <u>Distance between Buildings</u> (Sec 3.8.2.H): A Zoning Ordinance deviation is requested to reduce the building separation distance from the calculated formula as follows: The Vistas (side to side: 25 feet minimum proposed, 34.8 feet required; rear to rear: 50 feet proposed, 56 feet required); Woods and Meadows: (side to side: 25-feet proposed, 39.6 feet required); between Building 9 and 10 (32.8 feet proposed, 41.3 feet required). This deviation enables the layout of this project to fit within the available space while minimizing wetland and woodland impacts.
- 7. Parking along Major Drives (Sec. 5.10): A Zoning Ordinance deviation is requested to allow for perpendicular parking on a major drive. This deviation is requested to due to the impracticality of providing a minor road (defined as less than 600 feet in length) given the site constraints (woodlands, wetlands, and property configuration). Perpendicular parking for guests is proposed on two Major Drives (Simi Drive and Beckham Drive) in several locations, where driveways are also proposed. The parking spaces will not cause any more disruption on the roadway than cars that will be backing out of the driveways.
- 8. Wetland Mitigation (Code of Ordinances, Chapter 12, Sec 12-173): At this time, it appears the applicant would need to request deviations from the requirements of the Wetland and Watercourse Protection ordinance based on the information provided in the plan. The applicant should reevaluate their calculated impacts and mitigation plans based on comments in the Wetland Review. Current deviations needed would not be supported by staff.
- 9. <u>Section 9 Waiver (Section 5.15):</u> Proposed elevations for residential buildings have an underage of minimum required brick (0% proposed on some buildings, 30% minimum required), and an overage of Vinyl Siding on all buildings (0% allowed). This waiver is not supported. As a minimum, the amount of brick should be increased to more closely match the 30% required. As vinyl siding is not permitted, the applicant should consider wood of fiber cement siding.
- 10. <u>Parking Distance to Buildings</u> (Sec. 3.8.2.F): In two locations, off-street parking spaces are within 13-17 feet from the adjacent building. The ordinance requires 25-feet between parking spaces and a dwelling structure that contains openings involving living areas. The parking spaces are further away than the

driveways where parking is permitted, so it does not appear they will have a greater impact.

- 11. Number of Accessory Buildings (Sec. 4.19.1.J): For lots greater than ½ acre, not more than 2 detached accessory buildings are permitted. The PRO plan shows 4 detached garages. A recent text amendment allows the number of carports to exceed 2. This deviation to allow a greater number of garages is supported as it is a large site, provides covered parking options for a greater number of residents, and will not be detrimental to the area.
- 12. <u>Landscape Berms</u> (Sec. 5.5.3.A.ii): A landscape deviation is requested to not provide a 4-foot, 6-inch to 6-foot-high landscape berm on a proposed RM-2 district adjacent to an OST district on the east and south side. This deviation is supported by staff because of topography and the provision of dense landscaping along both property lines.
- 13. <u>Right-of-Way Landscaping</u> (Sec. 5.5.3.B.ii): A deviation to the required greenbelt berm and plantings along 12 Mile and Meadowbrook Road due to the existing natural areas to be preserved, and a heavily landscaped detention basin.
- 14. Right-of-Way Landscaping (Sec. 5.5.3.B.ii): A landscape deviation to allow a deficiency in street trees along Meadowbrook Road. This may be supported by staff depending on the justification. The applicant is asked to provide rationale for this deficiency.
- 15. <u>Building Foundation Landscaping</u> (Sec. 5.5.3.F.iii): A landscape deviation for the deficiency in building foundation landscaping. This deviation is not supported by staff as there are opportunities to more closely comply with the ordinance standards. The applicant states that additional plantings will be added to the building corners and sides.

CITY COUNCIL ACTION: This is City Council's opportunity to comment on the eligibility of the proposal according to the standards of the PRO Ordinance and offer feedback to the applicant. No motion is necessary at this time, but the table below contains examples of **conditions** (as listed in the Ordinance) that might assist the Council in reaching a conclusion that, as compared to the existing zoning and considering the site-specific land use proposed by the applicant, it is in the public interest to grant the rezoning with PRO.

Types of PRO Conditions (Section 7.13.2.C.ii.b)	Proposed	Notes
(1) Establishment of development features such as the location, size, height, area, or mass of buildings, structures, or other improvements in a manner that cannot be required under the Ordinance or the City's Code of Ordinances, to be shown in the PRO Plan.	Yes	Buildings and layout to be as shown in the PRO Plan.
(2) Specification of the maximum density or intensity of development and/or use, as shown on the PRO Plan and expressed in terms fashioned for the particular development and/or use (for example, and in no respect by way of limitation, units per acre, maximum usable floor area, hours of operation, and the like).	Yes	Number of units can be stated as maximum allowed. Additional restrictions could include limits on parking, height of buildings.
(3) Provision for setbacks, landscaping, and other buffers in a manner that exceeds what the Zoning Ordinance can require.	Yes	Open space exceeds requirements
(4) Exceptional site and building design, architecture, and other features beyond the minimum requirements of the Ordinance or the Code of Ordinances.	No	The building materials currently do not comply with minimum standards and should be revised.
(5) Preservation of natural resources and/or features, such as woodlands and wetlands, in a manner that cannot be accomplished through the Ordinance or the Code of Ordinances and that exceeds what is otherwise required. If such areas are to be affected by the proposed development, provisions designed to minimize or mitigate such impact.	Yes	While significant areas of wetland and woodlands are proposed to be preserved, the impacts are also significant. Wetland ordinance will require mitigation, which is proposed but will not meet full requirements.
(6) Limitations on the land uses otherwise allowed under the proposed zoning district, including, but not limited to, specification of uses that are permitted and those that are not permitted.	Yes	Use to be limited to multi-family residential
(7) Provision of a public improvement or improvements that would not otherwise be required under the ordinance or Code of Ordinances to further the public health, safety, and welfare, protect existing or planned uses, or alleviate or lessen an existing or potential problem related to public facilities. These can include, but are not limited to, road and infrastructure improvements; relocation of overhead utilities; or other public facilities or improvements.	Yes	10-foot wide shared-use pathway proposed within the site, and along 12 Mile Road

(8) Improvements or other measures to improve traffic congestion or vehicular movement with regard to existing conditions or conditions anticipated to result from the development.	No	Not proposed.
(9) Improvements to site drainage (storm water) or drainage in the area of the development not otherwise required by the Code of Ordinances.		
(10) Limitations on signage.	No	
(11) Creation or preservation of public or private parkland or open space.	Yes	Enhanced pedestrian seating areas proposed along Meadowbrook and 12 Mile, other areas are not publicly accessible
(12) Other representation, limitations, improvements, or provisions approved by the City Council.	TBD	

Appendix 3

Ordinance Deviations for the PRO Plan based on the RM-1 Zoning Classification. (7 total deviations)

- 1. <u>Building Setbacks (Sec 3.1.7.D):</u> A Zoning Ordinance deviation is requested to reduce the building setbacks from 75 feet to 50 feet. <u>Staff supports the deviation as sufficient screening is proposed.</u>
- 2. <u>Building Orientation (Sec. 3.8.2.D):</u> A Zoning Ordinance deviation is requested to revise the required orientation of the buildings from a minimum of 45 degrees in certain locations. **Staff supports the deviation.**
- 3. <u>Distance between Buildings (Sec 3.8.2.H)</u>: A Zoning Ordinance deviation is requested to reduce the building separation distance from the calculated formula. <u>As noted by City Staff, this deviation "enables the layout of this project to fit within the available space while minimizing wetland and woodland impacts".</u>
- 4. Parking along Major Drives (Sec. 5.10): A Zoning Ordinance deviation is requested to allow for perpendicular parking on a major drive. Perpendicular parking for guests is proposed on two Major Drives (Simi Drive and Beckham Drive) in several locations, where driveways are also proposed. This deviation is requested due to the impracticality of providing a minor road (defined as less than 600 feet in length) given the site constraints (woodlands, wetlands, and property configuration). As noted by City Staff "The parking spaces will not cause any more disruption on the roadway than cars that will be backing out of the driveways".
- 5. Parking along Curves (Sec. 5.10): A Zoning Ordinance may be required to allow on-street parking on curves with less than a 230-foot centerline radius. Perpendicular parking for guests is proposed along curves in several locations. These parking spaces will not cause any more disruption along the curves than cars that will be backing out of the driveways.
- 6. <u>Landscape Berms</u> (Sec. 5.5.3.A.ii): A landscape deviation is requested to not provide a 4-foot, 6- inch to 6-foot high landscape berm on a proposed RM-2 district adjacent to an OST district on the east and south side. <u>This deviation is supported by staff because of topography and the provision of dense landscaping along both property lines.</u>
- 7. <u>Right-of-Way Landscaping (Sec. 5.5.3.B.ii)</u>: A deviation to the required greenbelt berm and plantings along 12 Mile and Meadowbrook Road due to the existing natural areas to be preserved, and a heavily landscaped detention basin. <u>This deviation is supported by staff.</u>

APPLICANT'S "EXECUTIVE SUMMARY"



A PLACEMAKING DESTINATION

NOVI - MICHIGAN

09/16/2025

EXECUTIVE SUMMARY



EXPERIENCE

+ previous developments



- Proven track record of high-quality development and creative master planned communities.
- Environmentally-sensitive, award-winning projects in development, construction, and planning
- 3-time winner of the Michigan Association of Planning Best Project Award
- 2020 Home Builders Association of Southeast Michigan Developer of the Year Award




























OUR VISION

A DESTINATION COMMUNITY WITH FOUR UNIQUE VILLAGES

- Diverse options, including Townhomes, first floor master bedrooms.
- Centralized park/recreation gathering area.
- 7.8-acre, user-ready site for a multitude of typologies or demands for Trinity Health.
- Our market profile is to meet the needs of a variety of home buyers within a single community.
- Goal is to create a compatible community integrated with the environment.





REVISIONS FROM OUR PREVIOUS PROPOSAL

Many improvements were made based on input from the Planning Commission, City Council, City Staff and our continued due diligence:


- Reduced density from 438 to 232 homes
- Rezoning changed from RM-2 to lower RM-1
- All homes will be for sale, no rental units
- Added housing more suitable for seniors, over 50% of the units can accommodate first story primary bedroom
- Building architecture will now have enhanced facade materials no vinyl and more brick (removed request for variance)
- All homes will have garages, carports eliminated

- Modified design to integrate changes suggested by the City's wetland consultant
- Public access to Grove Nature Area Trail
- Rearranged the open space and parks, enlarged park on NE corner with public access
- Deviations reduced by half
- Added more public benefits




ACCESSIBILITY
TO COMMERCIAL
& RECREATION

- Site has great locational advantages convenient access to freeways
- Site convenient to shopping, along a SMART route
- Integrated into non-motorized network, including M-5 Metro Trail
- Twelve Oaks Mall and other shopping and personal care establishments within walking, biking, and scootering distance
- Proximity to accessible wetland and woodland areas for passive recreational activities- including hiking, biking, and nature-viewing




DEMAND FOR DIVERSE RESIDENTIAL OPTIONS


- Ivanhoe engaged numerous market consultants to evaluate potential uses
- Market studies concluded that there is a need for more diverse housing
 - Singles
 - Young Couples
 - First-Time Home Buyers
 - Active Seniors
- Housing that appeals to Generation X, Y, Z including those who grew up in the City
- Housing for seniors in Novi who want to downsize but stay in the City
- A walkable, environmentally sensitive design with ample open space and amenities
- Aligns with Master Plan goals for more diverse housing options



WHY OST IS NOT APPROPRIATE FOR THE ENTIRE SITE

- Limited market for OST uses, even when the office market was strong there was no interest
- Wetlands on our site makes it difficult to develop with OST uses and their parking
- Various sites, more attractive in Novi, remain available for development or redevelopment, especially along the M-5/Haggerty Corridor
- Northwest corner is more attractive for business development under the new GMX designation for the property





FUTURE LAND USE DESIGNATION

City of Novi 2023 Master Plan


- The location, size and environmental features make the site unique.
- Our proposal is consistent with the Master Plan GMX designation.
- Provide attainable and desirable housing essential to support the existing and evolving retail and entertainment hub of Novi.


The GMX land use category provides the highest flexibility of the categories. It recognizes that certain properties will be developed based on the prevailing market trends utilizing a site-specific master plan to guide development reserving certain portions of the subject property for different land use typologies.

-Adopted Master Plan



CITY OF NOVI FUTURE LAND USE MAP 2016 Edition






THE CORNER

A signature site

- 18% of developable area for future business uses, user-ready site for a multitude of uses or demands for Trinity Health or future use.
- Flexibilty to address evolving market trends and land use typologies.
 - Corporate office
 - Commercial
 - Retail / shopping
 - Other headquarters use
 - Healthcare facility
 - Integrated mixed-use
 - Hotel
 - Other complementary uses
- Setbacks and buffering to support office/business use at the corner.



MEADOWBROOK





PUBLIC/PRIVATE OPEN SPACE & PATHWAYS PLAN

- 32.5 % total open space.
- Connected network of sidewalks, compacted stone walking trails, and natural hiking trails
- Novi public SMART bus stop
- Public access to Grove Nature
 Area Trail along the MDOT
 Pond and Conservation
 Easement to the east with
 scenic overlook.
- When combined with adjacent open space protected by conservation easements, our open space creates a large, contiguous habitat area.
- Public access to 12 Mile
 Rd Park and Open Space

Off-site bike paths

8 ft sidewalk



Compacted stone walking trails


or natural hiking trails



Bus stop

PARK/RECREATION AREA

- Centralized park/ recreation area.
- Sidewalks, gravel walking trails, and natural hiking trails.
- Setbacks and buffering to support office/businesses.
- Outdoor parks and gathering areas.
- Amenities included:
 - Pocket parks
 - Pickleball court
 - Playscape
 - Picnic areas
 - Natural features
 - Bike racks

















FOUR DISTINCT VILLAGES







The Pointe



- Various home styles
- Diversity- vary by color, materials, height
- Include 1st floor bedroom ranches to appeal to seniors





The Meadows



- Various home styles
- Diversity- vary by color, materials, height
- Include 1st floor bedroom ranches to appeal to seniors



PRO PUBLIC BENEFITS

1. 12 Mile Road Park and Open Space

1 acre open space park/rest stop, accessible to the public

2. Grove Nature Area Trail

One mile loop trail along the east property line, providing scenic views of MDOT wetland, open to the public

3. Beacon Hill Park Improvements

A provision of funding towards the buildout of the Beacon Hill Public Park

4. Off-Site Pathway (per the 2023 Active Mobility Plan)

Over 700 ft of new off-site pathway along 12 Mile Rd.

5. New Novi Public Bus Stop

New SMART bus stop with seating, bike racks, and landscape area

6. Increased Usable Open Space

5.97 acres of "useable" open space, 260% more than the required 1.65 acres

7. Novi Connectivity Sidewalk

New 8 ft, wide internal loop bypass connecting 12 Mile Rd. with Meadowbrook Rd

8. Dedication of Woodland and Wetland Conservation Areas


Conservation easement for Woodlands and Wetlands is 25.8 acres. Over 47% of the site.

9. Decreased density

Density capped at 4.23 units per acre, 60% less than the 7.3 units allowed for 3-bedrooms

10. Meadowbrook Road Right-of-Way Dedication


Dedicate the right-of-way along the entire Meadowbrook Rd frontage (2,166 ft), totaling 2.5 acres.





ADDITIONAL BENEFITS

- Diverse Housing Options. Provide more housing options, particularly for multigenerational housing, including over 50% of the units which can accommodate first floor primary suites suitable for senior living
- Variety of housing styles- 80% front open space
- For sale homes (removed rental units)
- Varied designs with garages (removed car ports)
- Flexible floor plans, homebuyers can select their floor plan
- 80% less traffic than OST (and 40% less that initial plan)
- Creative design intended to preserve and enhance natural features of the site, unlike OST zoning
- High quality landscaping and natural buffers to enhance the viewsheds along Meadowbrook Rd






CONCLUSION


- OST uses are not the best fit for this property
- Design is consistent with the evolving character of the area
- Retains OST zoning for the prime corner
- Meets the need for unique, diverse housing in the City
- Adds population into the existing commercial market area
- Residential nestled among the ample open space (33%)













PLAN REVIEW CENTER REPORT

Planning Review

September 17, 2025

JZ 24-31 The Grove

Zoning Map Amendment No. 18.745

PETITIONER

Ivanhoe Companies

REVIEW TYPE

Revised Formal PRO Concept Plan

Rezoning Request from OST Office Service Technology to RM-1 Low-Density Multiple Family with a Planned Rezoning Overlay

PROPERTY CHARACTERISTICS

Section	13		
Site Location	East sic	East side of Meadowbrook, south of Twelve Mile Road;	
Site School District	Novi Community School District		
Current Site Zoning	OST, O	OST, Office Service Technology	
Proposed Site Zoning	RM-2, F	RM-2, High-Density Multiple Family	
Adjoining Zoning	North	R-4 and B-3 with a PRO; RA Residential Acreage	
	East	OST, Office Service Technology	
	West	OST, Office Service Technology	
	South	OST, Office Service Technology	
Current Site Use	Vacan	Vacant	
	North	Vacant, Beacon Hill park	
A di ainin a Hana	East	MDOT-owned natural area	
Adjoining Uses	West	U of D Mercy, vacant, Single Family, Office Buildings	
	South	Office Complex	
Site Size	Gross:	Gross: 61.86 Acres; Net: 54.85 acres (ROW: 2.32, Wetlands > 2: 4.69)	
	22-13-100-024; 22-13-100-026; 22-13-100-030; 22-13-100-028; 22-13-100-		
Parcel ID's	005; 22-13-100-006; 22-13-100-007; 22-13-100-008; 22-13-100-009; 22-13-		
	100-010; 22-13-100-020; 22-13-100-021		
Plan Date	August	August 22, 2025	

PROJECT SUMMARY

The subject property is located on the east side of Meadowbrook Road, south of Twelve Mile Road in Section 13 of the City of Novi. The property to be rezoned totals about 61.86 acres and contains a significant amount of regulated woodland and wetland areas. The applicant is proposing to develop a 232-unit multiple-family residential development (reduced from 438 units in the Initial PRO). The development consists of four "villages" of homes: The Meadows (67 attached units in 14 buildings), The Vistas (68 attached units in 15 buildings), The Woods (36 attached units in 8 buildings) and The Pointe (61 attached units in 12 buildings). Wetland mitigation is proposed on-site to replace impacted wetland areas. The development utilizes a private street network with two entrances off Meadowbrook Road, and one entrance off Twelve Mile Road. The applicant is requesting to rezone the site from Office Service Technology (OST) to Low-Density Multiple Family (RM-1) with a Planned Rezoning Overlay.

PRO OPTION

The PRO option creates a "floating district" with a conceptual plan attached to the rezoning of a parcel. As part of the PRO, the underlying zoning is proposed to be changed (in this case from OST to RM-1), and the applicant submits a conceptual plan for development of the site, along with site-specific conditions relating to the proposed improvements. After staff and consultant review, the proposed request goes through initial consideration by the Planning Commission and City Council to review and comment on whether the project meets the requirements of eligibility for a PRO. The applicant can then make any changes to the Concept Plan based on the feedback received, and resubmit for formal review. The Planning Commission holds a public hearing and makes a recommendation to City Council. The City Council reviews the Concept Plan, and if the plan receives tentative approval, it directs the preparation of an agreement between the City and the applicant, which also requires City Council approval. Following final approval of the PRO Plan and Agreement, the applicant will submit for Preliminary and Final Site Plan approval under standard site plan review procedures. If development is not commenced within two years from the effective date of the PRO Agreement it will expire, unless otherwise agreed to by the parties.

PROJECT HISTORY

The project was submitted and reviewed by staff and consultants in a pre-application submittal in May 2024. Comments were provided on the concept plans submitted, but no recommendations for approval were made at that time.

The initial PRO plan was submitted and reviewed in August/September 2024. At that time, the applicant was proposing to develop a 438-unit multiple-family residential development with a mix of townhomes and apartment buildings. The Planning Commission held a public hearing on October 30, 2024, and provided feedback on the proposal. On December 16, 2024, City Council considered the request and provided feedback to the applicant. Minutes from both meetings are available on the city website.

RECOMMENDATION

Staff supports the rezoning to RM-1 with the PRO Plan. There are conditions proposed that are more strict or limiting than the RM-1 standards, and that could be found to provide an overall benefit to the public. The identified benefits of rezoning appear to outweigh the anticipated detriments of introducing residential use to this section of Meadowbrook Road.

PLANNING COMMISSION

The Planning Commission held a Public Hearing on October 30, 2024, to review and make comments on the proposal's eligibility for using the Planned Rezoning Overlay option. Comments made at that time are reflected in the meeting minutes and are summarized here:

- Commissioners said they thought the use proposed could make sense, and could be compatible with adjacent uses if other concerns are addressed.
- Commissioners stated that more meaningful benefits to the public were needed.
- Commissioners were concerned about whether sufficient buffers or screening to adjacent non-residential properties are included, and would like to see better screening along Meadowbrook Road and Twelve Mile Road.
- Commissioners thought the façade materials need to be addressed to better conform to the Ordinance. (Note: The revised elevations are now fully compliant with the Ordinance. The designs show a high level of character and attention to detail.)
- Commissioners stated they thought the density of the proposed development was too high.
 (Note: The revised proposal has 206 fewer units than the previous plan, reducing the density

from 7.9 to 4.2 dwellings per acre. They have also revised the requested zoning from RM-2 to RM-1.)

- Commissioners encouraged the applicant to consider units that would accommodate senior housing. (Note: The revised proposal now includes over 50% of the units to be singlelevel living, which would enable aging in place.)
- Commissioners thought the amount of green space and walkability were positive aspects of the proposal.
- Commissioners stated the change from the use recommended in the 2016 Master Plan was a significant issue. (Note: The recently adopted 2025 Master Plan recommends mixed-use planned development. See further discussion in this review.)
- Commissioners encouraged the applicant to rethink the number of deviations requested, and should better conform to ordinance requirements. (Note: The number of requested deviations is now 8 as opposed to the previous proposal which had 16.)

CITY COUNCIL

The City Council provided feedback at its meeting on December 16, 2024, on the proposal's eligibility for using the Planned Rezoning Overlay option. Comments made at that time are reflected in the meeting minutes, and comments are summarized here:

- Councilmembers thought positive aspects of the proposal are the amount of open space, conservation easements to protect natural features, and the focus on connectivity.
- Councilmembers were in favor of protecting the existing wetland and woodland areas as much as possible. (Note: The revisions in the design result in less wetland impacts, and the mitigation can now be fully provided on-site.)
- Councilmembers thought the use of multiple types of housing was beneficial. (Note: The
 revised proposal includes two housing types (ranch and 2-story townhomes), rather than 3
 types proposed previously.)
- Councilmembers were in favor of having for-sale units that would accommodate senior housing. (Note: All units are now for-sale. The revised proposal now includes over 50% of the units to be single-level living, which would accommodate aging in place.)
- Councilmembers expressed concerns about the departure from Façade Ordinance standards. (Note: The revised elevations are now fully compliant with the Ordinance. The designs show a high level of character and attention to detail.)
- Councilmembers stated that greater effort to provide meaningful benefits to the public was needed, and clarified that amenities that are not available to the general public are not considered public benefits. (Note: In the revised plan the applicant has refined the list of benefits offered. See discussion of benefits on page 15 of this review.)
- Councilmembers suggested public art, SMART bus amenities, incorporating best practices
 for sustainable building materials and energy efficiency, as well as recommendations from
 the Active Mobility Plan, could be public benefits to consider. (Note: See the discussion of
 benefits offered on page 15 of this review).
- Councilmembers encouraged the applicant to consider adding fiber internet infrastructure at the outset.
- Councilmembers expressed concerns about screening from future development on the Trinity parcel, and thought it would be beneficial if that parcel was part of the development proposal to allow better coordination. (Note: While the development of the parcel is not included in this proposal, additional landscape screening is provided where the closest homes are located, and some existing trees are to remain.)

- Councilmembers wanted to see more garage parking as opposed to open lots or carport parking. (Note: In the revised plan each unit has a two-car attached garage and no large parking lots are proposed.)
- Councilmembers stated that building heights could be taller in this part of the city, especially if it offered an opportunity to preserve more natural features. (Note: In the revised plan the buildings are shorter, and all will comply with the 35-foot height limit of the RM-1 District.)

REVIEW CONCERNS

This project was reviewed for conformance with the Zoning Ordinance with respect to Article 3 (Zoning Districts), Article 4 (Use Standards), Article 5 (Site Standards), Section 7.13 (Amendments to Ordinance) and any other applicable provisions of the Zoning Ordinance. Please see the attached chart for additional information pertaining to ordinance requirements. Items in bold below must be addressed and incorporated as part of the next submittal:

- 1. <u>Supporting Documentation:</u> The applicant has provided the following studies as part of their application packet
 - a. Narrative: The statement provided states Rezoning allows for development of an otherwise very difficult parcel to develop, and that a residential development will result in significantly less impact on the existing natural features as compared to an OST development. The applicant notes office market challenges that restrict the desirability of office development on this site. The proposed development will offer "diverse housing options within a single residential community, geared toward young professionals, families, and those looking for a maintenance-free lifestyle." The proposed community will be organized into 4 "villages". The narrative indicates the isolated location of the Property and the natural features on and around the site are ideal and attractive for a successful residential project, and will help buffer the project from OST-zoned properties around it.
 - b. The statement also notes the conditions and deviations proposed, as well as public benefits. Those are detailed later in this review.
 - c. **Traffic Impact Study** (Fleis & Vandenbrink, 10/11/24 and Memo 7/1/25): The City's review of the submitted study notes that the change of use should result in fewer vehicle trips on the traffic system compared to development under OST standards. A tapered right-hand turning lane is recommended to be provided on Twelve Mile Road. **AECOM's review of the October 2024 revised TIS recommends approval.**
 - d. Community Impact Statement (8/7/24): This document describes the property and its relationship to adjacent land uses. It also discusses the environmental features on the site, as well as open space and stormwater disposal strategies. Economic benefits, community and social impacts are mentioned. Finally, the impacts on City services and utilities are covered, including police and fire demand, utilities, and traffic/mobility networks. As requested by members of the Planning Commission, the applicant attempted to request data to compare the impacts of the proposed development with the parallel plan under OST development for Fire and Police responses, but were told the City's emergency services do not keep that type of data. The CIS has been updated to reflect the changes to the plan made since the Initial PRO plan.
 - e. Commercial Market Study (CBRE, INC. 12/13/23): The study area includes a map of OST-zoned property in Novi, which encompasses areas zoned for Regional Commercial. The study concludes that there is little interest in OST-type uses on this site due to the overall depressed office market, more attractive locations, and the environmental factors on the subject property. The extensive presence of both woodland and wetland areas on this particular site are not attractive to OST development because of the development limitations and high costs associated with developing large-scale uses and needing to mitigate for those impacts.

- f. **Residential Market Evaluation** (The Chesapeake Group, INC. 8/9/24): The document notes a strong demand for multi-family housing types in Novi and Oakland County, like that proposed by The Grove. A survey found that the majority of respondents who indicated they may move within 5 years would seek homes that are smaller or the same size as their current home. The most dominant factors in determining where to live are safety and walkability. "The Grove's housing mix, walkability, ownership-rental options, and proximity to the region's amenities are consistent with the market's desires. Inclusion of townhomes provides attainable housing even for those who want to purchase. The Grove's longer-term success is extremely probable due to the variety of options."
- g. **Sign Location Plan:** Location and size of signage was previously approved, and has been posted on the site.
- 2. Eligibility for PRO (Section 7.13.2): "In order to be eligible for the proposal and review of a rezoning with PRO, an applicant must propose a rezoning of property to a new zoning district classification, and must, as part of such proposal, propose clearly-identified site-specific conditions relating to the proposed improvements that (1) are in material respects, more strict or limiting than the regulations that would apply to the land under the proposed new zoning district, including such regulations or conditions as set forth in Subsection C [of the Ordinance]; and (2) constitute an overall benefit to the public that outweighs any material detriments or that could not otherwise be accomplished without the proposed rezoning." The applicant provided a request to rezone to RM-1, along with a PRO Plan. The conditions proposed that are more strict or limiting than typical RM-1 standards include providing much greater open space, limiting the density, greater number of parking spaces, and providing conservation easements over a large portion of the project area. The applicant states that their proposal constitutes an overall enhancement of the area because they intend to make a majority of the units have firstfloor primary bedrooms to enable single-floor living and provide an 8-foot pathway through the community that is available to the public. Other benefits to the public include construction of an off-site missing pathway segment (on Trinity parcel), relocation and enhancement of a SMART bus stop, the provision of public art for nearby Beacon Hill Trailhead, and a publicly-accessible park in the northeast corner of the site with seating and access to a 1-Mile nature trail overlooking MDOT's wetland area. See page 15 for further discussion of benefits to the general public.
- 3. <u>Detrimental Effects of Rezoning</u>: Compared to the types of commercial establishments that could be developed by-right in the current OST District, the multiple-family development proposed may create some undesirable impacts on the adjacent parcels, such as:
 - a. <u>Development Limitations:</u> Adjacent undeveloped properties will now be required to construct a 4-6 foot berm between their property and the proposed residential district.
 - b. <u>Greater Setbacks:</u> When adjacent to a residential district, the OST district requires a building setback of 100 feet, rather than 50 feet.
 - c. <u>Employment Impact:</u> Compared to an OST development, a residential development will not create long-term employment opportunities on the site, but will provide homes for workers.

If the PRO rezoning were to be approved, the City would want to ensure that these detriments are minimized or offset to a large extent to protect the existing OST Landowners as well as future residents of the development. Additional conditions have been included in the formal submittal that are more strict or limiting than would be permitted under the RM-1 district to minimize these negative impacts.

4. <u>Façade Materials (Sec. 5.15):</u> As noted in the Façade Review, the façade materials proposed now conform to the Ordinance requirements. **The building designs have eliminated vinyl siding, which is not permitted, and now meet or exceed the 30% minimum brick requirement. In addition, the attention to detail and character of the building designs qualify as an**

enhancement of the area beyond what could be required by the ordinance. These characteristics will need to be shown to carry through on the Preliminary and Final Site Plans.


- 5. Pickleball Court: The plan and narrative indicates a pickleball court will be one of the amenities to be developed, along with a playscape, in a central area of the project. As shown on the plan, the court would be 100 feet from the nearest residence. While pickleball is a very popular and growing sport, we have heard reports from Novi residents and other communities that the sound produced during play is very disruptive/disturbing to those living in proximity to these facilities. Consideration of sound buffering around the pickleball court would need to be a condition to protect future residents from this nuisance. A condition could be included in the PRO Agreement that a noise impact study be provided in the site plan process for any pickleball courts proposed to ensure it and any noise mitigation will comply with the performance standards of Section 5.14 of the Zoning Ordinance.
- 6. <u>Plan Review Chart:</u> See the attached chart for additional comments on many of the Ordinance review standards. Identified deviations from ordinance standards are listed in detail on pages 16-17 of this review letter.

LAND USE AND ZONING: FOR SUBJECT PROPERTY AND ADJACENT PROPERTIES

The maps below show both the current zoning of the subject property and adjacent areas, and the Future Land Use map which was recently updated by the 2025 Master Plan. The General Mixed Use designation is new with the adopted 2025 Master Plan. See further discussion on pages 10-11 of this review.



Figure 2: Future Land Use (2025 Master Plan)



The following table summarizes the zoning and land use status for the subject property and surrounding properties.

	Existing Zoning	Existing Land Use	Master Plan Land Use Designation
Subject Property	OST: Office Service Technology and RM-1 Multiple Family	Vacant	General Mixed Use (GMX)
Northern Parcels	RA, R-4: One Family Residential and B-3 General Business	Public Park and Vacant	Public Park, Community Commercial, and Single Family
Eastern Parcels	OST: Office Service Technology	M-DOT wetland/stormwater area	Public
Western Parcels	OST: Office Service Technology and RM-1: Multiple Family (proposed)	Single family; Multi-family residential (proposed) and Office/warehouse uses	General Mixed Use (GMX)
Southern Parcels	OST: Office Service Technology	Office park	General Mixed Use (GMX)

Compatibility with Surrounding Land Use

The subject property is located along the east side of Meadowbrook Road, south of Twelve Mile Road and west of M-5. There are existing office developments to the south and west in areas zoned OST. On the west side of Meadowbrook the Elm Creek PRO is under consideration for RM-1 zoning to allow a townhome development. The area to the east is a 30-acre property owned by M-DOT that is used for wetland mitigation and stormwater management. To the north across Twelve Mile Road is the City's Beacon Hill Trailhead Park and a vacant area zoned B-3 which was part of the Beacon Hill PRO. To the northeast is area zoned Residential Acreage, which has been approved for the Armenian Church and Cultural Center. Most of the surrounding properties are developed, but there are some parcels that are currently vacant. The proposed use is not consistent with the surrounding existing uses to the north, west and south based on current Zoning requirements. However, it would be complementary with the open space to the east and the proposed Elm Creek development on the west side of Meadowbrook Road.

The applicant's narrative notes that the target market of the proposed development is multigenerational. "The Grove is intended to provide a full range of flexible housing options catering to diverse, multi-generational residents, ranging from younger residents, families and older residents to age in the community.

The current concept plan proposes a development of 232 units (density of 4.2 dwellings per net acre) for a mid-density multifamily development which is below the 15.2 density recommended in the current Master Plan, and less than the 5.4 dwellings per acre maximum in the RM-1 District for 3-bedroom units. The buildings are clustered in 4 different "villages," thoughtfully arranged to allow for the preservation of extensive wetland and woodland areas on the site. The applicant is proposing a deviation to allow 50-foot setbacks where adjacent to other OST properties, which are consistent with the current OST zoning, rather than the 75 feet requirement for RM-1 zoning. This also places the units closer to the existing office uses in the surrounding area than would be expected in the RM-1 district.

The site is adjacent to high tech office developments to the west and south, where the zoning will remain OST. Some potential conflicts with the adjacent users could be the noise and disruption of truck traffic, including loading and unloading functions, on the future residents. The adjacent OST property owners may be affected in the future being adjacent to a residential zoning district: additional berms and screening are required, and building setbacks are increased to 100 feet. The closest residential unit would be about 125 feet from a potential future building site in the office park to the south. To the north, there are approved but not yet built projects that will eventually be built on the north side of 12 Mile Road: the B-3 portion is subject to a PRO Agreement that allows

about 11,000 square feet of retail uses to be developed, and on the R-A zoned property the multiphased Armenian Church and Cultural Center is anticipated to be developed.



Figure 3: Names of surrounding developments and businesses

The narrative states that there are natural buffers in place that will shield the residential units from the surrounding commercial uses. The undisturbed woodland and wetland areas on the site and surrounding properties would allow the proposed use to "remain relatively secluded" from the commercial properties, as well as provide natural spaces contiguous with adjacent preserved areas. The remaining undeveloped properties in the area that could develop under the OST zoning district are not likely to cause significantly greater conflicts with residential use on this site since they are located on the other side of Meadowbrook. The applicant has proposed a berm and dense landscaping along the southern portion of the property, which will provide an adequate screening buffer to that office complex. The area to the east of the property will remain undeveloped as it is an MDOT stormwater and wetland mitigation site.

Comparison of Zoning Districts

The following table provides a comparison of the current (OST) and proposed (RM-1) zoning classifications. It is not a direct comparison between the two uses, given that the two uses are

clearly distinct from each other. It is a change of use from Office to Residential. The requirements for building setbacks, buffering and lot coverage are also different between the two districts.

	OST (EXISTING)	RM-1 (PROPOSED)
Principal Permitted Uses	Professional and Medical offices; Data processing and computer centers; Laboratories; Research, testing, design & development, technical training; Hotels; Higher learning institutions; Motion picture, TV, & radio production facilities; Facilities for human care; Public parks/parkways, outdoor recreation; Public utilities; Financial institutions; Indoor/outdoor recreation facilities; Day care centers and adult day care; Sit down restaurants	Multiple-family dwellings; Independent and congregate elderly living facilities; Two-family dwellings; Shared elderly housing; One-family dwellings; Farms & greenhouses; Public parks, parkways, and outdoor recreation; Cemeteries; Home occupations; Family day care homes
Special Land Uses	Retail business and retail service; Restaurants, sit down and drive-through	Convalescent homes, assisted living facilities, hospice care facilities and child care centers
Lot Size	Except where otherwise provided in this Ordinance, the minimum lot area and	See Section 3.8.1
Lot Coverage	width, and the maximum percent of lot coverage shall be determined on the basis of off-street parking, loading, greenbelt screening, yard setback or usable open space requirements as set forth in this Ordinance.	25%
Usable Open Space	NA	200 sf per unit
Building Height	46 ft. or 3 stories, whichever is less	35 ft or 2 stories, whichever is less
Building Setbacks	Front: 50 feet Rear: 50 feet Side: 50 feet Exterior side yard setbacks same as front yard Building setbacks increased to 100 feet when adjacent to residential	Front: 50 feet Rear: 75 feet Side: 75 feet Exterior side yard setbacks same as front yard
Parking Setbacks See 3.6.2. for	Front: 20 feet Rear: 20 feet Side: 20 feet Exterior side yard setbacks same as front	Subject to 3.8 RM-1 and RM-2 Required Conditions
additional conditions	yard	

DEVELOPMENT POTENTIAL

Like much of the City of Novi, this area was formerly agricultural land. Based on aerial imagery, the land was no longer plowed for crops after 1960. There were 5 homes present for many years, but all were demolished by 2010. Land records indicate that all 12 properties were purchased by Mercy Health in 1997-1998. The land is currently vacant.

Development under the current OST zoning could result in a substantial amount of Office or Research & Development building space being constructed on this large parcel. In the narrative provided, the applicant states that a commercial development on this property would result in significantly greater disturbance of the woodlands and wetlands on the site due to the typically large footprint of the buildings and the parking lots that are required to support them. A parallel

plan is provided (Sheet SP-3.8) that shows a potential OST development scenario, which includes nearly 1,000,000 square feet of building, with nearly 3,000 parking spaces. Underground stormwater detention and bioswales would be used. This parallel plan has not been fully reviewed to determine feasibility, such as accommodating wetland mitigation.

There have been no formal submittals for development proposals in the last 30 years for the subject property. The City's records show a development called Sinai Park was proposed on the property in the mid-1990s, proposing a 540,000 square foot medical health care and office complex. The developer has provided a market study that concludes that there is a lack of development potential for OST-type uses on this site due to the overall depressed office market, more attractive locations, and the environmental factors on the subject property would make this location very expensive. The extensive presence of both woodland and wetland areas on this particular site are not, the Developer contends, attractive to OST development because of the development limitations and high costs associated with developing large-scale uses and needing to mitigate for those impacts.

2025 MASTER PLAN FOR LAND USE: GOALS AND OBJECTIVES

Since the review of the Initial PRO plan, the City has adopted the 2025 Master Plan. The subject area was included in the Land Use Framework plan as an "Area of Transformation" (page 93). These areas are generally located south of Twelve Mile Road, north of Grand River Avenue between Beck Road on the west and Haggerty Road on the east. Another map titled "Potential Opportunities" (page 94) indicates the subject site for new development.

The Future Land Use map now designates the subject area and those surrounding it as General Mixed Use (GMX). This new land use category is meant to provide a high degree of flexibility in development, with a site-specific master plan to guide development. "Properties within this designated land use category can also utilize the PUD (Planned Unit Development Option) as a development tool to provide a variety of uses within an approved master plan development."

GENERAL MIXED USE (GMX)				
Purpose	The GMX land use category provides the highest flexibility of the categories. It recognizes that certain properties will be developed based on prevailing market trends utilizing a site-specific master plan to guide development, reserving certain portions of the subject property for different land use typologies. Properties within this designated land use category can also utilize the PUD option as a development tool to provide a variety of uses within an approved master plan development.			
Regulated Uses	Non-Residential	Residential		
	» Retail; General	» Attached Single Family		
	» Exhibition and Conference Facilities	» Multiple Family		
	» Research and Development	» Upper Story Apartments and Lofts		
	» Scientific and Technical Services			
	» Healthcare Facilities			
	» Professional Offices			
	» Restaurants			
	» Open Space and Plazas			
Built Form	Unique properties that may have environmental limitations (wetlands, brownfields, etc.)			
	Development is focused on maximizing the site while creating a unique and integrated development.			
	Pedestrian walkability and connectivity would be desirable. Building height could vary between 2 to 5 stories.			

The following Action Plan items (<u>underlined</u>) as listed in the Master Plan are applicable to the proposed development. Please refer to staff comments in bold and revisions recommended in <u>bold</u> <u>and underline</u>.

- 1. General Goal A: Quality and Variety of Housing. The City of Novi is known for its high-quality residential neighborhoods. It should strive to ensure the availability of a wide range of attractive housing choices protected from noise, traffic, and other impacts of non-residential development. Encourage the development of neighborhood open space and neighborhood commercial goods and services to minimize motorized travel.
 - a. Amend the zoning ordinance to encourage "age-in-place" housing types, considering experts' recommendations, to include affordable options such as low-maintenance detached single-family homes, attached single-family homes and townhouses.
 - b. Explore opportunities to increase housing density in the proposed mixed-use planned unit development area to create "walkable density" environments (A6). The development proposes the required sidewalks along the private streets, as well as a 10-foot mutli-use pathway along the main internal roadway. Pathways are present along Meadowbrook Road, and will be constructed on 12 Mile Road on-site and off-site on the adjacent Trinity parcel. Additional recreational amenities shown on the plans are a pickleball court, a playscape, and nature trails. A clubhouse is also included as an optional facility.
- 2. **General Goal B: Community Identity.** The City's identity is largely based on its high-quality residential neighborhoods and schools, destination retail and convention space, and its parks. The City should supplement that identity by enhancing the preservation of its historic resources and expanding its cultural opportunities. New development of land should continue to be of high-quality design and materials.

- a. Encourage the use of high-quality right-of-way plantings, site landscaping, and building materials to enhance the appearance of the community. The proposed elevations are mostly compliant with Façade Ordinance. Please refer to the façade review letter for opportunities to achieve full compliance. The landscaping has been improved to comply with standards, with only two supported waivers now needed.
- b. As development and redevelopment occur, incentivize the use of LEED-certified buildings, water resources, and energy-efficient best practices, and green infrastructure techniques through zoning and permit bonuses. The applicant indicates they will utilize sustainable, energy-efficient and best-practice design for site elements and building materials. See Conditions section for further discussion.
- **3. General Goal C: Environmental Stewardship.** The City of Novi is significantly enhanced by the preservation of natural resources in both residential and non-residential areas. Maintain public and private stewardship of the natural environment using low-impact development techniques.
 - a. <u>Utilize a general Planned Unit Development ordinance provision to encourage the preservation of natural features, such as woodlands, wetlands, and wildlife habitats.</u> While the City does not currently have a general PUD ordinance of the sort discussed in the Master Plan, the PRO ordinance is a kind of PUD and provides a similar mechanism for the City to authorize a master-planned development tied to a rezoning. The applicant is proposing as a condition of the PRO protection of a significant portion of existing and mitigated woodland and wetland areas.
 - b. Implement the Active Mobility Plan's Near-Term Network recommendations to create continuous walking and biking networks to reach key destinations. The Concept plan proposes recreational opportunities for the residents. The applicant proposes a clubhouse with a pool and park area with pickleball courts and a playground. A 10-foot pathway along their 12 Mile frontage is shown, as required. The applicant has also included an internal 10-foot multiuse pathway and a network of walking trails and nature overlooks. Along Meadowbrook and 12 Mile the plan also proposes a rest/seating areas that would be available to the general public. The seating areas appear to consist of landscaping and benches. One would serve as a SMART bus stop on 12 Mile and the Meadowbrook area would have a public art piece.
 - c. <u>Implement the recommendations of the Active Mobility Plan with a focus on reducing vehicle miles traveled (VMT) and providing residents with alternative modes of transportation.</u>
- **4. General Goal D: Infrastructure.** Invest wisely in the ongoing maintenance and improvements to existing infrastructure, including utilities and the transportation network. Ensure that new development appropriately relates to the City's existing and planned infrastructure. Support the entire transportation network through the development and enhancement of non-motorized transportation facilities and amenities.
 - a. Apply the Active Mobility Plan's Long-Term Network recommendations to public and private development projects to continue to enhance safety and connectivity of the non-motorized network. A bus stop is proposed along 12 Mile Road frontage, which would need to be coordinated with SMART.
- 5. General Goal E: Economic Development. The City's developed land, infrastructure, and natural resources are interconnected and collectively impact the daily lives of the City's residents and business owners. The City should strive to maintain the balance between the economy, the environment, and the community to ensure sustainable development that meets the needs of today while ensuring that the needs of future generations can be met.

Rev Formal PRO Concept Plan Review

There is an existing 10-foot wide pathway along the Meadowbrook Road frontage. This pathway connects the I-275 Metro Trail (Meadowbrook & Eleven Mile) to the Beacon Hill Trailhead Park at the northeast corner of Meadowbrook and Twelve Mile. From there, connections are also available to the Airline Trail in Commerce Township, north of the City's boundary, via the M-5 Metro Trail.

The applicant is proposing to construct the missing pathway gap along their Twelve Mile Road frontage as well as the Trinity Parcel, which is a <u>Near-term priority</u> in the AMP. This would result in approximately 1,300 feet of new 10-foot pathway. To the east, the M-5 interchange presents a significant barrier to continuing the pathway – there will remain a 2,060 foot gap in the non-motorized network. Existing pathway to the west would connect this area to the Twelve Oaks, West Oaks and Fountain Walk commercial areas.

With the presence of SMART transit stops on Twelve Mile Road, the recommendations to better connect non-motorized users to transit are particularly relevant in this area. These recommendations include:

- Coordinate crosswalks with transit stops
- Incorporate streetscape amenities to create an inviting and pedestrian-friendly environment at transit locations
- Establish mobility hubs, a place where people can connect to multiple modes of transportation

Meadowbrook Road is classified as a cross-town corridor in the AMP, while 12 Mile Road is a multi-modal thoroughfare. The recommended baseline pedestrian facility improvements for minor road stops (where the pathway crosses the entrances to the development) on both roads would include crosswalk lighting, a raised high visibility crossing and recessed crossings where feasible. For bicycle facility improvements, separated bike lanes are preferred, or a 12-foot shared-use pathway to accommodate both bikes and pedestrians. Mid-block crossings might be considered on 12 Mile Road – the AMP contains an example of a Median U-turn on page 77, which would need to be controlled with traffic signals.

INFRASTRUCTURE

Engineering

The Staff Engineer has reviewed the rezoning request and expressed concerns regarding the REU calculations provided. These inconsistencies have been corrected in the current submittal. It appears the impacts of RM-1 land use on the utilities in this area are expected to be similar or somewhat less than the utility demands if developed under OST uses.

Traffic

City Traffic consultants estimated the vehicle trips of the proposed use. The proposed development is expected to result in significantly fewer trips than alternative land uses under the current OST zoning. Based on the TIS, the site warrants a right-turn tapered lane on Twelve Mile Road. A weave analysis concludes that there is adequate distance between the site driveway and the boulevard crossover location. The Traffic consultant's September 2025 review of the TIS recommends approval of the study, and that the applicant coordinate with RCOC if the project moves forward. See the traffic review letter for additional information.

NATURAL FEATURES

Wetlands: The survey shows 21 wetlands, ranging in size from 0.02 – 4.79 acres, with a total of 9.64 acres on-site. Chapter 12 of the City Code (Section 12-174(b)), indicates that any wetland in the City that meets one or more of the 10 criteria listed in that section would be considered essential, and therefore would be regulated. As described in the Wetland Review, each of the delineated wetlands on the site meet the criteria of providing wildlife habitat as well as flood and storm control.

The proposed development results in a total permanent wetland impact area of 1.44 acres out of

the total 9.64 acres present (~15 percent). Approximately 2.47 acres of on-site mitigation area is noted on the plan, which slightly exceeds the 2.46-acre requirement. The applicant indicates that they intend to accommodate the required wetland mitigation that will be needed for the parcel retained by Trinity Health. See detailed comments in the Wetland review letter. The applicant notes that approximately 8 acres of wetlands are regulated by the State of Michigan.

<u>Woodlands:</u> The woodland survey indicates a total of 2,775 City-regulated trees on the site. There are a wide variety of species listed, including Scots Pine, Black Cherry, Silver Maple, Eastern Cottonwood, Bitternut hickory, Black locust, Black walnut, American Elm, and Eastern Red Cedar. The plans show 2,019 regulated trees to be removed (73 percent), which will require 3,143 tree replacement credits under the Woodland Protection Ordinance. The plans show approximately 250 credits to be planted on-site.

MAJOR CONDITIONS OF PLANNED REZONING OVERLAY AGREEMENT

The Planned Rezoning Overlay process involves a PRO concept plan and specific PRO conditions in conjunction with a rezoning request. The submittal requirements and the process are codified under the PRO ordinance (Section 7.13.2). Within the process, which is initiated by the applicant, the applicant and City Council can agree on a series of conditions to be included as part of the approval which must be reflected in the Concept Plan and or the PRO agreement.

The PRO conditions must be in material respects, more strict or limiting than the regulations that would apply to the land under the proposed new zoning district. Development and use of the property shall be subject to the more restrictive requirements shown or specified on the PRO Plan, and/or in the PRO Conditions imposed, and/or in other conditions and provisions set forth in the PRO Agreement.

The applicant could consider the following conditions for development to be included in the PRO Agreement:

- 1. Preservation of approximately 10 acres of City regulated woodlands and woodland replacements in a conservation easement.
- 2. Preservation of approximately 15.5 acres of City regulated wetlands and wetland mitigation areas in a conservation easement.
- 3. Removal of invasive species within the existing wetlands on site.
- 4. Density shall not exceed 4.2 dwelling units per acre (More limiting than the dwelling units per acre allowed in the RM-1 District).
- 5. Providing the community amenities shown in the PRO Plan.
- 6. As an option, a clubhouse could be placed where the pickleball court and playscape are currently shown. The design of the clubhouse would need to meet Façade ordinance requirements at the time of site plan approval.
- 7. Dedication of 1,650 linear feet of Right of Way on Meadowbrook Road.
- 8. Building height will be limited to 30 feet, which is more limiting than the 35 feet permitted in the RM-1 District.
- 9. The traffic improvements as shown on the PRO Plan.
- 10. If pickleball court(s) are proposed at the time of Preliminary Site Plan submittal, a noise impact statement shall be submitted showing that the activity, with any noise mitigation measures required, will comply with the City's Performance Standards.
- 11. Sustainable design features will include:
 - a. Pre-wire all garages for one 240-volt EV chargers.
 - b. All appliances used within the development must be EnergyStar-rated or applicable equivalent standards.
 - c. All applicable plumbing fixtures shall be WaterSense labeled or applicable equivalent standard.

Rev Formal PRO Concept Plan Review

- d. Building material on the exterior façade of a majority of the exterior elevations are energy-efficient, durable, and low maintenance, including brick and composite siding.
- e. Use of energy-efficient glass/glazing.
- f. Use of energy-efficient insulation materials.
- g. Offer a tankless water heater option.
- h. Install smart scheduling technology for sprinklers.
- i. Multi-modal non-motorized pathway network and infrastructure as shown on the PRO plan that reduces emissions and promotes pedestrian connectivity with bike/pedestrian friendly streets, and bicycle parking in units throughout the site.
- j. Benches will be made with recycled materials will be used throughout the open space areas.

Additional conditions to be included in the PRO Agreement, if it should be approved, may be added during review by the public bodies.

APPLICANT'S BURDEN UNDER PRO ORDINANCE

The Planned Rezoning Overlay ordinance (PRO) requires the applicant to demonstrate that certain requirements and standards are met. The applicant should be prepared to discuss these items, especially in number 1 below, where the ordinance suggests that the enhancement under the PRO request would be unlikely to be achieved or would not be assured without utilizing the Planned Rezoning Overlay. Section 7.13.2.D.ii states the following:

- (Sec. 7.13.2.D.ii.a) The PRO accomplishes the integration of the proposed land development project with the characteristics of the project area in such a manner that results in an enhancement of the project area as compared to the existing zoning that would be unlikely to be achieved or would not be assured in the absence of the use of a Planned Rezoning Overlay.
- 2. (Sec. 7.13.2.D.ii.b) Sufficient conditions shall be included on and in the PRO Plan and PRO Agreement such that the City Council concludes, in its discretion, that, as compared to the existing zoning and considering the site specific land use proposed by the applicant, it would be in the public interest to grant the Rezoning with Planned Rezoning Overlay. In determining whether approval of a proposed application would be in the public interest, the benefits which would reasonably be expected to accrue from the proposal shall be balanced against, and be found to clearly outweigh the reasonably foreseeable detriments thereof, taking into consideration reasonably accepted planning, engineering, environmental and other principles, as presented to the City Council, following recommendation by the Planning Commission, and also taking into consideration the special knowledge and understanding of the City by the City Council and Planning Commission.

The following conditions/benefits are suggested by the applicant as listed in their narrative (Staff comments in Bold):

a. A larger one-acre active park, accessible to residents and the general public, with pedestrian and bike rest stop area, at the northeast corner of the site along 12 Mile Road. The applicant states a public access easement will be placed over the park area. The "active" description seems to refer to the presence of a walking path, as no other activities appear to be planned. Staff suggests that without automobile parking, it is unlikely that many members of the public will utilize this park, and it will mostly serve as an attractive amenity to the residents of The Grove. Perhaps some signage at the Beacon Hill Trailhead could be provided that alerts visitors to the presence of this park and the nature trail.

- b. A one-mile loop Grove nature area trail, accessible to residents and the public, that extends from the newly created park area described above, along the east property line of the Property, providing scenic views of the adjacent 30-acre natural wetland area as well as natural features of the Property. The applicant states a public access easement will be placed over the trail area. As mentioned above, without the availability of automobile or bike parking, it is unlikely that many members of the public will utilize this trail, and it will mostly serve as an amenity to the residents of The Grove. The trail could be further enhanced with additional benches at other points along the path. Signage at the Beacon Hill Trailhead could be provided that alerts visitors to the presence of the park and the nature trail.
- c. In order to address the impact of additional use of Beacon Hill Park by the new residents and planned access and interconnectivity for Novi residents and Grove Nature Trail, Developer agrees to provide the City with \$25,000 to be used by the City at its discretion, for Beacon Hill Park improvements, art, services and/or maintenance. In the past the applicant has discussed with PRCS Director Muck the idea of art installation at the Beacon Hill Trailhead. A specific sculpture to be donated, or plans and construction of site amenities at the park could be proposed by the applicant as opposed to a cash donation. This might include a "comfort station" with seating area(s), a wetland overlook platform with connecting pathways, bike repair station, or other amenities in this public park.
- d. Consistent with Novi's mobility plans, over 700 feet of 10-foot wide pathway/sidewalk, off-site on the south side of 12 Mile Road to create a connection from the existing bike path, located along the east side of Meadowbrook Road, and the new sidewalk being constructed with The Grove. Staff agrees and supports the provision of this missing sidewalk segment, which would enhance the project and be a benefit to the public.
- e. Relocating the SMART bus stop to the east, and enhancing the area with landscaping and seating along 12 Mile Road, which is supported by SMART. Additional bike parking has also been added for a total of 8 spaces. The applicant states that SMART standards do not call for a covered shelter in this location. Maintenance and public access agreements would likely be required. This would be considered a benefit to the public.
- f. Approximately 1/3 of the property will be open space with most of the units abutting or overlooking open space and nature areas (1.65 acres usable open space required, 5.97 acres proposed). Exceeding the Ordinance requirement for usable open space would qualify as an enhancement that could not otherwise be required.
- g. Consistent with Novi's mobility plans, construct an 8-foot wide shared-use pathway within The Grove to provide pedestrian and bicycle connectivity between Meadowbrook Road and 12 Mile Road. The applicant states a public access easement will be placed over the pathway, so the pathway would be considered a benefit to the public at large.
- h. Proposed conservation easements protecting approximately 10 acres of woodland and woodland replacement areas and 15.5 acres of wetland and wetland mitigation areas. Staff supports the provision of conservation easements to protect the natural features, which represents over 47% of the property. This would be considered an enhancement that will benefit the public at large.
- i. Decrease in density from what would be permissible in the RM-1 zoning district (4.2 units per acre proposed, up to 7.3 units per acre permitted). This condition of the PRO Agreement would be considered an enhancement of the project.

- j. Dedicate right-of-way (60-foot width) along the entire Meadowbrook Road frontage, an approximate length of 2,166 feet. The total land area to be dedicated is approximately 2.5 acres. This would be considered an additional benefit in the interest of the public.
- k. The Façade review notes that the design of the buildings meet or exceed the requirements of the Façade Ordinance, and the high level of character and attention to detail represents an enhancement of the project that would be unlikely in the absence of a PRO.

This is a PRO in which the applicant seeks both a rezoning and a list of ordinance deviations. In Staff's opinion the proposed benefits to the community at large appear to outweigh the detriments.

ORDINANCE DEVIATIONS

Section 7.13.2.D.i.c(2) permits deviations from the strict interpretation of the Zoning Ordinance within a PRO agreement. These deviations must be accompanied by a finding by City Council that "each Zoning Ordinance provision sought to be deviated would, if the deviation were not granted, prohibit an enhancement of the development that would be in the public interest, and that approving the deviation would be consistent with the Master Plan and compatible with the surrounding areas." Such deviations must be considered by City Council, who will make a finding of whether to include those deviations in a proposed PRO agreement. A proposed PRO agreement would be considered by City Council only after tentative approval of the proposed concept plan and rezoning.

The Initial Concept Plan submitted required <u>16 deviations</u> from Ordinance standards. **The Formal PRO Plan requires 7 deviations as listed below.** All deviations are supported by Staff. Staff comments are in bold.

- 1. <u>Building Setbacks (Sec 3.1.7.D):</u> A Zoning Ordinance deviation is requested to reduce the building setbacks from 75 feet to 50 feet along the north, east, and south property lines. The property to the north, the Trinity parcel, is currently undeveloped. North of the units have a section of berm, along with new and existing trees to provide screening. Additional screening may be required by developer of Trinity parcel. Future development of the retained Trinity parcel (and adjacent parcel to the south) would be subject to increased building setbacks of 100 feet where adjacent to residential districts. The applicant indicates the property to the east will not be developed as it is the MDOT stormwater and natural wetland area, so the reduced setback will not impact this property. Along the southern boundary significant landscaping for additional screening is proposed. The applicant states this additional flexibility for building locations allows them to preserve additional wetland and woodland areas. Staff supports the deviation as sufficient screening appears to be proposed.
- 2. <u>Building Orientation (Sec. 3.8.2.D):</u> A Zoning Ordinance deviation is requested to revise the required orientation of the buildings from a minimum of 45 degrees in certain locations. This allows for a more uniform site layout with all of the units backing up to open space/wooded areas. This deviation has been requested and granted for many residential projects in the City in the last 5 years. Staff supports the deviation.
- 3. <u>Distance between Buildings (Sec 3.8.2.H)</u>: A Zoning Ordinance deviation is requested to reduce the building separation distance from the calculated formula as shown on the Building Separation Table on Sheet SP-3.6 of the PRO Plan). This deviation enables the layout of this project to fit within the available space while minimizing wetland and woodland impacts.
- 4. <u>Parking along Major Drives (Sec. 5.10)</u>: A Zoning Ordinance deviation is requested to allow for perpendicular parking on the major drives. This deviation is requested to due to the impracticality of providing a minor road (defined as less than 600 feet in length) given the site constraints (woodlands, wetlands, and property configuration). Perpendicular parking for

guests is proposed on four Major Drives (Simi Drive, Beckham Drive, Elle Parkway, and Ari Crest) in several locations, where driveways are also proposed. The parking spaces will not cause any more disruption on the roadway than cars that will be backing out of the driveways.

- 5. <u>Parking along Curves (Sec. 5.10):</u> A Zoning Ordinance deviation may be required to allow onstreet parking on curves with less than a 230-foot centerline radius. The deviation is supported as the parking spaces will not cause any more disruption on the roadway than cars that will be backing out of the driveways.
- 6. <u>Landscape Berms (Sec. 5.5.3.A.ii)</u>: A landscape deviation is requested to not provide a 4-foot, 6-inch to 6-foot high landscape berm on a proposed RM-1 district adjacent to an OST district on the east and south side. This deviation is supported by staff because of topography and the provision of dense landscaping along both property lines.
- 7. <u>Right-of-Way Landscaping</u> (Sec. 5.5.3.B.ii): A deviation to the required greenbelt berm and plantings along 12 Mile and Meadowbrook Road due to the existing natural areas to be preserved, and a heavily landscaped detention basin. This deviation is supported by staff.

See other review letters for deviations that have been identified other reviewers. Deviations from Ordinance standards may continue to be identified during the PRO Review process. All deviations from the ordinance requirements shall be identified and included in PRO Agreement. Any additional deviations identified during Site Plan Review (after the Concept Plan and PRO Agreement is approved), will require amendment of the PRO Agreement unless otherwise stated in the agreement.

SUMMARY OF OTHER REVIEWS:

- a. **Engineering:** Engineering recommends approval of the PRO Plan. See detailed comments in their review letter.
- b. **Landscape:** Landscape review recommends approval of the rezoning and PRO Plan. Two deviations from landscape ordinance standards are needed for the current design these are supported by staff in order to preserve existing natural features.
- c. **Traffic:** Traffic review recommends approval. Traffic review notes that the applicant would need a deviation for the parking areas on the major drive, and possibly for parking on a curve.
- d. **Traffic Study Review:** The traffic study is recommended for approval. Please see the review letter for additional comments.
- e. **Woodlands:** The tree survey indicates 2,775 trees within the regulated woodland areas. The plan proposes a total of 2,019 tree removals (73%) requiring about 3,180 Woodland Replacement Credits. Approximately 250 credits are to be planted on-site, with the remainder to be paid into the Tree Fund. Woodland review does not object to the rezoning request if the Woodland Ordinance requirements will be followed.
- f. **Wetlands:** Wetland review notes that the proposed development appears to result in a total permanent wetland impact area of 1.44 acres out of the total 9.64 acres present on site. Approximately 2.47 acres of on-site mitigation area is noted on the plan, which slightly exceeds the requirement.
- g. **Façade:** Façade notes that the elevations provided are now fully compliant with ordinance standards, and the building designs represent an enhancement of the area.
- h. **Fire**: No objections to the rezoning at this time.

NEXT STEP: PLANNING COMMISSION PUBLIC HEARING

Now that all reviewers recommend approval or conditional approval, the public hearing before the Planning Commission will be scheduled. Following the public hearing, they may make a recommendation to City Council whether to approve or deny the request, or may postpone making a recommendation if they determine additional information or changes are needed. **This** project is scheduled for public hearing on Wednesday, October 8, 2025.

CITY COUNCIL CONSIDERATION

After the Planning Commission makes its recommendation, the PRO Concept Plan will be scheduled for consideration by the City Council. If the City Council grants tentative approval at that time, they will direct the City Attorney to draft a PRO Agreement describing the terms of the rezoning approval. Once the PRO Agreement has been drafted and approved by the applicant's attorney, it will return City Council for final approval.

If the applicant has any questions concerning the above review or the process in general, do not hesitate to contact me at 248.347.0484 or Ibell@cityofnovi.org.

Lindsay Bell, AICP, Senior Planner

Kindsmy Bell



PLANNING REVIEW CHART: RM-2 with PRO

Review Date: September 18, 2025
Review Type: Revised Formal PRO Plan
Project Name: JZ24-31 THE GROVE

Plan Date: August 22, 2025

Prepared by: Lindsay Bell, AICP, Senior Planner

E-mail: lbell@cityofnovi.org; Phone: (248) 347-0484

Bold To be addressed in Formal PRO Plan submittal

<u>Underline</u> To be addressed with Preliminary Site Plan submittal

<u>Bold and Underline</u> Possible deviations to be included as part of PRO agreement

Italics Items to be noted

Item	Required Code	Proposed	Meets Code	Comments
Zoning and Use Red	quirements			
Master Plan (adopted July 26, 2017)	General Mixed Use	Multiple Family Residential	Yes	The proposed rezoning is supported by the 2025 Master Plan. See
Area Study	The site does not fall under any special category	NA	NA	further discussion in the Planning Review letter
Zoning (Effective January 8, 2015)	OST Office Service and Technology	RM-1 Low-density Multiple Family with a PRO	No	Rezoning requested
Uses Permitted (Sec 3.1.21.B & C)	Office and Service Uses Sec. 3.1.21.B Principal Uses Permitted. Sec. 3.1.21.C. – Special Land Uses Permitted.	Sec. 3.1.8. Multi-Family Residential	No	The proposed rezoning category would allow Multi-family uses of various types.
Phasing	If proposed, show proposed phasing lines on the plan. Each phase should be able to stand on its own with regards to utilities, open space, parking, etc.	Clarify whether the project would be phased	TBD	If proposed, Phasing should be discussed in the PRO Agreement – provide information about any proposed phasing plans/conditions
Planned Rezoning (Overlay Document Requireme	nts (SDM link: <u>Site Plan & D</u>	evelopm	ent Manual)
Written Statement (Site Plan & Development	Potential development under the proposed zoning and current zoning	Provided	Yes	See Planning Review letter for detailed comments
manual) The statement	Identified benefit(s) of the development	Provided	Yes	
should describe the following	Conditions proposed for inclusion in the PRO Agreement (i.e., Zoning Ordinance deviations, limitation on total units, etc.)	Provided	Yes	
Sign Location Plan (Page 23,SDM)	Installed within 15 days prior to public hearing Located along all road frontages	Provided and previously installed	Yes	

Item	Required Code	Proposed	Meets	Comments
Traffic Impact Study (Site Plan & Development manual)	A Traffic Impact Study as required by the City of Novi Site Plan and Development Manual.	Provided – by Fleis & Vandenbrink, 10/2024	Yes Yes	See AECOM review
Community Impact Statement (Sec. 2.2)	 Over 30 acres for permitted non-residential projects Over 10 acres in size for a special land use All residential projects with more than 150 units A mixed-use development, staff shall determine 	Provided – dated 8/25/25	Yes	See Planning Review letter for detailed comments
Market Study	Optional: a Market study to provide a market demand analysis for the proposed project.	Provided – • Office Market Report, 12/13/23 by CBRE • Housing Report, 8/9/24 by The Chesapeake Group	Yes	See Planning Review letter for detailed comments
Height, bulk, densit	y and area limitations (Sec 3.1	.8.D)		
Frontage on a Public Street. (Sec. 5.12)	Frontage on a Public Street is required	The site has frontage and access to Meadowbrook and 12 Mile Roads	Yes	
Minimum Zoning Lot Size for each Unit: in Acres (Sec 3.8.1)	RM-1 and RM-2 Required Conditions	61.86 acres gross 54.85 acres net	Yes	
Minimum Zoning Lot Size for each Unit: Width in Feet (Sec 3.8.1)			NA	
Usable Open Space Area (Sec 3.1.8.D) Article 2: Definitions	200 sf of Minimum usable open space per dwelling unit For a total of 232 dwelling units, required Open Space: 46,400 SF (~1.15 acre) Refer to definitions for Usable Open Space and	Sheet SP3.4 – Usable OS: 5.97 acres "Additional Open Space" = 11.99 acres	Yes	This could be a condition of development as it represents an enhancement of the project beyond what would be required
Maximum % of Lot Area Covered (By All Buildings)	Open Space 25%	21%	Yes	
Building Height	35 ft. or 2 stories whichever	2 stories proposed	Yes	

Item	Required Code	•	Proposed	Meets Code	Comments
(Sec. 3.1.7)	is less		1-story units: 20 ft 3 in 2-story towns: ~28 ft		
Minimum Floor	Efficiency	400 sq. ft.			
Area per Unit	1 bedroom	500 sq. ft.			
(Sec. 3.1.7.D)	2 bedroom	750 sq. ft.	1905 sf	Yes	
	3 bedroom	900 sq. ft.	1958 sf	Yes	
	4 bedroom	1,000 sq. ft.		NA	
Maximum Dwelling Unit	Efficiency	Max 5%	0	Yes	Overall proposed is 4.2 du/ac
Density/Net Site	1 bedroom	Max 20%	0		30,40
Area	1 200100111	10.9			
(Sec. 3.1.7.D)		du/ac			
Per Sec. 3.8.2.B,		, , , , ,			
all buildings less	2 bedroom	7.3 du/ac		1	
than four stories					
should comply					
with RM-1	3+ bedroom	5.4 du/ac			
regulations for					
limits on percent					
of 1 bedroom					
units and number					
of rooms.					
Residential Building		•	T == 4:	T	T
Front @ Meadowbrook Rd	50 ft. (Sec. 3.6.	В)	50 ft	Yes	
	LO 41		125 #	V	
Exterior Side at 12	50 ft.		~135 ft	Yes	
Mile				1	Deviation requested for
Side - East	75 ft.		50 ft	No	east, north and south side
0.1	75.0		50.0	1	setbacks
Side - South	75 ft.		50 ft	No	
Side – North (adj	75 ft.		50 ft.	No	
to Trinity parcel)					
Parking Setback (Se	ec 3.1.8.D) (Sec	3.1.12.D)Refe	r to applicable notes in Sec	3.6.2	
Front (3.6.2.B)	75 ft.			NA	
Exterior side	75 ft.			NA	
Rear (3.6.2.B)	20 ft.			NA	
Side (3.6.2.B)	20 ft.			NA	
Note To District Star	ndards (Sec 3.6.2)			
Exterior Side Yard	All exterior side	yards	12 Mile Road	Yes	
Abutting a Street	abutting a stre	•	considered exterior side		
(Sec 3.6.2.C)	provided with		yard		
· 	equal to front y	vard.		<u> </u>	
Off-Street Parking	Off-street parki	ng is	Parking is not proposed	NA	
in Front Yard	allowed in fron	t yard	in the front yard		
(Sec 3.6.2.E) Distance between	It is governed b	W (8C 3 8 3	RM-1 code has	+	See Comments later in
buildings	or by the minim	•	additional requirements		the review
(Sec 3.6.2.H)	setback requir		for distance between		IIIC ICVICW
1000 0.0.2.11)	whichever is gr		buildings.		
	91		· · · · · · · · · · · · · · · · · ·	1	J

Item	Required Code		Proposed	Meets Code	Comments
Wetland/Waterco urse Setback (Sec 3.6.2.M)	A setback of 25 wetlands and fr watermark cou maintained	om high	Extensive wetland areas exist –buffer impacts likely	TBD	Refer to wetland review letter for more detail
Parking setback screening (Sec 3.6.2.P)	Required parking area shall be lared per sec 5.5.3.				Refer to landscape review for comments
Modification of parking setback requirements (Sec 3.6.2.Q)	The Planning Co may modify par setback require based on its de according to Se	king ments termination		NA	
RM-1 and RM-2 Red	quired Conditions	(Sec 3.8)			
Total number of rooms (Sec. 3.8.1.A)	For RM-1 District of rooms < Net s SF/2000		2,389,266 sf/2000 = 1,195 rooms allowed Total number of rooms Proposed: ~928	Yes	Note: assumes a room count of 4 for each unit on average
Public Utilities (Sec. 3.8.1)	All public utilities	s should be	All public utilities are available	Yes	Refer to Engineering review for more details
Maximum Number of Units	Efficiency < 5 pe	ercent of		NA	
(Sec. 3.8.1.A.ii)	1 bedroom units percent of the u	-		NA	
Applicable for RM-1 building and RM-2 buildings less than four stories	Balance should 2 bedroom units		Proposed	Yes	
Room Count per Dwelling Unit Size (Sec. 3.8.1.C) *An extra room	Dwelling Unit Size	Room Count *			Floorplans are provided. The plans indicate a
	Efficiency	1	NA		combined living/dining,
	1 bedroom	2	NA	\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \	The Vistas include
such as den count towards an	2 bedroom	3	3	Yes	Office/Flex room as 5 th
extra room	3 or more bedrooms	4	4 eents and density in a multip		room

For the purpose of determining lot area requirements and density in a multiple-family district, a room is a living room, dining room or bedroom, equal to at least eighty (80) square feet in area. A room shall not include the area in kitchen, sanitary facilities, utility provisions, corridors, hallways, and storage. Plans presented showing one (1), two (2), or three (3) bedroom units and including a "den," "library," or other extra room shall count such extra room as a bedroom for the purpose of computing density.

Setback along natural shore line (Sec. 3.8.2.A)	A minimum of 150 feet along natural lake shore line is required.	No natural lake shore line exists within the property	NA	
Structure frontage (Sec. 3.8.2.B)	Each structure in the dwelling group shall front either on a dedicated public street or approved private drive.	Proposed Private Drives	Yes	Subject to City Council approval

Item	Required Code	Proposed	Meets Code	Comments
Maximum length of the buildings (Sec. 3.8.2.C)	A single building or a group of attached buildings cannot exceed 180 ft.	~150 feet max (The Woods & The Pointe)	Yes	
Modification of maximum length (Sec. 3.8.2.C)	Planning Commission may modify the extra length up to 360 ft. if		NA	
	Common areas with a minimum capacity of 50 persons for recreation or social purposes			
	Additional setback of 1 ft. for every 3 ft. in excess of 180 ft. from all property lines abutting a residential district or major thoroughfare			
Building Orientation (Sec. 3.8.2.D)	Where any multiple dwelling structure and/ or accessory structure is located along an outer perimeter property line adjacent to another residential or nonresidential district, said structure shall be oriented at a minimum angle of forty-five (45) degrees to said property line.	Buildings 1-5, 24-26, 40- 44 do not appear to meet the minimum requirement for 45- degree orientation	No	<u>Deviation requested</u>
Yard setback restrictions (Sec. 3.8.2.E)	Within any front, side or rear yard, off-street parking, maneuvering lanes, service drives or loading areas cannot exceed 30% of yard area	Complies –parking areas are all internal to the site	Yes	
Off-Street Parking or related drives (Sec. 3.8.2.F) Off-street parking	No closer than 25 ft. to any wall of a dwelling structure that contains openings involving living areas or	Off-street parking spaces are placed greater than 25 feet from buildings	Yes	
and related drives shall be	No closer than 8 ft. for	Complies	Yes	
unves shall be	other walls or No closer than 20 ft. from ROW and property line	Minimum of 20 ft. is maintained	Yes	
Pedestrian Connectivity (Sec. 3.8.2.G)	5 feet sidewalks on both sides of the Private drive are required to permit safe and convenient pedestrian access.	5-ft sidewalks mostly proposed, 10-ft pathway on one side of Elle Pkwy and part of Simi Lane	Yes?	
	Where feasible sidewalks shall be connected to other pedestrian features	Provides connectivity to Meadowbrook and 12 Mile Road	Yes	

Item	Required Code	Proposed	Meets Code	Comments
	abutting the site.			
	All sidewalks shall comply with barrier free design standards	Details not yet provided	Yes?	Will be verified during Site Plan review
Minimum Distance between the buildings (Sec. 3.8.2.H)	(Total length of building A + total length of building B + 2(height of building + height of building B))/6	Table provided on sheet SP3.6 – several proposed distances are less than the calculated requirement	No	Deviation requested for overall requirement - Table updated on sheet 3.6
Minimum Distance between the buildings (Sec. 3.8.2.H)	In no instance shall this distance be less than thirty (30) feet unless there is a corner-to-corner relationship in which case the minimum distance shall be fifteen (15) feet.	Corner to corner relationships are min. of 25 feet	Yes	
5.10 Additional Roa	d Design, Building Setback, A	nd Parking Setback Require	ements, <i>N</i>	Multiple-Family Uses
Road standards	A private drive network	Major and minor drive	Yes	

Road standards	A private drive network	Major and minor drive	Yes	
(Sec. 5.10)	within a cluster, two -family,	network shown		
	multiple-family, or non-			
	residential uses and			
	developments shall be built			
	to City of Novi Design and			
	Construction Standards for			
	local street standards			
	(twenty-eight (28) feet			
	back-to-back width			



For the purpose of this review, staff categorized the drives as follows:

1. Major Drive: Blue line

- Minor Drive: Red line

Item	Required Code	Proposed	Meets Code	Comments
Major Drives	- Width: 28 feet	Elle Pkwy, Ari Crest, Simi Ln, and Beckham Dr are 28-feet and greater than 600 feet length	Yes	
Minor Drive	 Cannot exceed 600 feet Width: 24 feet with no onstreet parking Width: 28 feet with parking on one side Parking on two sides is not allowed Needs turn-around if longer than 150 feet 	Leo Drive would be considered minor, 28-ft width	Yes	Provide road length of each drive proposed to confirm classification
Parking on Major and Minor Drives	 Angled and perpendicular parking, permitted on minor drive, but not from a major drive; minimum centerline radius: 100 feet Adjacent parking and on-street parking shall be limited near curves with less than two-hundred thirty (230) feet of centerline radius 	On-street perpendicular parking is proposed on the Major Drives (Simi Ln, Elle Pkwy, Ari Crest and Beckham Dr) Centerline radius: 125', 140', 150'	No	Consider allowing on- street parking along 1 side of 28-foot wide streets for extra visitor parking? Especially on Simi Dr north of Elle Pkwy where there are no visitor spots provided
Driveways, Parking	, Loading and Dumpster Requi	rements		
Number of Parking Spaces (Sec.5.2.12.A & B)	For 2 or less bedroom units: 2 spaces each For 3 or more bedroom units: 2 ½ spaces each 232 x 2.5 = TOTAL REQUIRED: 581 spaces	Meadows: 280 spaces Vistas: 276 spaces (garage, driveways and on-street) The Woods: 159 spaces, & the Pointe: 268 (garage, driveways and on-street) Park/Recreation area: 5 spaces TOTAL PROPOSED: 988	Yes	
Landbank Parking (Sec.5. 2.14)	Maximum number of Landbank spaces: 25% of required parking		NA	
Parking Space Dimensions and Maneuvering Lanes (Sec. 5.3.2)	 90° Parking: 9 ft. x 19 ft. 24 ft. two way drives 9 ft. x 17 ft. parking spaces allowed along 7 ft. wide interior sidewalks as long as detail indicates a 4" curb at these locations and along landscaping 	Appears to comply	Yes	

Item	Required Code	Proposed	Meets Code	Comments
Parking stall located adjacent to a parking lot entrance(public or private) (Sec. 5.3.13)	- shall not be located closer than twenty-five (25) feet from the street right-of-way (ROW) line, street easement or sidewalk, whichever is closer	Not applicable	NA	
End Islands (Sec. 5.3.12)	 End Islands with landscaping and raised curbs are required at the end of all parking bays that abut traffic circulation aisles. The end islands shall generally be at least 8 feet wide, have an outside radius of 15 feet, and be constructed 3' shorter than the adjacent parking stall as illustrated in the Zoning Ordinance 	End Islands not needed for small parking bays	Yes	Refer to Traffic comments.
Barrier Free Spaces Barrier Free Code			TBD	
Barrier Free Space Dimensions Barrier Free Code	 8' wide with an 8' wide access aisle for van accessible spaces 8' wide with a 5' wide access aisle for regular accessible spaces 		TBD	
Barrier Free Signs Barrier Free Code	One sign for each accessible parking space.			Traffic Signage will be verified during site plan review
Minimum number of Bicycle Parking (Sec. 5.16.1)	One (1) space for each five (5) dwelling units For 232 units, 47 bike spaces are required	8 spaces at recreation area 8 spaces at Bus stop 4 spaces at 12 Mile Park 232 in unit garages	Yes	
Bicycle Parking General requirements (Sec. 5.16)	No farther than 120 ft. from the entrance being served When 4 or more spaces are required for a building with multiple entrances, the spaces shall be provided in multiple locations	Complies Complies	Yes Yes	
	Spaces to be paved and the bike rack shall be inverted "U" design Shall be accessible via 6 ft. paved sidewalk			

Item	Required Code	Proposed	Meets	Comments
	-	•	Code	Collineins
Covered Bicycle Parking (Sec 5.16.4)	When 20 or more bike parking spaces are required, 25% shall be in covered locations	232 parking spaces provided in unit garages	Yes	
Bicycle Parking Lot layout (Sec 5.16.6)	Parking space width: 7 ft. One tier width: 11 ft. Two tier width: 18 ft. Maneuvering lane width: 4 ft. Parking space depth: 32 in	Not provided	TBD	Provide the bike layout plan as required at the time of final site plan. It shall meet the requirements.
Sec. 5.7	Photometric plan and exterior lighting details needed at time of Final Site Plan submittal	A lighting and photometric plan is not provided at this time	TBD	
Accessory Use (Sec	<u>.</u>		1	
Accessory Buildings Sec. 2.2. Definitions	Any structure, either temporary or permanent, having a roof supported by columns or walls, and intended for the shelter, or enclosure of persons, animals, chattels, or property of any kind.	Clubhouse – shown as optional sheet L-11	TBD	
Location:	They shall not be erected			
Accessory Building Sec. 4.19.1.B	in any required front yard or in any required exterior side yard.			
Setbacks: Detached Accessory Building Sec. 4.19.1.G	 It shall not be located closer than ten (10) feet to any main building It shall not be located closer than six (6) feet to any interior side lot or rear lot line. 			
Height: Detached Accessory Building Sec. 4.19.1.G	The height equal to the maximum permitted height of the district; provided, if the accessory building exceeds one (1) story or fourteen (14) feet in height, the building shall be set back one (1) foot for each foot the building exceeds fourteen (14) feet in height.			Location proposed for clubhouse would comply
Façade requirements for Carport Canopies Sec. 5.15.12.b	 Not greater than 12' tall <40 ft width Powder coated steel or aluminum material, neutral in color to harmonize with primary buildings 		NA	

Item	Required Code	Proposed	Meets Code	Comments
	- Solar photo voltaic and EV charging integration strongly encouraged			
Canopies and Carports Sec. 4.19.2.C	Two or more carports permitted on any lot greater than 2 acres, provided they comply with accessory building setback and height		NA	
Maximum number of Accessory buildings Sec. 4.19.1.J	Lots more than 21,780 SF: 2		NA	
Dumpster Sec 4.19.2.F	 Located in rear yard Attached to the building or No closer than 10 ft. from building if not attached Not located in parking setback If no setback, then it cannot be any closer than 10 ft, from property line. Away from Barrier free Spaces 		NA	
Dumpster Enclosure Sec. 21-145. (c) Chapter 21 of City Code of Ordinances	 Screened from public view A wall or fence 1 ft. higher than height of refuse bin And no less than 5 ft. on three sides Posts or bumpers to protect the screening Hard surface pad. Screening Materials: Masonry, wood or evergreen shrubbery 		NA	
Roof top equipment and wall mounted utility equipment Sec. 4.19.2.E.ii	All roof top equipment must be screened and all wall mounted utility equipment must be enclosed and integrated into the design and color of the building		NA	
Roof top appurtenances screening	Roof top appurtenances shall be screened in accordance with applicable facade regulations, and shall not be visible from any street,		NA	

			Meets	
Item	Required Code	Proposed	Code	Comments
	road or adjacent property.			
Accessory Structures (Sec. 4.19.2)	Anything constructed or erected, the use of which requires location on the ground or attachment to something having location on the ground. Flagpoles, solar structures, transformers and utility boxes	The plan does not appear to propose any other accessory structures	NA	Contact Planning department if any accessory structures are proposed Any future proposed structures are expected to comply with the requirements if not approved as part of the PRO plan
Sidewalks				
Active Mobility Plan	Proposed Off-Road Trails, enhanced road crossings, Shared-use Path of 10 feet on S side of 12 Mile, support new transit route on 12 Mile	10-foot pathway along S side of 12 Mile Road; 8-foot pathway along N side of Elle Pkwy and part of Simi Lane	Yes	See new Active Mobility Plan for other guidelines/recommendat ions, especially for 12 Mile and Meadowbrook
Internal Sidewalks Sec. 3.8.2.G	Five foot sidewalks required on both sides of internal public or private drives	5-ft Sidewalk provided on both sides for most part, 8-foot pathway along Elle Pkwy.	Yes	See comment above regarding
Public Sidewalks (Chapter 11, Sec.11-276(b))	A 10- foot sidewalk is required along 12-Mile Road; Existing pathway on Meadowbrook	Pathway proposed along 12 Mile Road	Yes	
Other Requirements	S			
Residential Entryway lighting Sec. 5.7	One street light is required per entrance.	Not provided at this time	TBD	Will be verified during site plan process
Design and Construction Standards Manual	Land description, Sidwell number (metes and bounds for acreage parcel, lot number(s), Liber, and page for subdivisions).	Legal description provided SP 7.3	Yes	
General layout and dimension of proposed physical improvements	Location of all existing and proposed buildings, proposed building heights, building layouts, (floor area in square feet), location of proposed parking and parking layout, streets and drives, and indicate square footage of pavement area (indicate public or private).	Generally Provided		Please provide additional information as requested in this and other review letters
Economic Impact	 Total cost of the proposed building & site improvements Number of anticipated jobs created (during 	Numbers not provided	No	

Item	Required Code	Proposed	Meets	Comments
	construction & after		Code	
	building is occupied, if known)			
Other Permits and A	·			
Development/ Business Sign (City Code Sec 28.3)	Signage if proposed requires a permit.	Signage is not proposed at this time.		For sign permit information contact Ordinance Division at 248-735-5678.
Development and Street Names	Development and street names must be approved by the Street Naming Committee	Not received	TBD	Project and Street Name application; Contact Stacey Choi at 248-347- 0475 to schedule consideration by the Committee
Property Split or Combination	The proposed property split must be submitted to the Assessing Department for approval.	12 parcels are supposed to be combined, with one 7-acre area at the corner of 12 Mile and Meadowbrook to be split off and remain OST	NA	The parcel combination must be completed prior to final stamping set approval.
Other Legal Require	ements			
PRO Agreement (Sec. 7.13.2.D(3)	A PRO Agreement shall be prepared by the City Attorney and the applicant (or designee) and approved by the City Council, and which shall incorporate the PRO Plan and set forth the PRO Conditions and conditions imposed	Not applicable at this moment	NA	PRO Agreement would need to be approved by the City Council if the Concept Plan is tentatively approved
Master Deed/Covenants and Restrictions	Applicant is required to submit this information for review with the Final Site Plan submittal	Not applicable at this moment	NA	If one is proposed, then a Master Deed draft shall be submitted prior to Stamping Set approval.
Conservation easements	Conservation easements may be required for woodland/wetlands	Not applicable at this moment	NA	Applicant proposes conservation easements over remaining woodlands and wetland areas, as well as wetland mitigation areas
Lighting and Photor	metric Plan (Sec. 5.7)			
Intent (Sec. 5.7.1)	Establish appropriate minimum levels, prevent unnecessary glare, reduce spillover onto adjacent properties & reduce unnecessary transmission of light into the night sky	Not provided at this time	TBD	A lighting and photometric plan is typically required during site plan review. If deviations are anticipated, we recommend providing one with the Concept Plan submittal

Item	Required Code	Proposed	Meets	Comments
	Site plan showing location		Code	
	of all existing & proposed			
Lighting Plan	buildings, landscaping,			
(Sec. 5.7.A.i)	streets, drives, parking			
,	areas & exterior lighting			
	fixtures			
	Relevant building elevation			
	drawings showing all			
Building Lighting	fixtures, the portions of the			
(Sec. 5.7.2.A.iii)	walls to be illuminated, illuminance levels of walls			
	and the aiming points of			
	any remote fixtures.			
	Specifications for all			
	proposed & existing			
	lighting fixtures			
	Photometric data			
Lighting Plan	Fixture height			
Elements	Mounting & design			
(Sec.5.7.2.A.ii)	Glare control devices			
	(Also see Sec. 5.7.3.D)			
	Type & color rendition of			
	lamps			
Maying up Uniobi	Hours of operation			
Maximum Height (Sec. 5.7.3.A)	Height not to exceed maximum height of zoning			
(300. 3.7.3.7)	district (or 25 ft. where			
	adjacent to residential			
	districts or uses.			
Required	- Electrical service to light			
Conditions	fixtures shall be placed			
(Sec. 5.7.3.B)	underground			
	- Flashing light shall not be permitted			
	- Only necessary lighting			
	for security purposes &			
	limited operations shall			
	be permitted after a site's			
	hours of operation			
Indoor Lighting	- Indoor lighting shall not			
(Sec. 5.7.3.H)	be the source of exterior			
Socurity Linkling	glare or spillover - All fixtures shall be			
Security Lighting (Sec. 5.7.3.1)	located, shielded and			
[000. 0.7.0.1]	aimed at the areas to be			
Lighting for	secured.			
security purposes	- Fixtures mounted on the			
shall be directed	building and designed to			
only onto the	illuminate the facade are			
area to be	preferred			
secured.	Non-Donous at A 4 1835 and 9 a			
Color Spectrum	Non-Res and Multifamily:			
Management	For all permanent lighting			


Item	Required Code	Proposed	Meets	Comments
(Sec. 5.7.3.F)	installations - minimum		Code	
[000.0.7.0.7]	Color Rendering Index of			
	70 and Correlated Color			
	Temperature of no greater			
	than 3000 Kelvin			
Parking Lot	- Provide the minimum			
Lighting (Sec. 5.7.3.J)	illumination necessary to ensure adequate vision			
(380. 3.7.3.3)	and comfort.			
	- Full cut-off fixtures shall			
	be used to prevent glare			
	and spillover.			
	Parking areas: 0.2 min			
	Loading & unloading			
	areas: 0.4 min			
Min. Illumination	Walkways: 0.2 min			
(Sec. 5.7.3.L)	Building entrances,			
	frequent use: 1.0 min			
	Building entrances, infrequent use: 0.2 min			
	Average light level of the			
Average Light	surface being lit to the			
Level (Sec.5.7.3.L)	lowest light of the surface			
,	being lit shall not exceed			
	4:1			
Max. Illumination	When site abuts a non-			
adjacent to Non-	residential district,			
Residential	maximum illumination at the property line shall not			
(Sec. 5.7.3.L)	exceed 1 foot candle			
	- Fixture height not to			
	exceed 25 feet			
	- Cut off angle of 90			
Max. Illumination	degrees or less			
adjacent to	- No direct light source			
Residential	shall be visible at the property line adjacent			
(Sec. 5.7.3.M)	to residential at ground			
	level			
	- Maximum illumination at			
	the prop line not to			
	exceed 0.5 fc.			
	- Provide sufficient			
	illumination (0.2 fc min) at each entrance from			
	major thoroughfare			
Residential	- Residential projects may			
Developments	deviate from the min.			
(Sec. 5.7.3.0)	illumination levels and			
	uniformity requirements			
	of 5.7.3.L so long as site			
	lighting for parking lots,			

Page 15 September 18, 2025

Item	Required Code	Proposed	Meets Code	Comments
	property lines and security lighting is provided			

NOTES:

- 1. This table is a working summary chart and not intended to substitute for any Ordinance or City of Novi requirements or standards.
- 2. The section of the applicable ordinance or standard is indicated in parenthesis. Please refer to those sections in Article 3, 4 and 5 of the zoning ordinance for further details
- 3. Please include a written response to any points requiring clarification or for any corresponding site plan modifications to the City of Novi Planning Department with future submittals.





PLAN REVIEW CENTER REPORT

9/10/2025

Engineering Review

The Grove JZ24-0031

APPLICANT

Ivanhoe Companies

REVIEW TYPE

Formal PRO Plan

PROPERTY CHARACTERISTICS

Site Location: Located on the south side of 12 Mile Road east of

Meadowbrook Road, in section 13 of the City of Novi

Site Size: +/- 67 acresPlan Date: 8/22/2025

Design Engineer: Zeimet Wozniak & Associates

PROJECT SUMMARY

- Proposed rezoning from OST to RM-1. The Grove shall consist of 4 residential zones with a total of 232 units proposed:
 - o Zone 1: The Vistas 68 Units
 - o Zone 2: The Meadows 67 Units
 - o Zone 3: The Woods 36 Units
 - o Zone 4: The Pointe 61 Units
- Site access shall be provided by two entrances on Meadowbrook Road and one entrance on 12 Mile Road. The residential development shall be on 61.83 acres, and 7.74 acres shall be left for future development.
- Three water main connections are proposed; one connection is proposed to the existing 24-inch water main on the south side of 12 Mile Road. Two connections are proposed to the 16-inch water main on the east side of Meadowbrook Road.
- One sanitary sewer connection is proposed to the existing 21-inch sanitary sewer located on-site on the southeast corner of the property.
- Storm water would be collected by the proposed storm sewer system; there are six total detention basins proposed on-site. All the proposed detention basins outlet to the on-site wetlands.

RECOMMENDATION

Approval of the Revised Formal PRO submittal is **recommended**. At this time, the plan meets the general requirements of the design and construction standards as set forth in Chapter 11 of the City of Novi Code of Ordinances, the Storm Water Management Ordinance, and the Engineering Design Manual, with the following items to be addressed at the time of Site Plan submittal:

THE FOLLOWING ITEMS TO BE ADDRESSED WITHIN THE PRO AGREEMENT:

- 1. The proposed bus stop is located on private property; the PRO agreement should address maintenance of this amenity, and the applicant should indicate if they will provide a public access easement.
- Applicant shall reach out to SMART to coordinate the relocation of the existing bus stop on the west side of Meadowbrook Road. SMART also offers an Adopt-a-Stop program to enhance bus stops (https://www.smartbus.org/Services/Adopt-A-Stop).
- 3. The applicant shall coordinate with SMART for any improvements. The SMART website has a bus stop updates/improvement plan for any benches, trash cans, public call phones, and real-time information displays added to bus stops. If any of these items are proposed, the applicant should coordinate with SMART and include information about maintenance and easements in the PRO agreement.

ITEMS TO BE ADDRESSED AT TIME SITE PLAN SUBMITTAL:

- Provide sight distance measurements for the Twelve Mile Road and Meadowbrook Road entrances in accordance with Figure VIII-E of the <u>Design</u> and <u>Construction Standards</u>, <u>Chapter 11 of the City of Novi Code of</u> <u>Ordinances</u>.
- 2. Sheet SP-3 indicates that decks and patios may extend a maximum of 10' beyond the building to envelope the perimeter of the building. Show deck and patios for each building to ensure there is no conflict with the detention basin drives, wetland buffers, or the retaining walls.
- 3. Provide a traffic control sign table listing the quantities of each **permanent** sign type proposed for the development. Provide a note along with the table stating all traffic signage will comply with the current MMUTCD standards.
- 4. Traffic signs in the Road Commission for Oakland County (RCOC) right-of-way will be installed by RCOC.
- 5. Provide a traffic control plan for the proposed road work activity on 12 Mile and Meadowbrook Road.
- 6. Provide a note stating if dewatering is anticipated or encountered during construction, then a dewatering plan must be submitted to the Engineering Division for review.
- 7. Generally, all proposed trees shall remain outside utility easements. Where proposed trees are required within a utility easement, the trees shall maintain a

The Grove JZ24-0031

- minimum 5-foot horizontal separation from the water main and storm sewer and 10-foot horizontal separation from the sanitary sewer. <u>All utilities shall be shown on the landscape plan</u> or other appropriate sheet to confirm the separation distance.
- 8. Show the locations of all light poles on the utility plan and indicate the typical foundation depth for the pole to verify that no conflicts with utilities will occur. Light poles in a utility easement will require a License Agreement.
- 9. The dedication of the master-planned 60-foot-wide right-of-way is requested for the project on Meadowbrook Road; there is an existing sidewalk easement. It is requested that the applicant provide a right-of-way easement instead of a sidewalk easement in this location.
- 10. A right-of-way permit will be required from the City of Novi and Oakland County.
- 11. **Only at the time of the printed Stamping Set submittal**, provide the City's standard detail sheets for water main (5 sheets), sanitary sewer (3 sheets), storm sewer (2 sheets), and paving (2 sheets). The most updated details can be found on the City's website under <u>Engineering Standards and Construction Details</u>.

WATER MAIN

- 12. Provide a water main basis of design for the development on the utility plan sheet. Indicate the material of the water main where the connections are proposed.
- 13. Provide a profile for all proposed public water main 8-inch or larger.
- 14. Show existing hydrants on Meadowbrook Road and 12 Mile Road and indicate if any hydrants must be relocated.
- 15. In general, valves shall be arranged so that no single line failure will require more than eight hundred (800) feet of main, twenty-four (24) homes, or thirty (30) multiple units to be out of service.
- 16. All public water main easements shall be 20 feet wide. Show 20-foot-wide proposed easement.
- 17. Water Systems must have the ability to serve at least <u>three thousand (3,000)</u> <u>gallons</u> per minute in apartments, cluster residential, and similar complexes.
- 18. A tapping sleeve, valve and well is required at the connection to the existing water main.
- 6-inch hydrant leads are allowed for leads less than or equal to 25 feet in length.8-inch leads are required for leads greater than 25 feet in length.
- 20. Valves shall be arranged so that no single line failure will require more than eight hundred (800) feet of main to be out of service.

IRRIGATION

21. If a common irrigation system is proposed, irrigation plans must be approved with final site plan submittal.


SANITARY SEWER

- 22. All public sanitary sewer shall be within a dedicated sanitary sewer easement unless proposed in the right-of-way. Show proposed 20-foot-wide sanitary sewer easement.
- 23. Illustrate all pipes intersecting with manholes on the sanitary profiles.


STORM SEWER

JZ24-0031

- 24. Wetland crossing culvert must be able to withstand a fire truck's 35-ton weight requirements. Provide additional information about culvert sizing with the site plan submittal.
- 25. Additional rear yard catch basins and storm sewer may be required at the time of site plan submittal. The proposed retaining wall behind building 2 may cause drainage issues.



26. The grading in the rear yard of buildings 4 and 5 should be routed towards the storm sewer near the road or detention basin G. Storm water shall not flow toward the property line.



The Grove JZ24-0031

- 27. A minimum cover depth of 3 feet shall be maintained over all proposed storm sewer. Currently, a few pipe sections do not meet this standard. Grades shall be elevated, and minimum pipe slopes shall be used to maximize the cover depth.
- 28. Storm manholes with differences in invert elevations exceeding two feet shall contain a 2-foot-deep plunge pool.
- 29. Provide a four-foot-deep sump and an oil/gas separator in the last storm structure prior to discharge to the storm water basin.
- 30. Provide profiles for all storm sewer 12-inch and larger. All storm pipes accepting surface drainage shall be 12-inch or larger.
- 31. Illustrate all pipes intersecting storm structures on the storm profiles.
- 32. An easement is required over the storm sewer accepting and conveying offsite drainage.
- 33. Provide a schedule listing the casting type, rim elevation, diameter, and invert sizes/elevations for each proposed, adjusted, or modified storm structure on the utility plan. Round castings shall be provided on all catch basins except curb inlet structures.
- 34. Show and label all roof conductors and show where they tie into the storm sewer.
- 35. Provide a storm sewer basis of design table at time of final site plan submittal.

STORM WATER MANAGEMENT PLAN


- 36. The Storm Water Management Plan (SWMP) for this development shall be designed in accordance with the Storm Water Ordinance and Chapter 5 of the Engineering Design Manual (updated Jan 31, 2024).
- 37. At the time of preliminary site plan submittal, the applicant should submit an infiltration study along with the soil borings. If infiltration is possible, it is recommended that the applicant design the landscaping to promote infiltration through rain gardens, bioretention, or permeable pavement.
- 38. Post-Development Drainage Master Plan table on sheet SP-5.1 must be updated; C factors do not match calculations on the next sheet.
- 39. Must obtain approval from the City's wetland consultant and EGLE for the proposed discharge into the wetlands

JZ24-0031


- 40. QVRP must be multiplied by the area in order to obtain the Q100P value; calculations should be updated at the time of site plan submittal.
 - 3. DETERMINE THE REQUIRED CHANNEL PROTECTION STORAGE VOLUME

 $V_{CP-R} = 4719 \times A \times C = 4719 \times 7.97 \times 0.70 = 26,327 CF$

4. DETERMINE THE REQUIRED 100-YEAR STORAGE VOLUME



- 41. Provide pre vs post flow calculations for the 12" culvert located at wetland L to ensure that proposed flow and volume is not greater than the existing flow and volume.
- 42. The applicant should revise drainage areas; all rear yard stormwater shall be routed to storm sewer or swales that ultimately discharge into on-site detention basins.
 - a) Approximately 1-acre drainage area behind buildings 24, 25, and 26 is routed towards wetland L. This untreated stormwater flows off-site. Provide information for pre- vs. post-development discharge at this location.
 - b) Basin A outlets into wetland H, while wetland H flows towards Basin B. Pass-through drainage is allowed, but a pre-treatment unit shall be required for Basin B, as the permanent pool for this basin will not be effective with pass-through drainage. The route should also be reinforced to avoid erosion. Ensure that the outlet pipe for basin B can accommodate the design outlet release rate and the pass-through volume for wetland H.
 - c) Rear yard stormwater between buildings 42, 41, 40, 39, 29, and 30 is all currently shown outside of any of the proposed drainage areas; this is approximately 2 acres. Stormwater from this area is not being routed towards a basin/treated prior to discharging towards wetland T. Indicate the impact of this additional drainage area on wetland T as well.



- 43. As part of the Storm Drainage Facility Maintenance Easement Agreement, provide an access easement for maintenance over the storm water detention system and the pretreatment structure. Also, include an access easement to the detention area from the public road right-of-way.
- 44. Provide a soil boring in the vicinity of each storm water basin to determine soil conditions and to establish the high-water elevation of the groundwater table. Note that the bottom of the detention facility/permanent pool must be a minimum of **three (3) feet** above the groundwater elevation.

PAVING & GRADING

- 45. Provide a construction materials table on the Paving Plan listing the quantity and material type for each pavement cross-section being proposed.
- 46. Site grading shall be limited to 1V:4H (25-percent), excluding landscaping berms.
- 47. The grade of the drive approach shall not exceed 2 percent within the first 25 feet of the intersection. Provide spot grades as necessary to establish this grade.
- 48. Provide top of curb/walk and pavement/gutter grades to indicate the height of curb adjacent to parking stalls or drive areas.
- 49. Dimensions of parking stalls abutting a curb or sidewalk are to the face of curb or walk. All other dimensions are to back of curb unless otherwise indicated.
- 50. The retaining wall proposed at the wetland crossing area is located within proposed water main easement. A License Agreement will be required for the proposed retaining wall within any utility easements. A plan view and cross-

The Grove JZ24-0031

- section shall be included with the agreement showing the relationship between the wall foundation and the existing/proposed utility.
- 51. Retaining walls that are 48-inches or larger shall need a permit from the Building Department. Ensure that retaining walls do not conflict with the patio and decks that are allowed for each building.


To the extent this review letter addresses items and requirements that require the approval of or a permit from an agency or entity other than the City, this review shall not be considered an indication or statement that such approvals or permits will be issued.

Please contact Humna Anjum at (248) 735-5632 or email at hanjum@cityofnovi.org with any questions.

Humna Anjum, Project Engineer

cc: Lindsay Bell, Community Development

Milad Alesmail, Engineering Kate Purpura, Engineering Ben Croy, City Engineer





PLAN REVIEW CENTER REPORT July 24, 2025 The Grove

Formal PRO Site Plan - Landscaping

Review Type	Job #
Formal PRO Site Plan Landscape Review	JZ24-31

Property Characteristics

Site Location: Southwest corner of Meadowbrook and 12 Mile Road

Site Acreage: 54.85 ac.Site Zoning: OST

Proposed Zoning: RM-1 with PRO

Adjacent Zoning: North: RA, R-4, R-3; East, South, West: OST

• Plan Date: 7/9/2025

Ordinance Considerations

This project was reviewed for conformance with Chapter 37: Woodland Protection, Zoning Article 5.5 Landscape Standards, the Landscape Design Manual and any other applicable provisions of the Zoning Ordinance. Items in **bold** below must be addressed and incorporated as part of the Preliminary Site Plan submittal. Underlined items must be addressed on the Final Site Plans. Please follow guidelines of the Zoning Ordinance and Landscape Design Guidelines. This review and the accompanying Landscape Chart are summaries and are not intended to substitute for any Ordinance.

RECOMMENDATION:

This project is **recommended for approval for the proposed rezoning**. Some site plan-related corrections need to be made, but there are no serious unsupported deviations from the landscape ordinances.

LANDSCAPE DEVIATIONS THAT ARE REQUIRED FOR THE PROPOSED LAYOUT:

- Deficiency in required screening berms between the site and Office Service/Tech supported by staff for east and south property lines because of topography and the provision of dense landscaping along both areas.
- Lack of greenbelt berms supported by staff for 12 Mile Road and for the areas with a heavily landscaped detention bond, preserved natural areas along Meadowbrook Road and sufficiently dense landscaping between Meadowbrook and Buildings 1 and 2.
- No greenbelt plantings in preserved areas supported by staff to preserve the natural areas

GENERAL NOTES:

- Please reduce the width of the 10 foot walk down to no more than 8 feet or whatever width Planning and Engineering request. The 10-foot width does not leave sufficient room for the street trees and would not be attractive along the interior street.
- Please use a symbol for woodland replacement evergreen trees that is very different from that used for multifamily unit trees. When they are small they are too hard to distinguish.
- If the clubhouse option is used, please reorient the clubhouse/pool layout to keep it out of the wetland buffer.
- Please switch the numbering of Sheets L-5 and L-6 to keep the greenbelt planting details together.

Ordinance Considerations

Existing Trees (Sec 37 Woodland Protection, Preliminary Site Plan checklist #17 and LDM 2.3 (2))

- 1. Tree survey and wetland surveys are provided.
- 2. Please see the Merjent letter for a detailed review of the woodlands and wetlands.
- **3.** A total of 248 trees are shown as being planted, with a deposit to the tree fund being made to the remaining 2895 credits required.
- **4.** When species are assigned to the symbols shown, please use species that are similar to those removed as much as possible.

Adjacent to Residential - Buffer (Zoning Sec. 5.5.3.B.ii and iii)

- 1. The project is adjacent to OST property on the east and south so a 4.5-6 foot tall landscaped berm is required for buffering.
- 2. The plan proposes dense landscaping as a buffer around the site instead of the required berm where significant existing landscaping is not preserved and where site grading makes a berm impractical. **This requires a landscape deviation**. It is supported by staff due to the nature of the adjacent uses, and the landscaping provided.

Adjacent to Public Rights-of-Way – Berm/Wall, Buffer and Street Trees (Zoning Sec. 5.5.3.B.ii, iii)

- 1. The required greenbelt widths are proposed for both 12 Mile Road and Meadowbrook Road.
- 2. No berm is proposed along 12 Mile Road. **This requires a landscape deviation**. It is supported due to the existing preserved wetlands that would prevent a consistent berm from being provided.
- 3. Berms are proposed along Meadowbrook except in the areas to be preserved in a natural condition, and where sitting areas are proposed. **This requires a landscape deviation**. It is supported by staff to preserve the natural areas.
- 4. The required greenbelt plantings are proposed for all developed areas with some minor corrections required. Landscape deviations are required for the areas being preserved in their natural state. They are supported by staff.
- 5. The required street trees are proposed along 12 Mile Road with one minor correction to be made that is discussed on the landscape chart.
- 6. The required street trees are proposed along Meadowbrook Road.

Parking Lot Landscaping (Zoning Sec. 5.5.3.C.)

- 1. There are no parking lots except for the clubhouse option.
- 2. Please include the widths of the guest parking bays in the calculation of the interior street trees and use interior street trees along the perimeter of the bays instead of having a separate calculation for the bays.

Multi-family Residential Landscaping (Zoning Sec 5.5.3.F.iii)

1. Multi-family unit trees

- a. 232 units are proposed, so 696 trees are required. It appears that all of the required trees are provided, but please double-check the counts and add more if required.
- b. <u>Tree species should be provided on the Preliminary Site Plans if possible, but no later</u> than Final Site Plans.
- c. No more than 25% of the trees used may be subcanopy trees

2. Interior roadway trees

- a. The plan proposes all of the required 248 trees are proposed, plus 24 parking lot perimeter trees. See the above discussion related to the perimeter trees.
- b. When species are assigned, all of them should be deciduous canopy trees.

3. Foundation landscaping

JZ24-31: THE GROVE

The detailed plans indicate that all of the buildings have the required landscaping, either entirely on the front of the building or a combination of mostly the front plus some on the sides facing the roads. This is acceptable.

Building Foundation Landscaping (Zoning Sec 5.5.3.D)

- 1. It appears from the calculations and shading shown around the building that the required foundation landscaping for the clubhouse will be provided.
- 2. Please provide detailed foundation planting plans on Final Site Plans.

Plant List (LDM 4, 10)

- 1. Please provide a plant list on the Preliminary Site Plans if possible.
- 2. At least 50% of the non-woodland replacement species used must be species native to Michigan.
- 3. The non-woodland tree diversity should have no more than 10% of the trees planted composed of a single species, and no more than 15% of them composed of a single genus.

Planting Notations and Details (LDM 10)

Provided

Storm Basin Landscape (Zoning Sec 5.5.3.E.iv and LDM 3)

- 1. All required landscaping appears to be proposed.
- 2. Please see the notes on the landscape chart for a more detailed discussion of the detention landscaping.

<u>Irrigation (LDM 10)</u>

- 1. If an irrigation system will be used, a plan for it must be provided with Final Site Plans.
- 2. <u>If alternative means of providing water to the plants for their establishment and long-term</u> survival, information regarding that is also required with Final Site Plans.

If the applicant has any questions concerning the above review or the process in general, do not hesitate to contact me at 248.735.5621 or rmeader@cityofnovi.org.

The Meader

Rick Meader – Landscape Architect

LANDSCAPE REVIEW SUMMARY CHART - Initial PRO Concept Plan

Review Date: July 24, 2025

Project Name: JZ24-31: The Grove

July 9, 2025

Prepared by: Rick Meader, Landscape Architect E-mail: rmeader@cityofnovi.org;

Phone: (248) 735-5621

Items in **Bold** need to be addressed by the applicant before approval of the Preliminary Site Plan. Underlined items need to be addressed on the Final Site Plan.

LANDSCAPE DEVIATIONS THAT MAY BE REQUIRED FOR PROPOSED LAYOUT:

- Deficiency in required screening berms between the site and Office Service/Tech supported by staff for east and south property lines because of topography and the provision of dense landscaping along both areas.
- Lack of greenbelt berms supported by staff for 12 Mile Road and for the areas with a heavily landscaped detention bond, preserved natural areas along Meadowbrook Road and sufficiently dense landscaping between Meadowbrook and Buildings 1 and 2.
- No greenbelt plantings in preserved areas supported by staff to preserve the natural areas

GENERAL NOTES:

Plan Date:

- Please reduce the width of the 10 foot walk down to no more than 8 feet or whatever width Planning and Engineering request. The 10-foot width does not leave sufficient room for the street trees and would not be attractive along the interior street.
- Please use a symbol for woodland replacement evergreen trees that is very different from that used for multifamily unit trees. When they are small they are too hard to distinguish.
- If the clubhouse option is used, please reorient the clubhouse/pool layout to keep it out of the wetland buffer.
- Please switch the numbering of Sheets L-5 and L-6 to keep the greenbelt planting details together.

Item	Required	Proposed	Meets Code	Comments
Landscape Plan Requir	ements – Basic Information	(LDM (2))		
Landscape Plan (Zoning Sec 5.5.2, LDM 2.e)	 New commercial or residential developments Addition to existing building greater than 25% increase in overall footage or 400 SF whichever is less. 1"-20' minimum with proper North. Variations from this scale can be approved by LA 	 Overall site (Sheets L-1 – L-3 and L-7): 1"=50 ft Greenbelt & Entry Plans, Amenity Plan (Sheets L-4 -, L-6, L-11): 1" = 30 ft Detention Ponds (Sheets L-8, L-9): 1" = 40 ft Building foundation landscaping plans (Sheet L-10): 1"=40' 	Yes	
Owner/Developer	Name, address and	Ivanhoe		
Contact Information	telephone number of	Companies - on	Yes	
(LDM 2.a.)	the owner and	Cover Sheet and		!

Item	Required	Proposed	Meets Code	Comments
	developer or association	on the landscape plan title block		
Project Information (LDM 2.d.)	Name and Address	Location map on Cover Sheet and Sheet L-1	Yes	
Survey information (LDM 2.c.)	Legal description or boundary line survey	Boundary: Sheets SP7-SP7.3Ex. Topo: Sheet 5, Sheets 9-9.4	Yes	
Landscape Architect contact information (LDM 2.b.)	Name, Address and telephone number of RLA/PLA/LLA who created the plan	Jim Allen – Allen Design	Yes	
Sealed by LA. (LDM 2.g.)	Requires original signature	Copy of seal and signature	Yes	
Miss Dig Note (800) 482-7171 (LDM.3.a.(8))	Show on all plan sheets	On Landscape Plan Title block	Yes	
EXISTING CONDITIONS				
Existing plant material Existing woodlands or wetlands (LDM 2.e.(2), Sec 12, 37))	 Show location type and size. Label to be saved or removed. Plan shall state if none exists. 	Tree survey is provided on Sheets SP9-9.8. Tree survey and removals are also provided on Sheets L-13 -L-20. Woodland replacement calculations are provided on L-20. Wetland boundaries are indicated on SP-8 and topographic survey sheets Trees to remain are shown on the landscape plan Wetland impacts and mitigation areas are shown on Sheets W-1 – W-4.	YesYesYesYesYesYes	 See Merjent letter for detailed reviews of wetlands and woodlands As long as the information is the same between the tree survey in the civil plans and that shown in the landscape plans, there isn't a need for the same information to be included in the set. If the civil sheets are kept, the removals and replacement calculations must be clearly shown and provided with either the tree chart or the landscape plans. When species are attached to the woodland replacements, please remember that the diversity requirement is not required for them, and it would be

Page 2 of 14 JZ24-31: THE GROVE

Item	Required	Proposed	Meets Code	Comments
				desirable to use similar species as those removed as much as possible to restore the lost habitat as much as possible.
Natural Features protection				Please show tree fencing at trees' actual CRZ, not the edge of the tree symbol.
Phragmites and Japanese Knotweed Control (Sec 6.B.i)	 Any/all populations of Phragmites australis and/or Japanese knotweed and related species shall be noted on plans. If any is found, instructions for their complete removal should be added to the plans. If none is found, a note stating that shall be added. 	 Phragmites locations are shown on L-2 Methods for its removal are also on L-2 No mention is made of Japanese knotweed 	YesYesTBD	Please either show locations of Japanese knotweed on the same sheet or add a note stating that no Knotweed was found on the site.
Soil type (LDM.2.r.)	As determined by Soils survey of Oakland County	 Soils boundaries and types are shown on SP-2 Soil Boring locations are also shown on SP-2 Soil Boring charts are provided on Sheets, SP-9.9 and SP-9.10 	• Yes • Yes	
Zoning (LDM 2.f.)	Site: OST Proposed: RM-1 with PRO North: RA, R-4, B-3, East: OST, South: OST, West: OST	Shown on L-1	Yes	
PROPOSED IMPROVEME	NTS			
Existing and proposed improvements (LDM 2.e.(4))	Existing and proposed buildings, easements, parking spaces, vehicular use areas, and R.O.W	 Site plan shows locations of buildings and drives All proposed improvements are shown on the landscape plans. 	• Yes • Yes	
Existing and	Overhead and	Utilities are shown	• Yes	Please add all

Item	Required	Proposed	Meets Code	Comments
proposed utilities (LDM 2.e.(4))	underground utilities, including hydrants • Show all proposed light posts	on SP-6.1 and SP-6.2 Utilities are included on the landscape plans Light posts are not provided yet	• Yes • No	proposed light posts to the landscape plans on the Final Site Plans at the latest and resolve all tree/post conflicts.
Proposed topography - 2' contour minimum (LDM 2.e.(1))	Provide proposed contours at 2' interval	 Proposed spot elevations and berms are shown on SP-4.0 - SP-4.2 Berms are shown on landscape plans Retaining wall TW/BW elevations are given for all of the walls except for the one near the intersection of Simi Lane and Elle Parkway 	• Yes • Yes • Yes	Please add TW/BW elevations for the unlabeled retaining wall.
Clear Zones (LDM 2.e.(5))	 Show clear vision zones for all entry points. Use RCOC clear vision guidelines for 12 Mile Road and City clear vision guidelines for Meadowbrook. Refer to exhibits at end of this chart. 	 City clear vision zones are shown for all entries. No trees or shrubs are shown within the zones. 	Yes	

Page 4 of 14

JZ24-31: THE GROVE

LANDSCAPING REQUIREMENTS

Berms and ROW Planting

- All berms shall have a maximum slope of 33%. Gradual slopes are encouraged. Show 1ft. contours
- Berm should be located on lot line except in conflict with utilities.
- Berms should be constructed with 6" of topsoil.

Residential Adjacent to Non-residential (Sec 5.5.3.A) & (LDM 1.a)

Berm requirements (Zoning Sec 5.5.A)	Residential adjacent to Office Service/Tech residential requires: • 4.5-6 foot high landscaped berm with 5 foot wide crest. • Opacity 80% winter, 90% summer.	 No berms are provided along the east side where there is just a large wetland mitigation/detention area. Dense plantings are provided east of Buildings 24-26 and over 140 feet of existing trees or densely planted 	No	 The lack of a screening berm along the east property line requires a landscape deviation. Since there are no actual Office Service/ Tech buildings east of the site, and either new or existing trees will provide screening
---	---	---	----	---

Page 5 of 14

JZ24-31: THE GROVE

Parkway sidewalk. 4. Please show the

Page 7 of 14

JZ24-31: THE GROVE

Page 8 of 14

Page 9 of 14

Page 10 of 14

Item	Required	Proposed	Meets Code	Comments
5.5.3.E.iv)	area at 10 ft away from the permanent water line. Canopy trees must be located at 1 per 35lf of the pond rim 10 feet away from the permanent water level 10" to 14" tall grass along sides of basin Refer to wetland for basin mix Include seed mix details on landscape plan	provided • A stormwater seed mix is called out on the pond details but no seed mix is provided for the areas around the ponds.		2. Please add all appropriate seed mixes to the plans on the Final Site Plans.
Landscape Notes and	Details— Utilize City of Novi S	tandard Notes		
Plant List (LDM 4) – Inclu	ude all cost estimates			
Quantities and sizes		No plant list is given	TBD	Provide plant list on landscape plans, preferably on the Preliminary Site Plans but no later than Final Site Plans.
Root type		No plant list is given	TBD	See above
Botanical and common names	 At least 50% of plant species used, not including seed mixes or woodland replacement trees, must be species native to Michigan. The non-woodland replacement tree diversity must meet the standards of the Landscape Design Manual section 4. As the number of trees will be more than 200, no more than 10% of the trees planted shall be of a given species, and no more than 15% shall be from a single genus. Woodland replacements do not need to meet the LDM diversity requirements, and should resemble the percentages of 	No plant list is provided	TBD	See above

Page 11 of 14 JZ24-31: THE GROVE

Page 12 of 14

No plant list is

provided

TBD

Do not use any plants

on the Prohibited

Species List

Prohibited Plants

(LDM 11.b)

Item	Required	Proposed	Meets Code	Comments
Recommended trees for planting under overhead utilities (LDM 3.e)		Overhead lines are not labeled on the landscape plans		
Collected or Transplanted trees (LDM 3.f)		None indicated		
Nonliving Durable Material: Mulch (LDM 4)	 Trees shall be mulched to 3" depth and shrubs, groundcovers to 2" depth Specify natural color, finely shredded hardwood bark mulch. Include in cost estimate. 	Shown on planting details		

Page 14 of 14


JZ24-31: THE GROVE

NOTES:

- 1. This table is a working summary chart and not intended to substitute for any Ordinance or City of Novi requirements or standards.
- 2. The section of the applicable ordinance or standard is indicated in parenthesis. For the landscape requirements, please see the Zoning Ordinance landscape section 5.5 and the Landscape Design Manual for the appropriate items under the applicable zoning classification.
- 3. Please include a written response to any points requiring clarification or for any corresponding site plan modifications to the City of Novi Planning Department with future submittals.

Irrigation System Requirements

- Any booster pump installed to connect the project's irrigation system to an existing irrigation system must be downstream of the RPZ.
- The RPZ must be installed in accordance with the 2015 Michigan Plumbing Code.
- The RPZ must be installed in accordance with the manufacture installation instructions for winterization that includes drain ports and blowout ports.
- The RPZ must be installed a minimum of 12-inches above FINISHED grade.
- Attached is a handout that addresses winterization installation requirements to assist with this.
- A plumbing permit is required.
- The assembly must be tested after installation with results recorded on the City of Novi test report form.





August 8, 2025

Lindsay Bell Planner – Community Development City of Novi 45175 Ten Mile Road Novi, MI 48375

Submitted electronically to lbell@cityofnovi.org

Re: The Grove Formal Planned Rezoning Overlay Submittal Wetland and Woodland Review (Formal PRO; JZ24-31)

Dear Lindsay,

Merjent, Inc. (Merjent) has conducted a site plan review of the formal planned rezoning overlay (PRO) submittal for The Grove (site). Two sets of plans were provided:

- One plan prepared by Zeimet Wozniak and Associates dated July 9, 2025. This plan contains the primary design/engineering information for the Formal PRO submittal.
- One plan prepared by Allen Design dated July 9, 2025 This plan contains the landscape and woodland replacement information for the Formal PRO submittal.

Merjent reviewed the plans for conformance with the City of Novi's (City) current Woodland Protection Ordinance, Chapter 37, and Wetlands and Watercourse Protection Ordinance, Chapter 12 Article V. The site is located southeast of the intersection of Meadowbrook Road and Twelve Mile Road in Section 13 of the City. Development is proposed within and is identified by approximately 12 different parcel numbers in the City of Novi records. The site contains City-regulated woodlands and City-regulated wetlands (**Figure 1** and **Figure 2**).

Woodlands

Woodland Recommendation: Merjent **recommends approval** of The Grove Formal PRO Submittal. A list of comments is provided below to meet the requirements of the Woodland Protection Ordinance. The following Woodland Regulations apply to this site:

Woodland Regulation	Required
Woodland Permit (Chapter 37, Section 37-26)	Yes
Tree Replacement (Chapter 37, Section 37-8)	Yes
Tree Protection (Fence; Chapter 37, Section 37-9)	Yes
Woodland Conservation Easement (Chapter 37-30[e])	Yes, if feasible

Woodland Review Comments

1. City-regulated woodlands, as identified on the City of Novi Woodlands interactive map website, are present onsite (**Figure 1**). A site visit was performed on August 23, 2024 to verify and review the extent of woodlands on-site. Due to the extent of invasive species on-site, such as European buckthorn

(*Rhamnus cathartica*), it is Merjent's opinion that the extent of the Woodlands listed in the map viewer is accurate. Select photos from the site visit were included in the initial concept plan submittal.

- 2. When a proposed site plan is located within a regulated woodland, any tree proposed for removal with a diameter at breast height (DBH) greater than or equal to eight inches will require tree replacement and a Woodland Use Permit per Section 37-8. This also applies to any tree that will be preserved, but where impacts to critical root zones are proposed.
- Regardless of the presence of regulated woodlands onsite, a Woodland Use Permit is required to perform construction on any site containing the removal of trees larger than 36 inches in diameter at breast height (DBH).
- 4. The plans have proposed the cumulative removal of 2,019 regulated trees (does not include dead or dying [very poor] trees). A **Woodland Use Permit** is required to perform construction on any site containing regulated woodlands. The permit for this site would require Planning Commission approval because there are more than three trees proposed to be impacted/removed by construction.
- 5. **Woodland Replacement**. Based on review of the plans, the following woodland replacements are currently listed:

Tree Size (DBH, inches)	Number of Trees	Ratio Replacement/Removed Tree	Total Replacements Required			
8-11	1,126	1	1,126			
12-20	715	2	1,430			
21-29	59	3	177			
30+	14	4	56			
Multi-stem	105	Sum of Stem DBH/8 (rounded up)	389			
Total	2,019	-	3,178			
Less Credits (for to	rrent woodland areas)	-35				
Total Replacement	Total Replacements Required					

• Requested edit for future submittals: on Sheet SP-9.4, a "10" (10-inch) Pine" is displayed south of Wetland I/K that may not be counted for in the tree list and may not be listed in the landscape plan. This pine should be clarified in future submittals to be given a unique identifier, classified down to species and condition, and given a similar symbol to other trees on-site.





6. For tree replacement credits that will be planted on-site, a financial guarantee of \$400/tree replacement credit is required to ensure the planting of the on-site woodland replacement credits. The financial guarantee will be released after trees have been planted and approved by the City of Novi. The applicant must request a tree planting inspection. For The Grove PRO, the applicant has proposed planting 248 replacement trees on-site. A **Woodland Replacement Financial Guarantee of \$99,200** (248 trees x \$400/tree) is required as part of the Woodland Use Permit fees to ensure a successful planting of on-site Woodland Replacement Tree Credits.

The Applicant shall guarantee trees for two growing seasons after installation and the City's acceptance, per the City's Performance Guarantees Ordinance. A **two-year maintenance bond in the amount of 25% (\$24,800)** of the value of the trees, but in no case less than \$1,000, shall be required to ensure the continued health of the trees following acceptance (Chapter 26.5, Section 26.5-37).

Note that the Applicant is responsible for requesting an inspection of the installed on-site Woodland Replacement Trees.

While not necessary for the formal PRO approval, a list of trees proposed for replacement will need to be provided in the preliminary site plan. Approximate locations are provided in the associated landscape plans. Section 37-8 of the City of Novi Woodlands Protection Ordinance and the City of Novi Landscape Design Manual provide guidelines for replacement trees.

- Requested edit/clarification: Sheet L-1 states that 248 trees will be provided on-site and a
 summary of subsequent sheets states that Sheet L-1 provides 56 trees, Sheet L-2 provides 110
 trees, and Sheet L-3 provides 82 trees. Upon further review, Sheet L-2 provides 141 trees and
 Sheet L-3 provides 112 trees. In further submittals, this discrepancy may be fixed by providing the
 species, locations, and total number of each species for replacement.
- 7. The Applicant will be required to pay into the **City of Novi Tree Fund \$1,158,000** for the remaining 2,895 woodland replacements not planted on site (2,895 woodland replacement credits x \$400/credit). This fee is non-refundable.



- a. Merjent understands that a small amount of tree replacements are required for the creation of a potential wetland mitigation site. It should be noted that any trees planted specifically to meet the requirements of the wetland mitigation performance standards (see wetland comments) cannot be double counted to meet the requirements of woodland replacement credits and viceversa. Therefore, any trees planted for potential wetland mitigation sites will only be counted toward either wetland mitigation performance standards or woodland replacement credits. Additional/supplemental plantings in these areas that exceed wetland mitigation performance standards can then be counted toward woodland replacement credits.
- 8. Critical root zone. Accurate critical root zones must be depicted on the site plan for all regulated trees within 50 feet of the proposed grading or construction activities. Tree symbols are present on the plan but are relatively small. Additionally, it is unclear whether the tree symbol on the plan represents the trunk, dripline, or critical root zone of the tree. The tree symbol should be clarified in the legend or elsewhere on the plan. Critical root zones should be identified using a separate symbol on the site plans. These impacts may have already been accounted for in the removal table provided, but the symbol should be clarified prior to the final site plan approval.
- 9. Regulated woodland disturbance includes impacts to the critical root zone of regulated trees, including but not limited to encroachment by grading, landscaping, and construction. If impacts to the critical root zone of regulated woodland trees are proposed – woodland replacements are required. Revised woodland replacement calculations or plan revisions may be necessary to address any unclear encroachments into the critical root zone.
- 10. A **woodland fence guarantee of \$6,000** (\$5,000 x 120%) is required per Chapter 26.5-37. The financial guarantee shall be paid prior to issuance of the City of Novi Woodland Use Permit.
- 11. Woodland Replacement Inspection The Applicant is responsible for walking the entire site to confirm that all woodland replacement trees/shrubs have been planted on site according to the approved site plan stamping set. If any material is missing, dead or dying, replacements should be made prior to requesting the inspection. The applicant should also provide an as-built landscape plan if the trees planted do not match the species and/or location shown on the approved site plan stamping set. Once this occurs the Applicant should contact the Bond Coordinator to schedule the inspection (Angie Sosnowski at asosnowski@cityofnovi.org; 248-347-0441) and complete the inspection request form. If additional inspections are needed, then additional inspection fees will be required to be paid by the applicant.
- 12. Woodland Guarantee Inspection Prior to requesting the 2-year woodland guarantee inspection, the Applicant is responsible for walking the entire site to confirm that all plant material has survived and is healthy. If any material is missing, dead or dying, replacements should be made prior to requesting the inspection. Once this occurs the Applicant should contact the Bond Coordinator to schedule the 2-year guarantee inspection (Angie Sosnowski at asosnowski@cityofnovi.org / 248-347-0441) and complete the inspection request form. If additional inspections are needed, then additional inspection fees will be required to be paid by the applicant. Based upon a successful inspection for the 2-year warranty the Landscape/Woodland/Street trees financial guarantee will be returned to the Applicant.

If the woodland replacements, street trees, or landscaping guarantee period is scheduled to end during the period when inspections are not conducted (November 15th – April 15th) the Applicant is



responsible for contacting the Bond Coordinator and Woodland/Landscape Inspector in the late summer/early fall prior to the 2-year expiration to schedule an inspection.

- 13. The Applicant may be required to provide preservation/conservation easements as directed by the City of Novi Community Development Department for any areas of woodland replacement trees. The applicant shall demonstrate that all proposed woodland replacement trees and existing regulated woodland trees to remain will be guaranteed to be preserved as planted with a conservation easement or landscape easement to be granted to the city. This language shall be submitted to the City Attorney for review. The executed easement must be returned to the City Attorney within 60 days of the issuance of the City of Novi Woodland permit. Any associated easement boundaries shall be indicated on the Plan.
 - a. An existing conservation easement is present southeast of the site associated with Meadowbrook Investments LLC. A map of conservation easements is provided as **Attachment** A.
- 14. It should be noted that based off the wetland impacts information (see below) wetland impacts are proposed to all wetlands within the area identified as "Parcel A." If the applicant intends to impact Parcel A as a part of this submittal, a tree survey should be conducted and provided in addition to woodland impacts similar to the information presented in the comments above.

Wetlands

Wetland Recommendation: Merjent **recommends approval** of the The Grove Formal PRO submittal based on the comments provided below. However, if the project moves toward a formal application, several comments should be addressed to meet the requirements of the City's Wetlands and Watercourse Protection Ordinance.

Upon review of published resources, the Site appears to contain or immediately borders:

- ☑ City-regulated wetlands, as identified on the City of Novi interactive map website. Note that both wetland and property limits depicted on the City's map are considered approximations (**Figure 2**).
- Wetlands that are regulated by the Michigan Department of Environment, Great Lakes, and Energy (EGLE).
- ☑ Wetlands as identified on National Wetland Inventory (NWI) and Michigan Resource Inventory System (MIRIS) maps, as identified on the EGLE Wetlands Viewer interactive map website (map provided in Wetland Boundary Review). NWI and MIRIS wetlands are identified by the associated governmental bodies' interpretation of topographic data and aerial photographs.

Permits and Regulatory Status

Due to the comments below, the following wetland-related items will be required for this project:

Item	Required/Not Required
Wetland Permit (specify Non-minor or Minor)	Required, Non-minor
Wetland Mitigation	Required



Item	Required/Not Required
Environmental Enhancement Plan	Required, Mitigation Plan
Wetland Buffer Authorization	Required
EGLE Wetland Permit	Likely Required*
Wetland Conservation Easement	Required

^{*}Final determination is at the discretion of EGLE

Wetland Review Comments

1. Impacts have been proposed to 17 wetlands on-site, totaling approximately 1.44 acres loss of wetland. The impacts are summarized below.

Table 1. Wetland Summary and Impact Table

Wetland ID	Classification*	Acres On- site	Wetland Impact Area (acre)	Wetland Impact Volume (cu. yd.)	Permanent Buffer Impact Area (acre)	Temporary Buffer Impact Area (acre)	Buffer Impact Volume (cu. ft.)
С	Emergent	0.10	0.100	525	Not Provided	Not Provided	Not Provided
E	Emergent	0.44	0.361	400	0.368	0.000	Not Provided
F	Emergent/Forested	0.29	0.000	0	0.137	0.000	Not Provided
G	Forested	0.07	0.060	190	0.230	0.000	Not Provided
Н	Forested	1.12	0.000	0	0.115	0.030	Not Provided
I/K	Emergent/Scrub- shrub/Forested	4.79	0.016	161	0.234	0.402	Not Provided
J	Scrub- shrub/Forested	0.04	0.034	68	0.140	0.000	Not Provided
L	Scrub-shrub	0.29	0.000	0	0.002	0.052	Not Provided
М	Emergent/Forested	0.21	0.060	267	0.107	0.000	Not Provided
N	Emergent/Scrub- shrub	0.06	0.000	0	0.022	0.000	Not Provided
0	Emergent/Scrub- shrub	0.39	0.000	0	0.000	0.000	Not Provided
Р	Scrub-shrub	0.03	0.030	130	0.130	0.000	Not Provided
Q	Forested	0.23	0.230	805	0.390	0.000	Not Provided
R	Emergent/Scrub- shrub	0.04	0.040	152	0.140	0.000	Not Provided
S	Forested	0.05	0.050	379	0.160	0.000	Not Provided
Т	Emergent/Scrub- shrub	0.97	0.000	0	0.040	0.289	Not Provided
U	Forested	0.12	0.070	45	0.100	0.000	Not Provided
V	Forested	0.14	0.140	775	0.200	0.000	Not Provided



Wetland ID	Classification*	Acres On- site	Wetland Impact Area (acre)	Wetland Impact Volume (cu. yd.)	Permanent Buffer Impact Area (acre)	Temporary Buffer Impact Area (acre)	Buffer Impact Volume (cu. ft.)
X	Scrub-shrub	0.07	0.022	31	0.070	0.000	Not Provided
Y	Emergent	0.21	0.210	777	0.280	0.000	Not Provided
Z	Scrub-shrub	0.02	0.020	47	0.120	0.000	Not Provided
Total	-	9.64	1.44	4,752	1.875	0.484	

*Classification per Sheet SP-8.1

- Requested edit/clarification: Wetland C is shown to have grading and a portion of the proposed Simi Lane to be within the setback/buffer.
 - o Similar to woodlands above, Wetlands M, U, V, Y, and Z are proposed to be impacted on the listed "Parcel A." However, no development plans are shown in the provided site plan. Additionally, the portion of Wetland U within Parcel A is shown to be impacted but is shown to be undisturbed on The Grove Parcels. Inversely, Wetland X is shown to be disturbed on the Grove Parcels, but is undisturbed on Parcel A. In future submittals, if the applicant is not proposing to develop Parcel A, reducing these proposed impacts may reduce the amount of required mitigation for the project.
- 2. In addition to wetlands, the City of Novi regulates wetland and watercourse buffers/setbacks. Article 24 of the Zoning Ordinance, Schedule of Regulations, states: "There shall be maintained in all districts a wetland and watercourse setback, as provided herein, unless and to the extent, it is determined to be in the public interest not to maintain such a setback. The intent of this provision is to require a minimum setback from wetlands and watercourses". The established wetland and watercourse buffer/setback limit is 25 horizontal feet, regardless of grade change.
 - a. Appropriate setbacks have been incorporated into the site plans. Prior to the site plan review process, the applicant should provide the buffer impact area for all wetlands on-site (see **Table 1**). Additionally, buffer impact volumes should be provided for all impacts.
- 3. The City of Novi requires the boundary lines of any watercourses or wetlands on the Site to be clearly flagged or staked and such flagging/staking shall remain in place throughout the conduct of permit activity. During Merjent's site visit on May 31, 2024 it was noted that the flagging from the delineation was still present. Select photos were provided in the Initial Concept Plan Review. The site does not need to be re-flagged during the site plan review process, but prior to granting a Wetland Use Permit and construction the wetlands should be verified as being accurately staked or flagged.
- 4. The cost to perform any wetland protection and restoration shall be listed on the site plan, per Chapter 26.5, Section 26.5-7 (b) of the City of Novi Code of Ordinances. A **Wetland Financial Performance Guarantee** in the amount of 120% of the cost to perform any wetland protection, restoration, and development will be collected prior to the granting of a Wetland Use Permit.
- 5. When a project permanently impacts 0.25 acre or more of essential wetland, the City of Novi requires mitigation at a ratio of 2:1 for forested wetlands and 1.5:1 for emergent and scrub-shrub wetlands.



Current wetland classifications in **Table 1** above reflect the classifications noted on Sheet SP-8.1. The total proposed impact to City-regulated wetlands is approximately 1.44 acres.

- 6. According to the City Ordinance Section 12-176 (Mitigation), "Mitigation shall be provided onsite where practical and beneficial to the wetland resources. If onsite mitigation is not practical and beneficial, mitigation in the immediate vicinity, within the same watershed, may be considered. Mitigation at other locations within the city will only be considered when the above options are impractical."
 - The applicant is required to provide 2.46 acres of mitigation on-site and has proposed 2.47 acres.
 - b. City-regulated mitigations will follow the City of Novi Mitigation Performance Standards (**Attachment B**), which are similar to EGLE's typical Mitigation Performance Standards.
 - c. During the preliminary site plan review process, the applicant will need to provide a conceptual mitigation plan. The conceptual mitigation plan should contain the following information:
 - The location of the proposed wetland mitigation site in relation to the proposed The Grove site. A location map for the mitigation site should be provided with the nearest crossroads and/or identifiable landmarks.
 - The total acreage and ecological type of the wetland that will be created and/or expanded.
 - A brief description of existing conditions at the proposed mitigation site. Existing
 conditions include but are not limited to, general topography, soils, vegetation, and
 any existing hydrology.
 - A brief description of the method with which the mitigated wetland will be created and/or expanded. A detailed engineering design is not required, but the source of water for the mitigated wetland should be identified.
 - d. For final site plan approval, the applicant will need to provide all required criteria stated in Section 12-176 in the final site plan or appended to the final site plan review submission.
- 7. The Applicant is encouraged to provide wetland conservation easements for any areas of remaining wetland and 25-foot wetland buffer. The Applicant shall provide wetland conservation easements as directed by the City of Novi Community Development Department for any areas of proposed wetland mitigation areas (if necessary). Additionally, EGLE may request conservation easements around remaining wetlands on-site if a permit is required from EGLE. This requirement would be unrelated to the requirements of the City of Novi Wetland Use Permit. This language shall be submitted to the City Attorney for review. The executed easement must be returned to the City Attorney within 60 days of the issuance of the City of Novi Wetland Use Permit.
 - a. An existing conservation easement is present southeast of the site associated with Meadowbrook Investments LLC. A map of conservation easements is provided as **Attachment** A.

Should you have any questions or concerns with this review, please contact me via email at jason.demoss@merjent.com or via phone at (619) 944-3835.



Sincerely,

Merjent, Inc.

felon Demoll

Jason DeMoss, PWS Environmental Consultant

Enclosures:

Figure 1 – City of Novi Woodlands Map
Figure 2 – City of Novi Wetlands Map
Attachment A – Site Photographs
Attachment B – Conservation Easement Map
Attachment C – Wetland Mitigation Performance Standards

CC:

Stacey Choi, City of Novi, schoi@cityofnovi.org
Rick Meader, City of Novi, rmeader@cityofnovi.org
Barbara McBeth, City of Novi, bmcbeth@cityofnovi.org
Matt Pudlo, Merjent, matt.pudlo@merjent.com





Figure 1. City of Novi Regulated Woodlands Map

Approximate Site boundary is shown in red. (Approximate) Regulated Woodland areas are shown in green.





Figure 2. City of Novi Regulated Wetlands Map
Approximate Site boundary is shown in red.
(Approximate) Regulated Wetland areas are shown in turquoise.



Attachment A Conservation Easement Map



City of Novi Conservation Easements





Conservation Easement

Wetland

Wetland & Woodland


World Imagery

Low Resolution 15m Imagery

High Resolution 60cm Imagery High Resolution 30cm Imagery

Citations

2.4m Resolution Metadata



Maxar, Esri Community Maps Contributors, City of Novi, Ml, Province of Ontario, Oakland County, Michigan, Esri, TomTom, Garmin, SafeGraph, GeoTechnologies, Inc, METI/NASA, USGS, EPA, NPS, US Census Bureau, USDA, USFWS

Attachment B Wetland Mitigation Performance Standards



- a. Construction has been completed in accordance with the City of Novi's approved plans and specifications included in the permit and mitigation plan (and associated approved site plan).
- b. The mitigation wetland is characterized by the presence of water at a frequency and duration sufficient to support a predominance of wetland vegetation and the wetland types specified at the end of the monitoring period. The monitoring period will follow the U.S. Army Corps of Engineers definition of the growing season as stated in the 1987 *Wetland Delineation Manual*:
 - i. "The portion of the year when soil temperatures at 19.7 inches (50 cm) below the soil surface are higher than biological zero (5°C [41°F]). For ease of determination, this period can be approximated by the number of frost-free days."
 - ii. "Estimating starting and ending dates for the growing season are based on 28°F (-2.2°C) air temperature thresholds at a frequency of five years in 10."
- c. A layer of high-quality topsoil, from the A horizon of an organic or loamy surface texture soil, is placed (or exists) over the entire wetland mitigation area at a minimum thickness of six inches.
- d. The mitigation wetland shall be free of oil, grease, debris, and all other contaminants.
- e. A minimum of six wildlife habitat structures, consisting of at least three types, have been placed per acre of mitigation wetland. At least 50 percent of each structure shall extend above the normal water level. The types of acceptable wildlife habitat structures are:
 - i. Tree stumps laid horizontally within the wetland area. Acceptable stumps shall be a minimum of six feet long (log and root ball combined) and 12 inches in diameter.
 - ii. Logs laid horizontally within the wetland area. Acceptable logs shall be a minimum of 10 feet long and six inches in diameter.
 - iii. Whole trees laid horizontally within the wetland area. Acceptable whole trees shall have all of their fine structure left intact (i.e., not trimmed down to major branches for installation), be a minimum of 20 feet long (tree and root ball), and a minimum of 12 inches in diameter.
 - iv. Snags which include whole trees left standing that are dead or dying, or live trees that will be flooded and die, or whole trees installed upright into the wetland. A variety of tree species should be used for the creation of snag habitat. Acceptable snags shall be a minimum of 20 feet tall (above the ground surface) and a minimum of 12 inches in diameter at breast height. Snags should be grouped together to provide mutual functional support as nesting, feeding, and perching sites.
 - v. Sand mounds at least 18 inches in depth and placed so that they are surrounded by a minimum of 30 feet of water measuring at least 18 inches in depth. The sand mound shall have at least a 200 square foot area that is 18 inches above the projected high-water level and oriented to receive maximum sunlight.
- f. The mean percent cover of native wetland species in the herbaceous layer at the end of the monitoring period is not less than:
 - i. 60 percent for emergent wetland.
 - ii. 80 percent for scrub-shrub wetland.

- iii. 80 percent for forested wetland.
- g. Extensive areas of open water and submergent vegetation areas having no emergent and/or rooted floating vegetation shall not exceed 20 percent of the mitigation wetland area. Extensive areas of bare soil shall not exceed five percent of the mitigation wetland area. For the purposes of these performance standards, extensive refers to areas greater than 0.01 acre (436 square feet) in size.
- h. The total percent cover of wetland species in each plot shall be averaged for plots taken in the same wetland type to obtain a mean percent cover value for each wetland type. For the purposes of this standard, total percent cover is the percent cover of the ground surface covered by vegetation, bare soil, and open water, when viewed from above. Total percent cover cannot exceed 100 percent. Plots within identified extensive open water and submergent areas, bare soil areas, and areas without a predominance of wetland vegetation shall not be included in this average. Wetland species refers to species listed as facultative and wetter (FAC, FACW, OBL) on the U.S. Army Corps of Engineer's 2020 Regional Plant List (version 3.5) for the Midwest Region.
- i. The mitigation wetland supports a predominance of wetland (hydrophytic) vegetation (as defined in the 2010 U.S. Army Corps of Engineers "Regional Supplement to the Corps of Engineers Wetland Delineation Manual: Midwest Region [Version 2.0]") in each vegetative layer, represented by a minimum number of native wetland species, at the end of the monitoring period. The minimum number of native wetland species per wetland type shall not be less than:
 - i. 15 species within the emergent wetland.
 - ii. 15 species within the scrub-shrub wetland.
 - iii. 15 species within the forested wetland.

The total number of native wetland plant species shall be determined by a sum of all species identified in sample plots of the same wetland type.


- j. At the end of the monitoring period, the mitigation wetland supports a minimum of:
 - i. 300 individual surviving, established, and free-to-grow trees per acre in the forested wetland that are classified as native wetland species and consisting of at least three different species.
 - ii. 300 individual surviving, established, and free-to-grow shrubs per acre in the scrub-shrub wetland that are classified as native wetland species and consisting of at least four different species.
 - iii. *Optional*: Eight native wetland species of grasses, sedges, or rushes per acre in the wet meadow wetland.
- k. Physiognomic classification of trees and shrubs shall be in accordance with the most updated resource from the following list:
 - i. The Michigan Floristic Quality Assessment
 - ii. Michigan Flora (also referred to as the University of Michigan Herbarium)
 - iii. The U.S. Army Corps of Engineer's Regional Plant List for the Midwest Region.
- I. The mean percent cover of invasive species including, but not limited to, *Phragmites australis* (Common Reed), *Lythrum salicaria* (Purple Loosestrife), and *Phalaris arundinacea* (Reed Canary Grass) shall in combination be limited to no more than 10 percent within each wetland type. Invasive species shall not dominate the vegetation in any extensive area of the mitigation wetland. A more exhaustive list of invasive species that are known to be in Michigan can be found on the State of Michigan's Invasive Species plant list (https://www.michigan.gov/invasives/id-report/plants)

If the mean percent cover of invasive species is more than 10 percent within any wetland type or if there are extensive areas of the mitigation wetland in which an invasive species is one of the dominant plant species, the permittee shall submit an evaluation of the problem to the City of Novi and/or the. If the permittee determines that it is infeasible to reduce the cover of invasive species to meet the above performance standard, the permittee must submit an assessment of the problem, a control plan, and the projected percent cover that can be achieved for review by the City of Novi. Based on this information, the City of Novi may approve an alternative invasive species standard. Any alternative invasive species standard must be approved in writing by the City of Novi.

If the mitigation wetland does not satisfactorily meet these standards by the end of the monitoring period, or is not satisfactorily progressing during the monitoring period, the permittee will be required to take corrective

Consultant review of Monitoring Reports will be split into the following sections:

- 1. Vegetation
- 2. Invasive Species
- 3. Hydrology
- 4. Wildlife Observations
- 5. Topsoil
- 6. Pollutants
- 7. Signage
- 8. Wetland Recommendations (as applicable)
 - a. Financial Guarantee Release





To:

Barbara McBeth, AICP City of Novi 45175 10 Mile Road Novi, Michigan 48375

CC:

Lindsay Bell, Dan Commer, Humna Anjum, Diana Shanahan, Milad Alesmail, Stacey Choi, Kate Puroura

AECOM 39575 Lewis Dr, Ste. 400 Novi MI, 48377 USA aecom.com

Project name:

JZ24-31 – The Grove Formal PRO Traffic Review

From:

Date:

October 2, 2025

Memo

Subject: JZ24-31 - The Grove Formal PRO Traffic Review

The formal PRO site plan was reviewed to the level of detail provided, and AECOM recommends **approval** as long as the comments provided below and the Traffic Impact study are adequately addressed to the satisfaction of the City.

GENERAL COMMENTS

- 1. The applicant, Ivanhoe Companies, is proposing a residential development consisting of 232 units.
- 2. The development is located on the southeast corner of Twelve Mile Road and Meadowbrook Road. Twelve Mile Road is under the jurisdiction of the Road Commission for Oakland County and Meadowbrook Road is under the jurisdiction of the City of Novi.
- 3. The site is zoned OST (Office Service Technology) and the applicant is requesting a PRO for RM-2 (High-Density Multiple-Family).
- 4. The following traffic related deviations have been requested by the applicant:
 - a. Parking on a major drive.
- 5. The following traffic related waivers may be required if revisions are not made to the plans:
 - a. Parking along street with centerline radius less than 230'.

TRAFFIC IMPACTS

1. AECOM performed an initial trip generation based on the ITE Trip Generation Manual, 11th Edition, as follows.

ITE Code: 220 – Multifamily Housing (Low-Rise) Development-specific Quantity: 232 Units Zoning Change: OST to RM-2 PRO

Trip Generation Summary	Estimated Trips	Estimated Peak- Direction Trips	City of Novi Threshold	Above Threshold?
AM Peak-Hour Trips	95	72	100	No
PM Peak-Hour Trips	120	76	100	Yes
Daily (One-Directional) Trips	1564	N/A	750	Yes

The City of Novi generally requires a traffic impact study/statement if the number of trips generated by the proposed development exceeds the City's threshold of more than 750 trips per day or 100 trips per either the AM or PM peak hour, or if the project meets other specified criteria.

Trip Impact Study Recommendation						
Type of Study:	Justification					
	Proposed rezoning from OST to RM-2, and estimated trips are above the City's threshold.					
Traffic Impact Statement (TIS) And Rezoning Traffic Impact Statement (RTIS)	The applicant submitted a revised Trip Generation Comparison Study dated July 1, 2025. Trip Generation Comparison is concluding lower total trips compared to Existing OST land use and the October 2024 Site plan, but higher than the threshold set for the Traffic Impact Study (TIS). The applicant is to update and submit the Traffic Impact Study for approval that was previously submitted and denied approval in 2024.					

TRAFFIC REVIEW

The following table identifies the aspects of the plan that were reviewed. Items marked O are listed in the City's Code of Ordinances. Items marked with ZO are listed in the City's Zoning Ordinance. Items marked with ADA are listed in the Americans with Disabilities Act. Items marked with MMUTCD are listed in the Michigan Manual on Uniform Traffic Control Devices.

The values in the 'Compliance' column read as 'met' for plan provision meeting the standard it refers to, 'not met' stands for provision not meeting the standard and 'inconclusive' indicates applicant to provide data or information for review and 'NA' stands for not applicable for subject Project. The 'remarks' column covers any comments reviewer has and/or 'requested/required variance' and 'potential variance'. A potential variance indicates a variance that will be required if modifications are not made or further information provided to show compliance with the standards and ordinances. The applicant should put effort into complying with the standards; the variances should be the last resort after all avenues for complying have been exhausted. Indication of a potential variance does not imply support unless explicitly stated.

EXT	EXTERNAL SITE ACCESS AND OPERATIONS							
No.	Item	Proposed	Compliance	Remarks				
1	Driveway Radii O <u>Figure IX.3</u>	35'	Met					
2	Driveway Width O Figure IX.3	28' and 23' at boulevard entrances	Met					
3	Driveway Taper O Figure IX.11							
3a	Taper length	100' and 75'	Met					
3b	Tangent	50'	Met					
4	Emergency Access O <u>11-</u> <u>194.a.19</u>	3 access points	Met					

EXT	EXTERNAL SITE ACCESS AND OPERATIONS							
No.	Item	Proposed	Compliance	Remarks				
5	Driveway sight distance O Figure VIII-E	1065.11' along 12 Mile Rd; 665.95', 649.13', 1421.94', 516.97' along Meadowbrook Rd	Met					
6	Driveway spacing							
6a	Same-side O <u>11.216.d.1.d</u>	N/A	-					
6b	Opposite side O 11.216.d.1.e	235.35' 12 Mile Rd, 199.51' and 493.08' Meadowbrook Rd	Met					
7	External coordination (Road agency)	RCOC	Met					
8	External Sidewalk <u>Master Plan</u> & EDM	Proposed 10' along Twelve Mile Rd and tying into existing on Meadowbrook Rd	Met					
9	Sidewalk Ramps EDM 7.4 & R- 28-K	Indicated	Partially Met	Include current R-28 detail in future submittal.				
10	Any Other Comments:	Label island length at each entrance/exit to ensure it meets the requirements shown in Figure IX.3.						

INTE	INTERNAL SITE OPERATIONS				
No.	Item	Proposed	Compliance	Remarks	
11	Loading zone <u>ZO 5.4</u>	N/A	-		
12	Trash receptacle ZO 5.4.4	Trash collection will be at each driveway	Met		
13	Emergency Vehicle Access	Provided	Met		
14	Maneuvering Lane <u>ZO</u> <u>5.3.2</u>	N/A	-		
15	End islands <u>ZO 5.3.12</u>				
15a	Adjacent to a travel way	N/A	-		
15b	Internal to parking bays	N/A	-		
16	Parking spaces <u>ZO 5.2.12</u>	Perpendicular spaces, garage and driveway parking		See Planning review letter. The applicant is seeking a waiver for parking along a major drive.	

INTE	INTERNAL SITE OPERATIONS				
No.	Item	Proposed	Compliance	Remarks	
17	Adjacent parking spaces ZO 5.5.3.C.ii.i	<15 spaces in all parking bays	Met		
18	Parking space length ZO 5.3.2	17'	Met		
19	Parking space Width ZO 5.3.2	9'	Met		
20	Parking space front curb height ZO 5.3.2	4" in front of 17' spaces, 6" everywhere else	Met		
21	Accessible parking – number ADA	1 proposed at pickleball courts	Met		
22	Accessible parking – size ADA	Not dimensioned	Inconclusive	Dimension accessible space and aisle in future submittal.	
23	Number of Van-accessible space <u>ADA</u>	1 indicated, 1 required	Partially Met	Dimension accessible space and aisle in future submittal.	
24	Bicycle parking				
24a	Requirement ZO 5.16.1	47 required, provided in units and 4 provided at pickleball courts	Met		
24b	Location <u>ZO 5.16.1</u>	Indicated	Met		
24c	Clear path from Street ZO 5.16.1	7'	Not Met	6' clear path required, note 2' overhang is not part of clear path.	
24d	Height of rack ZO 5.16.5.B	3'	Met		
24e	Other (Covered / Layout) ZO 5.16.1	Indicated	Met		
25	Sidewalk – min 5' wide <u>Master Plan</u>	5' minimum	Met		
26	Sidewalk ramps EDM 7.4 & R-28-K	Indicated	Partially Met	Include current R-28 detail in future submittal.	
27	Sidewalk – distance back of curb EDM 7.4	0' and not dimensioned, 5' standard in residential areas	Inconclusive	Dimension in future submittal. The applicant could consider providing an offset where parking is not present to increase pedestrian safety.	
28	Cul-De-Sac O <u>Figure VIII-</u> F	N/A	-		
29	EyeBrow O Figure VIII-G	N/A	-		

INTE	INTERNAL SITE OPERATIONS				
No.	Item	Proposed	Compliance	Remarks	
30	Minor/Major Drives ZO 5.10	28' wide, over minimum 100' radius proposed	Partially Met	Per Section 5.10.1.B.iv - "Adjacent parking and on-street parking shall be limited near curves with less than 230' centerline radius". The applicant could review the areas where parking is in a curve with a centerline radius of less than 230', and either move to a different location or review to ensure a safe and adequate sight distance is provided. An administrative waiver may be required.	
31	Any Other Comments:				

SIGI	SIGNING AND STRIPING				
No.	Item	Proposed	Compliance	Remarks	
32	Signing: Sizes MMUTCD	Indicated	Met		
33	Signing table: quantities and sizes	Indicated	Met	Review the quantity of speed limit signs proposed, they are not needed at several locations.	
34	Signs 12" x 18" or smaller in size shall be mounted on a galvanized 2 lb. U- channel post MMUTCD	Indicated	Met		
35	Signs greater than 12" x 18" shall be mounted on a galvanized 3 lb. or greater U-channel post MMUTCD	Indicated	Met		
36	Sign bottom height of 7' from final grade MMUTCD	Indicated	Met		
37	Signing shall be placed 2' from the face of the curb or edge of the nearest sidewalk to the near edge of the sign MMUTCD	Indicated	Met		
38	FHWA Standard Alphabet series used for all sign language MMUTCD	Indicated	Met		
39	High-Intensity Prismatic (HIP) sheeting to meet FHWA retro-reflectivity MMUTCD	Indicated	Met		
40	Parking space striping notes	Indicated	Met		
41	The international symbol for accessibility pavement markings ADA	Provided	Met		
42	Crosswalk pavement marking detail	None proposed	N/A		

SIG	SIGNING AND STRIPING					
No.	Item	Proposed	Compliance	Remarks		
43	Any Other Comments:	Provide maintaining traffic information for Meadowbrook Road and Twelve Mile Road entrance work in future submittal.				

Note: Hyperlinks to the standards and Ordinances are for reference purposes only, the applicant and City of Novi to ensure referring to the latest standards and Ordinances in its entirety.

Should the City or applicant have questions regarding this review, they should contact AECOM for further clarification.

Sincerely,


AECOM

Paula K. Johnson, PE Senior Transportation Engineer

Paulo K. Johnson

Saumil Shah, PE Project Manager

Saumis Shal





To: Barbara McBeth, AICP City of Novi 45175 10 Mile Road Novi, Michigan 48375

CC:

Lindsay Bell, Heather Zeigler, Diana Shanahan, Dan

AECOM 39575 Lewis Drive Suite 400 Novi, MI 48377 T 248.204.5900

Project name: JZ24-31 – The Grove PRO TIS Traffic Review

From: AECOM

Date:

September 9, 2025

Memo

Subject: JZ24-31 – The Grove PRO Updated TIS Traffic Review (10/11/2024)

The Traffic Impact Study was reviewed to the level of detail provided, and AECOM recommends **approval of the Traffic Impact Study**. The previous review letter is attached as **Appendix A**.

GENERAL COMMENTS

The memo will provide an update on comments raised during the previous review, as the applicant submitted an updated study.

COMMENTS AND REVISIONS

• We do not agree with the consultant's proposal of restriping the northbound through as shared through and right. The analysis that the consultant carried out to evaluate this mitigation at the Meadowbrook Road and 12 Mile Road Intersection considered a very low volume of traffic on the northbound through (5 cars in AM peak hour and 10 cars in PM peak hour, Figure 3). It seems these volumes are influenced by the construction (GLWA 54-Inch Water Main Loop) that has been ongoing for a very long period (Feb 2022 to Aug 2024) on Meadowbrook Road between 12 Mile Road and 13 Mile Road. Consult should perform a sensitivity analysis with the volumes growing to the future year by applying a growth rate to a set of volumes when there was no construction, and then confirm/explore mitigations.

Updated traffic study 10/11/24: The revised report adjusted the volume for non-construction time. The proposal of restriping has been removed from the updated report. No further comment.¹

• Sight Distance: The applicant needs to show the sight distance triangle and details on the plan set for further review and confirmation.

Updated traffic study 10/11/24: The updated report includes sight distance analysis and confirms that "The results of the sight distance analysis indicate that a driver waiting to egress the proposed site driveway onto 12-Mile Road will not experience any visual obstruction, provided the sight distance triangle area shown in the attached site plan is free of vegetation and a clear line of sight is provided." No further comment.

¹ Please note that we do not agree with the TIS preparer's response to the City's consultant to identify any closure or condition on the ground for the count. TIS preparer(s) to ensure that in every project, counts represent a typical weekday operation (that includes no inclement weather, no school holidays, no detours, no construction, no major crash, etc.).

• Right-tun lane: There is currently an existing center two-way left-turn lane (TWLTL) on Meadowbrook Road, adjacent to the project site, and 12-Mile Road is median-divided, with left-turns accommodated via median U-turns (crossovers) at intersections. Therefore, only the right-turn treatment criteria were evaluated at the proposed site driveways. The traffic study concluded that, due to traffic volumes along 12 Mile Road, the driveway qualifies for a right-turn lane according to the RCOC warrant graph. However, the applicant needs to coordinate with RCOC for geometrical standards and approval for the right-turn taper. And applicant needs to show the right-turn lane details with dimensions and adherence to the applicable standards on the plan set for further review and confirmation.

Updated traffic study 10/11/24: The applicant noted the comments for coordination with RCOC. The applicant is to provide RCOC coordination and approval for taper and access during the site plan reviews.

• The study indicated the site trip distribution for westbound 12 Mile Road to be 33% AM (63 trips) and 28% PM (66 trips). RCOC has some concerns related to the ability of vehicles to weave across the 3 lanes of 12 Mile Rd to enter/exit the site. The applicant should conduct a weave analysis from the nearest cross-overs. This is particularly concerning for the WB to EB 12 Mile Road movement, as the M-5/I-696 ramp traffic utilizes this same crossover.

Updated traffic study 10/11/24: The updated report includes a weave analysis and concludes that "The results of the weaving analysis indicate that there is adequate distance between the proposed Site Drive #1 and the existing crossover locations to accommodate the projected traffic volumes." No further comment.

Should the City or applicant have questions regarding this review, they should contact AECOM for further clarification.

Sincerely.

AECOM

Saumil Shah Project Manager

Saunis Shal

Appendix A: Previous Review Letter



To:

Barbara McBeth, AICP City of Novi 45175 10 Mile Road Novi, Michigan 48375

CC:

Lindsay Bell, Heather Zeigler, Diana Shanahan, Dan

AECOM 39575 Lewis Drive Suite 400 Novi, MI 48377 T 248.204.5900 www.aecom.com

Project name:

JZ24-31 – The Grove PRO TIS Traffic

Review

From: AECOM

Date:

September 6, 2024

Memo

Subject: JZ24-31 - The Grove PRO TIS Traffic Review

This Traffic Impact Study was reviewed by AECOM to the level of detail provided below and AECOM recommends **denial of the Traffic Impact Study**; the applicant should review the comments provided below and provide a revised study to the City of Novi.

GENERAL COMMENTS

- 1. This memo will provide comments on a section-by-section basis following the format of the submitted report.
- 2. The project is located on the southeast quadrant of the 12 Mile Road and Meadowbrook Road intersection.
- 3. The development consists of 182 single family attached housing and 256 multi-family housing.
- 4. The development is a Planned Rezoning Overlay (PRO) plan, and the project site is currently zoned OST (Office Service Technology) and is proposed to be rezoned RM-2 (High-Density Multiple-Family).

BACKGROUND DATA

- Applicant elaborated on uses permitted under the existing OST zoning and calculated trip generation based on the General Office Building land use category within the ITE Trip Generation Manua 11th Edition. The study concluded that the number of trips under existing OST zoning is estimated to be higher compared to the proposed rezoning to RM-2
- 2. The following roadways were included in the study:
 - a. 12 Mile Road: 45 mph, four (4) lanes divided, east/west
 - b. Meadowbrook Road: 35/40 mph, two (2) lanes, north/south
 - c. The following intersections were included in the study:
 - 12 Mile Road at Meadowbrook Road
 - 12 Mile Road eastbound to westbound crossover east of Meadowbrook Road
 - 12 Mile Road westbound to eastbound crossover west of Meadowbrook Road
 - 12 Mile Road westbound to eastbound crossover west of Summit Drive
 - 12 Mile Road westbound to eastbound crossover east of Meadowbrook Road
- 3. Applicant collected turning movements that occurred between the 7:00 AM to 9:00 AM and 4:00 PM to 6:00 PM peak periods at the study intersections on Tuesday, June 11, 2024.
- 4. Novi Schools were not in session when the data collection was performed; therefore, the data was reviewed to determine if adjustments to the AM peak hour traffic volumes are necessary to consider the impact of school traffic volumes. The result of the evaluation indicates that the data collection performed was greater than the historical traffic volume data when the school was in session. Therefore, the performed data collection was utilized in the analysis and no adjustments were applied to AM peak hour traffic counts.

EXISTING CONDITIONS

1. The overall levels of service (LOS) at the study area intersections is LOS D or better with no movements experiencing a delay of LOS E or F (Table 2).

BACKGROUND (NO BUILD) CONDITIONS 2024

- 1. A 0.5% annual growth rate was used to project the existing 2024 traffic volumes to the site buildout year of 2030.
- Overall operations at the intersections are not expected to change significantly compared to existing conditions except the LOS C in existing conditions is expected to be LOS D in future background conditions (Table 3) at the following intersection:
 - a. 12 Mile Road at Meadowbrook Road
 - b. Westbound 12 Mile Road through Meadowbrook Road in the PM peak hour
 - Westbound u-turn for 12 Mile Road at the eastbound to westbound crossover east of Meadowbrook Road in the PM peak hour

SITE TRIP GENERATION

- 1. A total of 3,052 daily trips are anticipated based on the ITE Trip Generation Manual 11th Edition (Table 4).
- 2. A net increase of 191 trips during the morning peak hour and 236 trips during the evening peak hour are considered for a traffic impact study on the surrounding road network (Table 4).

SITE TRAFFIC ASSIGNMENT


- 1. Adjacent street peak hour volumes were used to calculate site trip distribution.
 - a. The largest portion of the traffic is assumed to be coming from/going to 12 Mile Road with approximately 74% in morning peak hours and 60% in evening peak hours (Table 6).

FUTURE CONDITIONS

- 1. Overall operations at the intersections are not expected to change significantly compared to background conditions, except at the following locations:
 - a. LOS C in background conditions are expected to be LOS D in future build conditions:
 - i. Westbound 12 Mile Road u-turn at the westbound to eastbound crossover west of Meadowbrook Road in the PM peak hour
 - ii. Eastbound Meadowbrook Road at Elm Creek Drive/Site Driveway in the PM peak hour
 - b. LOS D in background conditions are expected to be LOS E in future build conditions:
 - i. Northbound Meadowbrook Road right-turn at 12 Mile Road in the PM peak hour
- 2. Eastbound 12 Mile Road at Site Drive #1 has a LOS E (44 seconds), however, the queue analysis indicated a small queue of only two (2) to three (3) vehicles.
- 3. The following major movements are estimated to experience or continue to experience a relatively higher delay in the future:
 - a. Westbound 12 Mile Road through at Meadowbrook Road would have a LOS D in the AM peak hour (20 seconds existing versus 46 seconds in the future).
 - b. Southbound M-5 Off-ramp southbound left-turn and right-turn at 12 Mile Road would have a LOS D in the AM (36 seconds in Existing and build conditions) and PM (42 seconds in existing and build conditions) peak hours.
 - c. Eastbound 12 Mile Road u-turn at the eastbound to westbound crossover east of Meadowbrook Road would have a LOS D in the PM peak hour (22 seconds existing versus 29 seconds in the future).

CONCLUSIONS

- The study concluded with a recommendation that would improve the failing levels of service and traffic conditions as shown below. However, it is not clear if the applicant has coordinated such improvement with the Road Commission for Oakland County (RCOC).
 - 12 Miler Road and Meadowbrook Road intersection: Re-stripe the northbound approach (currently
 provides a through lane and a right-turn lane) to provide dual right-turn lanes; with a shared
 through/right lane and an exclusive right-turn lane.
- 2. AECOM does not agree with the consultant's proposal of restriping the northbound through as a shared through and right-turn lane. The analysis that the consultant carried out to evaluate this mitigation at Meadowbrook Road at 12 Mile Road Intersection is considered a very low volume of traffic on northbound through (5 cars in AM peak hour and 10 cars in PM peak hour, Figure 3). It seems these volumes were influenced by the detour and closing of northbound through traffic due to construction (GLWA 54-Inch Water Main Loop) that has been ongoing for a very long period (February 2022 to August 2024) on Meadowbrook Road between 12 Mile Road and 13 Mile Road as per the image below. The consultant should perform a sensitivity analysis with the volumes growing to the future year by applying a growth rate to a set of volumes when there was no construction (pre-pandemic) and then confirm/explore the mitigation measures.



Access: Sight Distance, Right-turn Lane and Left-turn Lane

Accesses will also be reviewed under the site plan review and please refer comments provided in the site plan review letter. Please provide detailed drawings showing sight distances and right-turn and left-turn lanes for the proposed site driveways as part of the site plan review. The comments here are based on the level of detail provided as part of the Traffic Impact Study:

- Sight Distance: The applicant needs to show the sight distance triangle and details on the plan set for further review and confirmation.
- Right-tun lane: There is currently an existing center two-way left-turn lane (TWLTL) on Meadowbrook Road adjacent to the project site. 12 Mile Road is median divided with left-turn movements accommodated via median U-turns (crossovers) intersections. Therefore, only the right-turn treatment criteria were evaluated at the proposed site driveways. The traffic study concluded that due to high traffic volumes along 12 Mile Road (Table 8), this site driveway qualifies for a right-turn lane according to the RCOC warrant graph. However, the applicant needs to coordinate with RCOC for geometrical standards and approval for the right-turn taper. The applicant will need to show the right-turn taper details with dimensions and adherence to the applicable standards on the plan set for further review and confirmation.

RCOC Comments:

The study indicated the site trip distribution for westbound 12 Mile Road to be 33% AM (63 trips) and 28% PM (66 trips). RCOC has some concerns related to the ability of vehicles to weave across the 3 lanes of 12 Mile Rd to enter/exit the site. The applicant should conduct a weave analysis from the nearest cross-overs. This is particularly concerning for the WB to EB 12 Mile Road movement as the M-5/l-696 ramp traffic utilizes this same cross-over.

Should the City or applicant have questions regarding this review, they should contact AECOM for further clarification.

Sincerely,


AECOM

Saumil Shah Project Manager

Saunis Shal

Sarah Binkowski, PE, PTOE Michigan Traffic Engineering Manager

Darah E. Binkowski







September 10, 2025

City of Novi Planning Department 45175 W. 10 Mile Rd. Novi, MI 48375-3024

Attn: Ms. Barb McBeth – City Planner

Re: FACADE ORDINANCE

The Grove PRO, JZ24-31, Formal PRO, Revised

Façade Region: 1

Zoning District - Current: OST, Proposed: PRO RM-2.

Dear Ms. McBeth:

The following is the Facade Review for the above referenced project based on the drawings prepared by The Residential Design Group, dated 8/22/25. The applicant has revised The Woods and Clubhouse Options 1 & 2 in response to our prior review. This project is subject to the Façade Ordinance Section 5.15, and the Planned Rezoning Overlay Ordinance (PRO) Section 7.13. The percentages of materials proposed for each façade are as shown in the tables below. Materials in non-compliance are highlighted in bold.

The Vistas	Front	Left	Right	Rear	Ordinance Maximum (Minimum)
Brick or Stone	31%	37%	37%	38%	100% (30% Minimum)
Composite Siding, Horizontal	15%	12%	12%	12%	50%
Composite Siding, Shake	13%	5%	5%	0%	50%
Trim	10%	5%	5%	5%	15%
Asphalt Shingles	31%	41%	41%	45%	50% (Note 14)

The Meadows	Front	Left	Right	Rear	Ordinance Maximum (Minimum)
Brick or Stone	32%	37%	37%	38%	100% (30% Minimum)
Composite Siding, Horizontal	7%	12%	12%	12%	50%
Composite Siding, Shake	19%	5%	5%	0%	50%
Trim	8%	5%	5%	5%	15%
Asphalt Shingles	34%	41%	41%	45%	50% (Note 14)

The Woods	Front	Left	Right	Rear	Ordinance Maximum (Minimum)
Brick or Stone	30%	37%	37%	36%	100% (30% Minimum)
Composite Siding, Vertical	20%	12%	12%	0%	50%
Composite Siding, Horizontal	0%	25%	25%	11%	15%
Trim	7%	6%	6%	5%	15%
Standing Seam Roof	3%	0%	0%	0%	25%
Asphalt Shingles	40%	32%	32%	48%	50% (Footnote 14)

The Pointe	Front	Left	Right	Rear	Ordinance Maximum (Minimum)
Brick or Stone	35%	37%	37%	31%	100% (30% Minimum)
Composite Siding, Horizontal	12%	36%	36%	6%	50%
Trim	9%	5%	5%	3%	15%
Standing Seam Roof	1%	0%	0%	0%	
Asphalt Shingles	43%	22%	22%	60%	50% (Note 14)

All Above Residential Units - As shown above all models are now in full compliance with the Façade Ordinance.

Clubhouse, Option 1 (4,025 SF)	Front	Left	Right	Rear	Ordinance Maximum (Minimum)
Brick or Stone	22%			100% (30% Minimum)	
Composite Siding, Vertical	24%	Not Provided 50% 15% 25%			50%
Trim	10%				15%
Standing Seam Roof	1%				25%
Asphalt Shingles	42%				50% (Footnote 14)

Clubhouse, Option 2 (1,830 SF)	Front	Left	Right	Rear	Ordinance Maximum (Minimum)
Brick or Stone	32%			100% (30% Minimum)	
Composite Siding, Vertical	21%	Not Provided 50% 15% 25%			50%
Trim	9%				15%
Standing Seam Roof	6%				25%
Asphalt Shingles	32%				50% (Footnote 14)

Clubhouse, Option 3 (1,350 SF)	Front	Left	Right	Rear	Ordinance Maximum (Minimum)
Brick or Stone	36%	Not Provided (3			100% (30% Minimum)
Composite Siding, Vertical	15%			1 - 1	50%
Trim	11%			15%	
Standing Seam Roof	0%				
Asphalt Shingles	38%	50%		50% (Note 14)	

Clubhouse, Option 4 (620 SF)	Front	Left	Right	Rear	Ordinance Maximum (Minimum)
Brick or Stone	60%	Not Provided			100% (30% Minimum)
Composite Siding, Vertical	0%			1_1	50%
Trim	5%			iea	15%
Standing Seam Roof	0%				
Asphalt Shingles	35%				50% (Note 14)


Clubhouse - As shown above all options are now in full compliance with the Façade Ordinance.

Rezoning Overlay Ordinance (PRO) Section 7.13 Section 7.13.2.D.ii.a of the PRO Ordinance requires that the application shall result in an enhancement of the project as compared to the existing zoning and such enhancement would be unlikely in the absence of the use of a PRO." The design of all buildings now meet or exceed the minimum requirements of the Façade Ordinance. Moreover, the designs show a high level of character And attention to detail. We believe the designs for all buildings now meets the requirements of the PRO Ordinance.

Sincerely,

DRN & Associates, Architects PC

Douglas R. Necci, AIA





July 22, 2025

TO: Barbara McBeth - City Planner Lindsay Bell - Plan Review Center Dan Commer – Plan Review Center Diana Shanahan – Plan Review Center Stacey Choi – Planning Assistant

CITY COUNCIL

Mayor

Justin Fischer

Mayor Pro Tem Laura Marie Casey

Dave Staudt

Brian Smith

Ericka Thomas

Matt Heintz

Priya Gurumurthy

City Manager

Victor Cardenas

Director of Public Safety Chief of Police

Erick W. Zinser

Fire Chief

John B. Martin

Assistant Chief of Police

Scott R. Baetens

Assistant Fire Chief

Todd Seog

RE: The Grove

PRZ24-003 JZ24-31

Project Description:

New Multi residential building complex

Comments:

- All previous items in letter from developer dated 7/26/2024 are to be addressed. Previous approval was granted by FM Copeland in review dated Aug 28, 2024.
- Building numbers will need to be corrected/adjusted for final plan set. Numbers need to follow a better sequence while driving through complex for emergency access.
- 3. Fire truck turning radii will need to be re-calculated for a truck length of 48' and adjusted for 50' outside swing radii. Plan set page #SP3.7 indicated a measurement of only 38' truck length. Have this page re-submitted for final review.
- 4. Plans show a vehicle crossing over wetland area. If this is a vehicular bridge then this will need to be engineered for Fire lane & Fire Truck access. Bridge will need to support 35 ton weight specifications. Indicate this on final plans.

Recommendation:

Approved with the following conditions, that all items noted above are addressed before final stamping set.

Sincerely,

Novi Public Safety Administration

45125 Ten Mile Road Novi, Michigan 48375 248.348.7100 248.347.0590 fax

cityofnovi.org

Andrew Copeland – Fire Marshal City of Novi Fire Department

cc: file

CITY CO	UNCIL MINUTES
DECEMBER	16, 2024 EXCERPT

REGULAR MEETING OF THE COUNCIL OF THE CITY OF NOVI MONDAY, DECEMBER 16, 2024, AT 7:00 P.M.

Mayor Fischer called the meeting to order at 7:00 P.M.

PLEDGE OF ALLEGIANCE

ROLL CALL: Mayor Fischer, Mayor Pro Tem Casey, Council Members Gurumurthy,

Heintz (absent/excused until 7:08 PM), Smith, Staudt, Thomas

ALSO PRESENT: Victor Cardenas, City Manager

Danielle Mahoney, Assistant City Manager

Tom Schultz, City Attorney

APPROVAL OF AGENDA:

CM 24-12-167 Moved by Smith, seconded by Casey; MOTION CARRIED: 6-0

To approve the agenda as presented.

Roll call vote on CM 24-12-167 Yeas: Casey, Gurumurthy, Smith, Staudt,

Thomas, Fischer

Nays: None Absent: Heintz

PUBLIC HEARINGS: None

PRESENTATIONS:

Environmental Sustainability Committee Presentation - Member Smith explained that environmental sustainability is based on a simple principle of everything that we need for survival and wellbeing depends on, directly or indirectly, the natural environment. The City was awarded a \$100,000 Community Energy Management Grant this past summer. Novi's commitment to sustainability includes a Bee City USA designation, Arbor Day, LED lighting, educational programs, and annual tree plantings & seedling giveaways. The Committee came up with vision and mission statements. The four pillars of the Committee are Resource Efficiency, Clean Energy, Environmental Preservation and Community Engagement, being the most important. The Committee has met with Stewarts Sustainability Leadership Institute, Royal Oak & Ann Arbor Sustainability Managers and the Northville Sustainability Team to find out what those communities were doing. They met with community leaders at a HOA breakfast and talked to the Oakland County community. The next steps for the Committee include expansion of the Committee to included four additional residential members, work with City staff on the creation of an Environmental Action Plan, leverage existing City events to build awareness, and introduce the Solarize Pilot Program for Novi. Member Smith spoke about where they are with the Environmental Action Plan approach and what still needs to be accomplished.

Mayor Fischer said that in regard to the additional resident members, he thinks that getting out and getting that interest in the community is important. He'd like the Council to think about whether there is the right number of opportunities that match up with the number of people volunteering. The City may want to ask residents to spend more time on environmental sustainability but that may mean needing to take other areas or other board positions where

Member Thomas commented that this community will need some kind of connection. The green space is a huge benefit and simply removing the connection is not sufficient for her.

Roll call vote on CM 24-12-174 Yeas: Casey, Gurumurthy Heintz, Smith,

Staudt, Thomas, Fischer

Nays: None

6. Initial review of eligibility of The Grove, to rezone property at the southeast corner of Twelve Mile Road and Meadowbrook Road to High-Density Multiple Family with a Planned Rezoning Overlay.

Gary Shapiro, a representative from Ivanhoe was present and said his company takes pride in doing environmentally sensitive developments. They've hired outside consultants so they could be as professional as possible and be prepared. This site is 70 acres on the corner of Twelve Mile and Meadowbrook and is zoned OST. They've known about this property for 25 years and nothing's happened on it. They entered into an agreement with Trinity Hospital when they came to realize, after they bought it 30 years ago, that all of the OST uses at that time, they didn't consider. This is a very environmentally sensitive site. They began to study it and what the proper use is. They concluded that site is designed to be changed. It's clearly not OST. We sought out to use the highest and best use and put together a proposal under our zoning, restricting it from 1,000 units to 400 units with four distinct communities of multi-generational housing and a fifth area that's strictly for residential. A major focus is our awareness of connectivity and bike path. They did the Beacon Hill project across the street and donated to this community a public park and they spent far in excess cleaning up the wetland situation there, remediated the rivers to make sure they were proper and put in a trailhead. Brad Strader, of Cincar Consulting, is a land use planner. He has 40 years of experience and has worked for communities all around Novi. The vision is to take the former OST property and make a planned rezoning overlay to add what's needed in this area. We know that there's a demand for residential and the demand for OST has gone down in different areas. One thing we want to feature is the connectivity that we have. We are within an easy mile of e-bike, walking or jogging for a lot of this residential or commercial area. We know from studies that you need residential in the market area to keep the sustainability of your commercial area. We're right in the middle of commercial, including the proposed commercial on the north side of Twelve Mile. This is zoned as office service or technology by the real area is multi-use or mixed use. Approved residential includes the Lakes Health Assisted Living so there's already mixed-use residential development in the area. We are trying to appeal to the millennials and the independent seniors that aren't ready to move into assisted living but want to downsize. We've got 64 units that are geared toward independent seniors. We are keeping 7.8 acres at the corner and Trinity Health will maintain that and we are designing it in context with Trinity Health. OST isn't appropriate for this site because the market for OST has changed and because of all the wetlands. The uses of OST will obliterate the wetlands and the natural features on the site if you build the buildings and the parking and so forth. The regulations for wetlands are different than when Trinity bought it and the City's regulations are very different. Beckett-Rader came to the same conclusion and basically said the location and size and environmental features means that this site is unique and there needs to be a unique approach. They will be preserving 7.8 acres at the corner for Trinity Health which will be developed with OST uses. About 50% of the frontage on Meadowbrook and Twelve Mile will be open space. Our units will be tucked in behind and we'll have beautiful landscaping along Meadowbrook and pathways. North of Twelve Mile is the residential area that was just approved under another PRO and then commercial in the front. There's Tollgate Farms, residential and commercial to the north. There's MDOT open space detention area from along the M5 connector to the east. There's OST and a conservation easement to the south and a combination of uses to the west. Again, we're in the middle of a mixed-use zone and we're proposing a mixed-use type of project. He wanted to note that they'll have a pathway among the eastern property line and overlook in the MDOT conservation easement that right now nobody can enjoy. Adding the conservation easement to the south, our open space and the MDOT open, we're really increasing the habitat area. Amenities that we're providing are things like a pickleball court, pocket parks, playground, dog park, picnic areas, natural features, EV charging stations, and bike racks. We also have four landmarks along either Twelve Mile or Meadowbrook including relocating the SMART bus stop to a more advantageous location if the project is approved. One of the amenities is a clubhouse with a swimming pool. We use two different architects so there are some differences in design that adds variety. The Vistas will have about half of the units abutting open space. They are three-story town homes with a twostall garage and flex space and then kind of a living area on the first floor and then the bedrooms above. These are for either sale or for rent. The Woods and The Pointe offer two-story condominiums. The Pointe has about half of the units backing to open space and the others are in shared courtyards. The Meadows are more like a traditional multiple family, and they are unique because there's no corridors and everyone has an individual entrance. The first floor, 64 units are going to be single story. The second and third floor are a separate unit, and they have separate garages. One of the PRO benefits is just the use itself because it appeals to the independent seniors and people you're trying to retain or attract in Novi. We also note that compared to the OST, the traffic generation is going to be about half or a third of OST compared to this type of use. We're going for RM-2 but that is mostly because of the setbacks. The units we're requesting are about half of what the RM-2 would allow. We've carved out that these units will preserve like 83% of the regulated wetlands and we've tried to tuck into preserve the best parts of the woodland features. There's a pathway on Meadowbrook but nothing on Twelve Mile. Even if we put the pathway on Twelve Mile, there's a gap so we're going to fill in the gap. That's a public benefit. One thing that's consistent with the recent City plans is improving transit so we've talked to SMART and suggested moving a stop from the west side of Meadowbrook to the east side. It's easier and more convenient for our residents and SMART said that sounds great. That's another public benefit. The ordinance required two acres of open space, and we'll have twelve acres of open space.

Mayor Pro Tem Casey said when looking at the development, the pluses are the use of open space, the wetland conservation easement, the focus on connectivity, and the multiple types of housing within the development. Staff would not support deviations regarding building materials that aren't right, so she'll defer to them. In regard to public benefit, she does not consider anything that benefits only the residents but does like the SMART bus suggestions. If something isn't accessible to the general public, then it's not a public benefit. She suggested public art at the corner features. She acknowledged the planting of trees but noted that a lot of trees would also be removed. She asked if it was known when these units would be for sale or rent, and Mr. Shapiro said it would depend on when they came to market. The Mayor Pro Tem confirmed which units would have the first-floor bedrooms, which would be the 64 units in the Meadows. She said she is focused on the ability for Novi residents who currently have family homes, aren't ready for assisted living but would like to downsize. She would also like to see some of the onus on the

applicants for proper screening between this development and whatever Trinity builds on the 7.8 acres that they will be developing at some point.

Member Smith commented that a consideration might be is to have access to the second and third floors for people who don't want to go upstairs in the Meadows. In regard to the impact on wetlands, he asked that trading height of the buildings for more preservation to also be considered. He also mentioned solar panels, geothermal heat pumps and LEED standards. He considers energy savings a public benefit. He thinks it's good to have the EV charging stations and confirmed that they'll be in all the garages. He said it would be an important consideration for the new residence to make sure they get fiber in there.

Member Heintz seconded the comments of Member Smith regarding energy savings as a public benefit. He appreciates the environmental sensitivity.

Member Thomas said it looked like the applicants paid a lot of attention to preserving the wetlands. She'd like to see the mitigation in the plan get down to as little as possible. She addressed the ability to do something else to save more of those environmental features and hates the idea of all of the protected trees or the wetlands being destroyed. She confirmed that it is unknown if the community for seniors would be available for purchase. She addressed that close attention should be paid to the traffic and Mr. Strader said the site was designed to have three access points to minimize traffic impacts.

Member Staudt said he won't support anything with covered parking. He asked what the original intention was for the OST portion of the property. Mr. Shapiro said people who want to develop on the site can come to them. They will work to get it development ready which means having it wetland mitigated. Alan Green, attorney, said he's been working with Trinity from the beginning, and they are retaining that parcel, so they won't be doing anything to in terms of development. The Trinity site has the least amount of wetlands. Member Staudt said there's no public benefit here. He does like a lot of what he's seen but there's a lot that still needs to be thought out. He'd rather have taller buildings and fewer of them. The green space looks great. The wetlands look great. He's perplexed about what portion will be for sale and what will be for rent. Most people who have condos want a garage, not a covered parking space. From his perspective, there's a lot to like but garage optional isn't one of them. It's a great location and it's definitely not an OST location.

Member Gurumurthy said she was happy to see the senior specific area but would like to see them be able to be for purchase. In regard to wetland impact, she would like to see that come down as much as possible and would like the setbacks they've asked for to move from 75 to 50 across the east west. The sustainable energy, she like to see that mention and looks forward to more detail. In terms of public benefit, she encourages them to look at the active mobility plan and see how they can build a walkable community. She asked if the intent was to do a phased approach and Mr. Shapiro stated that it is their hope to do it all one time.

Mayor Fischer said he did his own research and to have residential there wouldn't be out of character. He thinks a plan like this is more environmental. He asked if there is a way to mitigate more wetland and preserve more green space. In this area of the City, building height may be less of an issue. If there is an opportunity to make some of the first-floor bedroom units be owner occupied that would go a long way. He needs to see more


creativity in regard to public benefits. He would be interested to see the Trinity parcel built into their parcel or encourage Trinity to move along faster with developing their parcel. He wants to very clear, and he'll be watching what happened with that because he doesn't want residents in the future to come before Council saying they were told nothing would ever be built there.

COMMITTEE REPORTS:

Account Clerk

Public Utilities & Technology Committee – Member Thomas said they met last Tuesday and discussed the Broadband Master Plan.

discussed the Broadband Master Plan.	
MAYOR AND COUNCIL ISSUES: None	
COMMUNICATIONS: None	
ADJOURNMENT – There being no further adjourned at 10:26 P.M.	business to come before Council, the meeting was
Cortney Hanson, City Clerk	Justin Fischer, Mayor
Transcribed by Becky Dockery,	Date approved: January 6, 2025



into the City of Novi Tree Fund for any outstanding Woodland Replacement Credits.

Planner Commer stated it is staff's suggestion that the Planning Commission approve the Woodland Use Permit. The applicant and applicant's representative are here tonight and available to answer any questions. Staff and the City's Woodland Consultant are also available to answer any questions.

Chair Pehrson invited the applicant to address the Planning Commission.

The applicant stated they did not wish to address the Planning Commission.

Chair Pehrson opened the public hearing and invited members of the audience who wished to speak to approach the podium. Seeing no one. Chair Pehrson requested Member Lynch read into the record the correspondence received. Member Lynch relayed correspondence was received from Mr. Michael Husak who is in support. Chair Pehrson closed the public hearing and turned the matter over to the Planning Commission.

Member Lynch had no comment.

Member Verma had no comment.

Member Roney expressed compliments to the plan as only twelve trees will be removed.

Member Avdoulos had no comment.

Motion to approve Woodland Use Permit PBR25-0258 made by Member Avdoulos and seconded by Member Lynch.

In the matter of Woodland Use Permit, PBR25-0258, motion to approve the removal of 12 regulated woodland trees within an area mapped as City Regulated Woodland at 51270 Nine Mile Road to build a single-family home. The approval is subject to on-site planting to the extent possible of 12 required woodland replacement credits. If necessary, any outstanding credits may be paid into the City's Tree Fund. In addition, any other conditions as listed in the Woodland Consultant's review letter shall be addressed.

ROLL CALL VOICE VOTE ON MOTION TO APPROVE WOODLAND USE PERMIT PBR25-0258 MOVED BY MEMBER AVDOULOS AND SECONDED BY MEMBER LYNCH. Motion carried 5-0.

3. JZ24-31 THE GROVE PRO PLAN WITH REZONING 18.745

Public hearing at the request of Ivanhoe Development for a Zoning Map Amendment from Office Service Technology to Low-Density Multiple Family with a Planned Rezoning Overlay. The subject site is approximately 62 acres and is located east of Meadowbrook Road, south of Twelve Mile Road (Section 13). The applicant is proposing to develop a 232-unit townhome development.

Senior Planner Lindsay Bell stated that the applicant is proposing to rezone about 62 acres south of Twelve Mile Road utilizing the Planned Rezoning Overlay option. To the north of Twelve Mile is largely vacant but approved for a retail area and the Armenian Cultural Center. On the east side of Meadowbrook are some office buildings and the proposed Elm Creek PRO project which is residential townhomes. South of the property is the Meadowbrook Corporate Park, and to the east is a large area owned by MDOT with stormwater facilities and wetland mitigation, and the M-5 access ramp.

The current zoning of the property is OST – Office Service Technology. The properties to the east, west and

south are also zoned OST. The area to the north is B-3, R-4 Single Family and RA Residential Acreage.

The recently adopted Master Plan identifies this property and those around it in purple as General Mixed Use. The area to the east is Public/Quasi-Public, and north of 12 Mile is Public Park, Community Commercial, and Single Family.

The natural features map shows there are significant wetland and woodland areas on this property as well as to the east and south. The tree and wetland surveys provided by the applicant confirm these features.

Planner Bell stated the initial PRO plan had proposed rezoning to RM-2 High Density Residential with 438 units, including both rental and for-sale options. In the formal PRO Plan, the applicant has revised the request to rezone the property to RM-1 Low Density Multiple Family and the number of units has also been reduced by over 200 units to 232. All of the units are now for-sale townhome units, with over 50 percent of those having a primary bedroom on the ground level to accommodate aging-in-place. The development consists of four "villages" of homes: The Meadows (67 attached units in 14 buildings), The Vistas (68 attached units in 15 buildings), The Woods (36 attached units in 8 buildings) and The Pointe (61 attached units in 12 buildings). There is also a central park area with amenities, including a pickleball court and a playground park, with an option to locate a clubhouse in the area shown on the right side of this image. A couple different design styles are provided for the clubhouse.

The development is accessed by two entrances off Meadowbrook Road, and one from Twelve Mile Road. The stormwater plan shows an interconnected system with six detention ponds of various sizes, along with the existing wetland system.

As described in the Wetland Review, each of the delineated wetlands on the site meet the criteria of providing wildlife habitat as well as flood and storm control. Wetland review notes that the proposed development appears to result in a total permanent wetland impact area of 1.44 acres out of the total 9.64 acres present on site (about 15 percent impact). The full requirement for mitigation is proposed to be provided.

For woodlands, the plan appears to remove about 73 percent of the regulated trees on the woodland survey. Approximately 250 credits are proposed to be planted on-site, with the remaining credits to be paid into the Tree Fund.

As noted in the Façade Review, the façade materials have been revised and now the proposed buildings are in full compliance with the standards. In addition, the level of detail and overall character of the designs qualify as an enhancement of the area beyond what could be required by the ordinance.

Planned Bell stated rezoning to the RM-1 category would permit the use proposed. As mentioned, the recently adopted Master Plan designates this area as General Mixed Use. This new category is meant to provide a high degree of flexibility in development, with a site-specific master plan to guide development. "Properties within this designated land use category can also utilize the PUD (Planned Unit Development Option) as a development tool to provide a variety of uses within an approved master plan development." Since the City has not adopted a Planned Unit Development ordinance, the Planned Rezoning Overlay represents the closest option available to achieve the intended vision.

Planner Bell noted some of the detriments of the proposal we identified include questions of compatibility and buffering from the adjacent uses that will remain OST. Being adjacent to a residential development will require additional setbacks and possible use restrictions, which can be an added burden to adjacent non-residential landowners, however this would primarily be an issue to the south and north which are not separated by a thoroughfare. The applicant has proposed a berm and dense landscaping along both borders, which will provide screening buffers. The area to the east of the property will remain undeveloped as it is an MDOT stormwater and wetland mitigation site.

The undisturbed woodland and wetland areas on the site and surrounding properties would allow the proposed use to remain relatively secluded from the commercial properties, as well as provide natural spaces contiguous with adjacent preserved areas. The remaining undeveloped properties in the area that could develop under the OST zoning district are not likely to cause significantly greater conflicts with residential use on this site since they are located on the other side of Meadowbrook.

A residential development is likely to result in smaller wetland and woodland impacts compared to an OST development due to the typical size of buildings and parking needs. OST permitted uses include offices, research & development, data processing, and hotels, which all have a larger footprint and greater surface parking than the RM-1 uses proposed. The Traffic study notes that the number of residential units would result in fewer vehicle trips compared to an OST development, including during peak hours.

The public benefits offered by the applicant include a one-acre park area, accessible to residents and the general public, with pedestrian and bike rest stop area, at the northeast corner of the site along 12 Mile Road. A one-mile loop Grove nature area trail, accessible to residents and the public, that extends from the newly created park area along the east property line of the Property, providing scenic views of the adjacent 30-acre natural wetland area as well as natural features of the Property. In order to address the impact of additional use of Beacon Hill Park by the new residents and planned access and interconnectivity for Novi residents and Grove Nature Trail, the Developer agrees to provide the City with \$25,000 to be used by the City at its discretion, for Beacon Hill Park improvements, art, services and/or maintenance. The applicant proposes to construct over 700 feet of 10-foot-wide pathway gap on the south side of 12 Mile Road to create a connection from the existing bike path, located along the east side of Meadowbrook Road, and the new sidewalk being constructed with The Grove. Additional benefits include relocating the SMART bus stop to the east and enhancing the area with landscaping and seating along 12 Mile Road, which is supported by SMART. Additional bike parking has also been added for a total of 8 spaces. Approximately 1/3 of the property will be open space with most of the units abutting or overlooking open space and nature areas which significantly exceeds the Ordinance requirement for usable open space. Consistent with Novi's mobility plans, construction an 8-foot wide shared-use public pathway within The Grove to provide pedestrian and bicycle connectivity between Meadowbrook Road and 12 Mile Road is proposed. Conservation easements are proposed which would protect approximately 10 acres of woodland and woodland replacement areas and 15.5 acres of wetland and wetland mitigation areas, which represents over 47 percent of the property. The applicant has proposed decreased density from what would be permissible in the RM-1 zoning district (4.2 units per acre proposed, up to 7.3 units per acre permitted) and dedication right-of-way (60-foot width) along the entire Meadowbrook Road frontage, a total land area of about 2.5 acres. As well as additional overall benefits previously mentioned and as listed in the suggested motion.

Planner Bell stated staff supports the requested rezoning with the stated benefits, conditions and deviations listed. There are conditions proposed that are more strict or limiting than the RM-1 standards and are found to have an overall benefit to the public. The identified benefits of rezoning appear to outweigh the anticipated detriments of introducing residential use to this section of Meadowbrook Road. The number of deviations has been reduced from 16 to 7 as listed in your suggested motion, with each being supported by staff.

Tonight, the Planning Commission is asked to hold the public hearing and consider making a recommendation for approval or denial to City Council on the PRO request. The applicant Gary Shapiro from Ivanhoe, is here representing the project tonight, along with other members of the team. Staff and our environmental consultant are also available to answer any questions you may have.

Chair Pehrson invited the applicant to address the Planning Commission.

Mr. Gary Shapiro with The Ivanhoe Companies stated it is great to be back in Novi. Ivanhoe has been proud developers of multiple developments in Novi over the last twenty years and take pride in working with communities to arrive at excellent end results. Mr. Shapiro noted he has been aware of this particular

piece of property for thirty years. It was expressed that Trinity Health purchased the property not knowing the environmental sensitivities of the parcel. In order to put a hospital on the parcel, much of the woodlands and wetlands would be destroyed. It was stated that Ivanhoe takes a lot of pride in their expertise of working with woodlands and wetlands.

Mr. Shapiro stated it was very productive to watch what Beckett and Raeder did in the City of Novi's new Master Plan. It was noted they were in attendance at many of those meetings and read the entirety of the meeting minutes. As you know, the new Master Plan was recently adopted acknowledging that OST in this area is not appropriate. Half of the land across the street is still vacant and the land to the south has been bankrupt three times.

It was stated that The Ivanhoe Companies took on a great challenge and that this is the best use for the land. Mr. Shapiro noted that the adjacency to MDOT is a source of excitement because the woodlands and wetlands can be developed and connected to achieve a cohesive ecosystem. After meeting with the Planning Commission the last time, the team felt well received at a community of 438 units. The previous project presented consisted of stacked flats of for rent condos. However, there were a few issues that the team was asked to consider. After much consideration, the project presented this evening has brought the number of units down from 438 to 232 units. Mr. Shapiro expressed his team has taken a lot of pride in listening to feedback from both the Planning Commission and City staff. He noted they are not only developers and builders but also land planners who really do their homework. He expressed that they are here tonight with much pride after listening to all the comments and more, noting that the public benefits have been improved.

It was highlighted that the proposed park on Twelve Mile adjacent to MDOT will be less than a quarter mile walk to Beacon Hill Park. Additionally, the sidewalk over the Trinity Health piece will be completed. Mr. Shapiro noted they were selected by Trinity Health to dive into this site in collaboration. The GMX Newzoning was considered which proposes to have sites available for new typologies not yet perceived. Everything was done in a cohesive fashion resulting in a development which would be world class with the proper buffers to any use of accord. It was noted their collaboration with Trinity Health extended to mitigation, in such that the mitigation is provided ahead of time. It was noted the roadmap has been laid to have quality development adjacent to this development. Mr. Shapiro stated he is available to answer any questions and introduced Mr. Brad Strader who will share a PowerPoint presentation.

Mr. Brad Strader from Cincar Consulting stated they have been working hard as a team since they appeared before the Planning Commission a year ago. The Planning Commission had several suggestions for looking at things. He stated the team took those suggestions and made a lot of changes to the plan; some of which were easy to accomplish with others taking a significant amount of consideration.

Mr. Strader stated some of the changes include reducing the density significantly, replacing the apartments with for sale homes resulting in a reduction from RM-2 to RM-1, designing units for seniors, removing the proposed carports, revising the architecture to meet City standards for building materials, modifying the wetland design to reduce the impact with all wetland mitigation occurring on site, rearranging the parks and open space, and reducing the requested deviations.

Next, Mr. Strader expressed the demand for residential developments in the area was considered and shared a map showing the development's proximity to commercial and recreation areas in the vicinity. Mr. Strader expressed this development will fit right in and provide support for some of the commercial uses that are facing the challenges of online shopping.

Market studies were conducted exploring why OST may not be appropriate. It was noted that the parcel is significantly environmentally challenged, even for residential development. This challenge is the reason it took significant time to rework the plan. Particular attention was given in order to fit the plan into the fabric of the wetlands and to preserve as much as possible. This was a difficult task for residential; it would be nearly impossible for some OST uses without having a major impact on the wetlands. A second component as to why OST may not be appropriate is there has been a lot of change in the need for OST

uses. Mr. Strader noted there are more appropriate locations for OST in the City and in this part of the City. In particular, the corner parcel that Trinity Health has retained is more appropriate for OST than their part of the combined parcel.

Mr. Strader stated it was important to Ivanhoe to be consistent with the new Master Plan. He noted they waited for the Master Plan to be adopted knowing it would be favorable. Trinity will retain six acres at the corner that will remain OST. The site has been designed in conjunction with Trinity looking at their wetlands and buffering the area for Trinity in the future.

Next, Mr. Strader touched on the open space and stated Mr. Shapiro and his team spent a lot of time looking at the wetlands and some of the key woodlands. Approximately, one third of the site will be open space with eighty percent of the units abutting open space in the rear. Key features include a nature trail along the eastern portion with an overlook which allows the views of the wetlands to be enjoyed. Residents and the public alike can access the Twelve Mile park to utilize and enjoy the wetland views. Trails, pathways, and sidewalks are provided within and along the development. It was noted they have worked with SMART to add a SMART bus stop with the location to be determined at a later date while going through the site plan process. Additionally, conservation easements, which were a feature recommended by the Planning Commission and City Council, will be part of the PRO Agreement. Further benefits include improvements to the Beacon Hill trail head, generous pathway widths, and the addition of 700 feet of sidewalk along Twelve Mile Road. A pickleball court will be included as an integrated feature of the development. Additionally, a play scape, picnic area, and bike racks throughout the open space will provide a variety of amenities. It was noted the area in which the previous plan contained carports has now been revised into green space. Generous buffers are placed adjacent to the Trinity parcel as well as the Meadowbrook office plaza to the south. Mr. Strader highlighted how the open space is integrated within the residential clusters.

Mr. Strader stated the architecture had been redesigned, noting the previously proposed flats have been removed. The architecture now meets all the City's architectural standards. The different villages will have different home styles; this allows a mixture of uses and styles within the development. First floor bedrooms that appeal to seniors is a notable change.

In summary, some of the PRO benefits that are provided with this development that may not be provided with a more traditional development include improvements to Beacon Hill Park, a pathway along the Trinity parcel, a SMART bus stop, open space which is two and a half times the City's requirement, network of non-motorized pathways and trails, conservation easements, and providing additional right of way along Meadowbrook. Additional benefits which are not technically PRO benefits but are still notable include diversity of housing within the development including first floor suites, for sale home as opposed to rentals, removing the carports, providing flexible floor plans, less traffic as opposed to OST uses, and high-quality landscaping along Meadowbrook.

Chair Pehrson opened the public hearing and invited members of the audience who wished to speak to approach the podium.

Mr. Paul Hatcher from Oliver Hatcher Construction at 27333 Meadowbrook Road stated he has submitted a letter to the Planning Department and is opposed to the proposed rezoning. Mr. Hatcher explained when he purchased the property approximately twenty years ago it was anticipated there would be an OST use across the street. He noted he had been in front of the Planning Commission previously as it was related to a proposed residential use to the west, and in that case did not desire to see residential units up against Meadowbrook Road. That developer has since redesigned the site to allow access off Meadowbrook Road and created all their residential units to the west. Most importantly, this proposal creates an island of OST between Twelve Oaks Mall and Meadowbrook Road. It was stated surrounding OST with residential is not compatible.

Mr. Hatcher stated when purchasing the property, he anticipated the surrounding uses to be similar to his building and noted the property owner to the north had also submitted a letter in opposition. He stated the developer has done a nice job of designing the project, however, would like to see an OST use on the property as planned when he purchased his property.

Seeing no one else, Chair Pehrson requested Member Lynch read into the record the correspondence received. Member Lynch relayed correspondence was received from Mr. Hatcher who objects. Additionally, Stephen Carey at 27421 Meadowbrook Road objects due to the negative impact on the commercial corridor that currently exists on Meadowbrook Road between Grand River Avenue and Twelve Mile Road. The development of low-density multi-family housing will add considerable congestion into the area, devalue the existing development, and limit future commercial development and job creation within the City of Novi. Chair Pehrson closed the public hearing and turned the matter over to the Planning Commission.

Member Lynch stated the applicant has done a lot of work since presenting last time. Regarding the carport in the previous proposal, he noted he had not approved a carport since being on the Planning Commission. It was stated that the conservation easements surrounding The Woods and The Pointe are a nice feature. It was suggested the townhome units next to the trail be provided with a buffer. Overall, it was stated this is a good use and it was nice to see single floor ranch units.

Mr. Shapiro stated The Woods units are a ranch, and The Pointe units have a first-floor master bedroom.

Member Lynch stated the ranch is impressive and inquired if the interior units can have first floor master bedrooms.

Mr. Shapiro stated the units can be interchanged and the public will determine what they want.

Member Lynch stated this project is much more consistent with what one would expect in Novi than the previous proposal and he is in support. He inquired why the clubhouse and pool are optional.

Mr. Shapiro stated attainability is being considered in regard to the clubhouse and pool as these amenities will increase dues.

Member Verma inquired if there would be an activity center for seniors.

Mr. Shapiro stated there is an area where units could have been built that has been left as open space with passive trails, park benches, and sitting areas throughout. He stated a clubhouse is on the threshold of being able to be supported economically.

Member Verma stated he likes the first floor living option.

Member Roney stated overall he likes how the project has a different personality depending on where you chose to live within the development. Additionally, the strong use of conservation easements is nice to see. He inquired if there is parking at the Beacon Hill trail head.

Planner Bell stated there are approximately four parking spaces at the Beacon Hill trail head.

Member Roney expressed he appreciates all the adjustments that were made based on the input from

the Planning Commission and the City Council. Since this has a future land use designation of mixed use, he stated he like this project.

Member Avdoulos stated he takes the concerns of the neighbors across the street into consideration. However, looking at the property, if it were developed into OST, it would be difficult to fit something in. The residential use allows the project to fit in and meander throughout the site a little bit better. He stated as this develops, he would like to ensure the residents understand there will be a development on the Trinity parcel in the future. It is important to enable the future residents to understand what could be developed on the adjacent parcel. The open space, lowered density, and aging in place component are appreciated. He noted compatibility with the site as opposed to OST has been considered. Utilizing a residential format for the use and development of this property will work best. Additionally, the sidewalk connection along Twelve Mile is important, as it gives residents of the development as well as people in the surrounding area the option to get their steps in outdoors.

Motion to recommend approval of JZ24-31 The Grove with Zoning Map Amendment 18.745 to City Council made by Member Avdoulos and seconded by Member Lynch.

In the matter of JZ24-31 The Grove, with Zoning Map Amendment 18.745 motion to recommend approval to City Council to rezone the subject property from Office Service Technology (OST) to Low-Density Multiple Family (RM-1) with a Planned Rezoning Overlay Concept Plan.

- A. The recommendation includes the following ordinance deviations for consideration by the City Council, for the reasons noted:
 - 1. Building Setbacks (Sec 3.1.7.D): A Zoning Ordinance deviation is requested to reduce the building setbacks from 75 feet to 50 feet along the north, east, and south property lines, as sufficient screening appears to be proposed.
 - 2. Building Orientation (Sec. 3.8.2.D): A Zoning Ordinance deviation is requested to revise the required orientation of the buildings from a minimum of 45 degrees in certain locations. This allows for a more uniform site layout with all of the units backing up to open space/wooded areas.
 - 3. Distance between Buildings (Sec 3.8.2.H): A Zoning Ordinance deviation is requested to reduce the building separation distance from the calculated formula as shown on the Building Separation Table on Sheet SP-3.6 of the PRO Plan). This deviation enables the layout of this project to fit within the available space while minimizing wetland and woodland impacts.
 - 4. Parking along Major Drives (Sec. 5.10): A Zoning Ordinance deviation is requested to allow for perpendicular parking on the major drives. This deviation is requested to due to the impracticality of providing a minor road (defined as less than 600 feet in length) given the site constraints (woodlands, wetlands, and property configuration). Perpendicular parking for guests is proposed on four Major Drives (Simi Drive, Beckham Drive, Elle Parkway, and Ari Crest) in several locations, where driveways are also proposed. The parking spaces will not cause any more disruption on the roadway than cars that will be backing out of the driveways.
 - 5. Parking along Curves (Sec. 5.10): A Zoning Ordinance deviation to allow on-street parking on curves with less than a 230-foot centerline radius. The deviation is supported as the parking spaces will not cause any more disruption on the roadway than cars that will be backing out of the driveways.
 - 6. Landscape Berms (Sec. 5.5.3.A.ii): A landscape deviation is requested to not provide a 4-foot, 6-inch to 6-foot high landscape berm on a proposed RM-1 district adjacent to an OST

- district on the east and south side. This deviation is supported because of topography and the provision of dense landscaping along both property lines.
- 7. Right-of-Way Landscaping (Sec. 5.5.3.B.ii): A deviation to the required greenbelt berm and plantings along 12 Mile and Meadowbrook Road due to the existing natural areas to be preserved, and a heavily landscaped detention basin.
- B. If the City Council approves the rezoning, the Planning Commission recommends the following conditions be made part of the PRO Agreement:
 - 1. Preservation of approximately 10 acres of City regulated woodlands and woodland replacements in a conservation easement.
 - 2. Preservation of approximately 15.5 acres of City regulated wetlands and wetland mitigation areas in a conservation easement.
 - 3. Removal of invasive species within the existing wetlands on site.
 - 4. Density shall not exceed 4.2 dwelling units per acre (More limiting than the dwelling units per acre allowed in the RM-1 District).
 - 5. Providing the community amenities shown in the PRO Plan.
 - 6. As an option, a clubhouse could be placed where the pickleball court and playscape are currently shown. The design of the clubhouse would need to meet Façade ordinance requirements at the time of site plan approval.
 - 7. Dedication of 1,650 linear feet of Right of Way on Meadowbrook Road.
 - 8. Building height will be limited to 30 feet, which is more limiting than the 35 feet permitted in the RM-1 District.
 - 9. The traffic improvements as shown on the PRO Plan.
 - 10. If pickleball court(s) are proposed at the time of Preliminary Site Plan submittal, a noise impact statement shall be submitted showing that the activity, with any noise mitigation measures required, will comply with the City's Performance Standards.
 - 11. Sustainable design features will include:
 - a. Pre-wire all garages for one 240-volt EV chargers.
 - b. All appliances used within the development must be EnergyStar-rated or applicable equivalent standards.
 - c. All applicable plumbing fixtures shall be WaterSense labeled or applicable equivalent standard.
 - d. Building material on the exterior façade of a majority of the exterior elevations are energy-efficient, durable, and low maintenance, including brick and composite siding.
 - e. Use of energy-efficient glass/glazing.
 - f. Use of energy-efficient insulation materials.
 - g. Offer a tankless water heater option.
 - h. Install smart scheduling technology for sprinklers.
 - i. Multi-modal non-motorized pathway network and infrastructure as shown on the PRO plan that reduces emissions and promotes pedestrian connectivity with bike/pedestrian friendly streets, and bicycle parking in units throughout the site.
 - j. Benches will be made with recycled materials will be used throughout the open space areas.
- C. This motion is made because the proposed RM-1 zoning district is a reasonable alternative to the current OST zoning and fulfills the intent of the Master Plan for Land Use, and because:
 - a. A one-acre park area, accessible to residents and the general public, with pedestrian and bike rest stop area, at the northeast corner of the site along 12 Mile Road. The applicant states a public access easement will be placed over the park area. This would be considered a benefit to the public.
 - b. A one-mile loop Grove nature area trail, accessible to residents and the public, that extends from the newly created park area described above, along the east property line of the Property, providing scenic views of the adjacent 30-acre natural wetland area as well as natural features of the Property. The applicant states a public access easement will be placed over the trail area. This would be considered a benefit to the public.
 - c. In order to address the impact of additional use of Beacon Hill Park by the new residents

and planned access and interconnectivity for Novi residents and Grove Nature Trail, Developer agrees to provide the City with \$25,000 to be used by the City at its discretion, for Beacon Hill Park improvements, art, services and/or maintenance. *Enhancements of the public trailhead would benefit the overall community*.

- d. Consistent with Novi's mobility plans, over 700 feet of 10-foot wide pathway/sidewalk, offsite on the south side of 12 Mile Road to create a connection from the existing bike path, located along the east side of Meadowbrook Road, and the new sidewalk being constructed with The Grove. The provision of this missing sidewalk segment enhances connectivity of the project area and benefits the public.
- e. Relocating the SMART bus stop to the east, and enhancing the area with landscaping and seating along 12 Mile Road, which is supported by SMART. Additional bike parking has also been added for a total of 8 spaces. Maintenance and public access agreements would likely be required. This would be considered a benefit to the public.
- f. Approximately 1/3 of the property will be open space with most of the units abutting or overlooking open space and nature areas (1.65 acres usable open space required, 5.97 acres proposed). Exceeding the Ordinance requirement for usable open space qualifies as an enhancement that could not otherwise be required.
- g. Consistent with Novi's mobility plans, construct an 8-foot wide shared-use pathway within The Grove to provide pedestrian and bicycle connectivity between Meadowbrook Road and 12 Mile Road. The applicant states a public access easement will be placed over the pathway, so the pathway would be considered a benefit to the public at large.
- h. Proposed conservation easements protecting approximately 10 acres of woodland and woodland replacement areas and 15.5 acres of wetland and wetland mitigation areas. The provision of conservation easements to protect the natural features, which represents over 47 percent of the property, is considered an enhancement that will benefit the public at large.
- Decrease in density from what would be permissible in the RM-1 zoning district (4.2 units per acre proposed, up to 7.3 units per acre permitted), which is considered an enhancement of the project.
- j. Dedicate right-of-way (60-foot width) along the entire Meadowbrook Road frontage, an approximate length of 2,166 feet. The total land area to be dedicated is approximately 2.5 acres, which is a benefit in the interest of the public.
- k. The Façade review notes that the design of the buildings meet or exceed the requirements of the Façade Ordinance, and the high level of character and attention to detail represents an enhancement of the project that would be unlikely in the absence of a PRO.
- I. The benefits to the City from the proposed multiple family development as proposed outweigh the detriments.

ROLL CALL VOICE VOTE ON MOTION TO RECOMMEND APPROVAL OF JZ24-31 THE GROVE WITH ZONING MAP AMENDMENT 18.745 TO CITY COUNCIL MOVED BY MEMBER AVDOULOS AND SECONDED BY MEMBER LYNCH. Motion carried 5-0.


MATTERS FOR CONSIDERATION

1. JSP25-24 FELDMAN KIA

Consideration of the request of Feldman Automotive for Preliminary Site Plan and Storm Water Management Plan. The subject property is zoned B-3 with a Planned Rezoning Overlay (PRO), which conditions development to the terms of a PRO Plan and Agreement. The applicant is proposing to develop a Kia dealership.

Planner Bell stated the petitioner has received approval of the rezoning to B-3 utilizing the Planned Rezoning Overlay option, so the development is subject to the terms of the PRO Agreement.

In this area of Grand River, there are professional offices, small strip retail centers, sit down restaurants and the US Energy fuel supplier. Single family residential homes are located to the south of the property. As you'll remember from the PRO process, the applicant proposes to redevelop the approximately 5-acre



55800 Grand River Avenue, Suite 100 New Hudson, Michigan 48165-9318 248.437.5099 · 248.437.5222 fax www.zeimetwozniak.com

September 30, 2025

Ms. Lindsay Bell, AICP, Senior Planner City of Novi Community Development Department – Planning Division 45175 Ten Mile Road Novi, MI 48375

Re: The Grove

PRO Plan JZ24-31

Planning Review Response

Dear Ms. Bell:

This letter is in response to the Plan Review Center Report dated September 17, 2025.

We offer the following responses to the few outstanding review comments summarized in your report.

As noted in the Façade Review, "The design of all buildings now meet or exceed the minimum requirements of the Façade Ordinance. Moreover, the designs show a high level of character and attention to detail. We (DRN & Associates) believe the designs for all buildings now meets the requirements of the PRO Ordinance.

The updated layout addresses the Planning Commission and City Council comments regarding multiple types of housing types and senior housing. The Grove will offer 2-story townhomes, 1st floor primary suite, and ranch units. Over 50% of the units can accommodate first floor primary suites as an option.

The Traffic review prepared by AECOM, dated 9/9/25, recommends approval of the Traffic Impact Study.

The Community Impact Statement has been updated to reflect the current reduced density.

We are cognizant of your concern regarding the proposed pickleball court and have located it over 100 feet away from the nearest unit. Additional landscaping and a fence sound barrier will be added to reduce the sound produced during play.

As noted in your letter, the required wetland mitigation will be provided for all wetland impact. This includes the impacts to wetlands M, U, V, Y, and Z on Parcel A. The wetlands impacts are shown on Sheet SP-8.1. To address the Mergent wetland review comments regarding Parcel A, the undisturbed portion of wetland U on the Grove is a natural area that will remain as a buffer. A portion of wetland X in the Grove will be impacted for the proposed buildings while the balance of the wetland will remain as a buffer.

An area on the Grove parcel, adjacent to Parcel A, has been set aside to accommodate the required wetland mitigation for Parcel A, when it is developed. Combining Parcel A wetland mitigation with the Grove mitigation will create a large, contiguous, high-quality wetland. Separate permits applications for wetland impacts in the Grove and Parcel A have been submitted to EGLE and plan Sheets W-1 through W-4 are included in the PRO plan set. A variation of the Parallel Plan was used for the EGLE application and will be submitted with the city wetland permit application during the review process.

The conditions for development suggested in your review letter will be included in the PRO Agreement. Please note that the woodland and wetland preservation areas totaling 10.2 acres and 15.6 acres respectively, are approximate and may vary slightly once the conservation easements are written. Also, the maximum building height will be increased from 28 feet to 30 feet to allow for potential adjustments as the plans are developed. This height is more limited than the 35 feet permitted in the RM-1 District.

Per staff recommendation, additional benches have been added along the path and bike racks have been added at the 12 Mile Park and Open Space (the "Grove Park") to encourage the public to use the park and to access the Grove Nature Area Trail. Documentation describing the public right of access and use of certain

open space and pathways will be reflected either in the Master Deed for the Condominium or by separate document in connection with final site planning.

The Grove Park is an easy, less than a 1/4 mile walk or bike ride from Beacon Hill Park and parking lot. These parks have been designed in concert with Novi's walkability, mobility, and pathway system. A 10' wide pathway along the 12 Mile Road frontage of the Grove and an additional off-site 700 feet pathway along the corner parcel, provides a direct connection between the two parks. In addition, an 8' wide sidewalk looping through the Grove will provide further connection to Beacon Hill Park. The Public Benefits Plan (Sheet SP-3.5) illustrates the connectivity between the Grove Park and Beacon Hill Park and parking lot. Signage at the entrance to the Grove Park will indicate public access to the Grove Nature Area Trail. Additional signage will be installed at Beacon Hill Park to indicate connectivity to The Grove Park and Nature Trail Area.

Per staff suggestion, and to address the impact of the use of Beacon Hill Park by the new residents of the Grove due to the close proximity of the Grove to the Beacon Hill Park and the planned access and interconnectivity for Novi residents to utilize the new Grove 12 Mile Park and Nature Trail, Developer agrees to provide \$25,000 to the City to be used by the City, at its discretion, for Beacon Hill Park improvements, including landscaping, art, new seating and other services and/or maintenance.

We are working with SMART to determine the location and design of a new bus stop. A copy of our initial engagement letter with SMART is attached. As noted in the SMART Bus Stop Standards Design Manual, dated January 2025, there are six different types of bus stops within SMART's network. The type of bus stop selected for a chosen location is based on "how many people and routes the stop has the capacity to serve, and the streetscape it is most appropriate within." The current east bound SMART bus stop, located west of the Grove is a Coverage Stop. A Coverage Stop, as defined in the SMART standards, does not include a covered seating area. We are proposing to construct a new Coverage Stop and add the adjacent seating and landscape area for passenger safety and comfort while they wait for the bus. We will continue to work with SMART during the site plan process to finalize the design. The number of bike racks near the bus stop has been increased to accommodate eight bikes.

The 10-foot pathway providing connectivity between Meadowbrook Road and 12 Mile Road has been reduced to 8-foot wide to address the Landscape review concern that a 10-foot pathway does not leave enough room to provide healthy street trees. As stated above, public rights of access and use will be provided.

As noted in your review, the Façade review notes that the design of the buildings meet or exceed the requirements of the Façade Ordinance, and the high level of character and attention to detail represents an enhancement of the project that would be unlikely in the absence of a PRO. This would be an added benefit to the PRO.

As requested, a revised building separation chart has been added to Sheet SP-3.6.

The number of deviations has been reduced to seven and all are supported by staff.

A detailed response letter addressing the Engineering review comments are attached. Again, we thank staff and all consultants for their unanimous recommendations for approval. We look forward to working with you on this exciting project.

Please let me know if you have any questions or comments.

Sincerely,

Andrew Wozniak

September 30, 2025

Ms. Humna Anjum, Project Engineer City of Novi Public Works – Engineering Division 23600 Lee Begole Drive Novi, MI 48375

Re: The Grove

PRO Plan Review Response

Dear Ms. Anjum:


Thank you for your recommendation of approval. In response to your Engineering Review letter, dated August 13, 2025, Items to be addressed within the PRO Agreement, we offer the following:

- The proposed "Coverage" bus stop will be located within the 12 Mile Rd. right-of-way. An easement for public access to the seating area and bike racks will be provided. Maintenance of the seating area and bike racks will be the responsibility of the Condominium Association and will be included in the PRO Agreement.
- The Applicant has been in contact with SMART regarding the bus stop and will continue to work with them throughout the site plan process.

Please let me know if you have any questions or comments.

Sincerely,

Andrew Wozniak



The Grove

Proposed Rezoning & PRO Concept Plan

Walkable Residential Development

Community Impact Statement

August 25, 2025 (Revised September 16, 2025)

Prepared for:



Ivanhoe Companies 6689 Orchard Lake Road, Suite 314 West Bloomfield, MI 48322

Introduction

The Community Impact Statement for The Grove Planned Rezoning Overlay was prepared by a group of consultants based, in part, on information prepared by others on the Ivanhoe project design team. Some of the information noted in this report was provided by the City of Novi. Ivanhoe specialists who contributed information included civil engineers, landscape architects, architects, a woodlands and wetlands consulting firm, traffic engineers, local real estate experts, and a national marketing firm noted on the cover page. Many of those firms and individuals prepared separate reports that go into more detail.

Contents of this report are based on the City of Novi's requirements for a Community Impact Statement, as listed in the Zoning Ordinance. This report also responds to a series of City staff requests during a pre-application meeting and review comments.

Project Description

Ivanhoe proposes a unique master-planned residential community containing four villages with for sale housing options. The residential villages are integrated through a comprehensive pathway system, a large open space park, two pocket parks, woodland corridors and other natural features.

Per the City's Master Plan Update (2025), "Novi's housing stock is growing, [but] housing demand outpaces supply...Novi supports a diverse array of housing typologies across housing tenures." In addition, "it is evident that the City is actively diversifying the housing typologies to further improve affordability and accessibility. It will be critical to adapt and match the current and upcoming housing stock with demand." The Master Plan also notes that "Novi's highest [residential] density is 30 dwellings per acre, [but that] the walkable density threshold is targeted at 40 dwelling units per acre." In the Future Land Use Framework Plan, The Grove site is located within the "Area of Transformation" and in the Future Land Use Map, the site is noted as "General Mixed Use" which "provides the highest flexibility of the [land use] categories. It recognizes that certain properties will be developed based on prevailing market trends utilizing a site-specific master plan to guide development, reserving certain portions of the subject property for different land use typologies. Properties within this designated land use category can also utilize the PUD option as a development tool..." The plan for the Grove is guided by these Master Plan objectives and analysis and will be a unique multigenerational community. Our marketing plan is targeted at providing different housing types to attract seniors, young residents and families and professionals.

Site and Relationship to the Adjacent Trinity Parcels

The subject property consists of the majority of the land owned by Trinity Health-Michigan located on 12 Mile and Meadowbrook Roads (the "Trinity Health Property"). The Trinity Health Property is currently zoned OST (Office Service Technology). Ivanhoe entered into an agreement with Trinity Health in November 2022 to acquire 62 acres of the Trinity Health Property, leaving an approximate eight-acre parcel at the corner of 12 Mile and Meadowbrook Roads for future business development for the creation of a compatible mixed-use development of the overall Trinity Health Property.

While Trinity is retaining ownership of the corner, Ivanhoe has discussed options with Trinity during Ivanhoe's due diligence including the best complementary uses for the sites. Ivanhoe also conferred with Trinity during a review of use options, initial planning and design, evaluation of woodlands and

wetlands, overall connectivity, and the setbacks/buffering needed. Ivanhoe's layout of residential buildings and landscaping buffers ensures that any future development of the corner parcel can be integrated to create a unified development. Based on those discussions, Trinity Health supports the uses and site plan layout, including the deviations Ivanhoe is requesting for the setbacks and landscaping that will separate the two properties Trinity agrees that our uses, open space configuration, series of non-motorized pathways, and design features will be complementary to future users of the remainder of the Trinity Health Property.

Adjacent Land Uses

The Property is close to a variety of office, retail, recreation, entertainment, and residential land uses. The entire eastern boundary of the Property abuts approximately 32 acres of MDOT right-of-way adjacent to the M-5 expressway, which is an undeveloped open space natural area containing wetlands complex and woodlands corridor and which is used, in part, for storm drainage for the highway.

To the north, across 12 Mile Road is the Beacon Hill Mixed Use project (which contains residential, future commercial and a City park, which was also developed by Ivanhoe) and MSU's Tollgate Farms. Ivanhoe's site is linked by pathways anchored by a City of Novi trailhead and park, developed and previously deeded to the City by Ivanhoe as part of the Beacon Hill mixed-use project. There is also an older office/type building on the southwest corner of 12 Mile Road and Meadowbrook.

The property is located within easy biking or driving distance to many commercial uses, including Twelve Oaks Mall and Twelve Mile Crossing at Fountain Walk. A substantial amount of office/commercial is located to the east and across M-5 there is a small office park, and the I-96/M-5 interchange.

Environmental Factors and Open Space

About 40 acres of the site will be green space. Approximately 15% of the site will useable open space, which far exceeds what the City's Zoning Ordinance requires. Other green areas that will be viewed as open space by our residents and visitors include 16 acres of natural forested areas, wetland areas and attractive detention areas.

The design of the Grove specifically included consideration of how the open spaces on the Property would relate to preserved open spaces on adjacent properties. Thus, The Grove's 40 acres of total green space, combined with the adjacent MDOT property to the east (34 acres) and land included in a conservation easement to the south (around 6 acres abutting The Grove), create 80 acres of connected natural wildlife habitat. In addition to the aesthetic appeal of this cumulative open space, it provides an extensive habitat for squirrels, raccoons, rabbits, other small mammals, and a variety of small birds. A pathway with observation areas on the Property adjacent to the MDOT wetland mitigation conservation easement will allow residents to appreciate this natural area.

Scattered small wetlands are located throughout the Property, in which invasive species are present. These wetlands have been flagged and were reviewed by the City's environmental consultant, who concurred that the highest quality wetlands are being conserved, with only the low-quality wetlands being disturbed by the proposed residential development. 100% of the required wetland mitigation will be provided.

As noted in the survey, the development will be saving high quality wetlands and impact low quality wetlands that contain invasive species. The location, topography, and natural features present development challenges which is why it remains one of the larger pieces of undeveloped properties left in the City, particularly considering the size and configuration of buildings typically developed for OST uses. These challenges also provide opportunities to create something unique, impactful, and synergistic with the key nearby, large-scale retail shopping areas in the City—Twelve Oaks Mall, Fountain Walk and Novi Town Center.

There is no known environmental contamination history of the site. There are also no known above or underground storage tanks of any kind. No hazardous or toxic chemicals will be stored on-site. No underground storage tanks, wells, or septic tanks are proposed and none will be permitted.

Storm Water Disposal

Stormwater will be collected by sewers and directed to a series of on-site forebays and detention basins. The water will be held in the basins and released to the on-site wetlands at a controlled rate.

Economic Benefit

There are many reasons that the Property has not been developed with OST uses in the past. On a site-specific basis, there are scattered wetlands and woodland corridors that significantly inhibit the area available for development of OST buildings and the large parking lots required. The need for additional office spaces in Novi, Southeast Michigan, and nationally have changed in the last few years. The office vacancy rate has increased, with more people working from home or virtually. Thus, the demand for office uses has decreased. And there is available land more suitably situated in the City to accommodate any future demand for OST uses. Conversely, as reflected in the marketing consultant reports submitted by Ivanhoe with its PRO application materials, the demand for different types of residential uses has increased.

As noted earlier, the new Master Plan (2025) recommends more flexible uses for this site, including residential, which is more appropriate and has less adverse environmental impact for the Property in order to respond to these changing trends.

As noted in our marketing reports, the stress in recent years on brick-and-mortar stores is well documented. Many shopping malls around the country and in Michigan are failing and some have closed. Oversaturation of commercial lands and loss of on-site sales means that new residential areas are needed to support the existing and future retailers and restaurants. The Grove is perfectly positioned to provide easy access to Twelve Oaks Mall, Fountain Walk, Novi Town Center and other uses within a convenient walking, bike or driving distance (refer to the maps in the submittal booklet).

In addition to the substantial property tax revenue to be achieved from Property that has sat vacant for many years, there will also be an economic benefit to the City during construction. There will be jobs in the construction industry, and with businesses that provide supplies or support services. We anticipate hundreds of contractors on site at various times during each of the phases.

For more detail, see the separate economic market studies was prepared by CBRE (confirms the lack of office market), and the nationally known The Chesapeake Group (highlights various market factors) provided with our submission.

Community and Social Impact

There are three key factors that drive this development. First, the size of the Property offers the opportunity to provide diverse, multi-generational, but integrated housing options in one development. Second, the isolated location of the Property and the natural features on and around the site are ideal and attractive for a successful residential project. The Property is also currently vacant and undeveloped and therefore there is no relocation of existing uses or persons required as part of this development.

Moreover, the entire east side of the property—over 2,200 hundred feet—abuts the M/5 right-of-way which will remain undeveloped. That MDOT-controlled property contains a wetlands complex, woodland corridors, and storm drainage features. A pathway with observation areas on the Property adjacent to the MDOT wetland mitigation conservation easement will allow residents to appreciate the natural area. (See also our Mobility Plan section at the end of this report).

Finally, consistent with the City's objectives and goals for sustainable development and Ivanhoe's own development philosophy, the Project will include numerous sustainable design features that will create positive community impacts, such as: bike racks and bike storage space; use of native vegetation and strategically placed canopy trees; applicable plumbing fixtures shall be Water Sense labeled or an equivalent standard; use of energy efficient exterior building materials, glass/glazing and insulation; installing smart scheduling technology for water use; and LED exterior lighting.

Demands on Police Services

Based on Police Department records, the per capita response was one Police Department response for every 2.63 persons. Based on the expected residential population of 344 to 423 persons, it is estimated that between 130 to 160 annual Police Department calls would be made from this project. These numbers are similar to other residential areas.

Demands on Fire Services

Between 2002 and 2017, the Novi Fire Department responded to 25-30 structure fires per year (for a population of roughly 60,000 persons). Based on the estimated Grove population in Novi of 344 to 423 persons (a small overall increase in population to the City), the total projected annual Fire Department responses are one or less calls based on previous data collected. The project is also located approximately 2.5 miles from Fire Station No. 1 at 42975 Grand River Avenue, Novi, Mi 48375. Due to the proximity of the fire station, response time is expected to be only a few minutes.

Additional Notes on Police and Fire Services

At the initial review meeting for the Project, when the project was 432 units, one Planning Commissioner asked about police and fire impacts with a change from OST to residential. We reviewed the Community Impact Statements of recent projects that the City had approved, looked at the City's website, and also sent a FOIA request to the City's Police and Fire Department. The FOIA request was to see if they had additional studies or information that compared costs of different land uses or other metrics that we could apply to an analysis of our proposal compared to OST uses. The City's Police and Fire Departments noted that, while they monitor crime, crashes, fire and EMS runs, they do not have any studies the compare costs for different types of uses (see their letter dated June 23, 2025). We have also not found any recent project in which such information was sought or provided for any other project. The analysis would be complicated by the fact that numerous uses are permitted in the OST district and even more uses under the Master Plan designation for the

property, which includes multi-family residential. With density reduced by almost one-half and the elimination of rental housing, there is no indication anywhere that the City's police and fire services are not fully sufficient to handle the additional residential as opposed to a large commercial, office or industrial use. Moreover, the voters just approved a massive bond financing for police and fire service improvements that would serve the City for generations to come.

City Performance Standards

The proposed Grove development shall comply with all existing City Performance Standards found in Section 5.14 of the Novi Zoning Ordinance.

Utility Connections

It is anticipated that the project will require approximately 51 sewer and water taps. The Grove will connect to the existing 24" and 16" watermain at three locations and the existing 21" and 12" sanitary sewer at two locations. These facilities have adequate capacity to accommodate the increased demand. Detailed sanitary and water needs will be determined as the engineering design process evolves.

Refuse and Solid Waste Disposal

The units will use individual receptacles which will be stored in the individual units' garage.

Traffic and Transportation Impacts

Ivanhoe's traffic engineers at Fleiss & VandenBrink compared the number of expected trips in the peak hours for a typical office use with the number of trips expected with the residential use. A typical OST development, for example, would generate far more traffic. Peak hour traffic differences are even more dramatic as shown in the table below (this Table 2 is from the Trip Generation Comparison. The traffic benefits could be even greater if people walk or bike to nearby retail and restaurants in the area. Ultimately, the Grove development's close proximity to nearby commercial areas can slightly help reduce the overall Vehicle Miles Traveled (VMT) since there are established and proposed walking and biking trail connections.

Notably, the development combines 12 parcels, which could otherwise be developed into individual access points, into one unified destination and just three access points. This means less conflicts with people traveling along the 12 Mile and Meadowbrook pathways, and less potential for crashes for all types of travelers.

PM Peak Hour (vph) AM Peak Hour (vph) ITE Amount Units Daily Traffic **Average** Zoning Land Use Code ln Out Out Total ln Total General Office Building 710 984,600 SF 8,487 1,053 144 1,197 188 920 1,108 Existing 738.450 112 934 873 General Office Building 710 SF 6,608 822 148 725 (OST) General Office Building 710 492,300 SF 4,643 580 79 659 106 517 623 984,600 Maximum for Existing Zoning SF 8,487 1,053 144 1,197 188 920 1,108 Proposed Single-Family 215 232 DU 1.717 29 86 115 80 55 135 (RM-1 w/ PRO) Attached Housing -6,770 -1.024 -58 -1.082 Difference -108 -865 -973

Table 2: Rezoning Trip Generation Comparison

Mobility Plan

The Grove will be a walkable and interconnected community consistent with the "Walkable Novi" Plan and the City's new Mobility Plan. The Grove will contribute to the completion of over 3,540 feet of bike and walking paths along 12 Mile Road and Meadowbrook Road. These pathways allow easy access to the Michigan Air Line Trail, M-5 Metro Trail as well as the I-275 Metro Trail (refer to the submittal booklet for a map). These pathway connections also provide access to the MSU's Tollgate Farms, and the Beacon Hill Park access trail, which was developed by Ivanhoe as part of the Beacon Hill mixed-use project on the north side of 12 Mile Road.


Internally, The Villages are tied together by an extensive pathway system and recreational and natural optional amenities, including a central gathering park, pocket parks, a nature area, clubhouse and pool facilities, pickleball court and a playscape.

In addition to the walking and bicycling pathways, we are also promoting the use of transit. There will be access to a new bus stop for residents to connect to SMART's Route 740 along 12 Mile Road. If approved by SMART and the City, Ivanhoe will construct a new bus stop as part of its public contributions.

Noise Impact Statement (Waiver Request)

The development will not create additional levels of noise that are not otherwise normally associated with residential areas. The level of noise from the residential development will be much less in comparison to potential noise levels that would come from OST use of the Property. The noise generated from the residential area is also much less significant than noise from the nearby freeway. There are no other single family uses adjacent to the development. Therefore, we are requesting a waiver for the Noise Impact Statement that is required for Special Land Uses.

077394.000050 4920-5909-3865.1



COMMERCIAL REAL ESTATE SERVICES

Charles M. Ginster Senior Vice President Industrial & Logistics CBRE, Inc **CBRE**

2000 Town Center Suite 2200 Southfield, MI 48075

248 351 2063 Tel 248 353 5400 Fax

chuck.ginster@cbre.com

The Ivanhoe Companies 6689 Orchard Lake Road, West Bloomfield, MI 48322

December 13, 2023

Gary,

Per your interest in an overview of OST zoned property in Novi including available land, please review my findings below. This is only my opinion based on my observations and years of experience in commercial real estate.

Overview of Novi OST Zoned Land- 12 Mile and Meadowbrook Road

The sum of Novi, MI, developed and undeveloped OST Zoned acres is +/- 535 (22,869,000 SF of Land). Attached #1 is a general outlined aerial outline map depicting most of the OST Zoned land in Novi.

Novi Michigan Office/OST Zoned Existing and Developed SF

There has been Negative Absorption to date in 2023. Attachment #2 is the CBRE third Quarter Repot substantiating the negative absorption.

Climbing Office vacancies in general in Metro Detroit (attachment #3) are increasing quarterly at historic rates and again are at historic negative absorption rates. This trend will continue remain for the foreseeable future as home related working with AI, Cloud and other Computer-Generated Systems enable this.

The redevelopment of Office buildings will be very long and tenuous process. Many of these buildings will be demolished and redeveloped into Data Centers and Residential Development.

Summary


In my opinion, the balance of the OST undeveloped land, especially the larger tracts, will take years, if ever, to being absorbed under this current zoning.

The 12 Mile and Meadowbrook southeast corner is not ideal for OST zoning due to its location and geoenvironmental features.

In my opinion, a high-density residential community coupled with a hard corner-12 and Meadowbrook special use would be the best use of the property.

Charles M. Ginster

Senior Vice President





FIGURES | DETROIT OFFICE | Q3 2023

Negative absorption continues as average lease size dips below 6K sq. ft.

20.3%

△ 26.8%

(1,216,683)

\$19.09

Lease Rate

Vacancy Rate

Availability Rate

SF Net Absorption

Note: Arrows indicate change from previous quarter.

Market Summary

- Q3 leasing activity was comprised of smaller sized deals highly prevalent in the Southfield and Troy submarkets. Transactions in these submarkets consisted of Dinsmore & Shohl LLP occupying 19,400 sq. ft. at the PNC Center in Troy and Motor & Equipment Manufactures Association occupying 14,299 sq. ft. at the Riverside Center in Southfield.
- Negative absorption experienced an uptick for the 4th consecutive quarter. Several large tenants vacated or downsized significantly. The Detroit submarket was hit hardest with negative absorption in Q3 (-495,145 SF) as 1 Campus Martius saw Meridian and Compuware vacate space which combined for over 130,000 sq. ft. of negative absorption. Overall, Class A buildings experienced (-713,973 SF) of absorption, more negative absorption than Class B and Class C buildings combined.
- The construction pipeline consists of 4 buildings totaling 1,776,376 sq. ft. highlighted by the Hudson Site, scheduled to deliver in Q3 2024.
- Southfield, Troy and Detroit each displayed negative absorption over 150,000 sq. ft.
- Sublease availability saw repeated growth with over 2.3 million sq. ft. of space available on the market.

FIGURE 1: Net Absorption and Average Asking Lease Rate



Source: CBRF Research, Q3 2023

CBRE RESEARCH © 2023 CBRE, INC.

Suburban

The suburban office market displayed 721,538 sq. ft. of negative net absorption. While still negative absorption, the suburban market experienced a positive increase in absorption compared to Q2 (-1,220,511 SF). Overall average asking lease rates for the suburban market continue to decline, as Q3 closed out with an average asking lease rate of \$18.13/SF. Notably, Ann Arbor (\$25.73/SF) and Birmingham/Bloomfield (\$24.47) displayed the highest average asking lease rates which follows the historic trend for those respective submarkets. Available sublease space experienced another quarter of growth with just under 2 million sq. ft. of space available within the suburban market.

Downtown


Source: CBRE Research, Q3 2023

Office vacancy in the downtown market continued to trend upwards in Q3, closing out at 19%. Available sublease space dropped for the 3rd consecutive quarter and direct asking lease rates fell to \$23.28/SF. Downtown negative absorption totaling just under 500,000 sq. ft. in Q3 was largely due to big tenants such as Meridian and Compuware, vacating space at 1 Campus Martius. As tenants continue to navigate the return to office, the market has experienced downsizing office footprints, along with short-term leases as a post-pandemic trend. FIGURE 2: Key Transactions

Transaction Type	Tenant / Buyer	Location	Transaction Size (SF)	Industry
Renewal	Umlaut	1225-1235 Spartan St, Madison Heights	35,497	Engineering
New Lease	Dinsmore & Shohl LLP	755 W Big Beaver Rd, Troy	19,400	Legal Services
Renewal	Motor & Equipment Manufacturers Association	25925 Telegraph Rd, Southfield	14,299	Manufacturing
Renewal	Entrega Systems Group	900 Wilshire Dr, Troy	13,190	Technology Systems
Renewal	Simons-Michelson- Zieve Inc.	1200 Kirts Blvd, Troy	11,706	Advertising

FIGURE 3: Vacancy, Availability, and Average Asking Lease Rate

Vacancy (%) and Lease Rate (\$/SF)



Source: CBRE Research, Q3 2023

CBRE RESEARCH

Construction

Q3 experienced no construction completions, and the construction pipeline consists of 4 buildings. Highlights within the construction pipeline include Ford Motor Company's Michigan Central Station, which is set to see first occupancy shortly after the beginning of 2024. Also, The Hudson Site at 1208 Woodward Avenue will add 655K SF to the market and is expected to deliver in Q3 2024. In total, the Detroit market closed out Q3 with 1,776,376 SF of space under construction.

Vacancy and Absorption

Vacancy rates saw an increase from 19.1% in Q2 to 20.3% in Q3. Net absorption remained in the red at (-1,216,683 SF). While employers continue to navigate what the future of office work looks like, the market continues to experience these trends. Although this is the 4th consecutive quarter of negative absorption in the Detroit market, the growing pace of these numbers appears to be slowing down.

FIGURE 4: Net Absorption, Under Construction Sq. Ft., and Vacancy Rate



Source: CBRE Research, Q3 2023

FIGURE 5: Net Absorption and Lease Rate by Class



Source: CBRE Research, Q3 2023

© 2023 CBRE, INC.

FIGURE 6: Detailed Market Statistics by Submarket

Submarket	Market Size (SF)	Vac. Rate (%)	Avail. Rate (%)	Avail. Sublease (SF)	Q3 2023 Net Absorption (SF)	2023 Net Absorption (SF)	Gross Asking Lease Rate (\$/SF)
Ann Arbor	5,800,735	17.4	22.2	258,504	(84,742)	(376,862)	\$25.73
Auburn Hills	2,152,118	20.4	23.9	92,850	21,069	12,977	\$19.14
Birmingham /Bloomfield	5,841,723	13.5	17.3	69,298	(45,698)	(8,056)	\$24.47
*Birmingham	1,525,550	8.0	9.0	38,820	(6,150)	583	\$32.38
Dearborn	4,120,297	21.8	24.5	0	(9,491)	(170,094)	\$16.62
Farmington Hills/West Bloomfield	6,594,374	17.3	21.8	170,751	(33,944)	(249,020)	\$17.77
I-275 Corridor	5,548,296	16.8	25.4	147,943	(44,970)	(86,745)	\$18.27
Macomb	1,331,663	7.7	9.6	0	364	1,998	\$16.25
Rochester	543,803	6.6	8.9	0	(12,419)	(19,313)	\$15.80
Southfield	16,881,776	26.5	38.5	801,276	(183,908)	(864,375)	\$16.35
Troy	12,836,496	22.7	30.9	424,300	(327,799)	(531,686)	\$16.94
SUBURBAN TOTAL	61,651,281	20.5	28.1	1,964,922	(721,538)	(2,291,203)	\$18.13
DOWNTOWN TOTAL	18,954,779	19.0	22.4	371,358	(495,145)	(693,449)	\$23.28
METRO DETROIT TOTAL	80,606,060	20.3	26.8	2,336,280	(1,216,683)	(2,984,652)	\$19.09

FIGURE 7: Detailed Market Statistics by Index and Class

Index and Class	Market Size (SF)	Vac. Rate (%)	Avail. Rate (%)	Avail. Sublease (SF)	Q3 2023 Net Absorption (SF)	2023 Net Absorption (SF)	Gross Asking Lease Rate (\$/SF)
Class A	23,173,809	18.8	24.9	868,968	(338,926)	(614,049)	\$20.15
Class B	33,228,025	23.3	32.0	1,093,512	(334,002)	(1,658,331)	\$17.30
Class C	5,249,447	12.1	17.2	2,442	(38,522)	(8,735)	\$14.12
SUBURBAN TOTAL	61,651,281	20.7	28.1	1,964,922	(721,538)	(2,281,115)	\$18.13
Class A	9,731,754	21.6	23.5	341,990	(375,047)	(397,427)	\$24.21
Class B	7,139,750	18.1	23.4	20,124	(57,967)	(178,624)	\$22.74
Class C	2,083,275	10.4	14.1	9,244	(62,131)	(117,398)	\$20.68
DOWNTOWN TOTAL	18,954,779	19.0	22.4	371,358	(495,145)	(693,449)	\$23.28
Class A	32,905,563	19.6	24.5	1,210,958	(713,973)	(1,011,476)	\$21.10
Class B	40,367,775	22.4	30.5	1,113,636	(402,057)	(1,847,043)	\$18.11
Class C	7,332,722	11.6	16.3	11,686	(100,653)	(126,133)	\$15.60
METRO DETROIT TOTAL	80,606,060	20.3	26.8	2,336,280	(1,216,683)	(2,984,652)	\$19.09

Source: CBRE Research, Q3 2023

^{*}Birmingham market is broken out from its primary submarket and its totals respectively are not included in the total at the bottom of the chart.

Market Area Overview



Definitions

Available Sq. Ft.: Space in a building, ready for occupancy within six months; can be occupied or vacant. Availability Rate: Total Available Sq. Ft. divided by the total building Area. Average Asking Lease Rate: A calculated average that includes net and gross lease rate, weighted by their corresponding available square footage. Building Area: The total floor area sq. ft. of the building, typically taken at the "drip line" of the building. Gross Activity: All sale and lease transactions completed within a specified time period. Excludes investment sale transactions. Gross Lease Rate: Rent typically includes real property taxes, building insurance, operating expenses, and common area maintenance. Net Absorption: The change in Occupied Sq. Ft. from one period to the next. Net Lease Rate: Rent excludes one or more of the "net" costs (real property taxes, building insurance, operating expenses, and common area maintenance) typically included in a Gross Lease Rate. Occupied Sq. Ft.: Building Area not considered vacant. Vacancy Rate: Total Vacant Sq. Ft. divided by the total Building Area. Vacant Sq. Ft.: Space that can be occupied within 30 days.

Survey Criteria

Includes office buildings 30,000 sq. ft. and greater in size. Excludes single-tenant owner-occupied buildings, government-owned-and-occupied buildings, and medical buildings. Buildings which have begun construction as evidenced by site excavation or foundation work.

Contact

Eric Horwitz

Senior Field Research Analyst +1 248 936 6866 eric.horwitz@cbre.com

Paul Van Devender

Managing Director +1 248 351 2030 paul.vandevender@cbre.com



INVENTORY SF

7.7M +0.5%

UNDER CONSTRUCTION SF

12 MO NET ABSORPTION SF

VACANCY RATE

MARKET RENT/SF

MARKET SALE PRICE/SF

MARKET CAP RATE

-100.0%

Prior Period (51.6K)

Key Metrics

Availability								
Vacant SF	905K ♦							
Sublet SF	202K ∤							
Availability Rate	15.7% ▲							
Available SF Total	1.2M ▲							
Available Asking Rent/SF	\$24.60							
Occupancy Rate	88.2% 🛊							
Percent Leased Rate	89.9% ♦							


Inventory	
Existing Buildings	218 🖡
Under Construction Avg SF	-
12 Mo Demolished SF	0
12 Mo Occupancy % at Delivery	6.4% ♥
12 Mo Construction Starts SF	0 ₩
12 Mo Delivered SF	40.7K ↓
12 Mo Avg Delivered SF	17.4K ↓


Sales Past Year	
Asking Price Per SF	\$155 ▲
Sale to Asking Price Differential	-41.8% ♦
Sales Volume	\$15.7M ♦
Properties Sold	10 ♠
Months to Sale	3.4 ♦
For Sale Listings	13 Å
Total For Sale SF	257K


Demand	
12 Mo Net Absorp % of Inventory	1.2% ▲
12 Mo Leased SF	239K ♦
Months on Market	14.9 ♦
Months to Lease	22.1 ♥
Months Vacant	2.3 ♦
24 Mo Lease Renewal Rate	59.6%
Population Growth 5 Yrs	2.1%


186826821 **CoStar** CoStar CoStar

Key Performance Indicators


























11/30/2023


























































































































































































Report Criteria

- 218 Properties / 182 Spaces
- Property Type: Office +1
- Construction Status: Existing
- City: Novi, MI





To: Gary Shapiro, The Ivanhoe Companies, LLC From: Howard Kohn, The Chesapeake Group, Inc.

Re: Market Evaluation for The Grove Residential Project in Novi, Michigan

Dated: August 9, 2024

The following is a market evaluation for the development of the proposed Grove project along 12 Mile Road, west of M-5 and north of I-96, in Novi, Michigan As explained below, all of the data indicate that there is more than sufficient market demand for the specific kinds and mix of housing options proposed for the Grove project.

The proposed development consists of 438 residences in four distinct villages. Two villages are targeted for for-sale condominiums, and two are villages with a range of housing offered for rent or sale. The four villages of the development and the associated units follow:

- ✓ The Vista has 49 three bedroom residences available for rent with ownership options.
- ✓ The Woods has 56 three bedroom condominiums.
- ✓ The Pointe has 77 three bedroom condominiums.
- ✓ The Meadows has 256 units available for rent with ownership options, in 32 buildings:
 - 21 studios.
 - 86 one-bedroom.
 - 149 two-bedrooms.

This assessment was prepared by The Chesapeake Group (TCG). TCG is the premier economic analysis and development firm in the United States, having prepared more than 1,700 analyses and plans since its inception. TCG has established a national reputation for all residential, commercial, industrial, entrepreneurial, entertainment, arts, technology, and institutional development in established and emerging communities.

TCG's mission is to facilitate sustainable land use, business development, redevelopment, and expansion in rural, suburban, and urban settings. TCG has been involved in numerous projects in Michigan for more than twenty-five years and maintains an office in the state. Current public sector client efforts in Michigan are in Battle Creek, Oshtemo Township, Rochester Hills, Sterling Heights, Dearborn, Delhi Township, and Detroit. TCG has completed projects for cities, economic development organizations and developers in many other Michigan communities, including Novi.

TCG is also the only consultant engaged with the State of Michigan's Redevelopment Ready Community Certification Program for recent administrations and the former "Cool Cities Neighborhood Program" during previous administrations. TCG has been involved with this effort throughout its evolution, guiding the conceptual development from a market perspective and assisting with reaching a viable conclusion that serves the community's needs.

RECENT HISTORICAL HOUSING CONTEXT

Novi is one of the most dynamic cities with growing households in Oakland County. Investments made in building new housing units are one sign of a community's health.

Oakland County has seen substantial household growth since 2011, or the close of the Great Recession. The lowest number of units permitted was in 2011, and the largest number permitted in 2017.

Table 1 - Oakland County Permitted New Homes from 2011 through 2023*

Oakland County	2023	2022	2021	2020	2019	2018	2017	2016	2015	2014	2013	2012	2011
Total Units	2,328	2,329	3,174	2,475	2,842	2,642	3,707	3,196	2,645	2,458	2,705	1,901	1,277
Units in Single- Family Structures	1764	1,797	2,044	1,935	1,976	2,482	2,744	2,143	2,180	2,114	2,296	1,880	1,266
Units in All Multi-Family Structures	564	532	1,130	540	866	160	963	1,053	465	344	409	21	11
Units in 2-unit Multi-Family Structures	8	14	20	14	0	16	4	60	58	16	14	6	0
Units in 3- and 4-unit Multi- Family Structures	26	98	127	111	83	71	105	49	44	49	60	15	11
Units in 5+ Unit Multi-Family Structures	530	420	983	415	783	73	854	944	363	279	335	0	0

^{*}Developed by The Chesapeake Group, Inc., 2024. Based on the HUD database.

Over 33,600 new housing units were permitted in Oakland County between 2011 and 2023. About 26,600 were "single-family" or detached homes, and roughly 7,000 were attached multifamily units.

✓ Detached units accounted for 79% of the total, averaging about 2,200 units annually.

✓ Attached units accounted for 21% of the total, averaging about 590 units annually.

Table 2 -Units Permitted, Share of Units Permitted, and Annual Average for Oakland County for 2011 to 2023*

Oakland County	Totals	% of County	Annual Average
Total Units	33,679	100%	2807
Units in Single-Family Structures	26,621	79%	2218
Units in All Multi-Family Structures	7,058	21%	588
Units in 2-unit Multi-Family Structures	230	1%	19
Units in 3- and 4-unit Multi-Family Structures	849	3%	71
Units in 5+ Unit Multi-Family Structures	5,979	18%	498

^{*}Developed by The Chesapeake Group, Inc., 2024. Based on the HUD database.

Novi reported growth in housing units permitted between 2011 and 2021. A total of just over 2,750 new homes were permitted during those years. The increase represents about 9.5 percent of the Oakland County total.

Future growth in rooftops can be based on recent history. Utilizing the historical patterns indicates a range of new units for Oakland County and Novi. For Oakland County, the range in annual average units permitted is from about 2,640 to 2,780. Utilizing the lower estimate for future projects results in the potential growth by 2030 of about 23,760 new permitted units. Utilizing the lower figure allows short-term downturns due to fluctuating national and regional economic conditions.

For Novi, the average annual permits issued was 251 from 2011 through 2021, and the yearly average number permitted between 2018 and 2021 was 193. Employing the lesser number results in the potential for about an additional 1,740 units by 2030.

Table 3 – Novi Permitted New Homes from 2011 through 2023*

Novi	2023	2022	2021	2020	2019	2018	2017	2016	2015	2014	2013	2012	2011
Total Units	63	46	114	321	190	147	516	184	289	203	197	322	275
Units in Single-Family Structures	63	46	114	218	190	147	181	184	173	198	197	316	275
Units in All Multi-Family Structures	0	0	0	103	0	0	335	0	116	5	0	6	0
Units in 2-unit Multi- Family Structures	0	0	0	0	0	0	0	0	0	0	0	6	0
Units in 3- and 4-unit Multi-Family Structures	0	0	0	0	0	0	32	0	0	0	0	0	0
Units in 5+ Unit Multi- Family Structures	0	0	0	103	0	0	303	0	116	5	0	0	0

^{*}Developed by The Chesapeake Group, Inc., 2024. Based on the HUD database.

The patterns for Novi generally meshed with the County's pattern.

✓ Novi permitted 2,867 homes.

- ✓ Novi averaged over 230 homes yearly.
- ✓ Eighty percent of all homes permitted were detached units.
- ✓ Twenty percent of all permitted homes were attached.

Table 4 -Units Permitted, Share of Units Permitted, and Annual Average for Novi for 2011 to 2023*

Novi	Total	% Novi	Annual Average
Total Units	2867	100%	239
Units in Single-Family Structures	2302	80%	192
Units in All Multi-Family Structures	565	20%	47
Units in 2-unit Multi-Family Structures	6	0%	1
Units in 3- and 4-unit Multi-Family Structures	32	1%	3
Units in 5+ Unit Multi-Family Structures	527	18%	44

^{*}Developed by The Chesapeake Group, Inc., 2024. Based on the HUD database.

As an established community, Novi naturally permitted a greater proportion of attached housing units than the County. On the other hand, Novi's share of the County's units permitted between 2011 and 2023 was the same proportion of attached units. One would have expected the share of attached units permitted in Novi to be greater if not for the potential need to "play catch-up."

Table 5 – Share of the Type of Units Permitted in Novi and Oakland Count an, the Annual Number Permitted in Novi from 2011 through 2023*

Novi	% of Novi	% of County	Novi Annual Average
Total Units	100%	9%	239
Units in Single-Family Structures	80%	9%	192
Units in All Multi-Family Structures	20%	8%	47
Units in 2-unit Multi-Family Structures	0%	3%	1
Units in 3- and 4-unit Multi-Family Structures	1%	4%	3
Units in 5+ Unit Multi-Family Structures	18%	9%	44

^{*}Developed by The Chesapeake Group, Inc., 2024. Based on the HUD database.

METRO DETROIT AREA HOUSING DATABASE AND HOUSING TRENDS

There are generally three market generators for new housing in Novi. These are internal movements of current residents to different homes, the internal generation of new households that results from the independence of youth raised by current residents or changes in household structure through divorce or other factors, and external movement or relocation of households from the county and beyond.

We have reviewed marketing, U.S. Census, demographic information, sales and rental figures, and permit data. Those data sets are covered in a separate Appendix attached to this report. In addition, we reviewed information on the recently submitted proposals for new multi-family residential in the City of Novi. Those projects will help fill the market need for more multiple-family housing in the City to bring better balance to the market. But The Grove project will add a different type of housing not available elsewhere, that will attract residents looking for a natural environment setting.

In addition to the market data analysis, The Chesapeake Group surveyed over 3,000 households in the Metro Detroit area since the end of the Covid pandemic and surveyed more than 4,000 additional households during the Covid pandemic. A large component of the housing market is the existing households and likelihood of moving. One community's goal should be to meet current residents' future needs. Key survey findings follow that have implications for the marketability of the proposed Grove project.

- ✓ At least 40% of the surveyed households note that they may or are likely to move to a different home in the next five years.
- ✓ While some will relocate outside of Michigan, the preponderance will move to a home within Michigan.
- ✓ The majority will prefer a location within the Metro area.
- ✓ If housing is available, many will prefer to stay within Novi.
- ✓ In addition to the relocation, a small proportion (less than 10%) will internally generate a new household requiring an additional housing unit.
- ✓ The most common factors for the moves are the desire to downsize, diminished desire to maintain housing units, and future flexibility in housing.
- ✓ The overwhelming majority will seek homes smaller or the same size as their current units.
- ✓ One, two, and some three-bedroom units will be sought, with the majority being twobedrooms or less.
- ✓ The two dominant factors in determining where they will choose to live are safety and walkability. (Schools are no longer the major factor for those households even with primary income earners 25 years or younger.)

NATIONAL FACTORS AND TRENDS

Michigan and national trends contribute to the potential long-term marketability of the proposed Grove development as follows.

- ✓ Pre-dating Covid but continuing housing market forces are factors including declining birth, fertility, and marriage rates and changing desires of both younger and aging households, which make up much of the housing market in the country.
- ✓ In addition to the surveys of Metro area households, TCG has performed more than 15,000 household surveys in many communities in the past four years. Fifteen years ago, safety and schools were the primary factors driving where people lived or wanted to live, and today's primary factors are safety and walkability.

- ✓ Pre-Covid, the home office was not yet the majority but was the most rapidly growing office "space" market. The market growth resulted from a growing number of employees working part or full-time from home, technological advances, and home-based business activity.
 - Many companies adopted hybrid or fully remote working arrangements. This shift has significantly impacted lifestyles including where renters choose to live. This trend is expected to continue as the prevalence of hybrid-work arrangements allows renters more flexibility in their living arrangements. According to the US News 2024-2028 Housing Market Predictions report, hybrid-work schedules are here to stay. Novi's geographic setting within Michigan's southeastern sphere of major employers will be an attractive and desired magnet for employees with hybrid-working arrangements who desire rental housing.
- ✓ Costs for all types of construction have risen dramatically over the past couple of years. Return-On-Investment is often impacted, and demand has somewhat diminished to a level that costs cannot be pushed to the buyer.
- ✓ Interest rates have increased substantially the past two years, impacting all borrowing forms, including construction and mortgages. While rates have risen, they remain low by historical standards but not by recent standards. The short-term shock is apparent.
- ✓ Many move after being located in one home for ten or more years having built equity in their current homes. This equity can often best be employed in other investments, resulting in a higher demand to rent now and in the future. Even in the "Baby Boomer" market segments the desire for renting has increased substantially.
- ✓ Few people under 50 have careers with one company. Employment opportunities often result in moves from one geographic area to another, even if moves are lateral with the same entity or company.
- ✓ Outstanding debt, often from lifestyle or education, makes accumulating financial resources difficult. The debt hinders the ability to purchase homes. Generation X, Y, and Z often do not wish to own a home as that diminishes their flexibility. This pattern will prevail in the future for generation A or Alpha as they leave their parents' homes.
- ✓ Many of those in the 30 years and under category extend their stay at home with their parents. They lack the capital needed to purchase homes, do not believe they will live in the same area for more than a few years until a "better" opportunity arises, and can ill-afford down payments to purchase homes.
- ✓ In many non-urban settings, the proportion of detached "single-family" homes not owner occupied is over 40% and rising.
- ✓ The proportion of "Baby Boomer" renters, even in the second-home markets of Arizona, North and South Carolina, and Florida, is growing substantially. "Baby Boomers" now often rent in one location for a few years and then "try" another location.

SHORT AND LONGER-TERM MARKETABILITY OF THE GROVE

Short and long-term successful development of the site will be dependent upon having a diverse form and type of housing. The Grove's four distinct

villages will help meet that need. Two villages are targeted for

There are no comparables, existing or proposed, with rental occupants' potential to own attached or similar units.

condominiums, and two are villages with a range of housing offered for rent or sale. A comprehensive review of existing and proposed housing options indicates the Grove will be successful by providing an integrated blend of dwelling types, designs, and appointments unique to current and future Novi residents. No comparables existing or proposed will have rental occupants' with the potential to own attached or similar units.

The information presented in this evaluation indicates the following.

- 1. Based on historical permitting patterns current sales, and current rent levels, the development's absorption will most likely occur over five or six years.
- 2. There is a growing demand for the walkable project with a range of housing to meet current Novi residents' future needs and attract others beyond the city limits.
- 3. Downsizing opportunities with no more than two-bedrooms are needed to meet current residents' future needs.
- 4. It will meet the needs of all age groups, from current and future households with primary income earners below 25 to active adults 55 and beyond. The Grove will offer various flexible housing options catering to diverse, multi-generational residents, ranging from "Baby Boomers" through generations X, Y, and X, and future generation A (Alpha).
- 5. The Grove's housing mix, walkability, ownership-rental options, and proximity to the region's amenities are consistent with the market's desires. Inclusion of townhomes provides attainable housing even for those who want to purchase. The Grove's longer-term success is extremely probable due to the variety of options.
- 6. The Grove will meet the growing demand for rental units based on the many household factors previously mentioned such as flexibility related to employment, education, education expense debt, other investments achieving greater returns, diminished ability for mortgage down payments, etc.

The rental market growth is well documented by others as well. According to a June 4, 2024, CNN Money article, owning a home is no longer the American dream for all. The article is quoted as stating that nearly two-thirds of Americans, or 64 percent, believe they are less likely to build wealth by buying a home today than they were 20 or 30 years ago, according to a survey sponsored by the non-profit MacArthur Foundation. A majority of respondents said they believe renting can be more appealing than buying and that renters are just as likely to be successful financially as someone who owns a home.

A June 28, 2024, article appearing in Financial Times, an international publication focusing on business and economic affairs, states that younger Americans are gravitating towards rental housing verses homeownership since the prices of homes coupled with the cost of borrowing money far exceed rental market rate prices. Per the article, young people also want the benefits that rental housing often provides. Among

these include no down payment, having greater disposable income for other desired lifestyle preferences, flexibility to relocate if needed or desired, and access to amenities.

- 7. The proposed density of development enhances walkability. The density affords the necessary diversity in housing sizes and structures to meet Novi's residents changing needs and desires for housing, creating proper sizes, payment structures, and proximity to commercial services.
- 8. The Grove's development will allow internal movement of households, freeing existing housing stock for that segment of the population that can afford and desires larger existing detached housing units.
 - According to the USNews 2024-2028 Housing Market Predictions report, hybrid-work schedules are here to stay. Novi's geographic setting within Michigan's southeastern sphere of major employers will be an attractive and desired magnet for employees with hybrid-working arrangements who desire apartment housing.
- 9. The residents of The Grove will likely pump an additional \$17.5 million in sales of Novi businesses annually. The Grove will be essential to the long-term viability of the continued evolution of Twelve Oaks Mall and Fountain Park retail clusters.

The site's current office zoning is inappropriate both now and in the foreseeable future from a market perspective. A metamorphosis in the office market continues throughout this country for many reasons including those that follow:

- ✓ Continued popularity of hybrid work.
- ✓ Tenants' desires for shorter-term leases.
- ✓ Too many dated buildings that once stored paper files and hosted server rooms.
- ✓ Too few single-tenant buildings that meet changing needs.
- ✓ Declines in the amount of square footage needed per worker.
- ✓ Increases in virtual meetings.
- ✓ Increases in medical patient virtual meetings.
- ✓ Digital replacement of book libraries in law offices and other professional offices.
- ✓ Difficulties with landlords getting returns if they put a lot of capital into a reconfiguration and are unable to get terms and a rental rate that reflects the costs of those improvements.

A study done by JLL indicates that office vacancy rates in "suburban" markets is growing nationally as of the reporting on July 12, 2024,

The "bottom line" from a market perspective, the four village Grove concepts as proposed will enhance Novi's ability to meet current and future multi-generational resident needs. The flexibility of the four Villages will also allow Ivanhoe to adjust to the market if conditions change.

Market Conclusion The Grove's four village concept
will enhance Novi's ability to
meet residents' needs.

The new housing types in The Grove will offer a different housing

types compared the projects in the City that have been recently approved. This project hits the "sweet spot" between a single-family home and living in a larger, mid-rise multiple-family development. These homes will appeal to a segment of the market that wishes to live in a natural setting, with a host of amenities and non-motorized connections, near what people are seeking — top municipal services, convenience to commercial, parks, access to freeways and quality schools.

Respectfully submitted

Howard Kohn, President (Howard Kohn electronic)

The Chesapeake Group, Inc. (TCG)

APPENDIX

MARKET RATE SALES AND RENTALS

Current sales and rental rates in and around the Novi area were reviewed. The data was developed using online sources such as Zillow.com, Realtor.com, Trulia.com, and a range of local Real Estate agency office sites. The websites of the apartment developments and rental agencies were also examined for rental units.

The following is a synopsis of current housing market patterns by zip code area and the number of bedrooms. Information is provided where the number of listings was sufficiently large enough to offer meaningful data. The price data reflects listing prices.

Detached Dwelling Units

The following summarizes the findings for Zip Code 48374.

- ✓ The range listing price per-square-foot for all units was between \$241 and \$524.
- ✓ The average listing price ranged from about \$646,000 to \$1.54 million.
- ✓ For two-bedroom units, the average listing price ranged from about \$1.3 million to \$1.7 million.
- ✓ For two-bedroom units, the average per-square-foot listing price was \$524.
- ✓ For three-bedroom units, the average listing price ranged from about \$450,000 to \$1.3 million.
- ✓ The range in listing price per-square-foot for three-bedroom units was \$160 and \$514.
- ✓ The average listing price per-square-foot was \$374 for three-bedroom homes.
- ✓ For four-bedroom units, the average listing price ranged from about \$600,000 to \$860,000.
- ✓ The listing price per-square-foot ranged from \$187 to \$302 for four- or more-bedroom units.
- ✓ For four or more bedroom units, the average listing price per-square-foot was \$241.

Table 6 - Listing Information for Detached Homes in Zip Code 48374 by the Number of Bedrooms*

			Listing Price Range	Average Listing Price
Bedrooms	Listing Price Range	Average Listing Price	Per-square-foot	Per-square-foot
2	\$1,295,000 - \$1,695,000	\$1,545,125	\$484 - \$590	\$524
3	\$449,900 - \$1,279,000	\$645,160	\$160 - \$514	\$374
4	\$596,000 – \$858,000	\$718,090	\$187 - \$302	\$241

^{*}Developed by The Chesapeake Group, Inc., 2024.

The following summarizes the findings for Zip Code 48375.

- ✓ The listing price per-square-foot for all units was between \$131 and \$293.
- ✓ The average listing price ranged from about \$385,000 to \$864,000.
- ✓ For three-bedroom units, the average listing price ranged from about \$385,000 to \$600,000.
- ✓ The range in listing price per-square-foot for three-bedroom units was \$193 and \$208.
- ✓ The average listing price per-square-foot was \$201 for three-bedroom homes.
- ✓ For four-bedroom units, the average listing price ranged from about \$480,000 to \$864,000.
- ✓ The range in listing price per-square-foot was from \$131 to \$293 for four- or more-bedroom units.
- ✓ For four or more bedroom units, the average listing price per-square-foot was \$252.

Table 7 - Listing Information for Detached Homes in Zip Code 48375 by the Number of Bedrooms*

Bedrooms	Listing Price Range	Average Listing Price	Listing Price Range Per-square-foot	Average Listing Price Per-square-foot
3	\$385,000 - \$599,999	\$492,500	\$193 - \$208	\$201
4	\$480 000 – \$863,585	\$634,717	\$131 - \$293	\$252

^{*}Developed by The Chesapeake Group, Inc., 2024.

The following summarizes the findings for Zip Code 48377.

- ✓ For four-bedroom units, the average listing price ranged from about \$350,000 to \$700,000.
- ✓ The listing price per-square-foot ranged from \$141 to \$281 for four- or more-bedroom units.
- ✓ For four or more bedroom units, the average listing price per-square-foot was \$209.

Table 8 - Listing Information for Detached Homes in Zip Code 48377 by the Number of Bedrooms*

			Listing Price Range	Average Listing Price
Bedrooms	Listing Price Range	Average Listing Price	Per-square-foot	Per-square-foot
4	\$350,000 - \$700,000	\$559,650	\$141 - \$281	\$209

^{*}Developed by The Chesapeake Group, Inc., 2024.

Condominiums

Condominiums are a form of ownership but are often viewed differently than detached or attached units. The following is a synopsis of condominiums on the market. Construction years are post-1972, when the Michigan Building Code was first established under the State Construction Code Act.

The following summarizes the findings for the condominiums by zip code.

Zip Code 48374

- ✓ The listing price for three-bedroom units ranged between \$435,000 and \$550,000.
- ✓ The average listing price per-square-foot was \$175 for three-bedroom units.
- ✓ The average monthly condo or homeowner association fee is \$538.

Table 9 - Condominium Information for Zip Code 48374*

Bedrooms	Listing Price Range	Average Listing Price	Listing Price Range Per- square-foot	Average Listing Price Persquare-foot	Monthly Association Fee
3	\$435,000 - \$549,900	\$492,450	\$166 -\$184	\$175	\$538

^{*}Developed by The Chesapeake Group, Inc., 2024.

Zip Code 48375

- ✓ The listing price for two-bedroom units ranged between \$240,000 and \$370,000.
- ✓ The average listing price per-square-foot was \$210 for two-bedroom units.
- ✓ The average monthly condo or homeowner association fee is \$382.

Table 10 – Condominium Information for Zip Code 48375*

		Average Listing	Listing Price Range	Average Price Per-	Monthly Association
Bedrooms	Listing Price Range	Price	Per-square-foot	square-foot	Fee
2	\$239,900 - \$369,000	\$279,900	\$167 - \$244	\$210	\$382

^{*}Developed by The Chesapeake Group, Inc., 2024.

Zip Code 48377

- ✓ The listing price for two-bedroom units ranged between \$196,000 and \$330,000.
- ✓ The average listing price per-square-foot was \$151 for two-bedroom units.
- ✓ The average monthly condo or homeowner association fee is \$495.
- ✓ The listing price for three-bedroom units ranged between \$300,000 and \$349,000.
- ✓ The average listing price per-square-foot was \$210 for three-bedroom units.
- ✓ The average monthly condo or homeowner association fee is \$382.

Table 11 – Condominium Information for Zip Code 48377*

Bedrooms	Listing Price Range	Average Listing Price	Listing Price Range Per- square-foot	Average Listing Price Per-square-foot	Monthly Association Fee
2	\$199,900 - \$330,000	\$265,675	\$116 - \$198	\$151	\$495
3	\$300,000 - \$349,000	\$319,633	\$181 - \$246	\$210	\$382

^{*}Developed by The Chesapeake Group, Inc., 2024.

Rental Units

As with single-family housing, information for rental units was reviewed based on rental rates in and around Novi. Once again, online sources such as Zillow.com, Realtor.com, Trulia.com, Rent.com, and a range of local real estate apartment sites were employed in developing the data. The 6,000 rental unit complexes in Zip Codes 48374, 48375, and 48377 were examined to ascertain market conditions.

The information summaries generated for each zip code area follow. The vacancy rate is extremely low, less than 3.5 percent for established developments.

Zip Code 48374 - Rental Units

The following summarizes the findings for Zip Code 48374.

- ✓ Apartments range in size from 1,065 to 1,189 square feet.
- ✓ Monthly rental rates range from \$1,872 to \$1,950.

Table 12 - Rental Information for Units in Zip Code Area 48374*

Bedrooms	Unit Size Range Square Feet	Average Size Square Feet	Unit Rent Range Monthly	Average Rent Monthly
1	1,065	1,065	\$1,872	\$1,872
2	1,189	1,189	\$1,950	\$1,950

^{*}Developed by The Chesapeake Group, Inc., 2024.

Zip Code 48375 - Rental Units

The following summarizes the findings for Zip Code 48375.

- ✓ One-bedroom apartments range in size from 727 to 980 square feet, with the average being 849 square feet.
- ✓ Monthly rental rates for one-bedroom apartments range from \$1,185 to \$2,500, with the average of \$1,710.
- ✓ Two-bedroom apartments range in size from 900 to 1,700 square feet, with the average being 1,180 square feet.
- ✓ Monthly rental rates for two-bedroom apartments range from \$1,500 to \$3,000, with an average of \$2,000.
- ✓ Three-bedroom apartments range in size from 1,800 to 2,600 square feet, with an average of 2,140 square feet.
- ✓ Monthly rental rates for three-bedroom apartments range from \$2,875 to \$3,600, with an average of \$3,330.

Table 13 - Rental Information for Units in Zip Code Area 48375*

	Unit Size Range	Average Size	Unit Rent Range	Average Rent
Bedrooms	Square Feet	Square Feet	Monthly	Monthly
1	727 – 980	849	\$1,185 - \$2,495	\$1,710
2	903 – 1,698	1,179	\$1,505 - \$2,999	\$1,992
3	1,820 – 2,600	2,136	\$2,875 - \$3,595	\$3,328
4	1,525	1,525	\$2,560	\$2,560

^{*}Developed by The Chesapeake Group, Inc., 2024.

Zip Code 48377 - Rental Units

The following summarizes the findings for Zip Code 48377.

- ✓ One-bedroom apartments range from 650 to 1,140 square feet, averaging 855 square feet.
- ✓ Monthly rental rates for one-bedroom apartments range from \$1,050 to \$2,300, with an average of \$1,650.
- ✓ Two-bedroom apartments range in size from 800 to 1,500 square feet, with the average being 1,000 square feet.
- ✓ Monthly rental rates for two-bedroom apartments range from \$1,200 to \$2,600, with an average of \$1,750.
- ✓ Three-bedroom apartments range in size from 1,560 to 2,000 square feet, with the average being 1,800 square feet.
- ✓ Monthly rental rates for three-bedroom apartments range from \$2,400 to \$3,300, with an average of \$2,900.

Table 14 - Rental Information for Units in Zip Code Area 48377*

Bedrooms	Unit Size Range Square Feet	Average Size Square Feet	Unit Rent Range Monthly	Average Rent Monthly
1	650 – 1,140	855	\$1,050 - \$2,300	\$1,649
2	800 – 1,491	1,007	\$1,196 - \$2,590	\$1,754
3	1,554 – 1,980	1,801	\$2,368 - \$3,325	\$2,911

^{*}Developed by The Chesapeake Group, Inc., 2024.

<u>Combined - Rental Information</u>


The following summarizes the rental information for Novi's one- and two-bedroom units.


Table 15 - Rental Information for the Novi Area*

	Unit Size Range	Average Size	Unit Rent Range	Average Rent
Zip Code	Square Feet	Square Feet	Monthly	Monthly
48374 – 1-bd	1,065	1,065	\$1,872	\$1,872
48375 – 1-bd	727 - 980	849	\$1,185 - \$2,495	\$1,710
48377-1-bd	650 – 1,140	855	\$1,050 - \$2,300	\$1,649
Novi Area	650 – 1,140	923	\$1,050 - \$2,495	\$1,744
Zip Code	Unit Size Range	Average Size	Unit Rent Range	Average Rent

	Square Feet	Square Feet	Monthly	Monthly
48374 – 2-bd	1,189	1,189	\$1,950	\$1,950
48375-2-bd	903 – 1,698	1,179	\$1,505 - \$2,999	\$1,992
48377-2bd	800 – 1,491	1,007	\$1,196 - \$2,590	\$1,754
Novi Area	800 – 1,698	1,125	\$1,196 - \$2,999	\$1,899

*Developed by The Chesapeake Group, Inc., 2024.









		VIA EMAIL: gshapiro@ivanhoecompanies.com
То:	Ivanhoe Companies	
From:	Jacob Swanson, PE, PTOE Abby Dykstra Fleis & VandenBrink Engineering	
Date:	July 1, 2025	
Re:	The Grove Residential Development Novi, Michigan Traffic Generation Comparison	

1 Introduction

This memorandum presents the results of the Trip Generation Analysis (TGA) for "The Grove" residential development in Novi, Michigan. Fleis & VandenBrink (F&V) previously completed a Traffic Impact Study (TIS) for this development, dated October 11, 2024. The site plan has since been revised to change the unit type and reduce the overall number of units. The land use permitted under the existing (OST) zoning, the previous proposed development plan, and the site plan changes are summarized in **Table 1**.

LAND USE	EXISTING (OST) ZONING	PREVIOUS SITE PLAN (2024 TRAFFIC STUDY)	PROPOSED SITE PLAN (JUNE 2025)
SINGLE-FAMILY ATTACHED	0 units	182 units	232 units
MULTI-FAMILY LOW RISE	0 units	256 units	0 units
GENERAL OFFICE BUILDING	492K – 984K SF	0 SF	0 SF
TOTAL	492K – 984K SF	438 UNITS	232 UNITS

Table 1: Lane Use Changes

The purpose of this study is to provide an addendum to the previously completed 2024 TS, in order to include the following evaluations:

- Trip generation comparison between the proposed site plan and the previously evaluated site plan,
- Updating the proposed rezoning trip generation evaluation, with the revised site plan, and
- Re-evaluation of the auxiliary turn lane warrants at the proposed site driveways.

The scope of work for this study was developed based on F&V's understanding of the development program, knowledge of the study area, accepted traffic engineering practice, professional experience, and methodologies published by the Institute of Transportation Engineers (ITE).

2 TRIP GENERATION ANALYSIS

2.1 REZONING TRIP GENERATION ANALYSIS

As part of the development plan for this project, the subject property is proposed to be rezoned from the existing OST to RM-1, with a PRO. Therefore, the trip generation comparison was performed, based on the revised site plan, in order to re-evaluate the maximum potential development that would be permitted under the existing OST zoning classification, as compared to the proposed development under RM-1 with a PRO. The results of the trip generation comparison are summarized in **Table 2**.

Zoning	Land Use	ITE	Amount	Units	Average	AM Pe	ak Hou	ır (vph)	PM Peak Hour (vph)			
	Luna 300	Code	runount	Omio	Daily Traffic	In	Out	Total	ln	Out	Total	
	General Office Building	710	984,600	SF	8,487	1,053	144	1,197	188	920	1,108	
Existing (OST)	General Office Building	710	738,450	SF	6,608	822	112	934	148	725	873	
	General Office Building	710	492,300	SF	4,643	580	79	659	106	517	623	
	Maximum for Existing	Zoning	984,600	SF	8,487	1,053	144	1,197	188	920	1,108	
Proposed (RM-1 w/ PRO)	Single-Family Attached Housing	215	232	DU	1,717	29	86	115	80	55	135	
			Diff	erence	-6,770	-1,024	-58	-1,082	-108	-865	-973	

Table 2: Rezoning Trip Generation Comparison

The results of the rezoning evaluation indicates that the proposed RM-1 with a PRO zoning will generate significantly <u>less</u> trips than the potential trip generation that is currently permitted under the existing OST zoning classifications. Therefore, the proposed development plan is expected to have a lower impact on adjacent roadway network, as compared to the potential use(s) of the project site based on the current zoning.

2.2 SITE TRIP GENERATION

The trip generation analysis from the 2024 TIS was updated to reflect the projected change in trips associated with the revised site plan. The number of weekday peak hour (AM and PM) and daily vehicle trips that would be generated by the currently proposed development plan were forecast based on data published in the ITE *Trip Generation Manual*, 11th Edition. The trip generation summary of previous TIS with the original site plan, as compared to the currently proposed development plan is summarized in **Table 3**.

	Land Use	Amount	Units	Average Daily	AM Pe	eak Hou	ır (vph)	PM Peak Hour (vph)			
		7	J	Traffic (vpd)	ln	Out	Total	In	Out	Total	
	Single-Family Attached Housing	182	DU	1,336	22	67	89	62	43	105	
October 2024 TIS Site Plan	Multi-Family Housing (Low-Rise)	256	DU	1,716	24	78	102	83	48	131	
Olto Fiam	Total Trips	438	DU	3,052	46	145	191	145	91	236	
Updated Site Plan	Single-Family Attached Housing	232	DU	1,717	29	86	115	80	55	135	
		Diff	erence	-1,335	-17	-59	-76	-65	-36	-101	

Table 3: Trip Generation Comparison

The results of the comparison shows that the revised site plan is expected to generate <u>less</u> trips, as compared to the previous site plan. Therefore, the proposed development is expected to have less impact on the adjacent roadway network, than what was evaluated in the 2024 TIS.

3 FUTURE CONDITIONS

3.1 FUTURE TRAFFIC VOLUMES

The site-generated traffic volumes with the revised site plan, shown in **Table 3**, were distributed to the study roadway network based on the site trip distribution developed in the 2024 TIS; the revised trip generation, with the currently proposed site plan are summarized in the attached **Figure 1**. The revised site-generated traffic volumes were then combined with the previously identified background traffic forecasts, determined from the 2024 TIS, in order to establish the future peak hour traffic volumes, with the revised site plan, which are shown in the attached **Figure 2**.



3.2 AUXILIARY TURN LANE EVALUATION

The RCOC & City of Novi auxiliary turn lane warrants were re-evaluated, based on the revised traffic volumes shown in the attached **Figure 2**. The results of the analysis are shown on the attached RCOC & City of Novi warrant charts and summarized in **Table 4**.

Site Driveway Intersection AM Peak Hour **PM Peak Hour** Recommendation 12-Mile Road & Site Drive #1 Right-Turn Taper Right-Turn Taper Right-Turn Taper Meadowbrook Road & Site Drive #2 No Treatment No Treatment No Treatment Meadowbrook Road & Site Drive #3 No Treatment No Treatment No Treatment

Table 4: Auxiliary Right-Turn Lane Analysis Summary

The results of the auxiliary turn lane evaluation indicate that a right-turn taper is warranted on 12-Mile Road, at the proposed Site Drive #1.


4 CONCLUSIONS

- The results of the trip generation comparison shows that the revised site plan is expected to generate <u>less</u> trips, as compared to the previous site plan.
 - Therefore, the proposed development is expected to have less impact on the adjacent roadway network, than what was evaluated in the 2024 TIS
- The RCOC & City of Novi auxiliary turn lane warrants were re-evaluated, based on the revised traffic volumes with the currently proposed site plan.
 - The results indicates that a right-turn deceleration taper is warranted along eastbound 12-Mile Road, at the proposed Site Drive #1.

5 RECOMMENDATIONS

Provide a right-turn deceleration taper along eastbound 12-Mile Road, at the proposed Site Drive #1.

Any questions related to this memorandum, study, analysis, and/or results should be addressed to Fleis & VandenBrink




I hereby certify that this engineering document was prepared by me or under my direct personal supervision and that I am a duly licensed Professional Engineer under the laws of the State of Michigan.

Attachments: Figures 1-2

Proposed Site Plan

Auxiliary Turn Lane Warrants






SITE-GENERATED TRAFFIC **VOLUMES**

THE GROVE TIS ADDENDUM - NOVI, MI

PROPOSED ROADS TRAFFIC VOLUMES (AM/PM)







FUTURE (2030) TRAFFIC VOLUMES

THE GROVE TIS ADDENDUM - NOVI, MI

PROPOSED ROADS TRAFFIC VOLUMES (AM/PM)








7.50-100 DIWC.22140 DIWC.22140 OVEDALL DAVING BLAN dura SD 3.0VEDALL SITE DLAN 8.14.2025 8.23.0

12-Mile Road and Site Drive # 1

FIGURE 6-3

WARRANT FOR RIGHT TURN DECELERATION LANE OR TAPER



RECOMMENDED

2023 ADT = 26,000 vpd (MDOT) 0.50% @ 7yrs= +924 vpd The Grove New Trips = +1058 vpd 2030 ADT= 27,982 vpd (Ord. No. 99-124.11, Pt. XXXIII, 7-26-99)

Figure IX.10

Meadowbrook Road and Site Drive # 2


28,000 26,000 24,000 2 22,000 RIGHT TURN LANE ONLY 20,000 $\forall \land \forall$ 18,000 24 16,000 HOUR 14,000 12,000 VOLUME 10,000 8,000 6,000 4,000 No RT Treatment 2000 **RECOMMENDED** FIGURE IX.10 PEAK HOUR RIGHT TURNS AM = 2 PM = 4CITY OF NOVI 2024 ADT = (204+396+495+346)/2*10= 7205 vpd STANDARD WARRANT 0.50% @ 6yrs= +219 vpd FOR RIGHT TURN The Grove New Trips = +316 vpd DECELERATION LANE 2030 ADT= 7,740 vpd OR TAPER WARRANT FOR RIGHT TURN DECELERATION LANE OR TAPER NO SCALE

DATE: 27-Jan-99

(Ord. No. 99-124.11, Pt. XXXIII, 7-26-99)

Figure IX.10

Meadowbrook Road and Site Drive # 3







VIA EMAIL: gshapiro@ivanhoecompanies.com

To: Ivanhoe Companies

Julie M. Kroll, PE, PTOE

From: Salman Ahmad

Fleis & VandenBrink

Date: July 16, 2024

Revised October 11, 2024

The Grove Residential Development

Re: Novi, Michigan

Traffic Impact Study

1 INTRODUCTION

This memorandum presents the results of the Traffic Impact Study (TIS) for the proposed residential development in Novi, Michigan. The project site is located generally in the southeast quadrant of the 12-Mile Road & Meadowbrook Road intersection, as shown on the attached **Figure 1**. The proposed development includes the construction of a residential development on property that is currently vacant.

The project site is currently zoned OST (Office Service Technology) and is proposed to be rezoned RM-2 (High-Density Multiple-Family), with a Planned Rezoning Overlay (PRO). Site access is proposed via one (1) right-in right-out (RIRO) driveway on 12-Mile Road and two (2) full-access driveways on Meadowbrook Road. 12-Mile Road is under the jurisdiction of Road Commission for Oakland County (RCOC) and Meadowbrook Road is under the jurisdiction of the City of Novi. A TIS is required for this project as part of the site plan and rezoning review process with the City of Novi and for permitting of site access.

This TIS has been completed to evaluate the impact of the proposed development on the adjacent roadway network. The scope of work for this study was developed based on Fleis & VandenBrink's (F&V) knowledge of the study area, understanding of the development program, accepted traffic engineering practices, and information published by Institute of Transportation Engineers (ITE). Additionally, the City of Novi and their traffic engineering consultant (AECOM) provided input regarding the scope of work included herein. The study analyses were completed using Synchro/SimTraffic (Version 11) & HCS2024 traffic analysis software. Sources of data for this study include F&V subconsultant Quality Counts, LLC (QC), RCOC, the City of Novi, the Southeast Michigan Council of Governments (SEMCOG), the Michigan Department of Transportation (MDOT), and ITE.

2 BACKGROUND

2.1 EXISTING ROAD NETWORK

Vehicle transportation for the study area is provided via 12-Mile Road and Meadowbrook Road, with regional transportation provided via M-5. Information on study roadways is attached and summarized in **Table 1** and the lane use and traffic control are shown on the attached **Figure 2**. For the purposes of this study, all minor streets and driveways were assumed to have an operating speed of 25 miles per hour (mph), unless otherwise noted. Additional information for the study roadways is described below.

Meadowbrook Road runs in the north / south directions, adjacent to the west side of the project site.

- North of 12-Mile Road, Meadowbrook Road provides a typical two-lane cross-section, with one (1) lane of travel in each direction.
- South of 12-Mile Road, adjacent to the project site, Meadowbrook Road provides a typical three-lane cross-section, with one (1) lane of travel in each direction and a center two-way left-turn lane (TWLTL).

 Meadowbrook Road widens at the signalized study intersection with 12-Mile Road, in order to provide exclusive right-turn lanes in both the northbound and southbound directions.

<u>12-Mile Road</u> runs in the east / west directions, adjacent to the north side of the project site. The study section of 12-Mile Road provides a median divided, six-lane cross-section, with three (3) lanes of travel in each direction; left-turn movements are accommodated via median U-turn (crossovers) intersections. Additionally, 12-Mile Road widens at the signalized study intersection with Meadowbrook Road, in order to provide exclusive right-turn lanes in both the eastbound and westbound directions.

<u>M-5</u> generally runs in the north / south directions, east of the project site. At the signalized study intersection with 12-Mile Road, the SB M-5 Exit-Ramp provides dual (2) right-turn lanes and dual (2) left-turn lanes.

	,		
Roadway Segment	12-Mile Road	Meadowbrook Road	M-5
National Functional Classification	Other Principal Arterial	Minor Arterial	Other Freeway
Posted Speed Limit	45-mph	35-mph (N. of 12-Mile Rd) 40-mph (S. of 12-Mile Rd)	70-mph
Road Jurisdiction	RCOC	City of Novi	MDOT
Daily Traffic Volumes (MDOT 2023)	26,000 vpd	5,050 vpd (N. of 12-Mile Road)	79,400 vpd
Roadway Improvement Projects	None	Water Main Installation & Street Reconstruction (8-Mile to 14-Mile)	None

Table 1: Roadway Information

2.2 EXISTING TRAFFIC VOLUMES

F&V subconsultant QC, collected existing Turning Movement Count (TMC) data on Tuesday, June 11, 2024, during the AM (7:00 AM to 9:00 AM) and PM (4:00 PM to 6:00 PM) peak periods at the study intersections¹:

- 12-Mile Road & Meadowbrook Road
- EB-to-WB X/O, East of Meadowbrook Road
- WB-to-EB X/O, West of Meadowbrook Road
- WB-to-EB X/O, West of Summit Drive
- WB-to-EB X/O, East of Meadowbrook Road

At the time the data collection was performed, there was ongoing detours due to construction on M-5/I-696 Meadowbrook Road. Therefore, the available historical traffic counts from RCOC's Sydney Coordinated Adaptive Traffic System (SCATS) database were obtained for Tuesday, January 11, 2022, prior to the detours and construction. The SCAT counts were obtained at the following intersections for use in the study:

• 12-Mile Road & Meadowbrook Road

12-Mile Road & SB M-5 Exit-Ramp

The SCATS peak hour traffic volumes were projected at a 0.5% annual growth rate at these intersections to calculate the expected 2024 traffic volumes (without detours) and were utilized in the study. The through volumes on 12-Mile Road were balanced upwards through the roadway network...During collection of the turning movement counts, Peak Hour Factors (PHFs), pedestrian and bicycle volumes, and commercial truck percentages were recorded and used in the traffic analysis. The weekday AM and PM peak hours for the adjacent roadway network were observed to generally occur between 8:00 AM to 9:00 AM and 4:00 PM to 5:00 PM, respectively. F&V collected an inventory of existing lane use and traffic controls, as shown on the attached **Figure 2**. Additionally, F&V obtained the current signal timing permits from RCOC for the signalized study intersections within the study roadway network.

The existing 2024 peak hour traffic volumes used in the analysis are shown on the attached **Figure 3**. These volumes shown on the exhibit are the balance traffic volumes used in the analysis, and therefore will not match

¹ The adjacent intersections of EB 12-Mile Road & WB-to-EB X/O, East of 12 Oaks Mall Road and EB 12-Mile Road & SB M-5 On-Ramp were included in the Synchro model to consider the impact of vehicle progression/platooning and for the distribution of traffic to/from the proposed development. Traffic volume assumptions were made based on the collected traffic volumes, available historical traffic volume data, and consideration of the nearby land uses utilizing these intersections.



the raw data collection collected or obtained from SCATS. All applicable background data used in this analysis is attached.

3 Existing Conditions (2024)

Existing peak hour vehicle delays and Levels of Service (LOS) were calculated at the study intersections using Synchro/SimTraffic (Version 11) traffic analysis software. This analysis was based on the existing lane use and traffic control shown on the attached **Figure 2**, the existing peak hour traffic volumes shown on the attached **Figure 3**, and the methodologies presented in the *Highway Capacity Manual*, 6th Edition (HCM6). Descriptions of LOS "A" through "F" as defined in the HCM6, are attached. Typically, LOS D is considered acceptable, with LOS A representing minimal delay and LOS F indicating failing conditions.

<u>Note:</u> The clustered signal operations are not supported by the HCM6 methodology; therefore, HCM 2000 was determined to be more appropriate for the evaluation of the signalized study intersections.

The signalized study intersections also operate on RCOC's SCATS; therefore, the signal timings were optimized for each scenario studied, in order to reflect the true signal operations and real time optimizations made to accommodate the traffic volumes observed by the approach lane detectors. The results of the existing conditions analysis are attached and shown in **Table 2**.

Table 2: Existing Intersection Operations

				Existing	Existing Conditions (2024)				
	Intersection	Control	Approach	AM Pe	eak	PM P	eak		
			Т	Delay (s/veh)	LOS	Delay (s/veh)	LOS		
10	EB 12-Mile Road &	Stop	EB		Fre	ee			
10	ω WB-to-EB X/O, West of Meadowbrook Road	(Minor)	SBL	13.1	В	12.3	В		
			EBT	12.9	В	11.0	В		
			EBR	8.5	Α	5.8	Α		
			WBT	20.6	С	21.7	С		
	12-Mile Road		WBR	36.1	D	30.3	С		
20	&	Signalized	NBT	26.4	С	32.8	С		
	Meadowbrook Road		NBR	26.6	С	38.9	D		
			SBT	27.6	С	33.8	С		
			SBR	26.5	С	31.0	С		
			Overall	21.9	С	22.8	С		
30	EB 12-Mile Road &	Stop	EB		Fre	ee			
30	WB-to-EB X/O, East of Meadowbrook Road	(Minor)	SBL	0.0*	А	10.1	В		
40	WB 12-Mile Road &	Stop	WB	Free					
40	EB-to-WB X/O, East of Meadowbrook Road	(Minor)	NBL	11.5	В	26.5	D		
EO	EB 12-Mile Road	Stop	EB		Fre	ee			
50	& WB-to-EB X/O, West of Summit Drive	(Minor)	SBL	10.3	В	12.6	В		
			EB	18.0	В	18.8	В		
	12-Mile Road		WB	16.7	В	25.1	С		
60	&	Signalized	SBL	25.4	С	24.5	С		
	SB M-5 Exit-Ramp		SBR	24.8	С	31.9	С		
			Overall	19.9	В	26.9	С		

^{*} Indicates no vehicle volume present.

The results of the existing conditions analysis indicates that all approaches and movements at the study intersections are currently operating acceptably, at LOS D or better, during both the AM and PM peak hours. Review of SimTraffic network simulations also indicates acceptable operations throughout the study roadway



network during both peak periods. Occasional periods of vehicle queues were observed at the signalized study intersections during the peak periods; however, these queues were observed to be serviced within each cycle lengths, leaving no residual vehicle queueing.

4 BACKGROUND CONDITIONS (2030)

4.1 BACKGROUND GROWTH

Historical population and employment community profile data was obtained for the City of Novi from the Southeast Michigan Council of Government (SEMCOG), in order to calculate a background growth rate to project the existing 2024 traffic volumes to the site buildout year of 2030. Population and employment projections from 2020 to 2050 were reviewed and indicate average annual growth rates of 0.37% and 0.39%, respectively. Therefore, a conservative annual background growth rate of **0.5%** per year was utilized for this study, in order to project the existing 2024 peak hour traffic volumes to buildout year of 2030.

In addition to the background traffic growth, it is important to account for traffic that will be generated by approved developments within the vicinity of the study area that are currently under construction or will be within the buildout year. At the time of this study, the following developments were identified by the City of Novi and were included within the study as background traffic:

Griffin Novi I

Griffin Novi II

Elm Creek

Information regarding the proposed background developments and trip generation included within the attachments for reference. The vehicular trips generated by the proposed background development were assigned to the study roadway network based on the existing peak hour traffic patterns in the adjacent roadway network and the methodologies published by ITE. After applying the background growth rate to the existing 2024 traffic volumes shown on the attached **Figure 3**, the site-generated traffic volumes from the background development were added to the study roadway network, in order to determine the background peak hour traffic volumes *without the proposed development*, as shown on the attached **Figure 4**.

4.2 BACKGROUND CONDITIONS ANALYSIS

Background peak hour vehicle delays and LOS *without the proposed development* were calculated at the study intersections based on the existing lane use and traffic control shown on the attached **Figure 2**, the background peak hour traffic volumes shown on the attached **Figure 4**, and the methodologies presented in the HCM. Results of the background conditions analysis are attached and summarized in **Table 3**.

Table 3: Background Intersection Operations

				Exis		Conditio 24)	ns	Backg		l Condit 30)	ions		Differ	ence	
	Intersection	Control	Approach	AM P	eak	PM P	eak	AM P	eak	PM P		AM P		PM P	eak
				Delay (s/veh)	LOS	Delay (s/veh)	LOS	Delay (s/veh)	LOS	Delay (s/veh)	LOS	Delay (s/veh)	LOS	Delay (s/veh)	LOS
10	EB 12-Mile Road & WB-to-EB X/O,	Stop	EB		Fr	ee			Fr	ee			Fr	ee	
10	W. of Meadowbrook	(Minor)	SBL	13.1	В	12.3	В	13.8	В	13.3	В	0.7	-	1.0	-
			EBT	12.9	В	11.0	В	13.5	В	11.1	В	0.6	-	0.1	-
			EBR	8.5	Α	5.8	Α	9.0	Α	5.7	Α	0.5	1	-0.1	-
			WBT	20.6	С	21.7	С	21.3	С	23.4	С	0.7	1	1.7	-
	12-Mile Road		WBR	36.1	D	30.3	С	35.6	D	24.1	С	-0.5	-	-6.2	-
20		Signal	NBT	26.4	С	32.8	С	25.8	С	32.9	С	-0.6	-	0.1	-
	Meadowbrook Road		NBR	26.6	С	38.9	D	26.3	С	43.0	D	-0.3	-	4.1	-
			SBT	27.6	С	33.8	С	27.0	С	34.1	С	-0.6	-	0.3	-
			SBR	26.5	С	31.0	С	26.1	С	31.0	С	-0.4	-	0.0	-
			Overall	21.9	С	22.8	С	22.2	С	23.1	С	0.3	-	0.3	-
30	EB 12-Mile Road & WB-to-EB X/O,	Stop	EB		Fr	ee			Fr	ee			Fr	ee	
30	E. of Meadowbrook	(Minor)	SBL	0.0*	Α	10.1	В	0.0*	Α	10.3	В	0.0*	-	0.2	-



	Intersection Control		Exis	ting C (20	onditio 24)	ns	Backg	round (20	l Condit 30)	ions	Difference				
	Intersection	Control	Approach	AM P	eak	PM P	eak	AM P	eak	PM P	eak	AM P	eak	PM P	eak
				Delay (s/veh)	LOS	Delay (s/veh)	LOS	Delay (s/veh)	LOS	Delay (s/veh)	LOS	Delay (s/veh)	LOS	Delay (s/veh)	LOS
10	WB 12-Mile Road	Stop	WB	Free		Free			Free						
40	& EB-to-WB X/O, E. of Meadowbrook	(Minor)	NBL	11.5	В	26.5	D	11.9	В	32.1	D	0.4	-	5.6	-
50	EB 12-Mile Road & WB-to-EB X/O,	Stop	EB		Fr	ee			Fr	ee			Fr	ee	
50	W. of Summit Dr.	(Minor)	SBL	10.3	В	12.6	В	10.5	В	12.9	В	0.2	-	0.3	-
			EB	18.0	В	18.8	В	18.3	В	19.7	В	0.3	-	0.9	-
	12-Mile Road		WB	16.7	В	25.1	С	16.9	В	26.1	С	0.2	-	1.0	-
60		Signal	SBL	25.4	С	24.5	С	25.4	С	24.5	С	0.0	-	0.0	-
	SB M-5 Exit-Ramp		SBR	24.8	С	31.9	С	24.8	С	33.3	С	0.0	-	1.4	-
			Overall	19.9	В	26.9	С	20.0	В	27.9	С	0.1	-	1.0	-

^{*} Indicates no vehicle volume present. Decreased delays are the result of SCATS optimizations, improved progression and/or HCM methodologies

The results of the background conditions analysis indicates that all approaches and movements at the study intersections are expected to continue operating acceptably, at LOS D or better during both peak periods, in a manner similar to the existing conditions analysis, with minor increases in delays. Review of SimTraffic network simulations also indicates acceptable operations during both peak periods, similar to those observations made during existing conditions.

5 Trip Generation

5.1 SITE TRIP GENERATION

The number of weekday peak hour (AM and PM) and daily vehicle trips that would be generated by the proposed development were forecasted based on data published in the ITE *Trip Generation Manual*, 11th *Edition*. The proposed development includes the construction residential units. Site trip generation forecast utilized in this analysis was reviewed and approved by the City of Novi's traffic engineering consultant (AECOM) prior to use in this TIS; the trip generation is summarized in **Table 4**.

PM Peak Hour (vph) AM Peak Hour (vph) ITE Average Daily Land Use Amount Units Code Traffic (vpd) Total In Out **Total** In Out 89 Single-Family Attached Housing 215 182 DU 1,336 22 67 62 43 105 Multi-Family Housing (Low-Rise) 220 256 DU 1,716 24 78 102 83 48 131 3,052 46 145 191 145 91 236 Total

Table 4: Site Trip Generation

5.2 REZONING TRIP GENERATION ANALYSIS

As part of the development plan for this project, the subject property is proposed to be rezoned from the existing OST to RM-2, with a PRO. A trip generation comparison was performed to evaluate the maximum potential development that would be permitted under the existing OST zoning classification, as compared to the proposed development under RM-2 with a PRO. The PRO zoning option permits only that land use which is proposed and approved; therefore, the uses that are permitted under the existing OST zoning were reviewed and matched to representative land uses within the ITE Trip Generation Manual.

Existing Zoning OST (Office Service Technology)

The City of Novi Ordinance definition of uses permitted under the OST zoning includes: professional office buildings, data processing and computer centers, laboratories, hotels and business motels, colleges, universities, and other such secondary institutions, etc.



Review of the ITE land use description indicates that the General Office Building (LUC 710) use generates the highest trips and best matches the uses defined by the City of Novi Ordinance and permitted by right under the existing OST zoning. As part of the proposed project, a parallel development plan was developed for what could be permitted under the existing OST zoning, which consist of office uses; the parallel plan is attached for reference. Additional options for the office building also included various sizes for this development plan, with the maximum development ranging from approximately 500kSF to approximately 1MSF.

Proposed Zoning RM-2 with PRO

The City of Novi Ordinance defines a PRO as a site-specific use authorization to accomplish the objectives of the zoning ordinance through a land development project review process. Therefore, the proposed development plan that will be approved within the PRO Agreement would be the only development that would be permitted within the proposed zoning.

Therefore, an analysis was performed in order to compare the site trip generation potential currently permitted by right under the existing OST zoning and the trip generation associated with the proposed development plan. The number of weekday peak hour (AM and PM) and daily vehicle trips that would be generated were calculated based on the rates and equations published by ITE in the *Trip Generation Manual*, 11th Edition. The results of the trip generation comparison are summarized in **Table 5**.

_	3										
Zoning	Land Use	ITE	Amount	Units	Average Daily	AM F	Hour	PM	Hour		
Zoning	Lanu USE	Code	Amount	UIIIIS	Traffic (vpd)	ln	Out	Total	ln	Out	Total
Existing (OST)	General Office Building	710	984,600	SF	8,487	1,053	144	1,197	188	920	1,108
Existing (OST)	General Office Building	710	738,450	SF	6,608	822	112	934	148	725	873
Existing (OST)	General Office Building	710	492,300	SF	4,643	580	79	659	106	517	623
	Maximum for Existing	Zoning	984,600	SF	8,487	1,053	144	1,197	188	920	1,108
Decreed	Single-Family Attached Housing	215	182	DU	1,336	22	67	89	62	43	105
Proposed (RM-2 w/ PRO)	Multi-Family Housing (Low-Rise)	220	256	DU	1,716	24	78	102	83	48	131
(IXIVI-2 W/ FIXO)		Total fo	r Proposed	Zoning	3,052	46	145	191	145	91	236
		ference	-5,435	-1,007	1	-1,006	-43	-829	-872		

Table 5: Rezoning Trip Generation Comparison

The results of the trip generation comparison indicates that the proposed RM-2 with a PRO zoning will generate less trips than the potential trip generation that is currently permitted under the existing OST zoning classifications. Therefore, the proposed development plan is expected to have a lower impact on adjacent roadway network, as compared to the potential use(s) of the project site, based on the current zoning.

6 SITE TRIP DISTRIBUTION

The vehicular trips that would be generated by the proposed development were assigned to the study roadway network based on the proposed site access plan, the existing peak hour traffic patterns in the adjacent roadway network, and the methodologies published by ITE. The ITE trip distribution methodology assumes that new trips will enter the network and access the development, then leave the development and return to their direction of origin. The site trip distributions used in this analysis were reviewed by the City of Novi's traffic engineering consultant (AECOM) prior to use in this TIS and are summarized in **Table 6**.

To/From Via AM PM North Meadowbrook Road 5% 4% South Meadowbrook Road 16% 9% East 12-Mile Road 23% 29% 22% West 12-Mile Road 16% 8% 13% North M-5 South M-5 26% 29% Total 100% 100%

Table 6: Site Trip Distribution



The site-generated vehicular traffic volumes shown in **Table 4** were distributed to the study roadway network according to the distribution shown in **Table 6**. The site-generated trips shown on the attached **Figure 5** were added to the background peak hour traffic volumes shown on the attached **Figure 4**, in order to calculate the future peak hour traffic volumes, with the addition of the proposed development. Future peak hour traffic volumes are shown on the attached **Figure 6**.

7 FUTURE CONDITIONS (2030 BUILDOUT)

7.1 FUTURE CONDITIONS ANALYSIS

Future peak hour vehicle delays and LOS with the proposed development were calculated based on the proposed lane use and traffic controls shown on the attached Figure 2, the future peak hour traffic volumes shown on the attached Figure 6, and the methodologies presented in the HCM. The results of the future conditions analysis are attached and summarized in Table 7.

The results of the future conditions analysis indicates that all study intersection approaches and movements are expected to continue operating acceptably, at LOS D or better during both peak periods, in a manner similar to the background conditions analysis. Review of SimTraffic network simulations also indicates acceptable operations throughout the study roadway during both peak periods. The majority of vehicle queues at the signalized study intersections were observed to be serviced within each cycle length, leaving minimal residual vehicle queueing. Additionally, review of SimTraffic microsimulations indicates that vehicles at the stop-controlled proposed site driveways were able to find adequate gaps within the through traffic, without experiencing significant delays or excessive vehicle queueing during both peak hours.

Table 7: Future Intersection Operations

				Backg	round (20	l Conditi 30)	ions	Fut	ture Co (20	ondition 30)	S		Differ	ence	
	Intersection	Control	Approach	AM P	eak	PM P	eak	AM P	eak	PM P	eak	AM F	Peak	PM F	Peak
				Delay (s/veh)	LOS	Delay (s/veh)	LOS	Delay (s/veh)	LOS	Delay (s/veh)	LOS	Delay (s/veh)	LOS	Delay (s/veh)	
10	EB 12-Mile Road	Stop	EB		Fr	ee			Fr	ee			Fre	ee	
10	& WB-to-EB X/O, W. of Meadowbrook	(Minor)	SBL	13.8	В	13.3	В	14.0	В	13.7	В	0.2	-	0.4	-
			EBT	13.5	В	11.1	В	14.6	В	11.7	В	1.1	-	0.6	-
			EBR	9.0	Α	5.7	Α	9.9	Α	6.1	Α	0.9	-	0.4	-
			WBT	21.3	С	23.4	С	21.8	С	24.9	С	0.5	-	1.5	-
	12-Mile Road		WBR	35.6	D	24.1	С	33.8	С	20.7	С	-1.8	D→C	-3.4	-
20	&	Signal	NBT	25.8	С	32.9	С	24.6	С	32.3	С	-1.2	-	-0.6	-
	Meadowbrook Road		NBR	26.3	С	43.0	D	25.2	С	44.1	D	-1.1	-	1.1	-
			SBT	27.0	С	34.1	С	25.7	С	33.4	С	-1.3	-	-0.7	-
			SBR	26.1	С	31.0	С	24.9	С	30.3	С	-1.2	-	-0.7	-
			Overall	22.2	С	23.1	С	22.2	С	23.7	С	0.0	-	0.6	-
20	EB 12-Mile Road	Stop	EB		Fr	ee			Fr	ee			Fre	ee	
30	& WB-to-EB X/O, E. of Meadowbrook	(Minor)	SBL	0.0*	Α	10.3	В	0.0*	Α	10.3	В	0.0*	-	0.0	-
	WB 12-Mile Road	Stop	WB		Fr	ee			Fr	ee			Fre	ee	
40	& EB-to-WB X/O, E. of Meadowbrook	(Minor)	NBL	11.9	В	32.1	D	12.3	В	34.3	D	0.4	-	2.2	-
50	EB 12-Mile Road & WB-to-EB X/O,	Stop	EB		Fr	ee			Fr	ee			Fre	ee	
30	W. of Summit Drive	(Minor)	SBL	10.5	В	12.9	В	10.8	В	15.0	С	0.3	-	2.1	в→с
			EB	18.3	В	19.7	В	18.0	В	19.5	В	-0.3	-	-0.2	-
	12-Mile Road		WB	16.9	В	26.1	С	15.9	В	26.4	С	-1.0	-	0.3	-
60		Signal	SBR	25.4	С	24.5	С	26.1	С	35.3	D	0.7	-	10.8	C→D
	SB M-5 Exit-Ramp		SBL	24.8	С	33.3	С	26.8	С	25.2	С	2.0	-	-8.1	-
			Overall	20.0	В	27.9	С	19.8	В	28.6	С	-0.2	-	0.7	-



				Background Condition (2030)			ions	Future Conditions (2030)				Difference			
	Intersection	Control	Approach	AM P	eak	PM P	eak	AM P	eak	PM P	eak	AM P		PM P	
				Delay (s/veh)	LOS	Delay (s/veh)		Delay (s/veh)	LOS	Delay (s/veh)	LOS	Delay (s/veh)	LOS	Delay (s/veh)	LOS
ſ.	EB 12-Mile Road	Stop	EB	NI/A			Free				N/A				
ľ	& Site Drive #1	(Minor)	NB	N/A –		13.8	В	20.8	С						
	Meadowbrook Road		EB	15.7	С	21.8	С	17.1	С	25.7	D	1.4	-	3.9	C→D
,	8,	Stop	WB	N/A			12.0	В	15.2	С		N/	A		
ľ	Elm Creek Drive	(Minor)	NBL	8.3	А	8.2	А	8.4	А	8.2	Α	0.1	-	0.0	-
	/ Site Drive #2		SBL			7.7	А	8.7	Α		N/	A			
Γ	Meadowbrook Road	Char	WB			11.0 B 12.9 B					В		N/	A	
9	80	Stop (Minor)	NB		N	/A			Fr	ee					
1	Site Drive #3	(IVIII IOI)	SBL					7.7	А	8.7	Α				

^{*} Indicates no vehicle volume present. Decreased delays are the result of SCATS optimizations, improved progression, and/or HCM methodologies.

7.2 WEAVING ANALYSIS

A weaving analysis was conducted using HCS2024 software for the crossovers adjacent to the east and west of Site Drive # 1 on EB 12-Mile Road. This analysis was performed to ensure that there is adequate distance between the cross-overs to accommodate the projected weaving to/from the site access driveway on 12-Mile Road. The results of the analysis are attached and summarized in **Table 8**.

Future Conditions AM Peak PM Peak **EB 12-Mile Road Segment** Density LOS Density (pc/mi/ln) LOS (pc/mi/ln) WB-to-EB X/O, West of Summit Drive to Site Drive # 1 7.1 Α 12.9 В 7.2 Site Drive # 1 to EB-to-WB X/O, West of M-5 Α 12.0

Table 8: Future Conditions Weaving Analysis

• The results of the weaving analysis indicates that there is adequate distance between the proposed Site Drive #1 and the existing crossover locations to accommodate the projected traffic volumes

8 ACCESS MANAGEMENT

8.1 AUXILIARY TURN LANE EVALUATION

Site access is proposed via one (1) right-in right-out (RIRO) driveway on 12-Mile Road and two (2) full-access driveways on Meadowbrook Road. 12-Mile Road is under the jurisdiction of RCOC and Meadowbrook Road is under the jurisdiction of the City of Novi. The RCOC & City of Novi auxiliary turn lane charts were utilized, in order to determine the need for auxiliary turn lanes at the proposed site driveways. There is currently an existing center two-way left-turn lane (TWLTL) on Meadowbrook Road, adjacent to the project site, and 12-Mile Road is median divided, with left-turns accommodated via median U-turns (crossovers) intersections. Therefore, only the right-turn treatment criteria was evaluated at the proposed site driveways. This analysis was based on the future peak hour traffic volumes shown on the attached Figure 6. The results of the analysis are shown on the attached RCOC & City of Novi warrant charts and summarized in Table 9.

• The results of the auxiliary turn lane evaluation indicates that a right-turn deceleration lane is recommended on 12-Mile Road at the proposed Site Drive #1.



		,	,
Site Driveway Intersection	AM Peak Hour	PM Peak Hour	Recommendation
12-Mile Road & Site Drive #1	Right-Turn Taper	Right-Turn Lane	Right-Turn Lane
Meadowbrook Road & Site Drive #2	No Treatment	No Treatment	No Treatment
Meadowbrook Road & Site Drive #3	No Treatment	No Treatment	No Treatment

Table 9: Auxiliary Right-Turn Lane Analysis Summary

8.2 Intersection Sight Distance

The horizontal sight distance was evaluated at the proposed site driveway along 12-Mile Road, in order to determine if there will be adequate clear vision triangles at the proposed location. The study section of 12-Mile Road is median divided, and the proposed site driveway provides right-in right-out (RIRO) only access. Therefore, the RCOC criteria was utilized to evaluate sight distance at the proposed site driveway for a vehicle making a right-turn from a complete stop. The RCOC intersection sight distance requirements require 500-feet of clearance for a 45-mph roadway. For all sight distance calculations, the height of the driver's eye is considered to be 3.5 feet above the road surface and the height of the object is considered to be 3.5 feet above the road surface.

The results of the sight distance analysis indicate that a driver waiting to egress the proposed site driveway onto 12-Mile Road will not experience any visual obstruction, provided the sight distance triangle area shown in the attached site plan is free of vegetation and a clear line of sight is provided.

9 CONCLUSIONS

The conclusions of this TIS are as follows:

1. Existing Conditions (2024)

 The results of the existing conditions analysis indicates that all approaches and movements at the study intersections are currently operating acceptably, at LOS D or better during both the AM and PM peak hours. Additionally review of SimTraffic network simulations indicates acceptable operations throughout the study roadway network during both peak periods.

2. Background Conditions (2030)

- A conservative annual background growth rate of <u>0.5%</u> per year was utilized to project the existing 2024 traffic volumes to the buildout year of 2030. In addition to background traffic growth, the following background developments were identified and were included within the background traffic volumes.
 - o Griffin Novi I o Griffin Novi II o Elm Creek
- The results of the background conditions analysis indicates that the study intersections are expected to continue operating acceptably, at LOS D or better during both peak periods, in a manner similar to the existing conditions analysis. Review of SimTraffic microsimulations also indicates acceptable operations and minimal vehicle queueing during both peak periods.

3. Future Conditions (2030)

- The results of the future conditions analysis indicates that all study intersection approaches and movements are expected to continue operating acceptably, at LOS D or better during both peak periods, in a manner similar to the background conditions analysis. Review of SimTraffic microsimulations also indicates acceptable operations throughout the study roadway network; additionally, vehicles at the stop-controlled proposed site driveways were able to find adequate gaps within the through traffic, without experiencing significant delays or excessive vehicle queueing.
- The results of the weaving analysis indicates that there is adequate distance between the proposed Site Drive #1 and the existing crossover locations to accommodate the projected traffic volumes.



4. Access Management

- The need for auxiliary turn lane at the proposed site driveways on 12-Mile Road and Meadowbrook Road were evaluated and indicate that right-turn lane is recommended on 12-Mile Road at the proposed Site Drive #1.
- The results of the sight distance analysis indicate that a driver waiting to egress the proposed site driveway onto 12-Mile Road will not experience any visual obstruction, provided the sight distance triangle area remain free of vegetation and a clear line of sight is provided.

10 RECOMMENDATIONS

The recommendations of this TIS are as follows:

Provide a right-turn deceleration lane along eastbound 12-Mile Road at the proposed Site Drive # 1.

Any questions related to this memorandum, study, analysis, and results should be addressed to Fleis &



I hereby certify that this engineering document was prepared by me or under my direct personal supervision and that I am a duly licensed Professional Engineer under the laws of the State of Michigan.

Julie M. Kuell 2024.10.11 16:20:02-04'00' Julie M. Kroll

Attachments: Figures 1 - 6

Proposed Site Plan Parallel Development Plan Traffic Volume Data Signal Timing Permits

SEMCOG Data

Synchro / SimTraffic Results

HCS2024 Results

Auxiliary Turn Lane Warrants









FIGURE 1 SITE LOCATION MAP


THE GROVE TIS - NOVI, MI








NORTH SCALE: NOT TO SCALE























Site Code : 16651601 Start Date : 6/11/2024

Page No : 1


																					
			2 Mile					2 Mile					dowbro					dowbro			
		E	astbou	ınd			W	<u>estbou</u>	und			N	<u>orthbo</u>	und			Sc	<u>outhbo</u>	<u>und</u>		
Start Time	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Int. Total
07:00 AM	0	230	54	0	284	0	346	0	0	346	0	0	34	0	34	0	0	1	0	1	665
07:15 AM	0	261	63	0	324	0	405	1	0	406	0	1	47	0	48	0	0	0	0	0	778
07:30 AM	0	328	83	0	411	0	437	2	0	439	0	0	60	0	60	0	1	6	0	7	917
07:45 AM	0	356	133	0	489	0	547	2	0	549	0	2	80	0	82	0	2	3	0	5	1125
Total	0	1175	333	0	1508	0	1735	5	0	1740	0	3	221	0	224	0	3	10	0	13	3485
08:00 AM	0	307	109	0	416	0	440	5	0	445	0	0	82	0	82	0	1	5	0	6	949
08:15 AM	0	327	96	0	423	0	429	3	0	432	0	2	71	0	73	0	5	3	0	8	936
08:30 AM	0	304	91	1	396	0	468	3	0	471	0	1	82	0	83	0	1	8	0	9	959
08:45 AM	0	334	131	0	465	0	527	4	0	531	0	1	103	0	104	0	3	3	0	6	1106
Total	0	1272	427	1	1700	0	1864	15	0	1879	0	4	338	0	342	0	10	19	0	29	3950
					· ·										·						
Grand Total	0	2447	760	1	3208	0	3599	20	0	3619	0	7	559	0	566	0	13	29	0	42	7435
Apprch %	0	76.3	23.7	0		0	99.4	0.6	0		0	1.2	98.8	0		0	31	69	0		
 Total %	0	32.9	10.2	0	43.1	0	48.4	0.3	0	48.7	0	0.1	7.5	0	7.6	0	0.2	0.4	0	0.6	
Light Vehicles	0	2306	751	1	3058	0	3470	19	0	3489	0	7	519	0	526	0	13	28	0	41	7114
% Light Vehicles	0	94.2	98.8	100	95.3	0	96.4	95	0	96.4	0	100	92.8	0	92.9	0	100	96.6	0	97.6	95.7
Heavy Vehicles	0	141	9	0	150	0	129	1	0	130	0	0	40	0	40	0	0	1	0	1	321
% Heavy Vehicles	0	5.8	1.2	0	4.7	0	3.6	5	0	3.6	0	0	7.2	0	7.1	0	0	3.4	0	2.4	4.3





Site Code : 16651601 Start Date : 6/11/2024

			2 Mile astbou					2 Mile estbou					dowbro	ook Rd und				dowbro	ook Rd und		
Start Time	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Int. Total
Peak Hour A	nalysis	s From	07:00	AM to	08:45 /	4M - P	eak 1	of 1													
Peak Hour fo	r Entir	e Inter	section	n Begir	ns at 07	:45 AN	1														
07:45 AM	0	356	133	0	489	0	547	2	0	549	0	2	80	0	82	0	2	3	0	5	1125
08:00 AM	0	307	109	0	416	0	440	5	0	445	0	0	82	0	82	0	1	5	0	6	949
08:15 AM	0	327	96	0	423	0	429	3	0	432	0	2	71	0	73	0	5	3	0	8	936
08:30 AM	0	304	91	1	396	0	468	3	0	471	0	1	82	0	83	0	1_	8	0	9	959
Total Volume	0	1294	429	1	1724	0	1884	13	0	1897	0	5	315	0	320	0	9	19	0	28	3969
% App. Total	0	75.1	24.9	0.1		0	99.3	0.7	0		0	1.6	98.4	0		0	32.1	67.9	0		
PHF	.000	.909	.806	.250	.881	.000	.861	.650	.000	.864	.000	.625	.960	.000	.964	.000	.450	.594	.000	.778	.882
Light Vehicles	0	1223	424	1	1648	0	1822	12	0	1834	0	5	299	0	304	0	9	18	0	27	3813
% Light Vehicles	0	94.5	98.8	100	95.6	0	96.7	92.3	0	96.7	0	100	94.9	0	95.0	0	100	94.7	0	96.4	96.1
Heavy Vehicles	0	71	5	0	76	0	62	1	0	63	0	0	16	0	16	0	0	1	0	1	156
% Heavy Vehicles	0	5.5	1.2	0	4.4	0	3.3	7.7	0	3.3	0	0	5.1	0	5.0	0	0	5.3	0	3.6	3.9






Site Code : 16651601 Start Date : 6/11/2024

Page No : 1


		1:	2 Mile	Rd			1.	2 Mile	Rd			Mead	dowbro	ook Rd			Mead	dowbro	ok Rd		
		E	astbou	ınd			W	estbol	und			N	orthbo	und			Sc	uthbo	und		
Start Time	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Int. Total
07:00 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:15 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:30 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:45 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
																					i
08:00 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
08:15 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1
08:30 AM	0	0	0	0	0	0	0	0	1	1	0	0	0	0	0	0	0	0	0	0	1
08:45 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total	0	0	0	0	0	0	0	0	1	1	0	0	0	0	0	0	0	0	1	1	2
																					1
Grand Total	0	0	0	0	0	0	0	0	1	1	0	0	0	0	0	0	0	0	1	1	2
Apprch %	0	0	0	0		0	0	0	100		0	0	0	0		0	0	0	100		
Total %	0	0	0	0	0	0	0	0	50	50	0	0	0	0	0	0	0	0	50	50	





Site Code : 16651601 Start Date : 6/11/2024

		1:	2 Mile	Rd			1	2 Mile	Rd			Mead	dowbro	ook Rd			Mead	dowbro	ook Rd		
		Е	astbou	ınd			W	estbo	und			No	orthbo	und			Sc	outhbo	und		
Start Time	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Int. Total
Peak Hour A	nalysis	From	07:00	AM to	08:45	4M - P	eak 1	of 1													
Peak Hour fo	r Entir	e Inter	sectio	n Begii	ns at 07	:45 AN	Λ														
07:45 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
08:00 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
08:15 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	1	1
08:30 AM	0	0	0	0	0	0	0	0	1	1	0	0	0	0	0	0	0	0	0	0	1_
Total Volume	0	0	0	0	0	0	0	0	1	1	0	0	0	0	0	0	0	0	1	1	2
% App. Total	0	0	0	0		0	0	0	100		0	0	0	0		0	0	0	100		
PHF	.000	.000	.000	.000	.000	.000	.000	.000	.250	.250	.000	.000	.000	.000	.000	.000	.000	.000	.250	.250	.500






Site Code : 16651602 Start Date : 6/11/2024

Page No : 1


		1	2 Mile	Rd			1.	2 Mile	Rd			Mea	dowbro	ook Rd			Mead	dowbro	ok Rd		
		E	astbou	ınd			W	estbo	und			N	orthbo	und			Sc	uthbo	und		
Start Time	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Int. Total
04:00 PM	0	364	80	1	445	0	548	10	0	558	0	2	109	0	111	0	2	9	0	11	1125
04:15 PM	0	412	75	1	488	1	547	5	0	553	0	2	106	0	108	0	2	5	0	7	1156
04:30 PM	0	380	92	1	473	0	532	1	0	533	0	6	93	0	99	0	1	6	0	7	1112
04:45 PM	0	392	96	3	491	1	547	3	0	551	1	1	135	0	137	0	7	7	0	14	1193
Total	0	1548	343	6	1897	2	2174	19	0	2195	1	11	443	0	455	0	12	27	0	39	4586
05:00 PM	0	430	104	0	534	0	553	4	0	557	0	2	112	0	114	0	4	5	0	9	1214
05:15 PM	0	392	87	1	480	0	508	8	0	516	0	5	123	0	128	0	3	6	0	9	1133
05:30 PM	0	374	96	0	470	0	607	9	0	616	0	2	126	0	128	0	3	10	0	13	1227
05:45 PM	0	347	103	1_	451	0	598	15	0	613	0	5	92	0	97	0	12	2	0	14	1175
Total	0	1543	390	2	1935	0	2266	36	0	2302	0	14	453	0	467	0	22	23	0	45	4749
Grand Total	0	3091	733	8	3832	2	4440	55	0	4497	1	25	896	0	922	0	34	50	0	84	9335
Apprch %	0	80.7	19.1	0.2		0	98.7	1.2	0		0.1	2.7	97.2	0		0	40.5	59.5	0		
Total %	0	33.1	7.9	0.1	41	0	47.6	0.6	0	48.2	0	0.3	9.6	0	9.9	0	0.4	0.5	0	0.9	
Light Vehicles	0	3038	727	8	3773	2	4352	53	0	4407	1	23	888	0	912	0	33	48	0	81	9173
% Light Vehicles	0	98.3	99.2	100	98.5	100	98	96.4	0	98	100	92	99.1	0	98.9	0	97.1	96	0	96.4	98.3
Heavy Vehicles	0	53	6	0	59	0	88	2	0	90	0	2	8	0	10	0	1	2	0	3	162
% Heavy Vehicles	0	1.7	8.0	0	1.5	0	2	3.6	0	2	0	8	0.9	0	1.1	0	2.9	4	0	3.6	1.7





Site Code : 16651602 Start Date : 6/11/2024

		1:	2 Mile	Rd			1:	2 Mile	Rd			Mead	dowbro	ook Rd			Mead	dowbro	ok Rd		
		E	<u>astbou</u>	ınd			W	<u>estbou</u>	ınd			N	orthbo	und			Sc	outhbo	und		
Start Time	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Int. Total
Peak Hour A	nalysis	s From	04:00	PM to	05:45 F	PM - P	eak 1	of 1													
Peak Hour fo	r Entir	e Inter	section	n Begir	ns at 04	:45 PN	/														
04:45 PM	0	392	96	3	491	1	547	3	0	551	1	1	135	0	137	0	7	7	0	14	1193
05:00 PM	0	430	104	0	534	0	553	4	0	557	0	2	112	0	114	0	4	5	0	9	1214
05:15 PM	0	392	87	1	480	0	508	8	0	516	0	5	123	0	128	0	3	6	0	9	1133
05:30 PM	0	374	96	0	470	0	607	9	0	616	0	2	126	0	128	0	3	10	0	13	1227
Total Volume	0	1588	383	4	1975	1	2215	24	0	2240	1	10	496	0	507	0	17	28	0	45	4767
% App. Total	0	80.4	19.4	0.2		0	98.9	1.1	0		0.2	2	97.8	0		0	37.8	62.2	0		
PHF	.000	.923	.921	.333	.925	.250	.912	.667	.000	.909	.250	.500	.919	.000	.925	.000	.607	.700	.000	.804	.971
Light Vehicles	0	1558	381	4	1943	1	2176	23	0	2200	1	9	492	0	502	0	16	26	0	42	4687
% Light Vehicles	0	98.1	99.5	100	98.4	100	98.2	95.8	0	98.2	100	90.0	99.2	0	99.0	0	94.1	92.9	0	93.3	98.3
Heavy Vehicles	0	30	2	0	32	0	39	1	0	40	0	1	4	0	5	0	1	2	0	3	80
% Heavy Vehicles	0	1.9	0.5	0	1.6	0	1.8	4.2	0	1.8	0	10.0	0.8	0	1.0	0	5.9	7.1	0	6.7	1.7






Site Code : 16651602 Start Date : 6/11/2024

Page No : 1


			2 Mile astbou					2 Mile estbo					dowbro	ook Rd und				dowbro	ook Rd und		
Start Time	Left	Thru	Right		App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru		Peds	App. Total	Int. Total
04:00 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:15 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:30 PM	0	0	0	0	0	0	0	0	0	0	0	1	0	0	1	0	1	0	0	1	2
04:45 PM	0	0	0	0	0	0	0	0	1	1	0	0	0	0	0	0	1	0	0	1	2
Total	0	0	0	0	0	0	0	0	1	1	0	1	0	0	1	0	2	0	0	2	4
,																					
05:00 PM	0	0	0	0	0	0	0	0	0	0	1	0	0	0	1	0	0	0	0	0	1
05:15 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	1	1
05:30 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
05:45 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total	0	0	0	0	0	0	0	0	0	0	1	0	0	0	1	0	1	0	0	1	2
Grand Total	0	0	0	0	0	0	0	0	1	1	1	1	0	0	2	0	3	0	0	3	6
Apprch %	0	0	0	0		0	0	0	100		50	50	0	0		0	100	0	0		
Total %	0	0	0	0	0	0	0	0	16.7	16.7	16.7	16.7	0	0	33.3	0	50	0	0	50	





Site Code : 16651602 Start Date : 6/11/2024

		1:	2 Mile	Rd			1	2 Mile	Rd			Mead	dowbro	ok Rd			Mea	dowbro	ook Rd	l	
		E	<u>astboι</u>	ınd			W	<u>estbo</u>	und			N	orthbo	und			Sc	outhbo	und		
Start Time	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Int. Total
Peak Hour A	nalysis	From	04:00	PM to	05:45 I	PM - P	eak 1	of 1													
Peak Hour fo	or Entir	e Inter	section	n Begii	ns at 04	:30 PN	Λ														
04:30 PM	0	0	0	Õ	0	0	0	0	0	0	0	1	0	0	1	0	1	0	0	1	2
04:45 PM	0	0	0	0	0	0	0	0	1	1	0	0	0	0	0	0	1	0	0	1	2
05:00 PM	0	0	0	0	0	0	0	0	0	0	1	0	0	0	1	0	0	0	0	0	1
05:15 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	0	0	1	1
Total Volume	0	0	0	0	0	0	0	0	1	1	1	1	0	0	2	0	3	0	0	3	6
% App. Total	0	0	0	0		0	0	0	100		50	50	0	0		0	100	0	0		
PHF	.000	.000	.000	.000	.000	.000	.000	.000	.250	.250	.250	.250	.000	.000	.500	.000	.750	.000	.000	.750	.750






Site Code : 16651603 Start Date : 6/11/2024

Page No : 1


			2 Mile					2 Mile /estbo		-		N	orthbo	und			Mead	dowbro	/O E o		
Ctort Times	1 -64	There	Distri	l		1 -44	Th	Distri			1 -64	Thru	D'ala			1 -64		outhbo			
Start Time	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left		Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Int. Total
07:00 AM	0	262	0	0	262	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	262
07:15 AM	0	304	0	0	304	0	0	0	0	0	0	0	0	0	0	1	0	0	0	1	305
07:30 AM	0	392	0	0	392	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	392
07:45 AM	0	430	0	0	430	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	430
Total	0	1388	0	0	1388	0	0	0	0	0	0	0	0	0	0	1	0	0	0	1	1389
08:00 AM	0	390	0	0	390	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	390
08:15 AM	0	397	0	0	397	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	397
08:30 AM	0	385	0	0	385	0	0	0	0	0	0	0	0	0	0	1	0	0	0	1	386
08:45 AM	0	432	0	0	432	0	0	0	0	0	0	0	0	0	0	1	0	0	0	1	433
Total	0	1604	0	0	1604	0	0	0	0	0	0	0	0	0	0	2	0	0	0	2	1606
	'															'					
Grand Total	0	2992	0	0	2992	0	0	0	0	0	0	0	0	0	0	3	0	0	0	3	2995
Apprch %	0	100	0	0		0	0	0	0	_	0	0	0	0	_	100	0	0	0		
Total %	0	99.9	0	0	99.9	0	0	0	0	0	0	0	0	0	0	0.1	Ö	0	0	0.1	
Light Vehicles	0	2828	0	0	2828	0	0	0	0	0	0	0	0	0	0	1	0	0	0	1	2829
% Light Vehicles	0	94.5	Ö	Ö	94.5	0	Ö	0	0	0	Ö	0	Ö	0	0	33.3	Ö	Ö	0	33.3	94.5
Heavy Vehicles	0	164	0	0	164	0	0	0	0	0	0	0	0	0	0	2	0	0	0	2	166
% Heavy Vehicles	0	5.5	0	0	5.5	0	0	0	0	0	0	0	0	0	0	66.7	0	0	0	66.7	5.5
70 I leavy Verlicies		5.5	U	U	5.5	U	U	U	U	U	U	U	U	U	U	00.7	U	U	U	00.7	5.5





Site Code : 16651603 Start Date : 6/11/2024

			2 Mile astbou					2 Mile estboo				N	orthbo	und			Mead		/O E o ook Rd und		
Start Time	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Int. Total
Peak Hour A	nalysis	s From	07:00	AM to	08:45 /	AM - P	eak 1	of 1													
Peak Hour fo	r Entir	e Inter	section	n Begir	ns at 07	:30 AN	1														
07:30 AM	0	392	0	0	392	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	392
07:45 AM	0	430	0	0	430	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	430
08:00 AM	0	390	0	0	390	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	390
08:15 AM	0	397	0	0	397	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	397
Total Volume	0	1609	0	0	1609	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1609
% App. Total	0	100	0	0		0	0	0	0		0	0	0	0		0	0	0	0		
PHF	.000	.935	.000	.000	.935	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.935
Light Vehicles	0	1522	0	0	1522	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1522
% Light Vehicles	0	94.6	0	0	94.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	94.6
Heavy Vehicles	0	87	0	0	87	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	87
% Heavy Vehicles	0	5.4	0	0	5.4	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	5.4






Site Code : 16651603 Start Date : 6/11/2024

Page No : 1


											N	orthbo	und			Mead	dowbro	ok Rd		
Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Int. Total
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		
	0 0 0 0 0 0 0 0	E Left Thru 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	Left Thru Right 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	Eastbound Left Thru Right Peds App. Total 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	Eastbound Left Thru Right Peds App. Total Left	Eastbound W Left Thru Right Peds App. Total Left Thru 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	Eastbound Westbound Left Thru Right Peds App. Total Left Thru Right 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0	Eastbound Westbound Left Thru Right Peds App. Total Left Thru Right Peds 0 0 0 0 0 0 0 0 0 0	Eastbound Westbound Left Thru Right Peds App. Total Left Thru Right Peds App. Total 0	Eastbound Westbound Left Thru Right Peds App. Total Left Thru Right Peds App. Total Left 0 <t< td=""><td> Left Thru Right Peds App. Total Left Thru Right Righ</td><td> Eastbound Westbound Northbook Left Thru Right Peds App. Total Left Thru Right Right </td><td> Left Thru Right Peds App. Total Left Thru Right Peds </td><td> Northbound Northbound Left Thru Right Peds App. Total </td><td> Left Thru Right Peds App. Total Left </td><td> T2 Mile Rd</td><td> T2 Mile Rd</td><td> T2 Mile Rd</td><td> Left Thru Right Peds App. Total Left Thru Right Right Peds App. Total Left Thru Right Peds App. Total Left Thru Right Right Peds App. Total Left Thru Right Right Peds App. Total Left Thru Right Right </td></t<>	Left Thru Right Peds App. Total Left Thru Right Righ	Eastbound Westbound Northbook Left Thru Right Peds App. Total Left Thru Right Right	Left Thru Right Peds App. Total Left Thru Right Peds	Northbound Northbound Left Thru Right Peds App. Total Left Thru Right Peds App. Total	Left Thru Right Peds App. Total Left	T2 Mile Rd	T2 Mile Rd	T2 Mile Rd	Left Thru Right Peds App. Total Left Thru Right Right Peds App. Total Left Thru Right Peds App. Total Left Thru Right Right Peds App. Total Left Thru Right Right Peds App. Total Left Thru Right Right





Site Code : 16651603 Start Date : 6/11/2024

			2 Mile astbou					2 Mile /estboo				N	orthbo	und			Mead		/O E o ook Rd und		
Start Time	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Int. Total
Peak Hour A	nalysis	From	07:00	AM to	08:45	4M - P	eak 1	of 1													
Peak Hour fo	r Entir	e Inter	section	n Begii	ns at 07	:00 AN	Λ														i
07:00 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:15 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:30 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:45 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Volume	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
% App. Total	0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		
PHF	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000






Site Code : 16651604 Start Date : 6/11/2024

Page No : 1


			2 Mile astbou					2 Mile estboo				N	orthbo	und			Mead	o-EB X	ok Rd		
Start Time	l oft	Thru	Dialet			Left	Thru	Diaba			Left	Thru	Diabt			l oft	Thru	outhbo			
	Left		Right	U-Turn	App. Total		IIIIu	Right	U-Turn	App. Total			Right	U-Turn	App. Total	Left	IIIIu	Right	U-Turn	App. Total	Int. Total
04:00 PM	0	472	0	0	472	0	0	0	0	0	0	0	0	0	0	1	0	0	0	1	473
04:15 PM	0	519	0	0	519	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	519
04:30 PM	0	474	0	0	474	0	0	0	0	0	0	0	0	0	0	1	0	0	0	1	475
04:45 PM	0	529	0	0	529	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	529
Total	0	1994	0	0	1994	0	0	0	0	0	0	0	0	0	0	2	0	0	0	2	1996
05:00 PM	0	542	0	0	542	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	542
05:15 PM	0	517	0	0	517	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	517
05:30 PM	0	497	0	0	497	0	0	0	0	0	0	0	0	0	0	3	0	0	0	3	500
05:45 PM	0	445	0	0	445	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	445
Total	0	2001	0	0	2001	0	0	0	0	0	0	0	0	0	0	3	0	0	0	3	2004
															- 1						
Grand Total	0	3995	0	0	3995	0	0	0	0	0	0	0	0	0	0	5	0	0	0	5	4000
Apprch %	0	100	0	0		0	0	0	0		0	0	0	0		100	0	0	0		
Total %	0	99.9	0	0	99.9	0	0	0	0	0	Ö	0	0	0	0	0.1	Ö	0	0	0.1	
Light Vehicles	0	3935	0	0	3935	0	0	0	0	0	0	0	0	0	0	5	0	0	0	5	3940
% Light Vehicles	l ő	98.5	0	0	98.5	0	0	0	0	0	0	0	0	0	0	100	0	0	0	100	98.5
Heavy Vehicles	0	60	0	0	60	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	60
,		1.5	0	0	1.5	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1.5
% Heavy Vehicles	l U	1.5	U	U	1.5	U	U	U	U	U	U	U	U	U	U	U	U	U	U	U	1.5





Site Code : 16651604 Start Date : 6/11/2024

			2 Mile astbou					2 Mile 'estbou				N	orthbo	und			Mead	o-EB X dowbro outhbo	ok Rd		
Start Time	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Int. Total
Peak Hour A	nalysi	s From	04:00	PM to	05:45 F	PM - P	eak 1	of 1													
Peak Hour fo	or Entii	e Inter	section	n Begir	ns at 04	:45 PN	1														
04:45 PM	0	529	0	0	529	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	529
05:00 PM	0	542	0	0	542	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	542
05:15 PM	0	517	0	0	517	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	517
05:30 PM	0	497	0	0	497	0	0	0	0	0	0	0	0	0	0	3	0	0	0	3	500
Total Volume	0	2085	0	0	2085	0	0	0	0	0	0	0	0	0	0	3	0	0	0	3	2088
% App. Total	0	100	0	0		0	0	0	0		0	0	0	0		100	0	0	0		
PHF	.000	.962	.000	.000	.962	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.250	.000	.000	.000	.250	.963
Light Vehicles	0	2051	0	0	2051	0	0	0	0	0	0	0	0	0	0	3	0	0	0	3	2054
% Light Vehicles	0	98.4	0	0	98.4	0	0	0	0	0	0	0	0	0	0	100	0	0	0	100	98.4
Heavy Vehicles	0	34	0	0	34	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	34
% Heavy Vehicles	0	1.6	0	0	1.6	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1.6






Site Code : 16651604 Start Date : 6/11/2024

Page No : 1


			2 Mile astbou					2 Mile 'estbou				N	orthbo	und			Mead	o-EB X dowbro outhbo	ok Rd		
Start Time	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Int. Total
04:00 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:15 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:30 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:45 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
05:00 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
05:15 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
05:30 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
05:45 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Grand Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Apprch %	0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		
Total %																					





Site Code : 16651604 Start Date : 6/11/2024

			2 Mile astbou					2 Mile /estboo				N	orthbo	und			Mead		/O E o ook Rd und		
Start Time	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Int. Total
Peak Hour A	nalysis	From	04:00	PM to	05:45 F	PM - P	eak 1	of 1													
Peak Hour fo	r Entir	e Inter	section	n Begii	ns at 04	:00 PN	Λ														i
04:00 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:15 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:30 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:45 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Volume	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
% App. Total	0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		
PHF	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000






Site Code : 16651605 Start Date : 6/11/2024

Page No : 1


				2 Mile astbou					2 Mile /estboo				N	orthbo	und		V	S	EB X/C ummit outhbo		of	
r	Start Time	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Int. Total
_	07:00 AM	0	259	0	0	259	0	0	0	0	0	0	0	0	0	0	3	0	0	0	3	262
	07:15 AM	0	289	0	0	289	0	0	0	0	0	0	0	0	0	0	7	0	0	0	7	296
	07:30 AM	0	396	0	0	396	0	0	0	0	0	0	0	0	0	0	2	0	0	0	2	398
_	07:45 AM	0	405	0	0	405	0	0	0	0	0	0	0	0	0	0	5	0	0	0	5	410
	Total	0	1349	0	0	1349	0	0	0	0	0	0	0	0	0	0	17	0	0	0	17	1366
	08:00 AM	0	396	0	0	396	0	0	0	0	0	0	0	0	0	0	1	0	0	0	1	397
	08:15 AM	0	391	0	0	391	0	0	0	0	0	0	0	0	0	0	6	0	0	0	6	397
	08:30 AM	0	381	0	0	381	0	0	0	0	0	0	0	0	0	0	2	0	0	0	2	383
_	08:45 AM	0	413	0	0	413	0	0	0	0	0	0	0	0	0	0	6	0	0	0	6	419
	Total	0	1581	0	0	1581	0	0	0	0	0	0	0	0	0	0	15	0	0	0	15	1596
	Grand Total	0	2930	0	0	2930	0	0	0	0	0	0	0	0	0	0	32	0	0	0	32	2962
	Apprch %	0	100	0	0		0	0	0	0		0	0	0	0		100	0	0	0		
_	Total %	0	98.9	0	0	98.9	0	0	0	0	0	0	0	0	0	0	1.1	0	0	0	1.1	
	Light Vehicles	0	2759	0	0	2759	0	0	0	0	0	0	0	0	0	0	29	0	0	0	29	2788
_	% Light Vehicles	0	94.2	0	0	94.2	0	0	0	0	0	0	0	0	0	0	90.6	0	0	0	90.6	94.1
	Heavy Vehicles	0	171	0	0	171	0	0	0	0	0	0	0	0	0	0	3	0	0	0	3	174
	% Heavy Vehicles	0	5.8	0	0	5.8	0	0	0	0	0	0	0	0	0	0	9.4	0	0	0	9.4	5.9





Site Code : 16651605 Start Date : 6/11/2024

			2 Mile astbou					2 Mile estbou				No	orthbo	und		٧	_	EB X/C ummit outhbo	Dr	of	
Start Time	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Int. Total
Peak Hour A								of 1													
Peak Hour fo	r Entir	e Inter	section	n Begii	ns at 07	:30 AN	Λ														
07:30 AM	0	396	0	0	396	0	0	0	0	0	0	0	0	0	0	2	0	0	0	2	398
07:45 AM	0	405	0	0	405	0	0	0	0	0	0	0	0	0	0	5	0	0	0	5	410
08:00 AM	0	396	0	0	396	0	0	0	0	0	0	0	0	0	0	1	0	0	0	1	397
08:15 AM	0	391	0	0	391	0	0	0	0	0	0	0	0	0	0	6	0	0	0	6	397
Total Volume	0	1588	0	0	1588	0	0	0	0	0	0	0	0	0	0	14	0	0	0	14	1602
% App. Total	0	100	0	0		0	0	0	0		0	0	0	0		100	0	0	0		
PHF	.000	.980	.000	.000	.980	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.583	.000	.000	.000	.583	.977
Light Vehicles	0	1498	0	0	1498	0	0	0	0	0	0	0	0	0	0	14	0	0	0	14	1512
% Light Vehicles	0	94.3	0	0	94.3	0	0	0	0	0	0	0	0	0	0	100	0	0	0	100	94.4
Heavy Vehicles	0	90	0	0	90	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	90
% Heavy Vehicles	0	5.7	0	0	5.7	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	5.6






Site Code : 16651605 Start Date : 6/11/2024

Page No : 1


			2 Mile astbou					2 Mile 'estbou				N	orthbo	und		V	_	B X/C ummit outhboo	Dr	of	
Start Time	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Int. Total
07:00 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:15 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:30 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:45 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
08:00 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
08:15 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
08:30 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
08:45 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Grand Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Apprch %	0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		
Total %																					





Site Code : 16651605 Start Date : 6/11/2024

			2 Mile astbou					2 Mile estboo				No	orthbo	und		V	_	B X/C ummit outhbo	Dr	of	
Start Time	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Int. Total
Peak Hour A	nalysis	From	07:00	AM to	08:45 /	AM - P	eak 1	of 1													
Peak Hour fo	or Entir	e Inter	section	n Begir	ns at 07	:00 AN	1														
07:00 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:15 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:30 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:45 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Volume	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
% App. Total	0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		
PHF	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000






Site Code : 16651606 Start Date : 6/11/2024

Page No : 1


			2 Mile					2 Mile /estbo		Ū		N	orthbo	und		٧	_	ummit	Dr	of	
Start Time	Left	Thru	Diaba			Left	Thru	Diabt			Left	Thru	Diabt			Left	Thru	uthbo			
			Right	U-Turn	App. Total		IIIIu	Right	U-Turn	App. Total			Right	U-Turn	App. Total			Right	U-Turn	App. Total	Int. Total
04:00 PM	0	445	0	0	445	0	0	0	0	0	0	0	0	0	0	5	0	0	0	5	450
04:15 PM	0	518	0	0	518	0	0	0	0	0	0	0	0	0	0	5	0	0	0	5	523
04:30 PM	0	462	0	0	462	0	0	0	0	0	0	0	0	0	0	6	0	0	0	6	468
04:45 PM	0	511	0	0	511	0	0	0	0	0	0	0	0	0	0	6	0	0	0	6	517
Total	0	1936	0	0	1936	0	0	0	0	0	0	0	0	0	0	22	0	0	0	22	1958
05:00 PM	0	531	0	0	531	0	0	0	0	0	0	0	0	0	0	5	0	0	0	5	536
05:15 PM	0	503	0	0	503	0	0	0	0	0	0	0	0	0	0	4	0	0	0	4	507
05:30 PM	0	463	0	0	463	0	0	0	0	0	0	0	0	0	0	3	0	0	0	3	466
05:45 PM	0	436	0	0	436	0	0	0	0	0	0	0	0	0	0	5	0	0	0	5	441
Total	0	1933	0	0	1933	0	0	0	0	0	0	0	0	0	0	17	0	0	0	17	1950
	'					'										'					
Grand Total	0	3869	0	0	3869	0	0	0	0	0	0	0	0	0	0	39	0	0	0	39	3908
Apprch %	0	100	0	0		0	0	0	0		0	0	0	0		100	0	0	0		I
Total %	0	99	0	0	99	0	0	0	0	0	0	0	0	0	0	1	0	0	0	1	l
Light Vehicles	0	3808	0	0	3808	0	0	0	0	0	0	0	0	0	0	36	0	0	0	36	3844
% Light Vehicles	0	98.4	0	0	98.4	0	0	0	0	0	0	Ö	Ö	0	0	92.3	Ö	Ö	0	92.3	98.4
Heavy Vehicles	0	61	0	0	61	0	0	0	0	0	0	0	0	0	0	3	0	0	0	3	64
% Heavy Vehicles	0	1.6	0	0	1.6	0	0	0	0	0	0	0	0	0	0	7.7	0	0	0	7.7	1.6
% neavy verticles	ı	1.0	U	U	1.0	ı U	U	U	U	U	U	U	U	U	U	1.7	U	U	U	1.1	1.0





Site Code : 16651606 Start Date : 6/11/2024

			2 Mile astbou					2 Mile 'estbou				No	orthbo	und		٧	S	EB X/C Summit outhbo	Dr	of	
Start Time	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Int. Total
Peak Hour A	nalysis	s From	04:00	PM to	05:45 F	PM - P	eak 1	of 1													
Peak Hour fo	r Entir	e Inter	section	n Begii	ns at 04	:15 PN	Λ														
04:15 PM	0	518	0	0	518	0	0	0	0	0	0	0	0	0	0	5	0	0	0	5	523
04:30 PM	0	462	0	0	462	0	0	0	0	0	0	0	0	0	0	6	0	0	0	6	468
04:45 PM	0	511	0	0	511	0	0	0	0	0	0	0	0	0	0	6	0	0	0	6	517
_05:00 PM	0	531	0	0	531	0	0	0	0	0	0	0	0	0	0	5	0	0	0	5	536
Total Volume	0	2022	0	0	2022	0	0	0	0	0	0	0	0	0	0	22	0	0	0	22	2044
% App. Total	0	100	0	0		0	0	0	0		0	0	0	0		100	0	0	0		
PHF	.000	.952	.000	.000	.952	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.917	.000	.000	.000	.917	.953
Light Vehicles	0	1996	0	0	1996	0	0	0	0	0	0	0	0	0	0	19	0	0	0	19	2015
% Light Vehicles	0	98.7	0	0	98.7	0	0	0	0	0	0	0	0	0	0	86.4	0	0	0	86.4	98.6
Heavy Vehicles	0	26	0	0	26	0	0	0	0	0	0	0	0	0	0	3	0	0	0	3	29
% Heavy Vehicles	0	1.3	0	0	1.3	0	0	0	0	0	0	0	0	0	0	13.6	0	0	0	13.6	1.4






Site Code : 16651606 Start Date : 6/11/2024

Page No : 1


			2 Mile astbou					2 Mile estbou				No	orthbo	und		V	_	EB X/C ummit outhbo	Dr	of	
Start Time	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Int. Total
04:00 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:15 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:30 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:45 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
05:00 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
05:15 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
05:30 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
05:45 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Grand Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Apprch % Total %	0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		





Site Code : 16651606 Start Date : 6/11/2024

			2 Mile astbou					2 Mile estbou				No	orthbo	und		٧	S	EB X/C ummit outhbo		of	
Start Time	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Int. Total
Peak Hour A	nalysis	From	04:00	PM to	05:45 F	PM - P	eak 1	of 1													
Peak Hour fo	r Entir	e Inter	section	n Begi	ns at 04	:00 PN	/														
04:00 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:15 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:30 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:45 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Volume	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
% App. Total	0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		
PHF	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000






Site Code : 16651607 Start Date : 6/11/2024

Page No : 1


			2 Mile astboo					2 Mile /estbo			E			ook Rd	-		Sc	outhbo	und		
Start Time	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Int. Total
07:00 AM	0	0	0	0	0	0	352	0	0	352	4	0	0	0	4	0	0	0	0	0	356
07:15 AM	0	0	0	0	0	0	406	0	0	406	4	0	0	0	4	0	0	0	0	0	410
07:30 AM	0	0	0	0	0	0	458	0	0	458	8	0	0	0	8	0	0	0	0	0	466
07:45 AM	0	0	0	0	0	0	518	0	0	518	11	0	0	0	11	0	0	0	0	0	529
Total	0	0	0	0	0	0	1734	0	0	1734	27	0	0	0	27	0	0	0	0	0	1761
00:00 414		0	0	0	0		450	^	_	450		0	^	^	44	0	0	^	0	0	470
08:00 AM	0	0	0	0	0	0	459	0	0	459	11	0	0	0	11	0	0	0	0	0	470
08:15 AM	0	0	0	0	0	0	411	0	0	411	4	0	0	0	4	0	0	0	0	0	415
08:30 AM	0	0	0	0	0	0	482	0	0	482	9	0	0	0	9	0	0	0	0	0	491
08:45 AM	0	0	0	0	0	0	490	0	0	490	16	0	0	0	16	0	0	0	0	0	506
Total	0	0	0	0	0	0	1842	0	0	1842	40	0	0	0	40	0	0	0	0	0	1882
Grand Total	0	0	0	0	0	0	3576	0	0	3576	67	0	0	0	67	0	0	0	0	0	3643
Apprch %	0	0	0	0	Ü	0	100	Ö	0	00.0	100	Ö	Ö	Ö	0.	0	0	0	0	ŭ	00.0
Total %	Ö	Ö	Ö	0	0	0	98.2	Ö	0	98.2	1.8	Ö	Ö	0	1.8	Ö	0	Ö	Ö	0	
Light Vehicles	0	0	0	0	0	0	3461	0	0	3461	62	0	0	0	62	0	0	0	0	0	3523
% Light Vehicles	0	0	0	0	0	0	96.8	0	0	96.8	92.5	0	0	0	92.5	Ö	0	0	0	0	96.7
Heavy Vehicles	0	0	0	0	0	0	115	0	0	115	5	0	0	0	5	0	0	0	0	0	120
% Heavy Vehicles	0	0	0	0	0	0	3.2	0	0	3.2	7.5	0	0	0	7.5	0	0	0	0	0	3.3





Site Code : 16651607 Start Date : 6/11/2024

			2 Mile astbou					2 Mile 'estbou			E	Mead		D East ook Rd und			Sc	uthbo	und		
Start Time	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Int. Total
Peak Hour A	nalysis	s From	07:00	AM to	08:45 /	4M - P	eak 1	of 1													
Peak Hour fo	r Entir	e Inter	sectio	n Begir	ns at 07	:45 AN	1														
07:45 AM	0	0	0	0	0	0	518	0	0	518	11	0	0	0	11	0	0	0	0	0	529
08:00 AM	0	0	0	0	0	0	459	0	0	459	11	0	0	0	11	0	0	0	0	0	470
08:15 AM	0	0	0	0	0	0	411	0	0	411	4	0	0	0	4	0	0	0	0	0	415
08:30 AM	0	0	0	0	0	0	482	0	0	482	9	0	0	0	9	0	0	0	0	0	491
Total Volume	0	0	0	0	0	0	1870	0	0	1870	35	0	0	0	35	0	0	0	0	0	1905
% App. Total	0	0	0	0		0	100	0	0		100	0	0	0		0	0	0	0		
PHF	.000	.000	.000	.000	.000	.000	.903	.000	.000	.903	.795	.000	.000	.000	.795	.000	.000	.000	.000	.000	.900
Light Vehicles	0	0	0	0	0	0	1817	0	0	1817	34	0	0	0	34	0	0	0	0	0	1851
% Light Vehicles	0	0	0	0	0	0	97.2	0	0	97.2	97.1	0	0	0	97.1	0	0	0	0	0	97.2
Heavy Vehicles	0	0	0	0	0	0	53	0	0	53	1	0	0	0	1	0	0	0	0	0	54
% Heavy Vehicles	0	0	0	0	0	0	2.8	0	0	2.8	2.9	0	0	0	2.9	0	0	0	0	0	2.8






Site Code : 16651607 Start Date : 6/11/2024

Page No : 1


			2 Mile astbou					2 Mile /estboo			E	Mead	VB X/O dowbro orthbo	ok Rd	-		Sc	outhboo	und		
Start Time	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Int. Total
07:00 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:15 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:30 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:45 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
08:00 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
08:15 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
08:30 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
08:45 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Grand Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Apprch % Total %	0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		





Site Code : 16651607 Start Date : 6/11/2024

			2 Mile astbou					2 Mile /estbo			E	Mead		East ook Rd und	-		Sc	outhbo	und		
Start Time	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Int. Total
Peak Hour A	Analysis From 07:00 AM to 08:45 AM - Peak 1 of 1																				
Peak Hour fo	r Entir	e Inter	sectio	n Begi	ns at 07	:00 AN	Λ														
07:00 AM	0	0 0 0 0					0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:15 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:30 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:45 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Volume	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
% App. Total	0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		
PHF	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000






Site Code : 16651608 Start Date : 6/11/2024

Page No : 1


			2 Mile astbou					2 Mile 'estbo			E	Mead		D East ook Rd und	-		Sc	outhbo	und		
Start Time	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Int. Total
04:00 PM	0	0	0	0	0	0	533	0	0	533	17	0	0	0	17	0	0	0	0	0	550
04:15 PM	0	0	0	0	0	0	539	0	0	539	10	0	0	0	10	0	0	0	0	0	549
04:30 PM	0	0	0	0	0	0	539	0	0	539	15	0	0	0	15	0	0	0	0	0	554
04:45 PM	0	0	0	0	0	0	548	0	0	548	14	0	0	0	14	0	0	0	0	0	562
Total	0	0	0	0	0	0	2159	0	0	2159	56	0	0	0	56	0	0	0	0	0	2215
	ı				i						ı										
05:00 PM	0	0	0	0	0	0	520	0	0	520	11	0	0	0	11	0	0	0	0	0	531
05:15 PM	0	0	0	0	0	0	508	0	0	508	14	0	0	0	14	0	0	0	0	0	522
05:30 PM	0	0	0	0	0	0	600	0	0	600	18	0	0	0	18	0	0	0	0	0	618
05:45 PM	0	0	0	0	0	0	600	0	0	600	28	0	0	0	28	0	0	0	0	0	628
Total	0	0	0	0	0	0	2228	0	0	2228	71	0	0	0	71	0	0	0	0	0	2299
		_	_	_	1	_		_	_			_	_	_				_	_		
Grand Total	0	0	0	0	0	0	4387	0	0	4387	127	0	0	0	127	0	0	0	0	0	4514
Apprch %	0	0	0	0		0	100	0	0		100	0	0	0		0	0	0	0		
Total %	0	0	0	0	0	0	97.2	0	0	97.2	2.8	0	0	0	2.8	0	0	0	0	0	
Light Vehicles	0	0	0	0	0	0	4306	0	0	4306	125	0	0	0	125	0	0	0	0	0	4431
% Light Vehicles	0	0	0	0	0	0	98.2	0	0	98.2	98.4	0	0	0	98.4	0	0	0	0	0	98.2
Heavy Vehicles	0	0	0	0	0	0	81	0	0	81	2	0	0	0	2	0	0	0	0	0	83
% Heavy Vehicles	0	0	0	0	0	0	1.8	0	0	1.8	1.6	0	0	0	1.6	0	0	0	0	0	1.8





Site Code : 16651608 Start Date : 6/11/2024

			2 Mile astbou					2 Mile 'estbou			E	Mead	, .	D East ook Rd und			Sc	uthbo	und		
Start Time	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Int. Total
Peak Hour A	nalysis	From	04:00	PM to	05:45 F	PM - P	eak 1	of 1													
Peak Hour fo	r Entir	e Inter	sectio	n Begir	ns at 05	:00 PN	1														
05:00 PM	0	0	0	0	0	0	520	0	0	520	11	0	0	0	11	0	0	0	0	0	531
05:15 PM	0	0	0	0	0	0	508	0	0	508	14	0	0	0	14	0	0	0	0	0	522
05:30 PM	0	0	0	0	0	0	600	0	0	600	18	0	0	0	18	0	0	0	0	0	618
05:45 PM	0	0	0	0	0	0	600	0	0	600	28	0	0	0	28	0	0	0	0	0	628
Total Volume	0	0	0	0	0	0	2228	0	0	2228	71	0	0	0	71	0	0	0	0	0	2299
% App. Total	0	0	0	0		0	100	0	0		100	0	0	0		0	0	0	0		
PHF	.000	.000	.000	.000	.000	.000	.928	.000	.000	.928	.634	.000	.000	.000	.634	.000	.000	.000	.000	.000	.915
Light Vehicles	0	0	0	0	0	0	2192	0	0	2192	70	0	0	0	70	0	0	0	0	0	2262
% Light Vehicles	0	0	0	0	0	0	98.4	0	0	98.4	98.6	0	0	0	98.6	0	0	0	0	0	98.4
Heavy Vehicles	0	0	0	0	0	0	36	0	0	36	1	0	0	0	1	0	0	0	0	0	37
% Heavy Vehicles	0	0	0	0	0	0	1.6	0	0	1.6	1.4	0	0	0	1.4	0	0	0	0	0	1.6






Site Code : 16651608 Start Date : 6/11/2024

Page No : 1

			2 Mile I astbou					2 Mile /estbo			E	Mead		D East ook Rd und	-		Sc	uthbo	und		
Start Time	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Int. Total
04:00 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:15 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:30 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:45 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
05:00 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
05:15 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
05:30 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
05:45 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Grand Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Apprch % Total %	0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		






File Name: 16651608 - EB-to-WB X_O East of Meadowbrook Rd -- 12 Mile Rd

Site Code : 16651608 Start Date : 6/11/2024

			2 Mile astbou					2 Mile estbou			E	Mead		D East ook Rd und	-		Sc	outhbo	und		
Start Time	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Int. Total
Peak Hour A	nalysis	From	04:00	PM to				of 1													
Peak Hour fo	or Entir	e Inter	section	n Begii	ns at 04	:00 PN	/														
04:00 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:15 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:30 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:45 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Volume	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
% App. Total	0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		
PHF	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000






Site Code : 16651609 Start Date : 6/11/2024

Page No : 1

Groups Printed- Light Vehicles - Heavy Vehicles


			2 Mile					2 Mile 'estbo		Ĭ		N	orthbo	und		WE		Mile R	d	of 12	
Otra t Time	1 6					1 6			1		1 6					1 6		uthbo			
Start Time	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Int. Total
07:00 AM	0	238	0	0	238	0	0	0	0	0	0	0	0	0	0	44	0	0	0	44	282
07:15 AM	0	279	0	0	279	0	0	0	0	0	0	0	0	0	0	50	0	0	0	50	329
07:30 AM	0	367	0	0	367	0	0	0	0	0	0	0	0	0	0	64	0	0	0	64	431
07:45 AM	0	410	0	0	410	0	0	0	0	0	0	0	0	0	0	67	0	0	0	67	477
Total	0	1294	0	0	1294	0	0	0	0	0	0	0	0	0	0	225	0	0	0	225	1519
08:00 AM	0	357	0	0	357	0	0	0	0	0	0	0	0	0	0	77	0	0	0	77	434
08:15 AM	0	339	0	0	339	0	0	0	0	0	0	0	0	0	0	63	0	0	0	63	402
08:30 AM	0	344	0	0	344	0	0	0	0	0	0	0	0	0	0	73	0	0	0	73	417
08:45 AM	0	355	0	0	355	0	0	0	0	0	0	0	0	0	0	91	0	0	0	91	446
Total	0	1395	0	0	1395	0	0	0	0	0	0	0	0	0	0	304	0	0	0	304	1699
										,					,					•	
Grand Total	0	2689	0	0	2689	0	0	0	0	0	0	0	0	0	0	529	0	0	0	529	3218
Apprch %	0	100	0	0		0	0	0	0		0	0	0	0		100	0	0	0		
 Total %	0	83.6	0	0	83.6	0	0	0	0	0	0	0	0	0	0	16.4	0	0	0	16.4	
Light Vehicles	0	2543	0	0	2543	0	0	0	0	0	0	0	0	0	0	524	0	0	0	524	3067
% Light Vehicles	0	94.6	0	0	94.6	0	0	0	0	0	0	0	0	0	0	99.1	0	0	0	99.1	95.3
Heavy Vehicles	0	146	0	0	146	0	0	0	0	0	0	0	0	0	0	5	0	0	0	5	151
% Heavy Vehicles	0	5.4	0	0	5.4	0	0	0	0	0	0	0	0	0	0	0.9	0	0	0	0.9	4.7





Site Code : 16651609 Start Date : 6/11/2024

			2 Mile astbou					2 Mile estbou				No	orthbo	und		WE		3 X/O V Mile R outhbo	d	f 12	
Start Time	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Int. Total
Peak Hour A	nalysis	s From	07:00	AM to	08:45 /	AM - P	eak 1	of 1													
Peak Hour fo	r Entir	e Inter	section	n Begir	ns at 07	:30 AN	1														
07:30 AM	0	367	0	0	367	0	0	0	0	0	0	0	0	0	0	64	0	0	0	64	431
07:45 AM	0	410	0	0	410	0	0	0	0	0	0	0	0	0	0	67	0	0	0	67	477
08:00 AM	0	357	0	0	357	0	0	0	0	0	0	0	0	0	0	77	0	0	0	77	434
08:15 AM	0	339	0	0	339	0	0	0	0	0	0	0	0	0	0	63	0	0	0	63	402
Total Volume	0	1473	0	0	1473	0	0	0	0	0	0	0	0	0	0	271	0	0	0	271	1744
% App. Total	0	100	0	0		0	0	0	0		0	0	0	0		100	0	0	0		
PHF	.000	.898	.000	.000	.898	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.880	.000	.000	.000	.880	.914
Light Vehicles	0	1390	0	0	1390	0	0	0	0	0	0	0	0	0	0	267	0	0	0	267	1657
% Light Vehicles	0	94.4	0	0	94.4	0	0	0	0	0	0	0	0	0	0	98.5	0	0	0	98.5	95.0
Heavy Vehicles	0	83	0	0	83	0	0	0	0	0	0	0	0	0	0	4	0	0	0	4	87
% Heavy Vehicles	0	5.6	0	0	5.6	0	0	0	0	0	0	0	0	0	0	1.5	0	0	0	1.5	5.0






Site Code : 16651609 Start Date : 6/11/2024

Page No : 1

Groups Printed- Bikes, Peds


			2 Mile astbou					2 Mile estboo				N	orthbo	und		WE		3 X/O Mile Routhbo	d	of 12	
Start Time	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right		App. Total	Int. Total
07:00 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:15 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:30 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:45 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
08:00 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
08:15 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
08:30 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
08:45 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Grand Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Apprch % Total %	0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		





Site Code : 16651609 Start Date : 6/11/2024

			2 Mile astbou					2 Mile /estboo				N	orthbo	und		WE		3 X/O ' Mile R outhbo		f 12	
Start Time	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Int. Total
Peak Hour A	nalysis	From	07:00	AM to	08:45	4M - P	eak 1	of 1													
Peak Hour fo	r Entir	e Inter	section	n Begii	ns at 07	:00 AN	Λ														
07:00 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:15 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:30 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:45 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Volume	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
% App. Total	0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		
PHF	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000






Site Code : 16651610 Start Date : 6/11/2024

Page No : 1

Groups Printed- Light Vehicles - Heavy Vehicles


			2 Mile					2 Mile 'estbo		Ū		N	orthbo	und		WE		Mile R	d	of 12	
				-					1									uthbo			
Start Time	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Int. Total
04:00 PM	0	372	0	0	372	0	0	0	0	0	0	0	0	0	0	62	0	0	0	62	434
04:15 PM	0	438	0	0	438	0	0	0	0	0	0	0	0	0	0	53	0	0	0	53	491
04:30 PM	0	409	0	0	409	0	0	0	0	0	0	0	0	0	0	67	0	0	0	67	476
04:45 PM	0	445	0	0	445	0	0	0	0	0	0	0	0	0	0	67	0	0	0	67	512
Total	0	1664	0	0	1664	0	0	0	0	0	0	0	0	0	0	249	0	0	0	249	1913
05:00 PM	0	446	0	0	446	0	0	0	0	0	0	0	0	0	0	63	0	0	0	63	509
05:15 PM	0	423	0	0	423	0	0	0	0	0	0	0	0	0	0	62	0	0	0	62	485
05:30 PM	0	406	0	0	406	0	0	0	0	0	0	0	0	0	0	60	0	0	0	60	466
05:45 PM	0	379	0	0	379	0	0	0	0	0	0	0	0	0	0	82	0	0	0	82	461
Total	0	1654	0	0	1654	0	0	0	0	0	0	0	0	0	0	267	0	0	0	267	1921
Grand Total	0	3318	0	0	3318	0	0	0	0	0	0	0	0	0	0	516	0	0	0	516	3834
Apprch %	0	100	0	0		0	0	0	0		0	0	0	0		100	0	0	0		
Total %	0	86.5	0	0	86.5	0	0	0	0	0	0	0	0	0	0	13.5	0	0	0	13.5	
Light Vehicles	0	3266	0	0	3266	0	0	0	0	0	0	0	0	0	0	510	0	0	0	510	3776
% Light Vehicles	0	98.4	0	0	98.4	0	0	0	0	0	0	0	0	0	0	98.8	0	0	0	98.8	98.5
Heavy Vehicles	0	52	0	0	52	0	0	0	0	0	0	0	0	0	0	6	0	0	0	6	58
% Heavy Vehicles	0	1.6	0	0	1.6	0	0	0	0	0	0	0	0	0	0	1.2	0	0	0	1.2	1.5





Site Code : 16651610 Start Date : 6/11/2024

			2 Mile astbou					2 Mile 'estbou				No	orthbo	und		WE		3 X/O Mile Routhbo	d	of 12	
Start Time	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Int. Total
Peak Hour A	nalysis	s From	04:00	PM to	05:45 F	PM - P	eak 1	of 1													
Peak Hour fo	r Entir	e Inter	section	n Begii	ns at 04	:15 PN	Λ														
04:15 PM	0	438	0	0	438	0	0	0	0	0	0	0	0	0	0	53	0	0	0	53	491
04:30 PM	0	409	0	0	409	0	0	0	0	0	0	0	0	0	0	67	0	0	0	67	476
04:45 PM	0	445	0	0	445	0	0	0	0	0	0	0	0	0	0	67	0	0	0	67	512
05:00 PM	0	446	0	0	446	0	0	0	0	0	0	0	0	0	0	63	0	0	0	63	509
Total Volume	0	1738	0	0	1738	0	0	0	0	0	0	0	0	0	0	250	0	0	0	250	1988
% App. Total	0	100	0	0		0	0	0	0		0	0	0	0		100	0	0	0		
PHF	.000	.974	.000	.000	.974	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.933	.000	.000	.000	.933	.971
Light Vehicles	0	1718	0	0	1718	0	0	0	0	0	0	0	0	0	0	247	0	0	0	247	1965
% Light Vehicles	0	98.8	0	0	98.8	0	0	0	0	0	0	0	0	0	0	98.8	0	0	0	98.8	98.8
Heavy Vehicles	0	20	0	0	20	0	0	0	0	0	0	0	0	0	0	3	0	0	0	3	23
% Heavy Vehicles	0	1.2	0	0	1.2	0	0	0	0	0	0	0	0	0	0	1.2	0	0	0	1.2	1.2






Site Code : 16651610 Start Date : 6/11/2024

Page No : 1

Groups Printed- Bikes, Peds


				2 Mile astbou					2 Mile estbou				N	orthbo	und		WE		3 X/O \ Mile R outhboo	d	of 12	
S	tart Time	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Int. Total
	04:00 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	04:15 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	04:30 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	04:45 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	05:00 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	05:15 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	05:30 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	05:45 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
	Grand Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
		0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		
	Total %																					
	04:15 PM 04:30 PM 04:45 PM Total 05:00 PM 05:15 PM 05:30 PM 05:45 PM Total	0 0 0 0	0 0 0 0 0	0 0 0 0 0	0 0 0 0 0 0 0 0	0 0 0 0	0 0 0 0 0	0 0 0 0 0	0 0 0 0 0	0 0 0 0 0	0 0 0 0	0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0	0 0 0 0 0 0 0 0	0 0 0 0 0	0 0 0 0 0 0 0 0	0 0 0 0 0	0 0 0 0 0 0 0 0	0 0 0 0 0	0 0 0 0	





Site Code : 16651610 Start Date : 6/11/2024

			2 Mile astbou					2 Mile /estboo				N	orthbo	und		WE		3 X/O ' Mile R outhbo		of 12	
Start Time	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Int. Total
Peak Hour A	nalysis	From	04:00	PM to	05:45 F	PM - P	eak 1	of 1													
Peak Hour fo	r Entir	Left Thru Right Peds App. Total Left Thru Right Peds App. Total Left Thru Right Peds App. Total App. Total Right Peds App. Total App. Total Peak 1 of 1 Entire Intersection Begins at 04:00 PM																			
04:00 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:15 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:30 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:45 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Volume	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
% App. Total	0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		
PHF	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000






Site Code : 16651611 Start Date : 6/11/2024

Page No : 1

Groups Printed- Light Vehicles - Heavy Vehicles


		1	2 Mile	Rd			1	2 Mile	Rd			M-5	Exit-F	Ramp			M-5	Exit-R	Ramp		
		E	astbou	ınd			W	estbou	und			N	orthbo	und [.]			Sc	outhbo	und [.]		
Start Time	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Int. Total
07:00 AM	0	0	0	0	0	0	295	0	0	295	0	0	0	0	0	0	54	63	0	117	412
07:15 AM	0	0	0	0	0	0	317	0	0	317	0	0	0	0	0	0	98	85	0	183	500
07:30 AM	0	0	0	0	0	0	386	0	0	386	0	0	0	0	0	0	91	83	0	174	560
07:45 AM	0	0	0	0	0	0	434	0	0	434	0	0	0	0	0	0	108	88	0	196	630
Total	0	0	0	0	0	0	1432	0	0	1432	0	0	0	0	0	0	351	319	0	670	2102
08:00 AM	0	0	0	0	0	0	366	0	0	366	0	0	0	0	0	0	102	80	0	182	548
08:15 AM	0	0	0	0	0	0	366	0	0	366	0	0	0	0	0	0	95	65	0	160	526
08:30 AM	0	0	0	0	0	0	389	0	0	389	0	0	0	0	0	0	118	82	0	200	589
08:45 AM	0	0	0	0	0	0	418	0	0	418	0	0	0	0	0	0	89	84	0	173	591
Total	0	0	0	0	0	0	1539	0	0	1539	0	0	0	0	0	0	404	311	0	715	2254
Grand Total	0	0	0	0	0	0	2971	0	0	2971	0	0	0	0	0	0	755	630	0	1385	4356
Apprch %	0	0	0	0		0	100	0	0		0	0	0	0		0	54.5	45.5	0		
Total %	0	0	0	0	0	0	68.2	0	0	68.2	0	0	0	0	0	0	17.3	14.5	0	31.8	
Light Vehicles	0	0	0	0	0	0	2869	0	0	2869	0	0	0	0	0	0	749	608	0	1357	4226
% Light Vehicles	0	0	0	0	0	0	96.6	0	0	96.6	0	0	0	0	0	0	99.2	96.5	0	98	97
Heavy Vehicles	0	0	0	0	0	0	102	0	0	102	0	0	0	0	0	0	6	22	0	28	130
% Heavy Vehicles	0	0	0	0	0	0	3.4	0	0	3.4	0	0	0	0	0	0	0.8	3.5	0	2	3





Site Code : 16651611 Start Date : 6/11/2024

			2 Mile astbou					2 Mile estbou					Exit-F					Exit-Fouthbo			
Start Time	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Int. Total
Peak Hour A	nalysis	From	07:00	AM to	08:45 /	AM - P	eak 1	of 1													
Peak Hour fo	r Entir	e Inter	section	n Begir	ns at 07	:45 AN	1														
07:45 AM	0	0	0	0	0	0	434	0	0	434	0	0	0	0	0	0	108	88	0	196	630
08:00 AM	0	0	0	0	0	0	366	0	0	366	0	0	0	0	0	0	102	80	0	182	548
08:15 AM	0	0	0	0	0	0	366	0	0	366	0	0	0	0	0	0	95	65	0	160	526
08:30 AM	0	0	0	0	0	0	389	0	0	389	0	0	0	0	0	0	118	82	0	200	589
Total Volume	0	0	0	0	0	0	1555	0	0	1555	0	0	0	0	0	0	423	315	0	738	2293
% App. Total	0	0	0	0		0	100	0	0		0	0	0	0		0	57.3	42.7	0		
PHF	.000	.000	.000	.000	.000	.000	.896	.000	.000	.896	.000	.000	.000	.000	.000	.000	.896	.895	.000	.923	.910
Light Vehicles	0	0	0	0	0	0	1500	0	0	1500	0	0	0	0	0	0	419	311	0	730	2230
% Light Vehicles	0	0	0	0	0	0	96.5	0	0	96.5	0	0	0	0	0	0	99.1	98.7	0	98.9	97.3
Heavy Vehicles	0	0	0	0	0	0	55	0	0	55	0	0	0	0	0	0	4	4	0	8	63
% Heavy Vehicles	0	0	0	0	0	0	3.5	0	0	3.5	0	0	0	0	0	0	0.9	1.3	0	1.1	2.7






Site Code : 16651611 Start Date : 6/11/2024

Page No : 1

Groups Printed- Bikes, Peds


			2 Mile astbou					2 Mile /estboo					Exit-Forthbo					Exit-Fouthbo			
Start Time	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Int. Total
07:00 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:15 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:30 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:45 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
,																					
08:00 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
08:15 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
08:30 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
08:45 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Grand Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Apprch %	0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		
Total %																					





Site Code : 16651611 Start Date : 6/11/2024

			2 Mile astbou					2 Mile					Exit-F					Exit-F			
Start Time	Left	Thru	Right		App. Total	Left		Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru			App. Total	Int. Total
Peak Hour A	nalysis	From	07:00	AM to	08:45 /	AM - P	eak 1	of 1													
Peak Hour fo	r Entir	e Inter	section	n Begi	ns at 07	:00 AN	Λ														
07:00 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:15 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:30 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
07:45 AM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Volume	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
% App. Total	0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		
PHF	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000






Site Code : 16651612 Start Date : 6/11/2024

Page No : 1

Groups Printed- Light Vehicles - Heavy Vehicles


			2 Mile					2 Mile		igne voi		M-5	Exit-F					Exit-F			
		E	astbou	ınd			W	<u>estbou</u>	<u>und</u>			N	orthbo	und			S	outhbo	und		
Start Time	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Int. Total
04:00 PM	0	0	0	0	0	0	476	0	0	476	0	0	0	0	0	0	19	69	0	88	564
04:15 PM	0	0	0	0	0	0	484	0	0	484	0	0	0	0	0	0	24	65	0	89	573
04:30 PM	0	0	0	0	0	0	487	0	0	487	0	0	0	0	0	0	14	54	0	68	555
04:45 PM	0	0	0	0	0	0	491	0	0	491	0	0	0	0	0	0	15	66	0	81	572
Total	0	0	0	0	0	0	1938	0	0	1938	0	0	0	0	0	0	72	254	0	326	2264
05:00 PM	0	0	0	0	0	0	458	0	0	458	0	0	0	0	0	0	20	67	0	87	545
05:15 PM	0	0	0	0	0	0	446	0	0	446	0	0	0	0	0	0	22	72	0	94	540
05:30 PM	0	0	0	0	0	0	549	0	0	549	0	0	0	0	0	0	30	69	0	99	648
05:45 PM	0	0	0	0	0	0	544	0	0	544	0	0	0	0	0	0	29	66	0	95	639
Total	0	0	0	0	0	0	1997	0	0	1997	0	0	0	0	0	0	101	274	0	375	2372
Grand Total	0	0	0	0	0	0	3935	0	0	3935	0	0	0	0	0	0	173	528	0	701	4636
Apprch %	0	0	0	0		0	100	0	0		0	0	0	0		0	24.7	75.3	0		
Total %	0	0	0	0	0	0	84.9	0	0	84.9	0	0	0	0	0	0	3.7	11.4	0	15.1	
Light Vehicles	0	0	0	0	0	0	3849	0	0	3849	0	0	0	0	0	0	170	519	0	689	4538
% Light Vehicles	0	0	0	0	0	0	97.8	0	0	97.8	0	0	0	0	0	0	98.3	98.3	0	98.3	97.9
Heavy Vehicles	0	0	0	0	0	0	86	0	0	86	0	0	0	0	0	0	3	9	0	12	98
% Heavy Vehicles	0	0	0	0	0	0	2.2	0	0	2.2	0	0	0	0	0	0	1.7	1.7	0	1.7	2.1





Site Code : 16651612 Start Date : 6/11/2024

			2 Mile astbou					2 Mile					Exit-F					Exit-Fouthbo			
Start Time	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Left	Thru	Right	U-Turn	App. Total	Int. Total
Peak Hour A	nalysis	From	04:00	PM to	05:45 I	PM - P	eak 1	of 1													
Peak Hour fo	r Entir	e Inter	section	n Begir	ns at 05	:00 PN	/														
05:00 PM	0	0	0	0	0	0	458	0	0	458	0	0	0	0	0	0	20	67	0	87	545
05:15 PM	0	0	0	0	0	0	446	0	0	446	0	0	0	0	0	0	22	72	0	94	540
05:30 PM	0	0	0	0	0	0	549	0	0	549	0	0	0	0	0	0	30	69	0	99	648
05:45 PM	0	0	0	0	0	0	544	0	0	544	0	0	0	0	0	0	29	66	0	95	639
Total Volume	0	0	0	0	0	0	1997	0	0	1997	0	0	0	0	0	0	101	274	0	375	2372
% App. Total	0	0	0	0		0	100	0	0		0	0	0	0		0	26.9	73.1	0		
PHF	.000	.000	.000	.000	.000	.000	.909	.000	.000	.909	.000	.000	.000	.000	.000	.000	.842	.951	.000	.947	.915
Light Vehicles	0	0	0	0	0	0	1959	0	0	1959	0	0	0	0	0	0	99	270	0	369	2328
% Light Vehicles	0	0	0	0	0	0	98.1	0	0	98.1	0	0	0	0	0	0	98.0	98.5	0	98.4	98.1
Heavy Vehicles	0	0	0	0	0	0	38	0	0	38	0	0	0	0	0	0	2	4	0	6	44
% Heavy Vehicles	0	0	0	0	0	0	1.9	0	0	1.9	0	0	0	0	0	0	2.0	1.5	0	1.6	1.9






Site Code : 16651612 Start Date : 6/11/2024

Page No : 1

Groups Printed- Bikes, Peds


	12 Mile Rd Eastbound							2 Mile					Exit-F					Exit-F			
			astbol	ına			V	estbo	<u>una</u>			IN	<u>orthbo</u>	una				outhbo	una		
Start Time	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Int. Total
04:00 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:15 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:30 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:45 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
		_	_	_	_ 1	_	_	_		_ 1	_	_		_			_	_	_		
05:00 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
05:15 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
05:30 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
05:45 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Grand Total	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Apprch %	0	0	0	0	· ·	0	0	0	0	· ·	0	0	0	0	Ü	0	0	0	0	· ·	
Total %																					





Site Code : 16651612 Start Date : 6/11/2024

			2 Mile astbou					2 Mile estboo					Exit-Forthbo					Exit-Fouthbo			
Start Time	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Left	Thru	Right	Peds	App. Total	Int. Total
Peak Hour A	nalysis	From	04:00	PM to	05:45 F	PM - P	eak 1	of 1													
Peak Hour fo	r Entir	e Inter	section	n Begii	ns at 04	:00 PN	Λ														
04:00 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:15 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:30 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
04:45 PM	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Total Volume	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
% App. Total	0	0	0	0		0	0	0	0		0	0	0	0		0	0	0	0		
PHF	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000	.000









Home

Locate

Locate All

Email This

Auto-Locate:

Disclaimer: The Michigan Department of Transportation (MDOT) works with individual agencies (cities/villages, counties, metropolitan planning organizations (MPOs), regional planning organizations (RPOs), and other areas of MDOT) to identify existing traffic count programs and/or traffic data. ... more

List View	All DIRs		Report Center									
Record	of 1 Goto Record	go										
Location ID	63-3804	MPO ID										
Туре	SPOT	HPMS ID										
On NHS	Yes	On HPMS	No									
LRS ID	4462980	LRS Loc Pt.	3.140335									
SF Group	Urban Non State	Route Type										
AF Group	NoFactor	Route										
GF Group	Urban Non State	Active	Yes									
Class Dist Grp	NTL_3	Category	Primary									
Seas Clss Grp												
WIM Group												
QC Group	Default											
Fnct'l Class	(3) Other Principal Arterial	Milepost										
Located On	12 MILE RD											
Loc On Alias												
EAST OF	EAST OF Meadowbrook Rd											
More Detail												
STATION DAT												

STATION DATA

Directions: 2-WAY EB WB



AADT	AADT ⑦														
	Year	AADT	DHV-30	K %	D %	PA	ВС	Src							
	2023	25,911 ³		11	53	25,030 (97%)	881 (3%)	Grown from 2022							
	2022	25,353 ³		11	53	24,567 (97%)	786 (3%)	Grown from 2021							
	2021	25,328	2,808	11	53	24,935 (98%)	393 (2%)								
	2020	28,377 ³		14	79	27,355 (96%)	1,022 (4%)	Grown from 2019							
	2019	33,228 ²		14	79	31,966 (96%)	1,262 (4%)								

VOL	UME COUNT		
	Date	Int	Total
6	Wed 8/25/2021	15	25,054
4	Tue 8/24/2021	15	25,602

VOLUME .	TREND 🕖
Year	Annual Growth
2023	2%
2022	0%
2021	-11%
2020	-15%

CLA	CLASSIFICATION											
	Date	Int	Total									
4	Wed 8/25/2021	15	25,054									
4	Tue 8/24/2021	15	25,602									
			No. 100 to 100 t									







Home

Locate

Locate All

Email This

Auto-Locate:

Disclaimer: The Michigan Department of Transportation (MDOT) works with individual agencies (cities/villages, counties, metropolitan planning organizations (MPOs), regional planning organizations (RPOs), and other areas of MDOT) to identify existing traffic count programs and/or traffic data. ... more

List View	All DIRs		Report Center
Record	of 1 Goto Record	go	
Location ID	63-3911	MPO ID	39812
Туре	SPOT	HPMS ID	
On NHS	Yes	On HPMS	No
LRS ID	4402005	LRS Loc Pt.	3.304827
SF Group	Urban	Route Type	M Rte
AF Group	South	Route	005
GF Group	Urban	Active	Yes
Class Dist Grp	2_005_001	Category	Primary
Seas Clss Grp			
WIM Group			
QC Group	Default		
Fnct'l Class	(3) Other Principal Arterial	Milepost	
Located On	M-5		
Loc On Alias	Haggerty Connector		
	.25 MI S OF 13 MI RD		
More Detail 🕨			
CTATION DAT	-A		

STATION DATA

Directions: 2-WAY NB SB



AADT	AADT ②												
	Year	AADT	DHV-30	K %	D %	PA	BC	Src					
	2023	79,422 ⁸		9	62	76,802 (97%)	2,620 (3%)						
	2022	78,805 ⁸		9	62	76,205 (97%)	2,600 (3%)						
	2021	78,793 ⁸		9	62	76,193 (97%)	2,600 (3%)						
	2020	65,705 ⁸	5,728	9	62	63,574 (97%)	2,131 (3%)						
	2019	58,990 ⁸				58,459 (99%)	531 (1%)						
<<	<	> >>	1-5 of 1	6									

VOLUME COUNT					
	Date Int		Total		
4	Mon 8/24/2020	15	71,200		
Þ	Tue 2/14/2017	60	82,365		
-	Tue 7/29/2014	-	0		
-	Mon 7/28/2014	-	0		
-	Wed 7/23/2014	-	0		
-	- Tue 7/22/2014		0		
4	Tue 2/14/2012		76,272		
Þ	Wed 8/24/2011		78,425		
Þ	Tue 8/23/2011		79,256		
4	Tue 8/11/2009 6		77,844		
	<< > >> 1-10 of 2	20	****		

VOLUME TREND ②				
Year	Annual Growth			
2023	1%			
2022	0%			
2021	20%			
2020	11%			
2019	-25%			
2018	0%			
2017	4%			
2016	3%			
2015	3%			
2014	-1%			
<< <	> >> 1-10 of 15			







Home

Locate

Locate All

Email This

Auto-Locate:

Disclaimer: The Michigan Department of Transportation (MDOT) works with individual agencies (cities/villages, counties, metropolitan planning organizations (MPOs), regional planning organizations (RPOs), and other areas of MDOT) to identify existing traffic count programs and/or traffic data. ... more

List View	All DIRs		Report Center		
Record	Record 1 of 1 Goto Record go				
Location ID	63-6119	MPO ID	41026		
Туре	SPOT	HPMS ID	1_4_125_065		
On NHS	No	On HPMS	Yes		
LRS ID	0656706	LRS Loc Pt.	4.502		
SF Group	Urban Non State	Route Type			
AF Group	NoFactor	Route			
GF Group	Urban Non State	Active	Yes		
Class Dist Grp	NTL_4	Category	Primary		
Seas Clss Grp					
WIM Group					
QC Group	Default				
Fnct'l Class	(4) Minor Arterial	Milepost			
Located On	MEADOWBROOK RD				
Loc On Alias	as				
	0.5 MILE N OF 12 MILE (IN NOVI)				
More Detail 🕨					
STATION DAT					

STATION DATA

Directions: 2-WAY NB SB

AADT 🕖								
	Year	AADT	DHV-30	K %	D %	PA	ВС	Src
	2023	5,053 ³		12	66	4,918 (97%)	135 (3%)	Grown from 2022
	2022	4,944	579	12	66	4,916 (99%)	28 (1%)	
	2021	4,774 ³		12	63	4,549 (95%)	225 (5%)	Grown from 2020
	2020	4,190 ³		12	63	3,988 (95%)	202 (5%)	Grown from 2019
	2019	4,906	594	12	63	4,885 (100%)	21 (0%)	
<<	<	> >>	1-5 of 8	•	•			

VOLUME COUNT					
	Date In		Total		
6	Wed 6/22/2022	15	4,960		
6	Tue 6/21/2022	15	4,928		
9	Tue 3/19/2019	15	5,026		
9	Mon 3/18/2019 15		4,786		
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1					

VOLUME TREND ②					
Year	Annual Growth				
2023	2%				
2022	4%				
2021	14%				
2020	-15%				
2019	149%				
2018	0%				
2017	4%				

CLASSIFICATION				
Date		Int	Total	







LOCATION INFO		
Location ID	63-3899	
Туре	SPOT	
Fnct'l Class	2	
Located On	M-5 CD ON LOOP	
Direction	RAMP	
County	Oakland	
Community	Novi	
MPO ID	50709	
HPMS ID		
Agency	MDOT	

COUNT DATA INFO		
Count Status	Accepted	
Holiday	No	
Start Date	Tue 11/14/2017	
End Date	Wed 11/15/2017	
Start Time	9:00:00 AM	
End Time	9:00:00 AM	
Direction	RAMP	
Notes		
Station	3771	
Study		
Speed Limit		
Description		
Sensor Type	Axle/Tube	
Source		
Latitude,Longitude		

INTERVAL:15-MIN					
	15-min Interval			Hourly	
Time	1st	2nd	3rd	4th	Count
0:00-1:00	4	5	12	3	24
1:00-2:00	2	2	2	0	6
2:00-3:00	1	5	1	0	7
3:00-4:00	1	0	0	1	2
4:00-5:00	1	0	0	4	5
5:00-6:00	3	1	2	5	11
6:00-7:00	5	13	13	19	50
7:00-8:00	26	32	30	32	120
8:00-9:00	46	31	38	29	144
9:00-10:00	18	24	27	26	95
10:00-11:00	26	25	32	31	114
11:00-12:00	48	38	30	44	160
12:00-13:00	44	45	53	62	204
13:00-14:00	64	57	41	63	225
14:00-15:00	63	70	61	60	254
15:00-16:00	60	62	68	56	246
16:00-17:00	77	75	83	80	315
17:00-18:00	86	106	52	54	298
18:00-19:00	71	65	49	55	240
19:00-20:00	69	39	56	54	218
20:00-21:00	42	62	52	36	192
21:00-22:00	55	51	38	30	174
22:00-23:00	34	11	16	11	72
23:00-24:00	12	7	5	6	30
Total					3,206
AADT					2,473
AM Peak				11	:45-12:45 186
PM Peak				16	:30-17:30 355







Volume Count Report

LOCATION INFO			
Location ID	Location ID 63-3898		
Туре	SPOT		
Fnct'l Class	2		
Located On	M-5 CD ON RAMP		
Direction	RAMP		
County	Oakland		
Community	Novi		
MPO ID	58341		
HPMS ID			
Agency	MDOT		

COUNT DATA INFO		
Count Status	Accepted	
Holiday	No	
Start Date	Tue 11/14/2017	
End Date	Wed 11/15/2017	
Start Time	5:00:00 PM	
End Time	5:00:00 PM	
Direction	RAMP	
Notes		
Station	3734	
Study		
Speed Limit		
Description		
Sensor Type	Axle/Tube	
Source		
Latitude,Longitude		

INTERVAL:15-MIN					
	15-min Interval			Hourly	
Time	1st	2nd	3rd	4th	Count
0:00-1:00	14	6	7	6	33
1:00-2:00	1	1	1	4	7
2:00-3:00	1	4	0	0	5
3:00-4:00	2	0	0	1	3
4:00-5:00	1	3	2	4	10
5:00-6:00	3	6	8	6	23
6:00-7:00	15	15	26	48	104
7:00-8:00	40	29	56	63	188
8:00-9:00	46	44	41	58	189
9:00-10:00	36	37	34	31	138
10:00-11:00	34	40	39	49	162
11:00-12:00	29	49	51	65	194
12:00-13:00	75	83	60	49	267
13:00-14:00	75	63	56	73	267
14:00-15:00	70	70	71	69	280
15:00-16:00	96	81	98	80	355
16:00-17:00	129	95	141	123	488
17:00-18:00	164	147	101	78	490
18:00-19:00	95	92	69	53	309
19:00-20:00	69	57	45	34	205
20:00-21:00	66	52	55	43	216
21:00-22:00	68	59	46	42	215
22:00-23:00	36	18	21	21	96
23:00-24:00	23	15	1	3	42
Total					4,286
AADT					3,307
AM Peak				11:	45-12:45 283
PM Peak				16:	30-17:30 575

189-vph (2017) + 7-years growth @ 0.5% per year = 196-vph (2024)

490-vph (2017) + 7-years growth @ 0.5% per year = 507-vph (2024)







LOCATION INFO			
Location ID	63-0822		
Туре	SPOT		
Fnct'l Class	2		
Located On	M-5 CD OFF RAMP		
Direction	RAMP		
County	Oakland		
Community	Novi		
MPO ID	66344		
HPMS ID			
Agency	MDOT		

COUNT DATA INF	FO
Count Status	Accepted
Holiday	No
Start Date	Tue 11/14/2017
End Date	Wed 11/15/2017
Start Time	6:00:00 PM
End Time	6:00:00 PM
Direction	RAMP
Notes	
Station	4221
Study	
Speed Limit	
Description	
Sensor Type	Axle/Tube
Source	
Latitude,Longitude	

INTERVAL:15-MIN					
	15-min Interval			Hourly	
Time	1st	2nd	3rd	4th	Count
0:00-1:00	0	0	0	0	0
1:00-2:00	0	3	0	0	3
2:00-3:00	0	0	1	0	1
3:00-4:00	0	4	0	0	4
4:00-5:00	2	2	5	6	15
5:00-6:00	3	10	15	24	52
6:00-7:00	28	46	46	38	158
7:00-8:00	45	59	59	56	219
8:00-9:00	63	88	86	66	303
9:00-10:00	68	41	33	36	178
10:00-11:00	28	17	22	25	92
11:00-12:00	19	25	26	24	94
12:00-13:00	29	33	38	36	136
13:00-14:00	41	23	26	38	128
14:00-15:00	24	15	11	8	58
15:00-16:00	17	24	18	16	75
16:00-17:00	23	28	15	27	93
17:00-18:00	33	21	16	28	98
18:00-19:00	18	15	8	13	54
19:00-20:00	14	12	8	5	39
20:00-21:00	6	12	8	6	32
21:00-22:00	12	6	2	4	24
22:00-23:00	4	5	0	2	11
23:00-24:00	2	2	5	2	11
Total					1,878
AADT					1,449
AM Peak				08	:15-09:15
				10	308
PM Peak				12	148







LOCATION INFO				
Location ID	63-3800			
Туре	SPOT			
Fnct'l Class	2			
Located On	NBD M-5 OFF RAMP			
Direction	RAMP			
County	Oakland			
Community	Novi			
MPO ID	66417			
HPMS ID				
Agency	MDOT			

COUNT DATA INFO		
Count Status	Accepted	
Holiday	No	
Start Date	Tue 11/14/2017	
End Date	Wed 11/15/2017	
Start Time	6:00:00 PM	
End Time	6:00:00 PM	
Direction	RAMP	
Notes		
Station	3797	
Study		
Speed Limit		
Description		
Sensor Type	Axle/Tube	
Source		
Latitude,Longitude		

INTERVAL:15-MIN					
	15-min Interval			Hourly	
Time	1st	2nd	3rd	4th	Count
0:00-1:00	9	6	8	6	29
1:00-2:00	2	1	2	4	9
2:00-3:00	2	5	4	1	12
3:00-4:00	0	1	2	3	6
4:00-5:00	8	3	10	15	36
5:00-6:00	24	28	47	76	175
6:00-7:00	83	150	209	255	697
7:00-8:00	242	293	296	342	1,173
8:00-9:00	354	361	335	370	1,420
9:00-10:00	263	209	201	170	843
10:00-11:00	150	149	156	130	585
11:00-12:00	114	117	110	114	455
12:00-13:00	102	104	138	167	511
13:00-14:00	139	127	121	127	514
14:00-15:00	119	114	106	141	480
15:00-16:00	152	231	217	276	876
16:00-17:00	300	348	346	314	1,308
17:00-18:00	354	337	344	287	1,322
18:00-19:00	277	229	157	106	769
19:00-20:00	86	59	69	55	269
20:00-21:00	56	45	50	48	199
21:00-22:00	42	32	45	39	158
22:00-23:00	28	22	22	17	89
23:00-24:00	10	19	7	1	37
Total					11,972
AADT					9,240
AM Peak				80	:00-09:00 1,420
PM Peak				16	:15-17:15 1,362







LOCATION INFO			
Location ID	63-3896		
Туре	SPOT		
Fnct'l Class	2		
Located On	M-5 CD ON RAMP		
Direction	RAMP		
County	Oakland		
Community	Novi		
MPO ID	39806		
HPMS ID			
Agency	MDOT		

COUNT DATA INFO		
Count Status	Accepted	
Holiday	No	
Start Date	Tue 11/14/2017	
End Date	Wed 11/15/2017	
Start Time	5:00:00 PM	
End Time	5:00:00 PM	
Direction	RAMP	
Notes		
Station	3714	
Study		
Speed Limit		
Description		
Sensor Type	Axle/Tube	
Source		
Latitude,Longitude		

INTERVAL:15-MIN					
	15-min Interval			Hourly	
Time	1st	2nd	3rd	4th	Count
0:00-1:00	1	2	1	0	4
1:00-2:00	1	0	4	1	6
2:00-3:00	0	0	2	0	2
3:00-4:00	0	0	0	0	0
4:00-5:00	1	0	0	0	1
5:00-6:00	1	1	3	2	7
6:00-7:00	1	1	3	6	11
7:00-8:00	9	16	4	10	39
8:00-9:00	11	15	11	19	56
9:00-10:00	12	18	14	16	60
10:00-11:00	14	16	34	21	85
11:00-12:00	28	23	45	25	121
12:00-13:00	53	27	27	24	131
13:00-14:00	28	28	35	22	113
14:00-15:00	26	30	30	36	122
15:00-16:00	31	55	63	53	202
16:00-17:00	62	79	57	80	278
17:00-18:00	73	71	62	57	263
18:00-19:00	54	37	46	25	162
19:00-20:00	39	23	24	17	103
20:00-21:00	21	9	16	14	60
21:00-22:00	9	18	13	8	48
22:00-23:00	6	7	13	3	29
23:00-24:00	5	2	0	2	9
Total					1,912
AADT					1,475
AM Peak				11	:30-12:30 150
PM Peak				16	:15-17:15 289







LOCATION INFO				
Location ID	63-3897			
Туре	SPOT			
Fnct'l Class	2			
Located On	M-5 CD ON LOOP			
Direction	RAMP			
County	Oakland			
Community	Novi			
MPO ID	58339			
HPMS ID				
Agency	MDOT			

COUNT DATA INFO		
Count Status	Accepted	
Holiday	No	
Start Date	Tue 11/14/2017	
End Date	Wed 11/15/2017	
Start Time	5:00:00 PM	
End Time	5:00:00 PM	
Direction	RAMP	
Notes		
Station	4490	
Study		
Speed Limit		
Description		
Sensor Type	Axle/Tube	
Source		
Latitude,Longitude		

INTERVAL:15-MIN					
	15-min Interval Hourly			Hourly	
Time	1st	2nd	3rd	4th	Count
0:00-1:00	7	2	5	4	18
1:00-2:00	0	3	10	3	16
2:00-3:00	1	0	7	3	11
3:00-4:00	1	6	2	3	12
4:00-5:00	6	2	8	7	23
5:00-6:00	6	21	21	18	66
6:00-7:00	30	49	58	57	194
7:00-8:00	89	82	101	100	372
8:00-9:00	127	103	109	93	432
9:00-10:00	98	98	78	95	369
10:00-11:00	63	80	98	86	327
11:00-12:00	119	103	114	117	453
12:00-13:00	135	133	110	77	455
13:00-14:00	109	94	92	103	398
14:00-15:00	107	137	136	109	489
15:00-16:00	197	190	273	289	949
16:00-17:00	375	383	378	376	1,512
17:00-18:00	382	416	357	284	1,439
18:00-19:00	295	211	160	121	787
19:00-20:00	111	105	67	66	349
20:00-21:00	66	59	64	38	227
21:00-22:00	30	41	31	25	127
22:00-23:00	39	25	15	17	96
23:00-24:00	13	7	6	6	32
Total					9,153
AADT					7,063
AM Peak				11:	30-12:30 499
PM Peak				16:	30-17:30 1,552





LOCATION INFO				
Location ID	557_EB			
Туре	SPOT			
Fnct'l Class	-			
Located On	TWELVE MILE ROAD			
WEST OF	MEADOWBROOK			
Direction	EB			
County	Oakland			
Community	-			
MPO ID				
HPMS ID				
Agency	Oakland County - SCATS			

COUNT DATA INF	:0
	Accepted
Holiday	No
Start Date	Tue 1/11/2022
End Date	Wed 1/12/2022
Start Time	12:00:00 AM
End Time	12:00:00 AM
Direction	EB
Notes	
Station	557
Study	
Speed Limit	
Description	
Sensor Type	NA
Source	CombineVolumeCountsIncremental
Latitude,Longitude	

INTERVAL:15-MIN					
	1:	5-min	Interv	al	Hourly
Time	1st	2nd	3rd	4th	Count
0:00-1:00	8	6	8	13	35
1:00-2:00	9	4	2	2	17
2:00-3:00	2	1	2	0	5
3:00-4:00	1	2	1	1	5
4:00-5:00	1	4	8	16	29
5:00-6:00	22	16	23	28	89
6:00-7:00	33	36	56	84	209
7:00-8:00	108	127	155	198	588
8:00-9:00	164	179	151	189	683
9:00-10:00	135	194	214	271	814
10:00-11:00	191	106	141	160	598
11:00-12:00	133	128	195	179	635
12:00-13:00	195	202	186	275	858
13:00-14:00	315	337	319	323	1,294
14:00-15:00	347	345	339	371	1,402
15:00-16:00	415	406	367	325	1,513
16:00-17:00	320	256	251	252	1,079
17:00-18:00	282	258	246	222	1,008
18:00-19:00	243	196	207	218	864
19:00-20:00	207	180	177	170	734
20:00-21:00	171	155	126	89	541
21:00-22:00	97	85	78	31	291
22:00-23:00	62	41	30	36	169
23:00-24:00 📵	21	15	14	17	67
Total					13,527
AM Peak				09	:15-10:15 870
PM Peak				14	:45-15:45 1,559







LOCATION INF	-0
LOCATION INF	-0
Location ID	557_4_EB
Туре	SPOT
Fnct'l Class	-
Located On	TWELVE MILE ROAD
WEST OF	MEADOWBROOK
Direction	4
County	Oakland
Community	-
MPO ID	
HPMS ID	
Agency	Oakland County - SCATS

COUNT DATA INF	:0
Count Status	Accepted
Holiday	No
Start Date	Tue 1/11/2022
End Date	Wed 1/12/2022
Start Time	12:00:00 AM
End Time	12:00:00 AM
Direction	
Notes	
Station	557
Study	
Speed Limit	
Description	
Sensor Type	NA
Source	
Latitude,Longitude	

INTERVAL:15-MIN					
	1:	15-min Interval			Hourly
Time	1st	2nd	3rd	4th	Count
0:00-1:00	2	1	0	2	5
1:00-2:00	0	1	0	0	1
2:00-3:00	0	0	1	0	1
3:00-4:00	0	0	0	1	1
4:00-5:00	1	2	5	8	16
5:00-6:00	8	10	9	14	41
6:00-7:00	17	14	21	43	95
7:00-8:00	44	47	59	83	233
8:00-9:00	65	72	61	80	278
9:00-10:00	56	67	60	82	265
10:00-11:00	48	32	43	35	158
11:00-12:00	32	41	61	59	193
12:00-13:00	39	45	46	55	185
13:00-14:00	51	66	52	43	212
14:00-15:00	53	53	46	72	224
15:00-16:00	65	46	39	38	188
16:00-17:00	48	44	54	48	194
17:00-18:00	57	53	63	52	225
18:00-19:00	59	37	32	44	172
19:00-20:00	32	41	25	34	132
20:00-21:00	21	25	22	24	92
21:00-22:00	17	8	14	10	49
22:00-23:00	18	5	5	3	31
23:00-24:00 📵	1	0	2	2	5
Total					2,996
AM Peak				07	':45-08:45 281
PM Peak				14	:15-15:15 236







LOCATION INFO				
Location ID	557_2_NB			
Туре	SPOT			
Fnct'l Class	-			
Located On	MEADOWBROOK			
SOUTH OF	TWELVE MILE ROAD			
Direction	2			
County	Oakland			
Community	-			
MPO ID				
HPMS ID				
Agency	Oakland County - SCATS			

COUNT DATA INF	:0
Count Status	Accepted
Holiday	No
Start Date	Tue 1/11/2022
End Date	Wed 1/12/2022
Start Time	12:00:00 AM
End Time	12:00:00 AM
Direction	
Notes	
Station	557
Study	
Speed Limit	
Description	
Sensor Type	NA
Source	
Latitude,Longitude	

INTERVAL:15-MIN					
	1:	15-min Interval			Hourly
Time	1st	2nd	3rd	4th	Count
0:00-1:00	4	7	1	2	14
1:00-2:00	1	0	0	0	1
2:00-3:00	1	0	0	1	2
3:00-4:00	0	1	1	1	3
4:00-5:00	0	0	1	2	3
5:00-6:00	1	0	9	5	15
6:00-7:00	9	8	17	8	42
7:00-8:00	22	15	25	37	99
8:00-9:00	36	27	31	38	132
9:00-10:00	38	30	36	33	137
10:00-11:00	56	40	39	36	171
11:00-12:00	40	42	42	47	171
12:00-13:00	47	56	44	49	196
13:00-14:00	51	44	40	52	187
14:00-15:00	47	43	59	45	194
15:00-16:00	56	52	50	66	224
16:00-17:00	91	76	88	79	334
17:00-18:00	84	73	65	40	262
18:00-19:00	42	61	41	32	176
19:00-20:00	41	36	44	32	153
20:00-21:00	34	21	26	21	102
21:00-22:00	25	21	22	23	91
22:00-23:00	11	14	9	6	40
23:00-24:00 📵	5	11	18	10	44
Total					2,793
AM Peak				11	:45-12:45 194
PM Peak				16	334 334







LOCATION INF	-O
	1
Location ID	557_1_NB
Туре	SPOT
Fnct'l Class	-
Located On	MEADOWBROOK
SOUTH OF	TWELVE MILE ROAD
Direction	1
County	Oakland
Community	-
MPO ID	
HPMS ID	
Agency	Oakland County - SCATS

COUNT DATA INF	:0
Count Status	Accepted
Holiday	No
Start Date	Tue 1/11/2022
End Date	Wed 1/12/2022
Start Time	12:00:00 AM
End Time	12:00:00 AM
Direction	
Notes	
Station	557
Study	
Speed Limit	
Description	
Sensor Type	NA
Source	
Latitude,Longitude	

INTERVAL 45 M	INI				
INTERVAL:15-MIN					
	15-min Interval			Hourly	
Time	1st	2nd	3rd	4th	Count
0:00-1:00	1	1	3	1	6
1:00-2:00	1	0	1	0	2
2:00-3:00	1	1	1	0	3
3:00-4:00	0	1	2	1	4
4:00-5:00	1	2	0	0	3
5:00-6:00	0	1	0	4	5
6:00-7:00	0	4	4	4	12
7:00-8:00	7	11	12	11	41
8:00-9:00	13	13	15	10	51
9:00-10:00	15	17	28	42	102
10:00-11:00	42	9	20	17	88
11:00-12:00	21	19	15	23	78
12:00-13:00	23	17	26	17	83
13:00-14:00	15	19	19	29	82
14:00-15:00	16	22	22	23	83
15:00-16:00	26	26	37	45	134
16:00-17:00	43	25	42	46	156
17:00-18:00	41	36	44	24	145
18:00-19:00	21	27	33	17	98
19:00-20:00	12	22	11	11	56
20:00-21:00	11	10	11	11	43
21:00-22:00	8	8	7	5	28
22:00-23:00	2	7	6	1	16
23:00-24:00 📵	1	3	5	2	11
Total		-			1,330
AM Peak				09	0:15-10:15 129
PM Peak				16	3:45-17:45 167







LOCATION INFO				
Location ID	557_2_SB			
Туре	SPOT			
Fnct'l Class	-			
Located On	MEADOWBROOK			
NORTH OF	TWELVE MILE ROAD			
Direction	2			
County	Oakland			
Community	-			
MPO ID				
HPMS ID				
Agency	Oakland County - SCATS			

COUNT DATA INF	:0
Count Status	Accepted
Holiday	No
Start Date	Tue 1/11/2022
End Date	Wed 1/12/2022
Start Time	12:00:00 AM
End Time	12:00:00 AM
Direction	
Notes	
Station	557
Study	
Speed Limit	
Description	
Sensor Type	NA
Source	
Latitude,Longitude	

INTERVAL:15-MIN					
	15-min Interval			Hourly	
Time	1st	2nd	3rd	4th	Count
0:00-1:00	2	0	1	1	4
1:00-2:00	0	1	0	0	1
2:00-3:00	0	0	0	0	0
3:00-4:00	0	1	0	1	2
4:00-5:00	0	4	1	0	5
5:00-6:00	6	3	6	8	23
6:00-7:00	12	15	19	30	76
7:00-8:00	26	39	29	20	114
8:00-9:00	19	20	27	26	92
9:00-10:00	31	41	23	33	128
10:00-11:00	24	18	7	10	59
11:00-12:00	12	7	6	9	34
12:00-13:00	9	7	6	12	34
13:00-14:00	7	10	9	0	26
14:00-15:00	11	12	10	21	54
15:00-16:00	16	9	15	22	62
16:00-17:00	30	16	5	4	55
17:00-18:00	6	6	13	46	71
18:00-19:00	28	35	19	17	99
19:00-20:00	31	16	15	17	79
20:00-21:00	11	17	10	11	49
21:00-22:00	16	6	13	8	43
22:00-23:00	3	5	3	2	13
23:00-24:00 📵	5	4	0	1	10
Total					1,133
AM Peak				09	0:00-10:00 128
PM Peak				17	':45-18:45 128







LOCATION INF	-0
LOCATION INF	·U
Location ID	557_1_SB
Туре	SPOT
Fnct'l Class	-
Located On	MEADOWBROOK
NORTH OF	TWELVE MILE ROAD
Direction	1
County	Oakland
Community	-
MPO ID	
HPMS ID	
Agency	Oakland County - SCATS

COUNT DATA INF	:0
Count Status	Accepted
Holiday	No
Start Date	Tue 1/11/2022
End Date	Wed 1/12/2022
Start Time	12:00:00 AM
End Time	12:00:00 AM
Direction	
Notes	
Station	557
Study	
Speed Limit	
Description	
Sensor Type	NA
Source	
Latitude,Longitude	

INTERVAL:15-MIN					
	15-min Interval			Hourly	
Time	1st	2nd	3rd	4th	Count
0:00-1:00	2	0	0	1	3
1:00-2:00	0	1	0	0	1
2:00-3:00	0	0	0	0	0
3:00-4:00	0	0	0	2	2
4:00-5:00	0	3	0	0	3
5:00-6:00	2	2	3	3	10
6:00-7:00	6	8	18	15	47
7:00-8:00	12	18	16	35	81
8:00-9:00	40	21	21	33	115
9:00-10:00	22	30	20	22	94
10:00-11:00	20	23	18	17	78
11:00-12:00	14	18	23	30	85
12:00-13:00	17	20	17	30	84
13:00-14:00	18	28	15	29	90
14:00-15:00	25	23	28	25	101
15:00-16:00	20	36	26	33	115
16:00-17:00	41	33	35	40	149
17:00-18:00	37	32	28	28	125
18:00-19:00	22	20	16	9	67
19:00-20:00	15	11	8	14	48
20:00-21:00	9	8	8	10	35
21:00-22:00	10	3	7	7	27
22:00-23:00	1	2	2	1	6
23:00-24:00 📵	3	2	0	0	5
Total					1,371
AM Peak				07	':45-08:45 117
PM Peak				16	5:00-17:00 149







LOCATION INF	:0
Location ID	557_WB
Туре	SPOT
Fnct'l Class	-
Located On	TWELVE MILE ROAD
EAST OF	MEADOWBROOK
Direction	WB
County	Oakland
Community	-
MPO ID	
HPMS ID	
Agency	Oakland County - SCATS

COUNT DATA INF	÷0
Count Status	Accepted
Holiday	No
Start Date	Tue 1/11/2022
End Date	Wed 1/12/2022
Start Time	12:00:00 AM
End Time	12:00:00 AM
Direction	WB
Notes	
Station	557
Study	
Speed Limit	
Description	
Sensor Type	NA
Source	CombineVolumeCountsIncremental
Latitude,Longitude	

INTERVAL:15-MIN					
	15	15-min Interval Hou			
Time	1st	2nd	3rd	4th	Count
0:00-1:00	9	9	4	12	34
1:00-2:00	7	3	7	2	19
2:00-3:00	4	1	2	4	11
3:00-4:00	0	0	2	0	2
4:00-5:00	4	10	19	19	52
5:00-6:00	17	21	30	56	124
6:00-7:00	63	47	67	102	279
7:00-8:00	97	110	121	183	511
8:00-9:00	176	166	178	269	789
9:00-10:00	175	210	234	344	963
10:00-11:00	254	182	180	172	788
11:00-12:00	153	180	219	201	753
12:00-13:00	182	179	214	350	925
13:00-14:00	323	369	363	302	1,357
14:00-15:00	270	339	315	393	1,317
15:00-16:00	431	346	428	536	1,741
16:00-17:00	509	564	701	313	2,087
17:00-18:00	302	274	233	299	1,108
18:00-19:00	215	210	180	153	758
19:00-20:00	142	130	104	88	464
20:00-21:00	98	116	105	65	384
21:00-22:00	68	53	49	36	206
22:00-23:00	31	21	33	32	117
23:00-24:00 📵	25	16	20	14	75
Total					14,864
AM Peak				09	:15-10:15 1,042
PM Peak				15	:45-16:45 2,310







LOCATION IN	-0				
LOCATION INFO					
Location ID	557_4_WB				
Туре	SPOT				
Fnct'l Class	-				
Located On	TWELVE MILE ROAD				
EAST OF	MEADOWBROOK				
Direction	4				
County	Oakland				
Community	-				
MPO ID					
HPMS ID					
Agency	Oakland County - SCATS				

COUNT DATA INFO			
Count Status	Accepted		
Holiday	No		
Start Date	Tue 1/11/2022		
End Date	Wed 1/12/2022		
Start Time	12:00:00 AM		
End Time	12:00:00 AM		
Direction			
Notes			
Station	557		
Study			
Speed Limit			
Description			
Sensor Type	NA		
Source			
Latitude,Longitude			

INTERVAL:15-MIN					
	15-min Interval				Hourly
Time	1st	2nd	3rd	4th	Count
0:00-1:00	2	1	2	1	6
1:00-2:00	2	0	1	0	3
2:00-3:00	0	1	0	1	2
3:00-4:00	0	0	0	0	0
4:00-5:00	0	0	0	0	0
5:00-6:00	2	0	0	3	5
6:00-7:00	1	1	0	3	5
7:00-8:00	0	2	5	13	20
8:00-9:00	12	20	15	19	66
9:00-10:00	8	10	9	16	43
10:00-11:00	18	7	12	7	44
11:00-12:00	7	12	7	7	33
12:00-13:00	8	10	10	16	44
13:00-14:00	13	21	15	26	75
14:00-15:00	19	21	22	29	91
15:00-16:00	33	33	41	59	166
16:00-17:00	55	83	151	47	336
17:00-18:00	29	25	20	18	92
18:00-19:00	16	15	11	19	61
19:00-20:00	14	6	12	5	37
20:00-21:00	10	15	8	6	39
21:00-22:00	8	6	4	4	22
22:00-23:00	2	3	4	9	18
23:00-24:00 📵	3	2	6	3	14
Total	1,222				
AM Peak	08:00-09:00 66				
PM Peak	15:45-16:45 348				







LOCATION INFO				
Location ID	19201_EB			
Туре	SPOT			
Fnct'l Class	-			
Located On	TWELVE MILE ROAD			
WEST OF	M-5 SB OFF RAMP			
Direction	EB			
County	Oakland			
Community	-			
MPO ID				
HPMS ID				
Agency	Oakland County - SCATS			

COUNT DATA INF	:O
Count Status	Accepted
Holiday	No
Start Date	Tue 1/11/2022
End Date	Wed 1/12/2022
Start Time	12:00:00 AM
End Time	12:00:00 AM
Direction	EB
Notes	
Station	19201
Study	
Speed Limit	
Description	
Sensor Type	NA
Source	CombineVolumeCountsIncremental
Latitude,Longitude	

INTERVAL:15-MIN					
	15-min Interval				Hourly
Time	1st	2nd	3rd	4th	Count
0:00-1:00	7	6	7	9	29
1:00-2:00	4	4	3	2	13
2:00-3:00	4	0	0	0	4
3:00-4:00	0	3	3	2	8
4:00-5:00	0	2	1	6	9
5:00-6:00	10	3	14	23	50
6:00-7:00	13	16	37	44	110
7:00-8:00	65	70	98	123	356
8:00-9:00	86	103	92	118	399
9:00-10:00	86	83	82	61	312
10:00-11:00	88	70	80	68	306
11:00-12:00	51	55	63	61	230
12:00-13:00	71	67	58	97	293
13:00-14:00	96	93	88	86	363
14:00-15:00	75	95	104	86	360
15:00-16:00	99	109	120	125	453
16:00-17:00	129	151	156	112	548
17:00-18:00	71	100	130	98	399
18:00-19:00	136	166	146	128	576
19:00-20:00	159	138	130	120	547
20:00-21:00	115	92	85	57	349
21:00-22:00	72	70	47	35	224
22:00-23:00	28	26	27	33	114
23:00-24:00 📵	10	8	32	15	65
Total					6,117
AM Peak	07:30-08:30 410				
PM Peak	18:15-19:15 599				







LOCATION INFO				
Location ID	19201_SB			
Туре	SPOT			
Fnct'l Class	-			
Located On	M-5 SB OFF RAMP			
NORTH OF	TWELVE MILE ROAD			
Direction	SB			
County	Oakland			
Community	-			
MPO ID				
HPMS ID				
Agency	Oakland County - SCATS			

COUNT DATA INF	:O
Count Status	Accepted
Holiday	No
Start Date	Tue 1/11/2022
End Date	Wed 1/12/2022
Start Time	12:00:00 AM
End Time	12:00:00 AM
Direction	SB
Notes	
Station	19201
Study	
Speed Limit	
Description	
Sensor Type	NA
Source	CombineVolumeCountsIncremental
Latitude,Longitude	

INTERVAL:15-MIN					
	15-min Interval				Hourly
Time	1st	2nd	3rd	4th	Count
0:00-1:00	17	10	2	6	35
1:00-2:00	0	0	0	4	4
2:00-3:00	0	0	0	4	4
3:00-4:00	0	0	11	0	11
4:00-5:00	0	22	32	9	63
5:00-6:00	36	31	43	62	172
6:00-7:00	42	50	89	101	282
7:00-8:00	99	106	64	104	373
8:00-9:00	80	100	76	90	346
9:00-10:00	58	67	56	52	233
10:00-11:00	43	46	48	57	194
11:00-12:00	51	54	57	47	209
12:00-13:00	48	56	40	72	216
13:00-14:00	61	48	59	45	213
14:00-15:00	42	38	53	67	200
15:00-16:00	61	49	39	39	188
16:00-17:00	45	43	59	85	232
17:00-18:00	48	44	60	95	247
18:00-19:00	78	72	112	71	333
19:00-20:00	94	80	46	46	266
20:00-21:00	75	65	14	36	190
21:00-22:00	13	20	14	22	69
22:00-23:00	25	11	11	20	67
23:00-24:00 📵	19	52	2	0	73
Total					4,220
AM Peak	06:30-07:30 395				
PM Peak	17:45-18:45 357				







Volume Count Report

LOCATION INF	Ю
Location ID	19201_1_SB
Туре	SPOT
Fnct'l Class	-
Located On	M-5 SB OFF RAMP
NORTH OF	TWELVE MILE ROAD
Direction	1
County	Oakland
Community	-
MPO ID	
HPMS ID	
Agency	Oakland County - SCATS

COUNT DATA INF	:0
Count Status	Accepted
Holiday	No
Start Date	Tue 1/11/2022
End Date	Wed 1/12/2022
Start Time	12:00:00 AM
End Time	12:00:00 AM
Direction	
Notes	
Station	19201
Study	
Speed Limit	
Description	
Sensor Type	NA
Source	
Latitude,Longitude	

INTERVAL:15-M	IN				
	1:	5-min	Interv	al	Hourly
Time	1st	2nd	3rd	4th	Count
0:00-1:00	1	2	1	1	5
1:00-2:00	0	0	0	0	0
2:00-3:00	0	0	0	0	0
3:00-4:00	0	0	0	0	0
4:00-5:00	0	2	2	0	4
5:00-6:00	9	6	10	10	35
6:00-7:00	8	13	13	26	60
7:00-8:00	20	21	14	21	76
8:00-9:00	13	20	18	19	70
9:00-10:00	10	9	7	6	32
10:00-11:00	7	11	7	7	32
11:00-12:00	9	5	4	6	24
12:00-13:00	7	10	8	23	48
13:00-14:00	17	6	19	7	49
14:00-15:00	10	5	13	6	34
15:00-16:00	10	13	6	7	36
16:00-17:00	4	10	8	4	26
17:00-18:00	1	5	7	40	53
18:00-19:00	16	7	16	12	51
19:00-20:00	13	12	4	3	32
20:00-21:00	6	14	2	3	25
21:00-22:00	3	4	1	3	11
22:00-23:00	5	4	1	8	18
23:00-24:00 📵	4	43	0	0	47
Total					768
AM Peak				06	:45-07:45 81
PM Peak				17	':45-18:45 79







Volume Count Report

LOCATION INF	0
Location ID	19201_2_SB
Туре	SPOT
Fnct'l Class	-
Located On	M-5 SB OFF RAMP
NORTH OF	TWELVE MILE ROAD
Direction	2
County	Oakland
Community	-
MPO ID	
HPMS ID	
Agency	Oakland County - SCATS

COUNT DATA INF	:0
Count Status	Accepted
Holiday	No
Start Date	Tue 1/11/2022
End Date	Wed 1/12/2022
Start Time	12:00:00 AM
End Time	12:00:00 AM
Direction	
Notes	
Station	19201
Study	
Speed Limit	
Description	
Sensor Type	NA
Source	
Latitude,Longitude	

INTERVAL:15-M	IN				
	1:	5-min	Interv	al	Hourly
Time	1st	2nd	3rd	4th	Count
0:00-1:00	4	2	1	2	9
1:00-2:00	0	0	0	0	0
2:00-3:00	0	0	0	1	1
3:00-4:00	0	0	2	0	2
4:00-5:00	0	7	6	2	15
5:00-6:00	5	4	9	17	35
6:00-7:00	8	11	20	21	60
7:00-8:00	20	21	18	33	92
8:00-9:00	25	30	19	16	90
9:00-10:00	11	12	15	11	49
10:00-11:00	10	7	6	13	36
11:00-12:00	10	9	8	8	35
12:00-13:00	10	10	11	12	43
13:00-14:00	9	10	6	6	31
14:00-15:00	7	5	8	15	35
15:00-16:00	14	13	15	10	52
16:00-17:00	11	11	7	14	43
17:00-18:00	8	13	10	8	39
18:00-19:00	17	13	19	14	63
19:00-20:00	20	18	11	13	62
20:00-21:00	13	9	3	8	33
21:00-22:00	2	4	2	5	13
22:00-23:00	6	2	2	5	15
23:00-24:00 📵	3	2	0	0	5
Total					858
AM Peak				07	':45-08:45 107
PM Peak				18	3:30-19:30 71







Volume Count Report

LOCATION INF	:0
Location ID	19201_WB
Туре	SPOT
Fnct'l Class	-
Located On	TWELVE MILE ROAD
EAST OF	M-5 SB OFF RAMP
Direction	WB
County	Oakland
Community	-
MPO ID	
HPMS ID	
Agency	Oakland County - SCATS

COUNT DATA INF	:0
Count Status	Accepted
Holiday	No
Start Date	Tue 1/11/2022
End Date	Wed 1/12/2022
Start Time	12:00:00 AM
End Time	12:00:00 AM
Direction	WB
Notes	
Station	19201
Study	
Speed Limit	
Description	
Sensor Type	NA
Source	CombineVolumeCountsIncremental
Latitude,Longitude	

INTERVAL:15-M	IN				
	1:	5-min	Interv	al	Hourly
Time	1st	2nd	3rd	4th	Count
0:00-1:00	8	7	4	9	28
1:00-2:00	8	3	7	4	22
2:00-3:00	1	3	2	4	10
3:00-4:00	0	0	1	1	2
4:00-5:00	5	11	17	12	45
5:00-6:00	19	17	24	52	112
6:00-7:00	59	38	56	79	232
7:00-8:00	72	90	104	128	394
8:00-9:00	134	148	160	143	585
9:00-10:00	114	83	98	119	414
10:00-11:00	83	94	116	96	389
11:00-12:00	109	97	102	118	426
12:00-13:00	115	101	125	136	477
13:00-14:00	112	146	134	128	520
14:00-15:00	113	144	111	136	504
15:00-16:00	164	135	192	176	667
16:00-17:00	167	141	183	208	699
17:00-18:00	187	180	160	146	673
18:00-19:00	155	167	142	132	596
19:00-20:00	101	91	98	69	359
20:00-21:00	74	83	65	48	270
21:00-22:00	34	46	41	34	155
22:00-23:00	39	25	26	21	111
23:00-24:00 📵	17	10	18	15	60
Total					7,750
AM Peak				08:	00-09:00 585
PM Peak				16:	30-17:30 758

OAKLAND COUNTY ROAD COMMISSION TRAFFIC - SAFETY DEPARTMENT SIGNAL WORK ORDER

BY: 7. CRECH.	NG:	MAINTENANCE		2 3 3 3 3 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4	REUZ d Z to W.F.G)	TONE		DATE: 1 /8 /15
CHARGES:	PLEASE PERFORM THE FOLLOWING:	L MODERNIZE	JOB#:	2 3 4 1 2 2 2 2 2 3 4 4 1 2 3 3 4 4 1 5 3 3 4 5 1 5 1 5 1 5 1 5 1 5 1 5 1 5 1 5 1 5	Change Pers & F	MINITROL	No.	
SS STATE#:	PLEASI	ELECTRICAL DEVICE: INSTALL UNDERGROUND:	EDISON OK: YES NO COORDINATE W/DISTRICT 7:	DIAL T SPLIT. 1 SPLIT. 1 CHANGE TIMING	CHANGE BREAKOUT OR EPROM: Chunge CHANGE HOURS OF OPERATION:	REPROGRAM TBC INSTALL INTERCONNECT:	MBT OK: YES NO OCHANGE - RECORD CORRECTION	

```
1. NO PED 1
2. 12 MILE PED NORTH & SOUTH
3. NO PED 3
4. MEADOWBROOK PED EAST & WEST (P-)
                                                                                                                                NOTE :- ALL DETECTORS ARE AUTOSCOPE
                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             FLR
FLR
                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   A APP 2 : EB 12 MILE L,C,R,RT B APP 2 : SB MEADOWBROOK L,R
                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                       JUMPERS: -
195-196,197-198,199-200,201-202,207-208,217-218,219-220,221-222,
223-224,229-230,233-234,235,236,237-238,298-302,321-PBL,325-326,
327-328,329-PBL,334-335,343-PBL,345-346,347-348,349-350,351-PBL,
356-357,365-366,367-368,369-PBL,373-PBL,387-PBL,391-PBL,
                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                          A B C M-1 W-2
                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                  Personality revision is 2 (=B).
A STAGE HAS PERMANENT DEWAND.
DEMAND FOR STAGE B IN FLEXI & ISOL, SET ZNEG TO DISABLE.
Pedestrians have automatic introduction using SCATS Y-.
MEADOWBROOK NEAR has early cut-off operation in B stage.
                                                                                                                                                              (2004 CAMERAS).
INTERSECTION :- 557 12 MILE & MEADOWBROOK
DESCRIPTION PROMS :- X00557 / E2403
CONTROLLER TYPE :- STANDARD PERSONALITY CONTROLLER
SOFTWARE TYPE :- MOD 52 SCATS
INFUTS :- ALL DETECTOR:
2. WB 12 MILE L (LK)
3. WB 12 MILE R (LK)
6. SB MEADOWBROOK L (LK)
5. SB MEADOWBROOK R (LK)
6. SB MEADOWBROOK R (LK)
7. EB 12 MILE R (LK)
8. EB 12 MILE R (LK)
9. EB 12 MILE R (LK)
10. EB 12 MILE R (LK)
11. NB MEADOWBROOK L (LK)
12. NB MEADOWBROOK R (LK)
12. NB MEADOWBROOK R (LK)
                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               BACKPANEL: - SIZE P-12 CABINET
LOAD SWITCH 2 - 12 MILE

· LOAD SWITCH 4 - MEADOWBROOK NEAR
LOAD SWITCH 5 - MEADOWBROOK FAR (OLA)
LOAD SWITCH 9 - 12 MILE PED NORTH & SOUTH
LOAD SWITCH 10 - MEADOWBROOK PED EAST & WEST
                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                             PEDESTRIANS :-
                                                                                                                                                                                                                                                                                                                                                                                                                                           PED 2: 12 MILE PED NORTH & SOUTH W.F.G. PED 4: MEADOWBROOK PED EAST & WEST P.B.
                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                   APPROACHES :-
A APP 1 : WB 12 MILE L,C,R,RT
B APP 1 : NB MEADOWBROOK L,R
                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 A, B
                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                               AB
                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                              SPECIAL FEATURES :-
                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 FLEXIDATA :-
SEQUENCE A, B
                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                 AUTO REL
                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                                      R- REL
Q- REL
Q+ REL
```

MMU:(MENU : SET/VIEW CONFIG)

Dual Indication Enable: R+G: Channel 2, 4, 5

R+Y: Channel 2, 4, 5

G+Y: Channel 2, 4, 5

Red Fail Enable:

Enable: Channel 2, 4, 5

All OFF except: Recurrent pulse Program Memory Card

Unit Options:

Y & R Clearance Disable: Channel 2, 4, 5 Enabled

Program Card:

Compatible Channels: 4-5 Min Flash Time: 4+2+1 Min Yellow Change Disable: None Voltage Monitor Latch: NONE

CHECKSUMS TIMES: 6A / 152 PERS: CB / 313 TOTAL: AI / 241

FLEXILINK PLAN DATA

Hours of Flashing: Abadowhrook Hours of Flashing: None PL0 PL1 PL2 PL3 PL4 PL5	Date: 12/18/14 Prepa	Prepared By: Terry Creech
rs of Operation: 7 Days: 24 Hours rs of Flashing: None PL0 PL1 PL2 PL3 PL4	City: Novi	Novi
None LO PL1 PL2 PL3 PL4 80 120 120 0 0 0 0 33 63 64 67 37 37	Appre	Approved By: Rachel Jones
CL 80 120 PL4 PL4 CL 80 120 120 C 0 0 0 0 C 0 0 0 0 0 D 0		
CL 80 120 A 0 0 0 B 33 63 C 0 E 6 F 6 G 7 R+ Of (Y-) C 2- Z+ C 2- Z+ C 2- Z+ C 37 XL XL	-	PL7 PL8
A 0 0 0 C C S S 63 D C E E F C C S S C S C S C S S C S S C S S S C S S C S S C S S C S S C S S C S S C S S C S S C S S C S S C		
B 33 63 C C C C C C C C C		
C D E E E E R-P ST		
D F G G F G G G G G G G G G G G G G G G		
E F G G S S S S S S S S S S S S S S S S S		
F G G G G G G G G G		
G R- R+ R+ Of (Y-) 67 37 Y+ C 27 Z- Z- Q- Q- C N XL XL		
R- R+ Of (Y-) 67 37 Y+ C 87 Z- Z+ Q- Q- Q- XH XH		
R+ Of (Y-) 67 37		
Of (Y-) 67 37 Y+ C 67 37 Z- Z- Z- C C C C C C C C C		
* ~ \$ & \$ X X		
H		

NOTE: Stages with 1 second of phase time are skipped. Blank entries are default values equal to 0. Except for an AWA controller, entries #8 to #15 (=254) and 'C' entry means continuous (=255).

								Ilmers	
Phase [Direction	Min	Max	ECO	Amber	All Red	Gap	Hdwy	Waste
V	12 Mile	10.0	50.0	17.0	4.3	1.7	3.0	1.2	10.0
В	Meadowbrook	8.0	30.0	4.0	3.9	2.5	3.5	1.4	10.0
C									
۵									
ш									
ш									
9									

						1		<	
Pedestrian Crossing Times	Direction	12 Mile Ped North & South (Ped2)	Aeadowbrook Ped East & West (Ped4)					Normal Operating M	Isolated Flexilink
Ped	Dire	12	M]			
Plan# Ped	1 Dire	2 12	1 We	3	_				
	0:00 1 Dire	6:00 2 12	9:00 1 Me	15:00 3	19:00 1				
Plan#	-	2	-	8 15:00 3	8 19:00 1				

	-	2	-	3	<u></u>					
	0:00	00:9	00:6	15:00	19:00					
-	14	00	00	00	00					
	SC1	SC2	SC3	SC4	SC5	SC6	SC7	SC8	000	- 000

	MON-FRI
	00
JMBER	WED
CODE NU	4
- WEEK	End of Schedule
DAY OF	0

Normal Operating Mode Isolated Flexilink Master Isolated

 Walk
 CL 1
 CL 2

 7.0
 17.0
 3.0


 7.0
 12.0
 3.4

4	WED	00	MON-FRI	12	MON, FRI, SAT
2	THUR	6	MON-SAT	13	SAT,SUN
9	FRI	10	TUE,WED,THU	14	EVERY DAY
7	SAT	11	MON,FRI	15	NEVER

Autoscope 37-Pin Male Output Harness (3345762) Wiring CO#557 - 12 Mile & Meadowbrook Autoscope Output Harness Pins #1 & #20 to Logic Common & Pins #18 & # 37 to +24 VDC

Camera	EIM	EIM	Output	D-Conn		stor No.	6	Phase No.
umber	Number Switch Position	LED#	Harness Pin#	Pin (1,2,)	D-Conn format On Print (9,10,) (1,2,)	On Print (1,2,)	Detector Description	(1,2,3,)
	-	-	29	-	6	1	WB 12 Mile L	2
	1	2	30	2	10	2	WB 12 Mile C	2
	1	3	31	3	11		WB 12 Mile R	2
*	1	4	32	4	12	4	WB 12 Mile RT	2
	1	2	33					
	1	9	34					
	1	7	35					
	-	8	36					
	2	1	10	5	13	5	SB Meadowbrook L	4
	2	2	11	9	14	9	SB Meadowbrook R	4
	2	က	12					
c	2	4	13					
7	2	5	14					
	2	9	15					
	2	7	16				i	
	2	8	17					
	3	1	21	7	15	7	EB 12 Mile L	2
	3	2	22	80	16	80	EB 12 Mile C	2
	3	3	23	6	17	6	EB 12 Mile R	2
c	3	4	24	10	18	10	EB 12 Mile RT	2
,	3	2	25					
	3	9	26					
	3	7	27					
	3	8	28					
	4	1	2	11	19	11	NB Meadowbrook L	4
	4	2	3	12	20	12	NB Meadowbrook R	4
	4	3	4					
	4	4	5					
+	4	2	9					
	4	9	7					
	4	7	80					
	-	a	0					

EIM		Input	Phase Status	
Switch	EIM	Harness	Input From	Backpanel Terminal Position and Number
Position	LED#	Pin#	+24 VDC	
5	-	29	Phase 8 Green	
2	-	30	Phase 7 Green	
5	-	31	Phase 6 Green	
5	-	32	Phase 5 Green	
5	-	33	Phase 4 Green	LS 4 Green 221
5	1	34	Phase 3 Green	
5	-	35	Phase 2 Green	LS 2 Green 199
5	1	36	Phase 1 Green	
9	2	10	Phase 8 Red	
9	2	11	Phase 7 Red	
9	2	12	Phase 6 Red	
9	2	13	Phase 5 Red	
9	2	14	Phase 4 Red	LS 4 Red 217
9	2	15	Phase 3 Red	
9	2	16	Phase 2 Red	LS 2 Red 195
9	2	17	Phase 1 Red	



OAKLAND COUNTY ROAD COMMISSION TRAFFIC - SAFETY DEPARTMENT SIGNAL WORK ORDER

LOCATION: M-5 5B Off	Ram	p	L	12	2	Mi	11					_ D	ATI	E:	-2	2-	-14	†	
CITY/TOWNSHIP: NOUI											_ B	Y:_	Т.	(re	ec	4		
COUNTY#: 19201 STATE#	63	192	z -(21-	101	(CH/	RG	ES:	4	94	12	1. (29	8		N	PK # 58	Medic
																			CON
PL	EASE	SPE	RFC	JKIVI	ın	E FO	المار	OW	INO										
ELECTRICAL DEVICE: IN:	STAL	L _		_ M	ODE	RNI	ZE	_	_	MA	INT	ENA	ANC	E			JUL	1	4 201
UNDERGROUND:										*	_								
EDISON OK: YES N	JO.						10	B#-								TR	AFF	CO	PERAT
- PAGE TO CONTROL OF THE CAR AS TO																			
COORDINATE W/DISTRICT 7:										-			-			_			-
20004											1	1	1		·				1
DIAL. SPLIT		2	3	1 4		2	2	3	2		3	2	3	3		1	2	3	4
CHANGE TIMING	1	L)	7		-		J	7		1	1	3		£1.	1		.5	4
CHANGE OFFSET																			
CHANGE CYCLE LENGTH																			
ADD DIAL/SPLIT																			
OLD:																			
REPROGRAM TBC																			
INSTALL INTERCONNECT:	_TB(C _		MI	NITI	ROL	_		TO	NE									
MBT OK:YESNO																			
NO CHANGE - RECORD CORRE	CTIO'	N																	
					ra.de	lee h			, .				•	r 4'	Tr	-	2.4	- Ala	00
OTHER: Swap out existing	,												100	CM	1 -	co	776	UFF	J,
ook up field wiring per p	pape	rv	101	rK	(1	54	+1	-5	5	sw	itch	reo	1).						
estall modern & prone jack														0-	an	NP	tor	. 8	hart
					-														1.001
o Autosope per paperu	iock	,		Ke	q	vire	es	-	7	d	rec	K	·W	n	ch	M	je.		
PPROVED BY:)				-								D	ATE	1: 1	1	31	14	
TE INSTALLED: 7-11-15	- VI								_	-							-		-
STALLED BY: Richardson (ase																		

```
DESCRIPTION PROMS :- X19200 / F2003
 CONTROLLER TYPE :- STANDARD PERSONALITY CONTROLLER
 SOFTWARE :- MOD 52 SCATS
 INPUTS :-
  1. EB 12 MILE L (LK)
                                         NOTE: ALL DETECTORS ARE
  2. EB 12 MILE C (LK)
                                                AUTOSCOPE (2004 CAMERAS).
  3. EB 12 MILE R (LK)
  4. WB 12 MILE L (LK)
  5. WB 12 MILE C (LK)
  6. WB 12 MILE R (LK)
  7. SB M-5 OFF RAMP LT L (LK)
  8. SB M-5 OFF RAMP LT R (LK)
  9. SB M-5 OFF RAMP RT L (NL)
 10. SB M-5 OFF RAMP RT R (NL)
 APPROACHES :-
A APP 1 : EB 12 MILE L,C,R A APP 2 : WB 12 MILE L,C,R B APP 1 : SB M-5 OFF RAMP LT L,R B APP 2 : SB M-5 OFF RAMP RT L,R
FLEXIDATA :-
                                PEDESTRIANS :-
                    A, B
SEQUENCE A, B
AUTO REL
 R- REL A
R+ REL B
 R+ REL
 Q- REL
Q+ REL
 SPECIAL FEATURES :-
    Personality revision is 1 (=A).
    M-5 OFF RAMP (NEAR) has early cut-off operation in B stage.
    A stage has a permanent demand.
    Demand for B stage in flexi and isol, set ZNEG to disable.
 BACKPANEL - 4 PHASE EAGLE
   LOAD SWITCH 2: 12 MILE ROAD
                                 A & C
    LOAD SWITCH 4: M-5 OFF RAMP (NEAR) B
                                                     FLR
   LOAD SWITCH 5: M-5 OFF RAMP (FAR) D
                                                     FLR
 JUMPERS :-
    121-213, 151-152, 153-154, 155-156, 158-159, 161-162, 164-165, 173-174,
    175-176, 177-178, 233-PB1, 237-PB1, 241-242, 243-244, 245-246, 255-256,
    257-258, 259-260, 261-262, 263-PB1.
 SIGNAL MONITOR: 4-5
   All switches OFF EXCEPT: Dual Select A&B; G&Y Enable; SSM 2,4,5.
   Minimum flash = 4 + 2 + 1.
   ******* Checksums: Times 93 / 223
    * CONTROLLER INFORMATION SHEET *
      FOR SITE NO. 19201 *
                                                Pers C2 / 302
             T. CREECH
             22-Jan-2014
                                                    Total 51 / 121
```

INTERSECTION :- 19201 M-5 SB OFF RAMP & 12 MILE

FLEXILINK PLAN DATA

Intersection # 19201 State # 63192-01-101 Date: 01/22/14 Prepared By: T. Creech

Intersection: M-5 SB Off Ramp & 12 Mile City: Novi

Hours of Operation: 7 Days: 5am - 12:30am Approved By: R. Jones

Hours of Flashing: 7 Days 12:30am - 5am

		PL0	PL1	PL2	PL3	PL4	PL5	PL6	PL7	PL8
0	CL		80	120	120					
1	A		0	0	0		1-5			
2	В		58	82	82					
3	С									
4	D									
5	E									
6	F									
7	G									
8	R-									
9	R+		0 = 1	11 - 1						
10	Of (Y-)		24	97	100					
11	Y+	С								
12	Z-									
13	Z+					1				
14	Q-									
15	Q+									
16	XH									2
17	XL									

NOTE: Stages with 1 second of phase time are skipped. Blank entries are default values equal to 0. Except for an AWA controller, entries #8 to #15 (=254) and 'C' entry means continuous (=255).

								Timers	
Phase	Direction	Min	Max	ECO	Amber	All Red	Gap	Hdwy	Waste
Α	12 Mile	12.0	48.0		4.3	1.6	3.0	1.2	10.0
В	M-5 Ramp	8.0	28.0	3.0	3.5	2.5	3.2	1.2	10.0
С									
D									
Е									
F									
G									

	Day	Hours	Plan#
SC1	8	6:00	2
SC2	8	9:00	1
SC3	8	15:00	3
SC4	8	19:00	1
SC5	14	0:00	1
SC6	14	0:30	0
SC7	14	5:00	-1
SC8			
SC9			
SC10			

Pedestrian Crossing Times

Direction	Walk	CL1	CL 2

Normal Operating Mode

Isolated	Flexilink	Masterlink	Master Isolated	Flexi Isolated
		X		

DAY OF WEEK CODE NUMBER

0	End of Schedule	4	WED	8	MON-FRI	12	MON, FRI, SAT
1	SUN	5	THUR	9	MON-SAT	13	SAT,SUN
2	MON	6	FRI	10	TUE,WED,THU	14	EVERY DAY
3	TUE	7	SAT	11	MON,FRI	15	NEVER


Autoscope 37-Pin Male Output Harness (33457G2) Wiring Autoscope Output Harness Pins #1 & 20 to Logic Common Autoscope Output Harness Pins #18 & 37 to +24VDC

Came	sui sui		M '	Autoscope Output Hamess Pin #	D-Con	ATS inector inal #	SCATS Detector Description
1	1	LED	1	29	1	-	EB 12 MILE TI PRE
1	1	LED	2	30	2		EB 12 MILE TZ PRE
1	1	LED	3	31	3		EB 12 MILE T3 PRES
	1	LED	4	32			
	1	LED	5	33			
	1	LED	5	- 34			
	1	LED 7		35			
	1	LED 8		36			
2	2	LED 1		10	4		WB 12 MILE TIPRES
2	2	LED 2		11	5		WB 12 MILE TZ PRES
2	2	LED 3		12	6		NB 12 MILE TO PRES
	2	LED 4	- 1	13		1	
	2	LED 5		14			
	2	LED 6		15			
	2	LED 7		16			
	2	LED 8		17			
3	3	LED 1		21	7	M	1-5 OFF RAMP LI PRES
3	3	LED 2	1	22	8		1-5 OFF RAMP LZ PRES
3	3	LED 3		23	9	· M.	-5 OFF RAMP RIPRES
3	3	LED 4		24	10		-5 OFF RAMP RT PRES
	3	LED 5		25		1.	3 OF MINITO PAR
	3	LED 6		26			
	3	LED 7		27		1	
	3	LED 8		28			
	4	LED 1		2			
	. 4	LED 2		3		1	
	4	LED 3		4			
	4	LED 4		5			
	4	LED 5		6			
	4	LED 6		7		1	
	4	LED 7	1	В			
	4	LED 8	9	i		-	

Autoscope 37-Pin Female Input Harnes (33467G3) Wiring Autoscope Output Harness Pins #1 & 20 to Logic Common Autoscope Output Harness Pins #18 & 37 to +24VDC

EIM Switch Position	Autoscope EIM LED #	Autoscope Input Harness Pln #	Phase Status Input From +24VDC	Back Pan Terminal Position
5	1	29	Ø8 Green	
5	2	30	Ø7 Green	
5	3	31	Ø6 Green	
5	4	32	Ø5 Green	
5	5	33	Ø4 Green	
5	6	34	Ø3 Green	LOAD SW5
5	7	35	Ø2 Green	LOAD SW4
5	8	36	Ø1 Green	LOAD SWZ
6	1	10	Ø8 Red	
6	2	11	Ø7 Red	
6	3	12	Ø6 Red	
6	., 4	13	Ø5 Red	
6	5	14	Ø4 Red	
6	6	15	Ø3 Red	LOAD SW5
6	7	16	Ø2 Red	LOAD SWZ LOAD SWZ LOAD SWZ
6	8	1.7	Ø1 Red	DAD SW2

The preceeding table represents the correct wiring for phase inputs from the SCATS controller. The Autoscope input harness wires should be terminated at the +24VDC location on the back panel. The far right column is intetionally left blank so that the back panel terminal positions can be added as the cabinet is completed. This information is used for Autoscope extension and delay calculations. It is imperative that this harness is wired correctly. Failure to do so will result in erratic detector performance.



<u>SEMCOG | Southeast Michigan</u> <u>Council of Governments</u>

Community Profiles

YOU ARE VIEWING DATA FOR:

City of Novi

45175 W 10 Mile Rd Novi, MI 48375-3024 http://www.cityofnovi.org



Census 2020 Population:

66,243

Area: 31.2 square miles


VIEW COMMUNITY EXPLORER MAP

VIEW 2020 CENSUS MAP

Economy & Jobs

Link to American Community Survey (ACS) Profiles: **Select a Year** 2018-2022 **▼ Economic**

Forecasted Jobs



Note: The base year for the employment forecast is 2019, as 2020 employment was artificially low due to the COVID recession.

Source: SEMCOG 2050 Regional Development Forecast

Forecasted Jobs by Industry Sector


Forecasted Jobs By Industry Sector	2019	2020	2025	2030	2035	2040	2045	2050	Change 2019-2050	Pct Change 2019-2050
Natural Resources, Mining, & Construction	2,219	2,200	3,029	3,015	2,991	2,906	2,831	2,840	621	28%
Manufacturing	4,670	4,239	4,627	4,575	4,344	4,101	3,935	3,913	-757	-16.2%
Wholesale Trade	3,118	2,929	3,139	3,197	3,288	3,266	3,202	3,138	20	0.6%
Retail Trade	7,892	6,944	7,207	6,823	6,338	6,029	5,777	5,623	-2,269	-28.8%
Transportation, Warehousing, & Utilities	1,418	1,410	1,667	1,701	1,747	1,751	1,774	1,783	365	25.7%
Information & Financial Activities	6,576	6,145	7,173	7,806	8,290	8,615	8,922	9,254	2,678	40.7%
Professional and Technical Services & Corporate HQ	8,452	7,940	9,299	9,800	10,237	10,599	11,019	11,441	2,989	35.4%
Administrative, Support, & Waste Services	3,477	3,026	3,421	3,565	3,729	3,854	3,960	4,107	630	18.1%
Education Services	2,212	2,060	2,213	2,286	2,347	2,362	2,379	2,398	186	8.4%
Healthcare Services	7,679	7,095	7,941	8,216	8,579	8,969	9,388	9,839	2,160	28.1%
Leisure & Hospitality	7,103	5,217	7,105	7,275	7,317	7,335	7,346	7,405	302	4.3%
Other Services	2,137	1,851	2,247	2,373	2,429	2,452	2,499	2,513	376	17.6%
Public Administration	719	682	718	732	736	732	732	731	12	1.7%
Total Employment Numbers	57,672	51,738	59,786	61,364	62,372	62,971	63,764	64,985	7,313	12.7%

Note: The base year for the employment forecast is 2019, as 2020 employment was artificially low due to the COVID recession.

Source: SEMCOG 2050 Regional Development Forecast

Daytime Population

Daytime Population	ACS 2016
Jobs	36,078
Non-Working Residents	28,531
Age 15 and under	12,980
Not in labor force	14,353
Unemployed	1,198
Daytime Population	64,609



Source: 2012-2016 American Community Survey
5-Year Estimates and 2012-2016 Census
Transportation Planning Products Program
(CTPP). For additional information, visit SEMCOG's
Interactive Commuting Patterns Map

Note: The number of residents attending school outside Southeast Michigan is not available. Likewise, the number of students commuting into Southeast Michigan to attend school is also not known.

<u>SEMCOG | Southeast Michigan</u> Council of Governments

Community Profiles

YOU ARE VIEWING DATA FOR:

City of Novi

45175 W 10 Mile Rd Novi, MI 48375-3024 http://www.cityofnovi.org



Census 2020 Population:

66,243

Area: 31.2 square miles


VIEW COMMUNITY EXPLORER MAP

VIEW 2020 CENSUS MAP

Population and Households

Link to American Community Survey (ACS) Profiles: **Select a Year** 2018-2022 > **Social | Demographic**Population and Household Estimates for Southeast Michigan, 2023

Population Forecast



Note for City of Novi: Incorporated as of the 1970 Census from Village of Novi. Population numbers prior to 1970 are of the village. The Village of Novi was incorporated in 1958 from the majority of Novi Township. Population numbers not available before 1960 as area was part of Novi Township.

Population and Households

Population and Households	Census 2020	Census 2010	Change 2010-2020	Pct Change 2010-2020	SEMCOG Jul 2023	SEMCOG 2050
Total Population	66,243	55,224	11,019	20.0%	68,080	74,081
Group Quarters Population	332	360	-28	-7.8%	604	763
Household Population	65,911	54,864	11,047	20.1%	67,476	73,318
Housing Units	27,863	24,226	3,637	15.0%	28,613	-
Households (Occupied Units)	26,458	22,258	4,200	18.9%	27,710	29,484
Residential Vacancy Rate	5.0%	8.1%	-3.1%	-	3.2%	-
Average Household Size	2.49	2.46	0.03	-	2.44	2.49

Source: U.S. Census Bureau and SEMCOG 2050 Regional Development Forecast

Components of Population Change

Components of Population Change	2000-2005 Avg.	2006-2010 Avg.	2011-2018 Avg.
Natural Increase (Births - Deaths)	390	252	213
Births	701	583	637
Deaths	311	331	424
Net Migration (Movement In - Movement Out)	534	353	826
Population Change (Natural Increase + Net Migration)	924	605	1,039

Source: Michigan Department of Community
Health Vital Statistics, U.S. Census Bureau, and
SEMCOG

Household Types

Household Types	Census 2010	ACS 2021	Change 2010-2021	Pct Change 2010-2021	SEMCOG 2050
With Seniors 65+	4,598	6,650	2,052	44.6%	-
Without Seniors	17,660	19,634	1,974	11.2%	-
Live Alone, 65+	2,210	2,984	774	35%	-
Live Alone, <65	4,348	4,765	417	9.6%	-
2+ Persons, With children	7,838	9,262	1,424	18.2%	-
2+ Persons, Without children	7,862	9,273	1,411	17.9%	-
Total Households	22,258	26,284	4,026	18.1%	-

Source: U.S. Census Bureau, Decennial Census, 2017-2021 American Community Survey 5-Year Estimates, and SEMCOG 2050 Regional Development Forecast

Table 1 Elm Creek Trip Generation

The color with color will										
00110001	ITE Code	Amerina	11,160	Average Daily	AN	l Peak Ho	our	PM	l Peak Ho	Jn.
Laild Ose		Allioulit	2	Traffic	드	Out Total	Total	ᆜ	Out	Total
Single-Family Attached Housing	215	121	Na	872	14	43	25	41	28	69




FIGURE 5 SITE-GENERATED TRAFFIC VOLUMES

LEGEND

ROADS

---- PROPOSED ROADS

™

TRAFFIC VOLUMES (AM/PM)



NORTH SCALE: NOT TO SCALE

GRIFFIN TWELVE OAKS APARTMENTS - NOVI, MI

Table 1 Griffin Novi II Trip Generation

	r (vph)	Total	40
	ak Hou	Out Total	16
	PM Pe	<u>ul</u>	24
	AM Peak Hour (vph) PM Peak Hour (vph	Out Total In	33
	ak Hou	Out	22
	AM Pe	<u>l</u> n	œ
Average	Daily	Traffic	440
		Units	Na
		Sode \moun Units	102
	ΞE	Code	221
-		Land Use	Multi-Family Housing (Mid-Rise)

Intersection						
Int Delay, s/veh	4.8					
Movement	EBL	EBT	WBT	WBR	SBL	SBR
Lane Configurations	LUL	ተ	1101	וטיי) T	אופט
Traffic Vol, veh/h	0	478	0	0	271	0
Future Vol, veh/h	0	478	0	0	271	0
Conflicting Peds, #/hr	0	0	0	0	0	0
Sign Control	Free	Free	Stop	Stop	Stop	Stop
RT Channelized	-			None	-	None
Storage Length	-	-	_	-	0	-
Veh in Median Storage,	# -	108208	94336	-	0	_
Grade, %	-	0	0	_	0	-
Peak Hour Factor	90	90	92	92	88	88
Heavy Vehicles, %	4	4	2	2	2	2
Mvmt Flow	0	531	0	0	308	0
		001			000	v
	1ajor1			N	/linor2	
Conflicting Flow All	-	0			212	-
Stage 1	-	-			0	-
Stage 2	-	-			212	-
Critical Hdwy	-	-			5.74	-
Critical Hdwy Stg 1	-	-			-	-
Critical Hdwy Stg 2	-	-			6.04	-
Follow-up Hdwy	-	-			3.82	-
Pot Cap-1 Maneuver	0	-			751	0
Stage 1	0	-			-	0
Stage 2	0	-			737	0
Platoon blocked, %		-				
Mov Cap-1 Maneuver	_	-			751	_
Mov Cap-2 Maneuver	-	-			751	-
Stage 1	-	-			_	_
Stage 2	-	-			737	-
0 -					-	
					0.5	
Approach	EB				SB	
HCM Control Delay, s	0				13.1	
HCM LOS					В	
Minor Lane/Major Mvmt		EBT S	SBLn1			
Capacity (veh/h)		-				
HCM Lane V/C Ratio		_	0.41			
HCM Control Delay (s)		_	13.1			
HCM Lane LOS		_	В			
HCM 95th %tile Q(veh)		_	2			
			_			

	۶	→	*	1	←	*	1	1	1	1	Į.	1
Movement	EBL	EBT	EBR	WBL	WBT	WBR	NBL	NBT	NBR	SBL	SBT	SBR
Lane Configurations					ተ	7		↑			↑	7
Traffic Volume (vph)	0	0	0	0	734	66	0	52	0	0	115	92
Future Volume (vph)	0	0	0	0	734	66	0	52	0	0	115	92
Ideal Flow (vphpl)	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000
Total Lost time (s)					6.0	6.0		6.4			10.4	10.4
Lane Util. Factor					0.91	1.00		1.00			1.00	1.00
Frpb, ped/bikes					1.00	0.98		1.00			1.00	1.00
Flpb, ped/bikes					1.00	1.00		1.00			1.00	1.00
Frt					1.00	0.85		1.00			1.00	0.85
Flt Protected					1.00	1.00		1.00			1.00	1.00
Satd. Flow (prot)					5301	1616		1905			1923	1635
Flt Permitted					1.00	1.00		1.00			1.00	1.00
Satd. Flow (perm)					5301	1616		1905			1923	1635
Peak-hour factor, PHF	0.90	0.90	0.90	0.73	0.73	0.73	0.93	0.93	0.93	0.88	0.88	0.88
Adj. Flow (vph)	0	0	0	0	1005	90	0	56	0	0	131	105
RTOR Reduction (vph)	0	0	0	0	0	44	0	0	0	0	0	53
Lane Group Flow (vph)	0	0	0	0	1005	47	0	56	0	0	131	52
Confl. Peds. (#/hr)	1					1			1	1		
Heavy Vehicles (%)	4%	4%	4%	3%	3%	3%	5%	5%	5%	4%	4%	4%
Turn Type					NA	Perm		NA			NA	Perm
Protected Phases					6			8			4	
Permitted Phases						6						4
Actuated Green, G (s)					62.0	62.0		45.6			41.6	41.6
Effective Green, g (s)					62.0	62.0		45.6			41.6	41.6
Actuated g/C Ratio					0.52	0.52		0.38			0.35	0.35
Clearance Time (s)					6.0	6.0		6.4			10.4	10.4
Vehicle Extension (s)					3.0	3.0		3.0			3.0	3.0
Lane Grp Cap (vph)					2738	834		723			666	566
v/s Ratio Prot					c0.19			0.03			c0.07	
v/s Ratio Perm						0.03						0.03
v/c Ratio					0.37	0.06		0.08			0.20	0.09
Uniform Delay, d1					17.3	14.4		23.8			27.5	26.5
Progression Factor					1.17	2.49		0.00			1.00	1.00
Incremental Delay, d2					0.4	0.1		0.0			0.1	0.1
Delay (s)					20.6	36.1		0.1			27.6	26.5
Level of Service					С	D		Α			С	С
Approach Delay (s)		0.0			21.9			0.1			27.1	
Approach LOS		Α			С			Α			С	
Intersection Summary												
HCM 2000 Control Delay			21.9	Н	CM 2000	Level of S	Service		С			
HCM 2000 Volume to Capacity	y ratio		0.30									
Actuated Cycle Length (s)			120.0		um of lost				16.4			
Intersection Capacity Utilization	n		33.8%	IC	CU Level	of Service			Α			
Analysis Period (min)			15									

c Critical Lane Group

	۶	-	7	1	←	*	1	†	1	1	Į.	1
Movement	EBL	EBT	EBR	WBL	WBT	WBR	NBL	NBT	NBR	SBL	SBT	SBR
Lane Configurations		ተ	7					↑	7		↑	
Traffic Volume (vph)	0	468	281	0	0	0	0	52	152	0	115	0
Future Volume (vph)	0	468	281	0	0	0	0	52	152	0	115	0
Ideal Flow (vphpl)	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000
Total Lost time (s)		6.0	6.0					10.4	10.4		6.4	
Lane Util. Factor		0.91	1.00					1.00	1.00		1.00	
Frpb, ped/bikes		1.00	1.00					1.00	0.99		1.00	
Flpb, ped/bikes		1.00	1.00					1.00	1.00		1.00	
Frt		1.00	0.85					1.00	0.85		1.00	
FIt Protected		1.00	1.00					1.00	1.00		1.00	
Satd. Flow (prot)		5250	1635					1905	1598		1923	
FIt Permitted		1.00	1.00					1.00	1.00		1.00	
Satd. Flow (perm)		5250	1635					1905	1598		1923	
Peak-hour factor, PHF	0.90	0.90	0.90	0.73	0.73	0.73	0.93	0.93	0.93	0.88	0.88	0.88
Adj. Flow (vph)	0	520	312	0	0	0	0	56	163	0	131	0
RTOR Reduction (vph)	0	0	151	0	0	0	0	0	106	0	0	0
Lane Group Flow (vph)	0	520	161	0	0	0	0	56	57	0	131	0
Confl. Peds. (#/hr)	1					1			1	1		
Heavy Vehicles (%)	4%	4%	4%	3%	3%	3%	5%	5%	5%	4%	4%	4%
Turn Type		NA	Perm					NA	Perm		NA	
Protected Phases		2						4			8	
Permitted Phases			2						4			
Actuated Green, G (s)		62.0	62.0					41.6	41.6		45.6	
Effective Green, g (s)		62.0	62.0					41.6	41.6		45.6	
Actuated g/C Ratio		0.52	0.52					0.35	0.35		0.38	
Clearance Time (s)		6.0	6.0					10.4	10.4		6.4	
Vehicle Extension (s)		3.0	3.0					3.0	3.0		3.0	
Lane Grp Cap (vph)		2712	844					660	553		730	
v/s Ratio Prot		c0.10						0.03			c0.07	
v/s Ratio Perm			0.10						0.04			
v/c Ratio		0.19	0.19					0.08	0.10		0.18	
Uniform Delay, d1		15.6	15.6					26.4	26.6		24.8	
Progression Factor		0.82	0.51					1.00	1.00		0.00	
Incremental Delay, d2		0.2	0.5					0.1	0.1		0.1	
Delay (s)		12.9	8.5					26.4	26.6		0.1	
Level of Service		В	Α					С	С		Α	
Approach Delay (s)		11.2			0.0			26.6			0.1	
Approach LOS		В			А			С			Α	
Intersection Summary												
HCM 2000 Control Delay			12.9	H	CM 2000	Level of S	Service		В			
HCM 2000 Volume to Capaci	ty ratio		0.19									
Actuated Cycle Length (s)			120.0	Sı	um of lost	time (s)			16.4			
Intersection Capacity Utilizati	on		33.8%			of Service			Α			
Analysis Period (min)			15									

Intersection						
Int Delay, s/veh	0					
	EBL	EBT	WBT	WBR	SBL	SBR
Lane Configurations		^			7	
Traffic Vol, veh/h	0	620	0	0	0	0
Future Vol, veh/h	0	620	0	0	0	0
Conflicting Peds, #/hr	0	0	0	0	0	0
Sign Control	Free	Free	Stop	Stop	Stop	Stop
RT Channelized	-	None	-		-	None
Storage Length	-	-	-	-	0	-
Veh in Median Storage, #	# -	108 0 5	41184	-	0	-
Grade, %	_	0	0	_	0	_
Peak Hour Factor	85	85	92	92	92	92
Heavy Vehicles, %	6	6	2	2	2	2
Mymt Flow	0	729	0	0	0	0
IVIVIIILI IOW	U	123	U	U	U	U
Major/Minor Ma	ajor1			N	Minor2	
Conflicting Flow All	_	0			292	_
Stage 1	_	_			0	_
Stage 2	_	_			292	_
Critical Hdwy	_	_			5.74	_
Critical Hdwy Stg 1	_	_			- 0.7	_
Critical Hdwy Stg 2	-	-			6.04	
					3.82	
Follow-up Hdwy	-	-				-
Pot Cap-1 Maneuver	0	-			688	0
Stage 1	0	-			-	0
Stage 2	0	-			671	0
Platoon blocked, %		-				
Mov Cap-1 Maneuver	-	-			688	-
Mov Cap-2 Maneuver	-	-			688	-
Stage 1	-	-			-	-
Stage 2	-	-			671	-
Ŭ						
Δ					00	
Approach	EB				SB	
HCM Control Delay, s	0				0	
HCM LOS					Α	
Minor Lane/Major Mvmt		ERT	SBLn1			
		LDI	JULITI			
Capacity (veh/h)		-	-			
HCM Lane V/C Ratio		-	-			
HCM Control Delay (s)		-	0			
HCM Lane LOS		-	Α			
HCM 95th %tile Q(veh)		_	_			

Intersection						
	0.5					
		EDD	WDI	WDT	NDI	NDD
	EBT	EBR	WBL	WBT	NBL	NBR
Lane Configurations				ተተተ	ሻ	
Traffic Vol, veh/h	0	0	0	765	35	0
Future Vol, veh/h	0	0	0	765	35	0
Conflicting Peds, #/hr	0	0	0	0	0	0
	Stop	Stop	Free	Free	Stop	Stop
RT Channelized	-	None	-	None	-	None
Storage Length	-	-	-	-	0	-
Veh in Median Storage, #	3	-	-	0	0	-
Grade, %	0	-	-	0	0	-
Peak Hour Factor	92	92	90	73	80	80
Heavy Vehicles, %	2	2	3	3	3	3
Mvmt Flow	0	0	0	1048	44	0
Major/Minor			//ajor2	1	/linor1	
Conflicting Flow All			-	-	419	-
Stage 1			-	-	0	-
Stage 2			-	-	419	-
Critical Hdwy			-	-	5.76	-
Critical Hdwy Stg 1			-	-	-	-
Critical Hdwy Stg 2			-	-	6.06	-
Follow-up Hdwy			-	-	3.83	-
Pot Cap-1 Maneuver			0	-	596	0
Stage 1			0	_	-	0
Stage 2			0	-	575	0
Platoon blocked, %						
Mov Cap-1 Maneuver			-	_	596	_
Mov Cap-2 Maneuver					596	_
Stage 1			_		-	
			-	-	575	-
Stage 2			-	-	5/5	-
Approach			WB		NB	
HCM Control Delay, s			0		11.5	
HCM LOS					В	
		_				
		ID	14/5-			
Minor Lane/Major Mvmt	1	NBLn1	WBT			
Capacity (veh/h)		596	-			
HCM Lane V/C Ratio		0.073	-			
HCM Control Delay (s)		11.5	-			
HCM Lane LOS		В	-			
HCM 95th %tile Q(veh)		0.2	-			

Intersection						
Int Delay, s/veh	0.3					
		EDT	WDT	WIDD	CDI	CDD
	EBL	EBT	WBT	WBR	SBL	SBR
Lane Configurations	0	ተ	^	0	ነ	0
Traffic Vol, veh/h	0	585	0	0	14	0
Future Vol, veh/h	0	585	0	0	14	0
Conflicting Peds, #/hr	0	0	0	0	0	0
	Free	Free	Stop	Stop	Stop	Stop
RT Channelized	-	None	-	None	-	None
Storage Length	-	-	-	-	0	-
Veh in Median Storage, #	+ -	0	0	-	0	-
Grade, %	-	0	0	-	0	-
Peak Hour Factor	85	85	92	92	60	60
Heavy Vehicles, %	6	6	2	2	0	0
Mvmt Flow	0	688	0	0	23	0
Majar/Minar	-i4				Aire a re	
	ajor1			I	/linor2	
Conflicting Flow All	-	0			275	-
Stage 1	-	-			0	-
Stage 2	-	-			275	-
Critical Hdwy	-	-			5.7	-
Critical Hdwy Stg 1	-	-			-	-
Critical Hdwy Stg 2	-	-			6	-
Follow-up Hdwy	-	-			3.8	-
Pot Cap-1 Maneuver	0	-			706	0
Stage 1	0	_			_	0
Stage 2	0	_			690	0
Platoon blocked, %	U	_			000	v
Mov Cap-1 Maneuver	_	_			706	_
Mov Cap-1 Maneuver					706	
	-				700	_
Stage 1	-	-			-	
Stage 2	-	-			690	-
Approach	EB				SB	
HCM Control Delay, s	0				10.3	
HCM LOS					В	
TIOM EGG						
Minor Lane/Major Mvmt		EBT S	SBLn1			
Capacity (veh/h)		-	706			
HCM Lane V/C Ratio		-	0.033			
HCM Control Delay (s)		-	10.3			
HCM Lane LOS		-	В			
HCM 95th %tile Q(veh)		_	0.1			
(1311)			3.7			

	۶	→	*	1	←	*	1	†	1	1	Ţ	4
Movement	EBL	EBT	EBR	WBL	WBT	WBR	NBL	NBT	NBR	SBL	SBT	SBR
Lane Configurations					ተ						^	77
Traffic Volume (vph)	0	0	0	0	591	0	0	0	0	0	162	188
Future Volume (vph)	0	0	0	0	591	0	0	0	0	0	162	188
Ideal Flow (vphpl)	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000
Total Lost time (s)					5.9						9.0	9.0
Lane Util. Factor					0.91						0.95	0.88
Frt					1.00						1.00	0.85
Flt Protected					1.00						1.00	1.00
Satd. Flow (prot)					5250						3762	2962
FIt Permitted					1.00						1.00	1.00
Satd. Flow (perm)					5250						3762	2962
Peak-hour factor, PHF	0.92	0.92	0.92	0.91	0.91	0.91	0.92	0.92	0.92	0.87	0.87	0.87
Adj. Flow (vph)	0	0	0	0	649	0	0	0	0	0	186	216
RTOR Reduction (vph)	0	0	0	0	0	0	0	0	0	0	0	137
Lane Group Flow (vph)	0	0	0	0	649	0	0	0	0	0	186	79
Heavy Vehicles (%)	2%	2%	2%	4%	4%	4%	2%	2%	2%	1%	1%	1%
Turn Type					NA						NA	Perm
Protected Phases					6						4	
Permitted Phases												4
Actuated Green, G (s)					61.1						44.0	44.0
Effective Green, g (s)					61.1						44.0	44.0
Actuated g/C Ratio					0.51						0.37	0.37
Clearance Time (s)					5.9						9.0	9.0
Vehicle Extension (s)					3.0						3.0	3.0
Lane Grp Cap (vph)					2673						1379	1086
v/s Ratio Prot					c0.12						c0.05	
v/s Ratio Perm												0.03
v/c Ratio					0.24						0.13	0.07
Uniform Delay, d1					16.5						25.3	24.7
Progression Factor					1.00						1.00	1.00
Incremental Delay, d2					0.2						0.0	0.0
Delay (s)					16.7						25.4	24.8
Level of Service					В						С	С
Approach Delay (s)		0.0			16.7			0.0			25.0	
Approach LOS		Α			В			Α			С	
Intersection Summary												
HCM 2000 Control Delay			19.9	Н	CM 2000	Level of S	Service		В			
HCM 2000 Volume to Capacity	ratio		0.20									
Actuated Cycle Length (s)			120.0		um of lost				14.9			
Intersection Capacity Utilization	1		29.9%	IC	CU Level	of Service			Α			
Analysis Period (min)			15									
c Critical Lane Group												

	۶	→	-	*	1	4	
Movement	EBL	EBT	WBT	WBR	SBL	SBR	
Lane Configurations		ተ			ሻሻ	02.1	
Traffic Volume (vph)	0	403	0	0	162	0	
Future Volume (vph)	0	403	0	0	162	0	
Ideal Flow (vphpl)	2000	2000	2000	2000	2000	2000	
Total Lost time (s)		5.9			6.0		
Lane Util. Factor		0.91			0.97		
Frt		1.00			1.00		
Flt Protected		1.00			0.95		
Satd. Flow (prot)		5151			3650		
FIt Permitted		1.00			0.95		
Satd. Flow (perm)		5151			3650		
Peak-hour factor, PHF	0.85	0.85	0.92	0.92	0.87	0.87	
Adj. Flow (vph)	0	474	0	0	186	0	
RTOR Reduction (vph)	0	0	0	0	113	0	
Lane Group Flow (vph)	0	474	0	0	73	0	
Heavy Vehicles (%)	6%	6%	2%	2%	1%	1%	
Turn Type		NA			Prot		
Protected Phases		2			8		
Permitted Phases							
Actuated Green, G (s)		61.1			47.0		
Effective Green, g (s)		61.1			47.0		
Actuated g/C Ratio		0.51			0.39		
Clearance Time (s)		5.9			6.0		
Vehicle Extension (s)		3.0			3.0		
Lane Grp Cap (vph)		2622			1429		
v/s Ratio Prot		c0.09			c0.02		
v/s Ratio Perm							
v/c Ratio		0.18			0.05		
Uniform Delay, d1		15.9			22.7		
Progression Factor		1.12			1.00		
Incremental Delay, d2		0.2			0.0		
Delay (s)		18.0			22.7		
Level of Service		В			С		
Approach Delay (s)		18.0	0.0		22.7		
Approach LOS		В	Α		С		
Intersection Summary							
HCM 2000 Control Delay			19.3	H	CM 2000	Level of Service	В
HCM 2000 Volume to Capacit	y ratio		0.13				
Actuated Cycle Length (s)			120.0		um of lost		14.9
Intersection Capacity Utilization	n		29.9%	IC	U Level o	of Service	Α
Analysis Period (min)			15				
c Critical Lane Group							

Intersection						
Int Delay, s/veh	0					
Movement	EBT	EBR	WBL	WBT	NBL	NBR
	*	רטוע	1100	1101	HUL	7
Traffic Vol, veh/h	599	0	0	0	0	0
Future Vol, veh/h	599	0	0	0	0	0
Conflicting Peds, #/hr	0	0	0	0	0	0
Sign Control	Free	Free	Stop	Stop	Stop	Stop
RT Channelized	-		-		-	None
Storage Length	-	-	_	-	_	0
Veh in Median Storage	e, # 0	_	_	0	0	-
Grade, %	0	_	_	0	0	_
Peak Hour Factor	85	85	92	92	92	92
Heavy Vehicles, %	6	6	2	2	2	2
Mymt Flow	705	0	0	0	0	0
WWWIICTIOW	100	U	U	0	U	0
Major/Minor I	Major1			N	Minor1	
Conflicting Flow All	0	0			-	353
Stage 1	-	-			-	-
Stage 2	-	-			-	-
Critical Hdwy	-	-			-	7.14
Critical Hdwy Stg 1	-	-			-	-
Critical Hdwy Stg 2	-	-			-	-
Follow-up Hdwy	-	-			-	3.92
Pot Cap-1 Maneuver	-	-			0	549
Stage 1	-	-			0	-
Stage 2	-	-			0	_
Platoon blocked, %	_	_				
Mov Cap-1 Maneuver	_	_			_	549
Mov Cap-2 Maneuver	_	_				-
Stage 1	_	_				
Stage 2	_	_				
Stage 2	_				-	
Approach	EB				NB	
HCM Control Delay, s	0				0	
HCM LOS					Α	
Minor Lane/Major Mvm	.4 1	UDI p1	ГОТ	EDD		
	it i	VBLn1	EBT	EBR		
Capacity (veh/h)		-	-	-		
HCM Lane V/C Ratio		-	-	-		
HCM Control Delay (s)		0	-	-		
LI : N/I I ODO I / NC'		Α	-	-		
HCM Lane LOS HCM 95th %tile Q(veh)		_	_	_		

Intersection												
Int Delay, s/veh	0											
Movement	EBL	EBT	EBR	WBL	WBT	WBR	NBL	NBT	NBR	SBL	SBT	SBR
Lane Configurations		4			4		ሻ	ĵ.		*	1>	
Traffic Vol, veh/h	0	0	0	0	0	0	0	204	0	0	396	0
Future Vol, veh/h	0	0	0	0	0	0	0	204	0	0	396	0
Conflicting Peds, #/hr	0	0	0	0	0	0	0	0	0	0	0	0
Sign Control	Stop	Stop	Stop	Stop	Stop	Stop	Free	Free	Free	Free	Free	Free
RT Channelized	-	-	None	-	-	None	-	-	None	-	-	None
Storage Length	-	-	-	-	-	-	500	-	-	475	-	-
Veh in Median Storage	e, # -	0	-	-	0	-	-	0	-	-	0	-
Grade, %	-	0	-	-	0	-	-	0	-	-	0	-
Peak Hour Factor	92	92	92	92	92	92	93	93	93	92	92	92
Heavy Vehicles, %	2	2	2	2	2	2	5	5	5	2	2	2
Mvmt Flow	0	0	0	0	0	0	0	219	0	0	430	0
Major/Minor I	Minor2			Minor1			Major1			Major2		
Conflicting Flow All	649	649	430	649	649	219	430	0	0	219	0	0
Stage 1	430	430	-	219	219	-	-	-	_		_	-
Stage 2	219	219	_	430	430	_	_	_	_	_	_	_
Critical Hdwy	7.12	6.52	6.22	7.12	6.52	6.22	4.15	_	-	4.12	_	-
Critical Hdwy Stg 1	6.12	5.52	-	6.12	5.52	-	-	-	-	-	-	-
Critical Hdwy Stg 2	6.12	5.52	-	6.12	5.52	_	_	_	_	_	_	-
Follow-up Hdwy	3.518	4.018	3.318	3.518	4.018	3.318	2.245	-	_	2.218	_	-
Pot Cap-1 Maneuver	383	389	625	383	389	821	1114	-	_	1350	_	-
Stage 1	603	583	-	783	722	-	-	-	-	-	-	-
Stage 2	783	722	-	603	583	-	-	-	-	-	-	-
Platoon blocked, %								-	-		-	-
Mov Cap-1 Maneuver	383	389	625	383	389	821	1114	-	-	1350	-	-
Mov Cap-2 Maneuver	383	389	-	383	389	-	-	-	-	-	-	-
Stage 1	603	583	-	783	722	-	-	-	-	-	-	-
Stage 2	783	722	-	603	583	-	-	-	-	-	-	-
Approach	EB			WB			NB			SB		
HCM Control Delay, s	0			0			0			0		
HCM LOS	A			A						•		
Minor Lang/Major Mum	*	NBL	NBT	NDD	EBLn1V	MDI 51	SBL	SBT	SBR			
Minor Lane/Major Mvm	IL		INDI	NDK	LDLIIIV				SDK			
Capacity (veh/h)		1114	-	-	-	-	1350	-	-			
HCM Control Doloy (a)		-	-	-	- 0	-	-	-	-			
HCM Control Delay (s) HCM Lane LOS		0	-	-	0	0	0	-	-			
HCM 95th %tile Q(veh)	\	A 0	-	-	А	A -	A 0	-	-			
HOW SOUT WHIE Q(Ven)		U	-	-	-	-	U	-	-			

Intersection						
Int Delay, s/veh	0					
		WED	NOT	NDD	051	ODT
Movement	WBL	WBR	NBT	NBR	SBL	SBT
Lane Configurations	Y		7			^
Traffic Vol, veh/h	0	0	204	0	0	396
Future Vol, veh/h	0	0	204	0	0	396
Conflicting Peds, #/hr	0	0	0	0	0	0
Sign Control	Stop	Stop	Free	Free	Free	Free
RT Channelized	-	None	-	None	-	None
Storage Length	0	-	-	-	500	-
Veh in Median Storage	e, # 0	-	0	-	-	0
Grade, %	0	-	0	-	-	0
Peak Hour Factor	92	92	93	93	92	92
Heavy Vehicles, %	2	2	5	5	2	2
Mvmt Flow	0	0	219	0	0	430
						.00
		_				
	Minor1		Major1		Major2	
Conflicting Flow All	649	219	0	0	219	0
Stage 1	219	-	-	-	-	-
Stage 2	430	-	-	-	-	-
Critical Hdwy	6.42	6.22	-	-	4.12	-
Critical Hdwy Stg 1	5.42	-	-	-	-	-
Critical Hdwy Stg 2	5.42	-	-	-	-	-
Follow-up Hdwy	3.518	3.318	_	-	2.218	_
Pot Cap-1 Maneuver	434	821	_	_	1350	_
Stage 1	817	-	_	_	-	_
Stage 2	656	_	_	_	_	_
Platoon blocked, %	000					
Mov Cap-1 Maneuver	434	821		-	1350	-
			-	-		-
Mov Cap-2 Maneuver	524	-	-	-	-	-
Stage 1	817	-	-	-	-	-
Stage 2	656	-	-	-	-	-
Approach	WB		NB		SB	
HCM Control Delay, s	0		0		0	
HCM LOS	A		U		U	
I IOWI LOG	A					
Minor Lane/Major Mvr	nt	NBT	NBRV	VBLn1	SBL	SBT
Capacity (veh/h)		_	-		1350	-
HCM Lane V/C Ratio		_	-	-	-	_
HCM Control Delay (s)	_	_	0	0	_
HCM Lane LOS		_	_	A	A	_
HCM 95th %tile Q(veh)	_	_	-	0	_
HOW SOUT WILL W(VEI))		_	•	U	-

Intersection							
Int Delay, s/veh	2.6						
Movement	EBL	EBT	WBT	WBR	SBL	SBR	
Lane Configurations		ተ			*		
Traffic Vol, veh/h	0	840	0	0	250	0	
Future Vol, veh/h	0	840	0	0	250	0	
Conflicting Peds, #/hr	0	0	0	0	0	0	
Sign Control	Free	Free	Stop	Stop	Stop	Stop	
RT Channelized	-	None	-		-	None	
Storage Length	-	-	-	-	0	-	
Veh in Median Storage,	# -	108208	94336	-	0	-	
Grade, %	-	0	0	-	0	-	
Peak Hour Factor	84	84	92	92	93	93	
Heavy Vehicles, %	2	2	2	2	1	1	
Mvmt Flow	0	1000	0	0	269	0	
				•			
NA=:==/NA:===	1-:1			N	A:O		
	/lajor1			ľ	Minor2		
Conflicting Flow All	-	0			400	-	
Stage 1	-	-			0	-	
Stage 2	-	-			400	-	
Critical Hdwy	-	-			5.72	-	
Critical Hdwy Stg 1	-	-			-	-	
Critical Hdwy Stg 2	-	-			6.02	-	
Follow-up Hdwy	-	-			3.81	-	
Pot Cap-1 Maneuver	0	-			*762	0	
Stage 1	0	-			-	0	
Stage 2	0	-			*762	0	
Platoon blocked, %		-			1		
Mov Cap-1 Maneuver	-	-			*762	-	
Mov Cap-2 Maneuver	-	-			*762	-	
Stage 1	-	-			-	-	
Stage 2	-	-			*762	-	
Approach	EB				SB		
HCM Control Delay, s	0				12.3		
HCM LOS					В		
NAI		EDT (ODL 4				
Minor Lane/Major Mvmt			SBLn1				
Capacity (veh/h)		-	762				
HCM Cantral Dalay (a)			0.353				
HCM Control Delay (s)		-	12.3				
HCM Lane LOS		-	B				
HCM 95th %tile Q(veh)		-	1.6				
Notes							
~: Volume exceeds cap	acity	\$: De	elay exc	ceeds 30	00s	+: Comp	outation Not Defined *: All major volume in platoon
							<u> </u>

	۶	→	*	1	←	*	1	1	1	1	Į.	4
Movement	EBL	EBT	EBR	WBL	WBT	WBR	NBL	NBT	NBR	SBL	SBT	SBR
Lane Configurations					ተ	7		^			1	7
Traffic Volume (vph)	0	0	0	0	1769	339	0	158	0	0	150	56
Future Volume (vph)	0	0	0	0	1769	339	0	158	0	0	150	56
Ideal Flow (vphpl)	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000
Total Lost time (s)					6.0	6.0		6.4			10.4	10.4
Lane Util. Factor					0.91	1.00		1.00			1.00	1.00
Frpb, ped/bikes					1.00	1.00		1.00			1.00	0.99
Flpb, ped/bikes					1.00	1.00		1.00			1.00	1.00
Frt					1.00	0.85		1.00			1.00	0.85
Flt Protected					1.00	1.00		1.00			1.00	1.00
Satd. Flow (prot)					5353	1667		1980			1869	1567
FIt Permitted					1.00	1.00		1.00			1.00	1.00
Satd. Flow (perm)					5353	1667		1980			1869	1567
Peak-hour factor, PHF	0.93	0.93	0.93	0.74	0.74	0.74	0.91	0.91	0.91	0.72	0.72	0.72
Adj. Flow (vph)	0	0	0	0	2391	458	0	174	0	0	208	78
RTOR Reduction (vph)	0	0	0	0	0	172	0	0	0	0	0	19
Lane Group Flow (vph)	0	0	0	0	2391	286	0	174	0	0	208	59
Confl. Peds. (#/hr)									1	1		
Confl. Bikes (#/hr)									1			2
Heavy Vehicles (%)	2%	2%	2%	2%	2%	2%	1%	1%	1%	7%	7%	7%
Turn Type					NA	Perm		NA			NA	Perm
Protected Phases					6			8			4	
Permitted Phases						6						4
Actuated Green, G (s)					68.0	68.0		39.6			35.6	35.6
Effective Green, g (s)					68.0	68.0		39.6			35.6	35.6
Actuated g/C Ratio					0.57	0.57		0.33			0.30	0.30
Clearance Time (s)					6.0	6.0		6.4			10.4	10.4
Vehicle Extension (s)					3.0	3.0		3.0			3.0	3.0
Lane Grp Cap (vph)					3033	944		653			554	464
v/s Ratio Prot					c0.45	• • • • • • • • • • • • • • • • • • • •		0.09			c0.11	
v/s Ratio Perm						0.17		0.00			•	0.04
v/c Ratio					0.79	0.30		0.27			0.38	0.13
Uniform Delay, d1					20.4	13.6		29.5			33.4	30.8
Progression Factor					0.98	2.18		0.00			1.00	1.00
Incremental Delay, d2					1.7	0.6		0.2			0.4	0.1
Delay (s)					21.7	30.3		0.2			33.8	31.0
Level of Service					C	C		A			C	C
Approach Delay (s)		0.0			23.1			0.2			33.0	
Approach LOS		A			C			A			C	
Intersection Summary												
HCM 2000 Control Delay			22.8	Н	CM 2000	Level of S	Service		С			
HCM 2000 Volume to Capacity	ratio		0.65									
Actuated Cycle Length (s)			120.0	S	um of los	t time (s)			16.4			
Intersection Capacity Utilization	l		53.6%			of Service			Α			
Analysis Period (min)			15									
c Critical Lane Group												

	۶	-	*	•	—	4	4	1	1	1		1
Movement	EBL	EBT	EBR	WBL	WBT	WBR	NBL	NBT	NBR	SBL	SBT	SBR
Lane Configurations		ተ	7					↑	7		^	
Traffic Volume (vph)	0	894	196	0	0	0	0	158	337	0	150	0
Future Volume (vph)	0	894	196	0	0	0	0	158	337	0	150	0
Ideal Flow (vphpl)	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000
Total Lost time (s)		6.0	6.0					10.4	10.4		6.4	
Lane Util. Factor		0.91	1.00					1.00	1.00		1.00	
Frpb, ped/bikes		1.00	1.00					1.00	0.99		1.00	
Flpb, ped/bikes		1.00	1.00					1.00	1.00		1.00	
Frt		1.00	0.85					1.00	0.85		1.00	
Flt Protected		1.00	1.00					1.00	1.00		1.00	
Satd. Flow (prot)		5353	1667					1980	1660		1869	
FIt Permitted		1.00	1.00					1.00	1.00		1.00	
Satd. Flow (perm)		5353	1667					1980	1660		1869	
Peak-hour factor, PHF	0.84	0.84	0.84	0.92	0.92	0.92	0.91	0.91	0.91	0.72	0.72	0.72
Adj. Flow (vph)	0	1064	233	0	0	0	0	174	370	0	208	0
RTOR Reduction (vph)	0	0	101	0	0	0	0	0	63	0	0	0
Lane Group Flow (vph)	0	1064	132	0	0	0	0	174	307	0	208	0
Confl. Peds. (#/hr)									1	1		
Confl. Bikes (#/hr)									1			2
Heavy Vehicles (%)	2%	2%	2%	2%	2%	2%	1%	1%	1%	7%	7%	7%
Turn Type		NA	Perm					NA	Perm		NA	
Protected Phases		2						4			8	
Permitted Phases		_	2					•	4			
Actuated Green, G (s)		68.0	68.0					35.6	35.6		39.6	
Effective Green, g (s)		68.0	68.0					35.6	35.6		39.6	
Actuated g/C Ratio		0.57	0.57					0.30	0.30		0.33	
Clearance Time (s)		6.0	6.0					10.4	10.4		6.4	
Vehicle Extension (s)		3.0	3.0					3.0	3.0		3.0	
Lane Grp Cap (vph)		3033	944					587	492		616	
v/s Ratio Prot		c0.20	0					0.09	.02		0.11	
v/s Ratio Perm		00.20	0.08					0.00	c0.18		0.11	
v/c Ratio		0.35	0.14					0.30	0.62		0.34	
Uniform Delay, d1		14.1	12.2					32.5	36.4		30.3	
Progression Factor		0.76	0.45					1.00	1.00		0.00	
Incremental Delay, d2		0.3	0.3					0.3	2.5		0.3	
Delay (s)		11.0	5.8					32.8	38.9		0.3	
Level of Service		В	A					C	D		A	
Approach Delay (s)		10.0	, , , , , , , , , , , , , , , , , , ,		0.0			36.9			0.3	
Approach LOS		В			A			D			A	
Intersection Summary												
HCM 2000 Control Delay			16.2	Н	CM 2000	Level of S	Service		В			
HCM 2000 Volume to Capacity	ratio		0.44									
Actuated Cycle Length (s)			120.0	Sı	um of lost	time (s)			16.4			
Intersection Capacity Utilization			53.6%			of Service			A			
Analysis Period (min)			15									
c Critical Lane Group												

Intersection						
Int Delay, s/veh	0					
Movement	EBL	EBT	WBT	WBR	SBL	SBR
Lane Configurations		ተ			*	
Traffic Vol, veh/h	0	1231	0	0	3	0
Future Vol, veh/h	0	1231	0	0	3	0
Conflicting Peds, #/hr	0	0	0	0	0	0
Sign Control	Free	Free	Stop	Stop	Stop	Stop
RT Channelized	-		-		-	None
Storage Length	-	-	-	-	0	-
Veh in Median Storage,	# -	108 0 5	41184	-	0	-
Grade, %	_	0	0	_	0	-
Peak Hour Factor	95	88	92	92	60	60
Heavy Vehicles, %	2	1	2	2	0	0
Mymt Flow	0	1399	0	0	5	0
Within the William		1000				
				_		
	1ajor1			<u> </u>	/linor2	
Conflicting Flow All	-	0			560	-
Stage 1	-	-			0	-
Stage 2	-	-			560	-
Critical Hdwy	-	-			5.7	-
Critical Hdwy Stg 1	-	-			-	-
Critical Hdwy Stg 2	-	-			6	-
Follow-up Hdwy	-	-			3.8	-
Pot Cap-1 Maneuver	0	-			*706	0
Stage 1	0	-			-	0
Stage 2	0	-			*706	0
Platoon blocked, %		-			1	
Mov Cap-1 Maneuver	-	_			*706	-
Mov Cap-2 Maneuver	_	_			*706	_
Stage 1	_	-			-	_
Stage 2	_	_			*706	_
Olage 2					700	
Approach	EB				SB	
HCM Control Delay, s	0				10.1	
HCM LOS					В	
Minor Lane/Major Mvmt		EDT (SBLn1			
		EDI				
Capacity (veh/h)		-	706			
HCM Lane V/C Ratio			0.007			
HCM Control Delay (s)		-	10.1			
HCM Lane LOS		-	В			
HCM 95th %tile Q(veh)		-	0			
Notes						
~: Volume exceeds capa	acity	¢. Do	lay ovo	oods 30	Ne	+: Comr
volume exceeds capa	acity	ф. De	ay exc	eeds 30	105	+: Comp

Intersection						
Int Delay, s/veh	1					
		EDD	14/51	MOT	NE	NES
Movement	EBT	EBR	WBL	WBT	NBL	NBR
Lane Configurations				ተተተ	٦	
Traffic Vol, veh/h	0	0	0	2040	71	0
Future Vol, veh/h	0	0	0	2040	71	0
Conflicting Peds, #/hr	0	0	0	0	0	0
Sign Control	Stop	Stop	Free	Free	Stop	Stop
RT Channelized	-	None	-	None	-	None
Storage Length	-	-	-	-	0	-
Veh in Median Storage,	# 3	-	-	0	0	-
Grade, %	0	-	-	0	0	-
Peak Hour Factor	92	92	93	74	63	63
Heavy Vehicles, %	2	2	2	2	1	1
Mvmt Flow	0	0	0	2757	113	0
Major/Minor		N	Major2	N	/linor1	
		ľ				
Conflicting Flow All			-	-		-
Stage 1			-	-	0	-
Stage 2			-	-	1103	-
Critical Hdwy			-	-	5.72	-
Critical Hdwy Stg 1			-	-	-	-
Critical Hdwy Stg 2			-	-	6.02	-
Follow-up Hdwy			-	-	3.81	-
Pot Cap-1 Maneuver			0	-	278	0
Stage 1			0	-	-	0
Stage 2			0	-	253	0
Platoon blocked, %				-		
Mov Cap-1 Maneuver			-	-	278	-
Mov Cap-2 Maneuver			-	-	278	-
Stage 1			-	-	-	-
Stage 2			-	-	253	-
Annanah			WD		ND	
Approach			WB		NB	
HCM Control Delay, s			0		26.5	
HCM LOS					D	
Minor Lane/Major Mvmt	1	NBLn1	WBT			
Capacity (veh/h)		278	-			
HCM Lane V/C Ratio		0.405	_			
HCM Control Delay (s)		26.5	_			
HCM Lane LOS		20.5 D	_			
HCM 95th %tile Q(veh)		1.9	_			
HOW JOHN JOHN Q(VEII)		1.3	-			

Intersection						
Int Delay, s/veh	0.2					
		EDT	WDT	MDD	CDI	CDD
	EBL	EBT	WBI	WBR	SBL	SBR
Lane Configurations	0	*	^	0	<u>ነ</u>	0
Traffic Vol, veh/h	0	1163	0	0	22	0
Future Vol, veh/h	0	1163	0	0	22	0
Conflicting Peds, #/hr	_ 0	_ 0	0	0	0	0
	Free	Free	Stop	Stop	Stop	Stop
RT Channelized	-	None	-	None	-	None
Storage Length	-	-	-	-	0	-
Veh in Median Storage, #	‡ -	0	0	-	0	-
Grade, %	-	0	0	-	0	-
Peak Hour Factor	88	88	92	92	92	92
Heavy Vehicles, %	1	1	2	2	14	14
Mvmt Flow	0	1322	0	0	24	0
Major/Minor Ma	ajor1			N	Minor2	
				IV.		
Conflicting Flow All	-	0			529	-
Stage 1	-	-			0	-
Stage 2	-	-			529	-
Critical Hdwy	-	-			5.98	-
Critical Hdwy Stg 1	-	-			-	-
Critical Hdwy Stg 2	-	-			6.28	-
Follow-up Hdwy	-	-			3.94	-
Pot Cap-1 Maneuver	0	-			500	0
Stage 1	0	-			-	0
Stage 2	0	-			478	0
Platoon blocked, %		-				
Mov Cap-1 Maneuver	-	-			500	-
Mov Cap-2 Maneuver	_	_			500	_
Stage 1	_	_			-	_
Stage 2	_	_			478	_
Olago Z					710	
Approach	EB				SB	
HCM Control Delay, s	0				12.6	
HCM LOS					В	
NATIONAL TO A STATE OF THE STAT		EDT (3DL 4			
Minor Lane/Major Mvmt			SBLn1			
Capacity (veh/h)		-	000			
HCM Lane V/C Ratio		-	0.048			
HCM Control Delay (s)		-	12.6			
HCM Lane LOS HCM 95th %tile Q(veh)		-	0.1			

	۶	→	*	1	←	*	1	†	1	1	Ţ	1
Movement	EBL	EBT	EBR	WBL	WBT	WBR	NBL	NBT	NBR	SBL	SBT	SBR
Lane Configurations					ተ						^	77
Traffic Volume (vph)	0	0	0	0	1549	0	0	0	0	0	165	513
Future Volume (vph)	0	0	0	0	1549	0	0	0	0	0	165	513
Ideal Flow (vphpl)	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000
Total Lost time (s)					5.9						9.0	9.0
Lane Util. Factor					0.91						0.95	0.88
Frt					1.00						1.00	0.85
Flt Protected					1.00						1.00	1.00
Satd. Flow (prot)					5353						3725	2933
Flt Permitted					1.00						1.00	1.00
Satd. Flow (perm)					5353						3725	2933
Peak-hour factor, PHF	0.92	0.92	0.92	0.84	0.84	0.84	0.92	0.92	0.92	0.68	0.68	0.68
Adj. Flow (vph)	0	0	0	0	1844	0	0	0	0	0	243	754
RTOR Reduction (vph)	0	0	0	0	0	0	0	0	0	0	0	16
Lane Group Flow (vph)	0	0	0	0	1844	0	0	0	0	0	243	738
Turn Type					NA						NA	Perm
Protected Phases					6						4	
Permitted Phases												4
Actuated Green, G (s)					59.1						46.0	46.0
Effective Green, g (s)					59.1						46.0	46.0
Actuated g/C Ratio					0.49						0.38	0.38
Clearance Time (s)					5.9						9.0	9.0
Vehicle Extension (s)					3.0						3.0	3.0
Lane Grp Cap (vph)					2636						1427	1124
v/s Ratio Prot					c0.34						0.07	
v/s Ratio Perm												c0.25
v/c Ratio					0.70						0.17	0.66
Uniform Delay, d1					23.6						24.4	30.5
Progression Factor					1.00						1.00	1.00
Incremental Delay, d2					1.6						0.1	1.4
Delay (s)					25.1						24.5	31.9
Level of Service					С						С	С
Approach Delay (s)		0.0			25.1			0.0			30.1	
Approach LOS		А			С			Α			С	
Intersection Summary												
HCM 2000 Control Delay			26.9	Н	CM 2000	Level of S	Service		С			
HCM 2000 Volume to Capaci	ty ratio		0.68									
Actuated Cycle Length (s)			120.0	S	um of lost	time (s)			14.9			
Intersection Capacity Utilization	on		57.9%	IC	CU Level o	of Service			В			
Analysis Period (min)			15									

c Critical Lane Group

	۶	-	←	*	1	4		
Movement	EBL	EBT	WBT	WBR	SBL	SBR		
Lane Configurations		ተ			ሻሻ	52.1		
Traffic Volume (vph)	0	678	0	0	165	0		
Future Volume (vph)	0	678	0	0	165	0		
Ideal Flow (vphpl)	2000	2000	2000	2000	2000	2000		
Total Lost time (s)		5.9			6.0			
Lane Util. Factor		0.91			0.97			
Frt		1.00			1.00			
Flt Protected		1.00			0.95			
Satd. Flow (prot)		5406			3614			
FIt Permitted		1.00			0.95			
Satd. Flow (perm)		5406			3614			
Peak-hour factor, PHF	0.88	0.88	0.92	0.92	0.68	0.68		
Adj. Flow (vph)	0	770	0	0	243	0		
RTOR Reduction (vph)	0	0	0	0	144	0		
Lane Group Flow (vph)	0	770	0	0	99	0		
Heavy Vehicles (%)	1%	1%	2%	2%	2%	2%		
Turn Type		NA			Prot			
Protected Phases		2			8			
Permitted Phases		_			-			
Actuated Green, G (s)		59.1			49.0			
Effective Green, g (s)		59.1			49.0			
Actuated g/C Ratio		0.49			0.41			
Clearance Time (s)		5.9			6.0			
Vehicle Extension (s)		3.0			3.0			
Lane Grp Cap (vph)		2662			1475			
v/s Ratio Prot		c0.14			c0.03			
v/s Ratio Perm								
v/c Ratio		0.29			0.07			
Uniform Delay, d1		18.0			21.6			
Progression Factor		1.03			0.04			
Incremental Delay, d2		0.3			0.0			
Delay (s)		18.8			0.8			
Level of Service		В			Α			
Approach Delay (s)		18.8	0.0		8.0			
Approach LOS		В	Α		Α			
Intersection Summary								
HCM 2000 Control Delay			14.5	Н	CM 2000	Level of Service	В	
HCM 2000 Volume to Capacity	ratio		0.19					
Actuated Cycle Length (s)			120.0	Sı	um of lost	time (s)	14.9	
Intersection Capacity Utilization			57.9%		U Level c		В	
Analysis Period (min)			15					
c Critical Lane Group								

Intersection						
Int Delay, s/veh	0					
Movement	EBT	EBR	WBL	WBT	NBL	NBR
Lane Configurations	ተተቱ	רטוע	TTDL	1101	TADE	7
Traffic Vol, veh/h	1185	0	0	0	0	0
Future Vol, veh/h	1185	0	0	0	0	0
	0	0	0	0	0	0
Conflicting Peds, #/hr						
Sign Control	Free	Free	Stop	Stop	Stop	Stop
RT Channelized	-	None	-	None	-	None
Storage Length	-	-	-	-	-	0
Veh in Median Storage		-	-	0	0	-
Grade, %	0	-	-	0	0	-
Peak Hour Factor	88	88	92	92	92	92
Heavy Vehicles, %	1	1	2	2	2	2
Mvmt Flow	1347	0	0	0	0	0
Major/Minor	Major1			N	/linor1	
	Major1			I)		C7.4
Conflicting Flow All	0	0			-	674
Stage 1	-	-			-	-
Stage 2	-	-			-	-
Critical Hdwy	-	-			-	7.14
Critical Hdwy Stg 1	-	-			-	-
Critical Hdwy Stg 2	-	-			-	-
Follow-up Hdwy	-	-			-	3.92
Pot Cap-1 Maneuver	-	-			0	341
Stage 1	-	-			0	-
Stage 2	-	-			0	-
Platoon blocked, %	_	_				
Mov Cap-1 Maneuver	_	_			_	341
Mov Cap 1 Maneuver	_	_			_	-
Stage 1	_	_			_	_
Stage 2		_			_	_
Staye 2		-			-	-
Approach	EB				NB	
HCM Control Delay, s	0				0	
HCM LOS					Α	
NA: 1 /NA: NA		NDL 4	EDT	EDD		
Minor Lane/Major Mvr	nt I	NBLn1	EBT	EBR		
Capacity (veh/h)		-	-	-		
HCM Lane V/C Ratio		-	-	-		
HCM Control Delay (s)	0	-	-		
HCM Lane LOS		Α	-	-		
HCM 95th %tile Q(veh)	-	-	-		

Intersection												
Int Delay, s/veh	0											
Movement	EBL	EBT	EBR	WBL	WBT	WBR	NBL	NBT	NBR	SBL	SBT	SBR
Lane Configurations		4			4		7	1→		ሻ	1	
Traffic Vol, veh/h	0	0	0	0	0	0	0	495	0	0	346	0
Future Vol, veh/h	0	0	0	0	0	0	0	495	0	0	346	0
Conflicting Peds, #/hr	0	0	0	0	0	0	0	0	0	0	0	0
Sign Control	Stop	Stop	Stop	Stop	Stop	Stop	Free	Free	Free	Free	Free	Free
RT Channelized	-	-	None	-	-	None	-	-	None	-	-	None
Storage Length	-	-	-	-	-	-	500	-	-	475	-	-
Veh in Median Storage	e,# -	0	-	-	0	-	-	0	-	-	0	-
Grade, %	-	0	-	-	0	-	-	0	-	-	0	-
Peak Hour Factor	92	92	92	92	92	92	91	91	91	92	92	92
Heavy Vehicles, %	2	2	2	2	2	2	1	1	1	2	2	2
Mvmt Flow	0	0	0	0	0	0	0	544	0	0	376	0
Major/Minor	Minor2			Minor1			Major1		I	Major2		
Conflicting Flow All	920	920	376	920	920	544	376	0	0	544	0	0
Stage 1	376	376	-	544	544	-	-	-	-	-	-	-
Stage 2	544	544	-	376	376	-	-	-	-	-	-	-
Critical Hdwy	7.12	6.52	6.22	7.12	6.52	6.22	4.11	-	-	4.12	-	-
Critical Hdwy Stg 1	6.12	5.52	-	6.12	5.52	-	-	-	-	-	-	-
Critical Hdwy Stg 2	6.12	5.52	-	6.12	5.52	-	-	-	-	-	-	-
Follow-up Hdwy	3.518	4.018	3.318	3.518	4.018	3.318	2.209	-	-	2.218	-	-
Pot Cap-1 Maneuver	251	271	670	251	271	539	1188	-	-	1025	-	-
Stage 1	645	616	-	523	519	-	-	-	-	-	-	-
Stage 2	523	519	-	645	616	-	-	-	-	-	-	-
Platoon blocked, %								-	-		-	-
Mov Cap-1 Maneuver	251	271	670	251	271	539	1188	-	-	1025	-	-
Mov Cap-2 Maneuver	251	271	-	251	271	-	-	-	-	-	-	-
Stage 1	645	616	-	523	519	-	-	-	-	-	-	-
Stage 2	523	519	-	645	616	-	-	-	-	-	-	-
Approach	EB			WB			NB			SB		
HCM Control Delay, s	0			0			0			0		
HCM LOS	A			A								
		_	_		_	_	_	_	_	_	_	_
Minor Lane/Major Mvm	nt	NBL	NBT	NBR	EBLn1V	VBLn1	SBL	SBT	SBR			
Capacity (veh/h)		1188				-	1025					
HCM Lane V/C Ratio			_	_	_	_	- 020	_	_			
HCM Control Delay (s)		0	_	-	0	0	0	-	_			
HCM Lane LOS		A	_	_	A	A	A	_	_			
HCM 95th %tile Q(veh))	0	_	_	-	-	0	_	_			
		- 0										

Intersection						
Int Delay, s/veh	0					
		WDD	NDT	NDD	CDI	SBT
Movement	WBL	WBR	NBT	NBR	SBL	
Lane Configurations	M	^	♣	^	<u>`</u>	↑
Traffic Vol, veh/h	0	0	495	0	0	346
Future Vol, veh/h	0	0	495	0	0	346
Conflicting Peds, #/hr	0	0	_ 0	_ 0	_ 0	_ 0
Sign Control	Stop	Stop	Free	Free	Free	Free
RT Channelized	-	None	-		-	None
Storage Length	0	-	-	-	500	-
Veh in Median Storage	e, # 0	-	0	-	-	0
Grade, %	0	-	0	-	-	0
Peak Hour Factor	92	92	91	91	92	92
Heavy Vehicles, %	2	2	1	1	2	2
Mvmt Flow	0	0	544	0	0	376
Majar/Minar	Minard		Ania na		Mais	
	Minor1		Major1		Major2	
Conflicting Flow All	920	544	0	0	544	0
Stage 1	544	-	-	-	-	-
Stage 2	376	-	-	-	-	-
Critical Hdwy	6.42	6.22	-	-	4.12	-
Critical Hdwy Stg 1	5.42	-	-	-	-	-
Critical Hdwy Stg 2	5.42	-	-	-	-	-
Follow-up Hdwy	3.518	3.318	-	-	2.218	-
Pot Cap-1 Maneuver	301	539	-	-	1025	-
Stage 1	582	-	-	_	-	-
Stage 2	694	_	_	_	_	_
Platoon blocked, %			_	_		_
Mov Cap-1 Maneuver	301	539	_	-	1025	_
Mov Cap-1 Maneuver	424	-	_		1025	
	582			_		
Stage 1		-	-	_	-	-
Stage 2	694	-	-	-	-	-
Approach	WB		NB		SB	
HCM Control Delay, s	0		0		0	
HCM LOS	A		0		0	
TOW LOO	Α					
Minor Lane/Major Mvn	nt	NBT	NBRV	VBLn1	SBL	SBT
Capacity (veh/h)		-	-	-	1025	-
HCM Lane V/C Ratio		-	-	-	-	-
HCM Control Delay (s))	-	-	0	0	-
HCM Lane LOS		-	-	Α	Α	-
HCM 95th %tile Q(veh)	-	-	-	0	-
	,					

Intersection: 10: EB 12-Mile Road & WB-to-EB XO, W. of Meadowbrook

Movement	SB
Directions Served	L
Maximum Queue (ft)	87
Average Queue (ft)	58
95th Queue (ft)	82
Link Distance (ft)	23
Upstream Blk Time (%)	27
Queuing Penalty (veh)	75
Storage Bay Dist (ft)	
Storage Blk Time (%)	
Queuing Penalty (veh)	

Intersection: 11: WB-to-EB XO, W. of Meadowbrook & WB 12-Mile Road

Movement	WB	WB
Directions Served	L	T
Maximum Queue (ft)	121	8
Average Queue (ft)	25	0
95th Queue (ft)	79	6
Link Distance (ft)		651
Upstream Blk Time (%)		
Queuing Penalty (veh)		
Storage Bay Dist (ft)	250	
Storage Blk Time (%)		
Queuing Penalty (veh)		

Intersection: 20: Meadowbrook Road & WB 12-Mile Road

Movement	WB	WB	WB	WB	NB	SB	SB
Directions Served	Т	Т	Т	R	Т	Т	R
Maximum Queue (ft)	163	157	128	55	4	170	56
Average Queue (ft)	91	73	44	20	0	69	24
95th Queue (ft)	154	134	103	49	4	137	45
Link Distance (ft)	148	148	148	148	56	837	
Upstream Blk Time (%)	1	0	0				
Queuing Penalty (veh)	3	1	0				
Storage Bay Dist (ft)							275
Storage Blk Time (%)							
Queuing Penalty (veh)							

Intersection: 21: Meadowbrook Road & EB 12-Mile Road

Movement	EB	EB	EB	EB	NB	NB	SB
Directions Served	Т	Т	Т	R	Т	R	Т
Maximum Queue (ft)	76	64	94	122	86	84	5
Average Queue (ft)	35	21	29	41	32	36	0
95th Queue (ft)	67	53	72	85	74	66	4
Link Distance (ft)	634	634	634		878		56
Upstream Blk Time (%)							
Queuing Penalty (veh)							
Storage Bay Dist (ft)				350		250	
Storage Blk Time (%)							
Queuing Penalty (veh)							

Intersection: 30: EB 12-Mile Road & WB-to-EB XO, E. of Meadowbrook

Movement
Directions Served
Maximum Queue (ft)
Average Queue (ft)
95th Queue (ft)
Link Distance (ft)
Upstream Blk Time (%)
Queuing Penalty (veh)
Storage Bay Dist (ft)
Storage Blk Time (%)
Queuing Penalty (veh)

Intersection: 31: WB-to-EB XO, E. of Meadowbrook & WB 12-Mile Road

Movement	WB	WB
Directions Served	Т	Т
Maximum Queue (ft)	64	27
Average Queue (ft)	4	2
95th Queue (ft)	31	15
Link Distance (ft)	506	506
Upstream Blk Time (%)		
Queuing Penalty (veh)		
Storage Bay Dist (ft)		
Storage Blk Time (%)		
Queuing Penalty (veh)		

Intersection: 40: EB-to-WB XO, E. of Meadowbrook & WB 12-Mile Road

Movement	NB
Directions Served	L
Maximum Queue (ft)	52
Average Queue (ft)	20
95th Queue (ft)	46
Link Distance (ft)	18
Upstream Blk Time (%)	4
Queuing Penalty (veh)	2
Storage Bay Dist (ft)	
Storage Blk Time (%)	
Queuing Penalty (veh)	

Intersection: 41: EB 12-Mile Road & EB-to-WB XO, E. of Meadowbrook

Movement	EB
Directions Served	L
Maximum Queue (ft)	6
Average Queue (ft)	0
95th Queue (ft)	4
Link Distance (ft)	
Upstream Blk Time (%)	
Queuing Penalty (veh)	
Storage Bay Dist (ft)	250
Storage Blk Time (%)	
Queuing Penalty (veh)	

Intersection: 50: EB 12-Mile Road & WB-to-EB XO, W. of Summit Dr.

Movement	SB
Directions Served	L
Maximum Queue (ft)	31
Average Queue (ft)	10
95th Queue (ft)	32
Link Distance (ft)	23
Upstream Blk Time (%)	1
Queuing Penalty (veh)	0
Storage Bay Dist (ft)	
Storage Blk Time (%)	
Queuing Penalty (veh)	

Intersection: 51: WB-to-EB XO, W. of Summit Dr. & WB 12-Mile Road

Queuing Penalty (veh)

Intersection: 60: SB M-5 Exit-Ramp & WB 12-Mile Road

Movement	WB	WB	WB	SB	SB	SB	SB
Directions Served	Ţ	Т	Т	Т	Т	R	R
Maximum Queue (ft)	171	116	56	126	149	78	40
Average Queue (ft)	76	22	11	30	87	43	15
95th Queue (ft)	142	73	40	78	138	69	41
Link Distance (ft)	1226	1226	1226			958	
Upstream Blk Time (%)							
Queuing Penalty (veh)							
Storage Bay Dist (ft)				250	250		250
Storage Blk Time (%)							
Queuing Penalty (veh)							

Intersection: 61: EB 12-Mile Road & SB M-5 Exit-Ramp

Movement	EB	EB	EB	SB
Directions Served	T	Т	T	L
Maximum Queue (ft)	87	86	94	8
Average Queue (ft)	33	28	29	0
95th Queue (ft)	67	67	73	5
Link Distance (ft)	141	141	141	22
Upstream Blk Time (%)				1
Queuing Penalty (veh)				1
Storage Bay Dist (ft)				
Storage Blk Time (%)				
Queuing Penalty (veh)				

Intersection: 70: Site Drive #1 & EB 12-Mile Road

Movement

Directions Served

Maximum Queue (ft)

Average Queue (ft)

95th Queue (ft)

Link Distance (ft)

Upstream Blk Time (%)

Queuing Penalty (veh)

Storage Bay Dist (ft)

Storage Blk Time (%)

Queuing Penalty (veh)

Intersection: 80: Meadowbrook Road & Elm Creek Drive/Site Drive #2

Movement

Directions Served

Maximum Queue (ft)

Average Queue (ft)

95th Queue (ft)

Link Distance (ft)

Upstream Blk Time (%)

Queuing Penalty (veh)

Storage Bay Dist (ft)

Storage Blk Time (%)

Queuing Penalty (veh)

Intersection: 90: Meadowbrook Road & Site Drive #3

Movement

Directions Served

Maximum Queue (ft)

Average Queue (ft)

95th Queue (ft)

Link Distance (ft)

Upstream Blk Time (%)

Queuing Penalty (veh)

Storage Bay Dist (ft)

Storage Blk Time (%)

Queuing Penalty (veh)

Zone Summary

Zone wide Queuing Penalty: 81

Intersection: 10: EB 12-Mile Road & WB-to-EB XO, W. of Meadowbrook

Movement	SB
Directions Served	L
Maximum Queue (ft)	74
Average Queue (ft)	59
95th Queue (ft)	78
Link Distance (ft)	23
Upstream Blk Time (%)	32
Queuing Penalty (veh)	80
Storage Bay Dist (ft)	
Storage Blk Time (%)	
Queuing Penalty (veh)	

Intersection: 11: WB-to-EB XO, W. of Meadowbrook & WB 12-Mile Road

Movement	WB
Directions Served	L
Maximum Queue (ft)	121
Average Queue (ft)	28
95th Queue (ft)	83
Link Distance (ft)	
Upstream Blk Time (%)	
Queuing Penalty (veh)	
Storage Bay Dist (ft)	250
Storage Blk Time (%)	
Queuing Penalty (veh)	

Intersection: 20: Meadowbrook Road & WB 12-Mile Road

Movement	WB	WB	WB	WB	NB	SB	SB
Directions Served	Т	Т	Т	R	Т	Т	R
Maximum Queue (ft)	179	186	175	143	8	208	106
Average Queue (ft)	142	146	139	69	0	85	23
95th Queue (ft)	194	201	195	125	4	162	64
Link Distance (ft)	148	148	148	148	56	837	
Upstream Blk Time (%)	7	9	7	0			
Queuing Penalty (veh)	39	47	38	1			
Storage Bay Dist (ft)							275
Storage Blk Time (%)							
Queuing Penalty (veh)							

Intersection: 21: Meadowbrook Road & EB 12-Mile Road

Movement	EB	EB	EB	EB	NB	NB	SB
Directions Served	Т	Т	Т	R	Т	R	T
Maximum Queue (ft)	133	136	199	84	168	199	5
Average Queue (ft)	60	58	83	36	83	82	0
95th Queue (ft)	113	118	163	71	152	154	3
Link Distance (ft)	634	634	634		878		56
Upstream Blk Time (%)							
Queuing Penalty (veh)							
Storage Bay Dist (ft)				350		250	
Storage Blk Time (%)						0	
Queuing Penalty (veh)						0	

Intersection: 30: EB 12-Mile Road & WB-to-EB XO, E. of Meadowbrook

Movement	SB	
Directions Served	L	
Maximum Queue (ft)	24	
Average Queue (ft)	2	
95th Queue (ft)	16	
Link Distance (ft)	19	
Upstream Blk Time (%)	1	
Queuing Penalty (veh)	0	
Storage Bay Dist (ft)		
Storage Blk Time (%)		
Queuing Penalty (veh)		

Intersection: 31: WB-to-EB XO, E. of Meadowbrook & WB 12-Mile Road

Movement	WB	WB	WB	WB	
Directions Served	Т	Т	Т	Т	
Maximum Queue (ft)	226	219	210	66	
Average Queue (ft)	50	57	45	3	
95th Queue (ft)	144	159	141	46	
Link Distance (ft)	506	506	506		
Upstream Blk Time (%)					
Queuing Penalty (veh)					
Storage Bay Dist (ft)				150	
Storage Blk Time (%)	0		0		
Queuing Penalty (veh)	0		3		

Intersection: 40: EB-to-WB XO, E. of Meadowbrook & WB 12-Mile Road

Movement	NB
Directions Served	L
Maximum Queue (ft)	63
Average Queue (ft)	37
95th Queue (ft)	63
Link Distance (ft)	18
Upstream Blk Time (%)	29
Queuing Penalty (veh)	24
Storage Bay Dist (ft)	
Storage Blk Time (%)	
Queuing Penalty (veh)	

Intersection: 41: EB 12-Mile Road & EB-to-WB XO, E. of Meadowbrook

Movement	EB
Directions Served	L
Maximum Queue (ft)	63
Average Queue (ft)	6
95th Queue (ft)	32
Link Distance (ft)	
Upstream Blk Time (%)	
Queuing Penalty (veh)	
Storage Bay Dist (ft)	250
Storage Blk Time (%)	
Queuing Penalty (veh)	

Intersection: 50: EB 12-Mile Road & WB-to-EB XO, W. of Summit Dr.

Movement	SB	
Directions Served	L	
Maximum Queue (ft)	59	
Average Queue (ft)	16	
95th Queue (ft)	45	
Link Distance (ft)	23	
Upstream Blk Time (%)	3	
Queuing Penalty (veh)	1	
Storage Bay Dist (ft)		
Storage Blk Time (%)		
Queuing Penalty (veh)		

Intersection: 51: WB-to-EB XO, W. of Summit Dr. & WB 12-Mile Road

Movement	WB
Directions Served	L
Maximum Queue (ft)	8
Average Queue (ft)	0
95th Queue (ft)	6
Link Distance (ft)	
Upstream Blk Time (%)	
Queuing Penalty (veh)	
Storage Bay Dist (ft)	300
Storage Blk Time (%)	
Queuing Penalty (veh)	

Intersection: 60: SB M-5 Exit-Ramp & WB 12-Mile Road

Movement	WB	WB	WB	SB	SB	SB	SB	
Directions Served	T	Т	Т	Т	Т	R	R	
Maximum Queue (ft)	341	343	289	156	218	308	242	
Average Queue (ft)	161	126	93	32	95	133	91	
95th Queue (ft)	275	249	198	99	171	238	197	
Link Distance (ft)	1226	1226	1226			958		
Upstream Blk Time (%)								
Queuing Penalty (veh)								
Storage Bay Dist (ft)				250	250		250	
Storage Blk Time (%)					0	1	0	
Queuing Penalty (veh)					0	5	0	

Intersection: 61: EB 12-Mile Road & SB M-5 Exit-Ramp

Movement	EB	EB	EB	SB	
Directions Served	Т	Т	Т	L	
Maximum Queue (ft)	119	128	145	19	
Average Queue (ft)	45	45	55	1	
95th Queue (ft)	95	103	116	7	
Link Distance (ft)	141	141	141	22	
Upstream Blk Time (%)	0	0	0	2	
Queuing Penalty (veh)	0	0	0	2	
Storage Bay Dist (ft)					
Storage Blk Time (%)					
Queuing Penalty (veh)					

Intersection: 70: Site Drive #1 & EB 12-Mile Road

Movement

Directions Served

Maximum Queue (ft)

Average Queue (ft)

95th Queue (ft)

Link Distance (ft)

Upstream Blk Time (%)

Queuing Penalty (veh)

Storage Bay Dist (ft)

Storage Blk Time (%)

Queuing Penalty (veh)

Intersection: 80: Meadowbrook Road & Elm Creek Drive/Site Drive #2

Movement

Directions Served

Maximum Queue (ft)

Average Queue (ft)

95th Queue (ft)

Link Distance (ft)

Upstream Blk Time (%)

Queuing Penalty (veh)

Storage Bay Dist (ft)

Storage Blk Time (%)

Queuing Penalty (veh)

Intersection: 90: Meadowbrook Road & Site Drive #3

Movement

Directions Served

Maximum Queue (ft)

Average Queue (ft)

95th Queue (ft)

Link Distance (ft)

Upstream Blk Time (%)

Queuing Penalty (veh)

Storage Bay Dist (ft)

Storage Blk Time (%)

Queuing Penalty (veh)

Zone Summary

Zone wide Queuing Penalty: 241

Intersection						
Int Delay, s/veh	4.9					
Movement	EBL	EBT	WBT	WBR	SBL	SBR
Lane Configurations	LUL	ተተተ	1101	אוטוג	<u> </u>	אופט
Traffic Vol, veh/h	0	526	0	0	287	0
Future Vol, veh/h	0	526	0	0	287	0
Conflicting Peds, #/hr	0	0	0	0	0	0
Sign Control	Free	Free	Stop	Stop	Stop	Stop
RT Channelized	-		-		-	None
Storage Length	_	-	_	-	0	-
Veh in Median Storage,	# -	108208	94336	_	0	_
Grade, %	<i>"</i>	0	0	_	0	_
Peak Hour Factor	90	90	92	92	88	88
Heavy Vehicles, %	4	4	2	2	2	2
Mvmt Flow	0	584	0	0	326	0
			•		0_0	•
				_		
	lajor1			N	/linor2	
Conflicting Flow All	-	0			234	-
Stage 1	-	-			0	-
Stage 2	-	-			234	-
Critical Hdwy	-	-			5.74	-
Critical Hdwy Stg 1	-	-			-	-
Critical Hdwy Stg 2	-	-			6.04	-
Follow-up Hdwy	-	-			3.82	-
Pot Cap-1 Maneuver	0	-			733	0
Stage 1	0	-			-	0
Stage 2	0	-			719	0
Platoon blocked, %		-				
Mov Cap-1 Maneuver	-	-			733	-
Mov Cap-2 Maneuver	-	-			733	-
Stage 1	-	-			-	-
Stage 2	-	-			719	-
, and the second						
A	ED				CD.	
Approach	EB				SB	
HCM Control Delay, s	0				13.8	
HCM LOS					В	
Minor Lane/Major Mvmt		FBT S	SBLn1			
Capacity (veh/h)			733			
HCM Lane V/C Ratio			0.445			
HCM Control Delay (s)		_	13.8			
HCM Lane LOS		_	В			
HCM 95th %tile Q(veh)		_	2.3			
			0			

	۶	→	*	1	←	*	1	1	1	1	↓	4
Movement	EBL	EBT	EBR	WBL	WBT	WBR	NBL	NBT	NBR	SBL	SBT	SBR
Lane Configurations					ተ	7		↑			↑	7
Traffic Volume (vph)	0	0	0	0	784	68	0	56	0	0	119	95
Future Volume (vph)	0	0	0	0	784	68	0	56	0	0	119	95
Ideal Flow (vphpl)	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000
Total Lost time (s)					6.0	6.0		6.4			10.4	10.4
Lane Util. Factor					0.91	1.00		1.00			1.00	1.00
Frpb, ped/bikes					1.00	0.98		1.00			1.00	1.00
Flpb, ped/bikes					1.00	1.00		1.00			1.00	1.00
Frt					1.00	0.85		1.00			1.00	0.85
Flt Protected					1.00	1.00		1.00			1.00	1.00
Satd. Flow (prot)					5301	1616		1905			1923	1635
Flt Permitted					1.00	1.00		1.00			1.00	1.00
Satd. Flow (perm)					5301	1616		1905			1923	1635
Peak-hour factor, PHF	0.90	0.90	0.90	0.73	0.73	0.73	0.93	0.93	0.93	0.88	0.88	0.88
Adj. Flow (vph)	0	0	0	0	1074	93	0	60	0	0	135	108
RTOR Reduction (vph)	0	0	0	0	0	46	0	0	0	0	0	42
Lane Group Flow (vph)	0	0	0	0	1074	47	0	60	0	0	135	66
Confl. Peds. (#/hr)	1					1			1	1		
Heavy Vehicles (%)	4%	4%	4%	3%	3%	3%	5%	5%	5%	4%	4%	4%
Turn Type					NA	Perm		NA			NA	Perm
Protected Phases					6			8			4	
Permitted Phases						6						4
Actuated Green, G (s)					61.0	61.0		46.6			42.6	42.6
Effective Green, g (s)					61.0	61.0		46.6			42.6	42.6
Actuated g/C Ratio					0.51	0.51		0.39			0.36	0.36
Clearance Time (s)					6.0	6.0		6.4			10.4	10.4
Vehicle Extension (s)					3.0	3.0		3.0			3.0	3.0
Lane Grp Cap (vph)					2694	821		739			682	580
v/s Ratio Prot					c0.20			0.03			c0.07	
v/s Ratio Perm						0.03						0.04
v/c Ratio					0.40	0.06		0.08			0.20	0.11
Uniform Delay, d1					18.2	14.9		23.2			26.8	26.0
Progression Factor					1.15	2.37		0.00			1.00	1.00
Incremental Delay, d2					0.4	0.1		0.0			0.1	0.1
Delay (s)					21.3	35.6		0.1			27.0	26.1
Level of Service					С	D		Α			С	С
Approach Delay (s)		0.0			22.4			0.1			26.6	
Approach LOS		Α			С			Α			С	
Intersection Summary												
HCM 2000 Control Delay			22.2	Н	CM 2000	Level of S	Service		С			
HCM 2000 Volume to Capacit	y ratio		0.32									
Actuated Cycle Length (s)			120.0		um of lost				16.4			
Intersection Capacity Utilization	n		35.2%	IC	CU Level	of Service			Α			
Analysis Period (min)			15									

	۶	→	*	•	←	4	1	1	1	1	↓	4
Movement	EBL	EBT	EBR	WBL	WBT	WBR	NBL	NBT	NBR	SBL	SBT	SBR
Lane Configurations		ተ	7					↑	7		↑	
Traffic Volume (vph)	0	504	309	0	0	0	0	56	192	0	119	0
Future Volume (vph)	0	504	309	0	0	0	0	56	192	0	119	0
Ideal Flow (vphpl)	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000
Total Lost time (s)		6.0	6.0					10.4	10.4		6.4	
Lane Util. Factor		0.91	1.00					1.00	1.00		1.00	
Frpb, ped/bikes		1.00	1.00					1.00	0.99		1.00	
Flpb, ped/bikes		1.00	1.00					1.00	1.00		1.00	
Frt		1.00	0.85					1.00	0.85		1.00	
Flt Protected		1.00	1.00					1.00	1.00		1.00	
Satd. Flow (prot)		5250	1635					1905	1598		1923	
Flt Permitted		1.00	1.00					1.00	1.00		1.00	
Satd. Flow (perm)		5250	1635					1905	1598		1923	
Peak-hour factor, PHF	0.90	0.90	0.90	0.73	0.73	0.73	0.93	0.93	0.93	0.88	0.88	0.88
Adj. Flow (vph)	0	560	343	0	0	0	0	60	206	0	135	0
RTOR Reduction (vph)	0	0	169	0	0	0	0	0	133	0	0	0
Lane Group Flow (vph)	0	560	174	0	0	0	0	60	73	0	135	0
Confl. Peds. (#/hr)	1					1			1	1		
Heavy Vehicles (%)	4%	4%	4%	3%	3%	3%	5%	5%	5%	4%	4%	4%
Turn Type		NA	Perm					NA	Perm		NA	
Protected Phases		2						4			8	
Permitted Phases			2						4			
Actuated Green, G (s)		61.0	61.0					42.6	42.6		46.6	
Effective Green, g (s)		61.0	61.0					42.6	42.6		46.6	
Actuated g/C Ratio		0.51	0.51					0.36	0.36		0.39	
Clearance Time (s)		6.0	6.0					10.4	10.4		6.4	
Vehicle Extension (s)		3.0	3.0					3.0	3.0		3.0	
Lane Grp Cap (vph)		2668	831					676	567		746	
v/s Ratio Prot		c0.11						0.03			c0.07	
v/s Ratio Perm			0.11						0.05			
v/c Ratio		0.21	0.21					0.09	0.13		0.18	
Uniform Delay, d1		16.2	16.2					25.8	26.2		24.1	
Progression Factor		0.82	0.52					1.00	1.00		0.00	
Incremental Delay, d2		0.2	0.6					0.1	0.1		0.1	
Delay (s)		13.5	9.0					25.8	26.3		0.1	
Level of Service		В	Α					С	С		Α	
Approach Delay (s)		11.8			0.0			26.2			0.1	
Approach LOS		В			Α			С			Α	
Intersection Summary												
HCM 2000 Control Delay			13.5	H	CM 2000	Level of S	Service		В			
HCM 2000 Volume to Capac	city ratio		0.20									
Actuated Cycle Length (s)			120.0	Sı	um of lost	time (s)			16.4			
Intersection Capacity Utiliza	tion		35.2%	IC	U Level o	of Service			Α			
Analysis Period (min)			15									
0.111 0												

Intersection						
Int Delay, s/veh	0					
		EDT	MOT	WDD	CDI	CDD
Movement	EBL	EBT	WBT	WBR	SBL	SBR
Lane Configurations		444	_	^	ሻ	_
Traffic Vol, veh/h	0	696	0	0	0	0
Future Vol, veh/h	0	696	0	0	0	0
Conflicting Peds, #/hr	_ 0	_ 0	0	0	0	0
	Free	Free	Stop	Stop	Stop	Stop
RT Channelized	-	None	-		-	None
Storage Length	-	-	-	-	0	-
Veh in Median Storage,	# -	108 0 5		-	0	-
Grade, %	-	0	0	-	0	-
Peak Hour Factor	85	85	92	92	92	92
Heavy Vehicles, %	6	6	2	2	2	2
Mvmt Flow	0	819	0	0	0	0
NA = i = /NAi =	-:1				A: C	
	lajor1			1	/linor2	
Conflicting Flow All	-	0			328	-
Stage 1	-	-			0	-
Stage 2	-	-			328	-
Critical Hdwy	-	-			5.74	-
Critical Hdwy Stg 1	-	-			-	-
Critical Hdwy Stg 2	-	-			6.04	-
Follow-up Hdwy	-	-			3.82	-
Pot Cap-1 Maneuver	0	-			661	0
Stage 1	0	-			-	0
Stage 2	0	_			644	0
Platoon blocked, %		_			V 11	
Mov Cap-1 Maneuver	_	_			661	_
Mov Cap-1 Maneuver	-	_			661	_
Stage 1	-	-			001	-
•					644	
Stage 2	-	-			044	-
Approach	EB				SB	
HCM Control Delay, s	0				0	
HCM LOS	U				A	
TIOWI LOG						
Minor Lane/Major Mvmt		EBT S	SBLn1			
Capacity (veh/h)		-	_			
HCM Lane V/C Ratio		-	_			
HCM Control Delay (s)		_	0			
HCM Lane LOS		-	A			
HCM 95th %tile Q(veh)			, (
TOWN COURT FORMIC CONTROL						

Intersection						
Int Delay, s/veh	0.6					
		EDD	MPI	WET	ND	NDD
Movement	EBT	EBR	WBL	WBT	NBL	NBR
Lane Configurations	^	^	^	^ ^	ሻ	^
Traffic Vol, veh/h	0	0	0	805	47	0
Future Vol, veh/h	0	0	0	805	47	0
Conflicting Peds, #/hr	0	0	0	_ 0	0	0
Sign Control	Stop	Stop	Free	Free	Stop	Stop
RT Channelized	-	None	-	None	-	None
Storage Length	-	-	-	-	0	-
Veh in Median Storage,		-	-	0	0	-
Grade, %	0	-	-	0	0	-
Peak Hour Factor	92	92	90	73	80	80
Heavy Vehicles, %	2	2	3	3	3	3
Mvmt Flow	0	0	0	1103	59	0
Major/Minor		N	/loior?	ı	/linor1	
Major/Minor		IV	Major2	IN.		
Conflicting Flow All			-		441	-
Stage 1			-	-	0	-
Stage 2			-	-	441	-
Critical Hdwy			-	-	5.76	-
Critical Hdwy Stg 1			-	-	-	-
Critical Hdwy Stg 2			-	-	6.06	-
Follow-up Hdwy			-	-	3.83	-
Pot Cap-1 Maneuver			0	-	582	0
Stage 1			0	-	-	0
Stage 2			0	-	561	0
Platoon blocked, %				-		
Mov Cap-1 Maneuver			-	-	582	-
Mov Cap-2 Maneuver			-	-	582	-
Stage 1			_	-	-	-
Stage 2			-	-	561	-
0 -						
A			\A/D		ND	
Approach			WB		NB	
HCM Control Delay, s			0		11.9	
HCM LOS					В	
Minor Lane/Major Mvmt		NBLn1	WBT			
Capacity (veh/h)		582	1101			
HCM Lane V/C Ratio		0.101	-			
HCM Control Delay (s)		11.9				
HCM Lane LOS			-			
		В	-			
HCM 95th %tile Q(veh)		0.3	-			

Intersection						
Int Delay, s/veh	0.3					
Movement	EBL	EBT	WBT	WBR	SBL	SBR
Lane Configurations	LDL	^ ^	VVDI	ופייי	SDL 1	אופט
Traffic Vol, veh/h	0	649	0	0	14	0
Future Vol, veh/h	0	649	0	0	14	0
Conflicting Peds, #/hr	0	043	0	0	0	0
Sign Control	Free	Free	Stop	Stop	Stop	Stop
RT Channelized	-		-		-	None
Storage Length	-	-	_	-	0	-
Veh in Median Storage	.# -	0	0	_	0	_
Grade, %	-	0	0	_	0	-
Peak Hour Factor	85	85	92	92	60	60
Heavy Vehicles, %	6	6	2	2	0	0
Mvmt Flow	0	764	0	0	23	0
NA - : /NA:	M-!. 4				Alian C	
	Major1				Minor2	
Conflicting Flow All	-	0			306	-
Stage 1	-	-			0	-
Stage 2	-	-			306	-
Critical Hdwy	-	-			5.7	-
Critical Hdwy Stg 1	-	-			-	-
Critical Hdwy Stg 2	-	-			6	-
Follow-up Hdwy	-	-			3.8	-
Pot Cap-1 Maneuver	0	-			683	0
Stage 1	0	-			-	0
Stage 2	0	-			666	0
Platoon blocked, %		-				
Mov Cap-1 Maneuver	-	-			683	-
Mov Cap-2 Maneuver	-	-			683	-
Stage 1	-	-			-	-
Stage 2	-	-			666	-
Approach	EB				SB	
HCM Control Delay, s	0				10.5	
HCM LOS					В	
Minor Lane/Major Mvm	ıt	EBT S	SBLn1			
Capacity (veh/h)		-				
HCM Lane V/C Ratio		-	0.034			
HCM Control Delay (s)		-	10.5			
HCM Lane LOS		-	В			
HCM 95th %tile Q(veh)		-	0.1			
			J. 1			

	۶	→	*	1	←	•	1	1	~	1	Ţ	1
Movement	EBL	EBT	EBR	WBL	WBT	WBR	NBL	NBT	NBR	SBL	SBT	SBR
Lane Configurations					ተ						^	77
Traffic Volume (vph)	0	0	0	0	622	0	0	0	0	0	167	197
Future Volume (vph)	0	0	0	0	622	0	0	0	0	0	167	197
Ideal Flow (vphpl)	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000
Total Lost time (s)					5.9						9.0	9.0
Lane Util. Factor					0.91						0.95	0.88
Frt					1.00						1.00	0.85
Flt Protected					1.00						1.00	1.00
Satd. Flow (prot)					5250						3762	2962
FIt Permitted					1.00						1.00	1.00
Satd. Flow (perm)					5250						3762	2962
Peak-hour factor, PHF	0.92	0.92	0.92	0.91	0.91	0.91	0.92	0.92	0.92	0.87	0.87	0.87
Adj. Flow (vph)	0	0	0	0	684	0	0	0	0	0	192	226
RTOR Reduction (vph)	0	0	0	0	0	0	0	0	0	0	0	143
Lane Group Flow (vph)	0	0	0	0	684	0	0	0	0	0	192	83
Heavy Vehicles (%)	2%	2%	2%	4%	4%	4%	2%	2%	2%	1%	1%	1%
Turn Type					NA						NA	Perm
Protected Phases					6						4	
Permitted Phases											•	4
Actuated Green, G (s)					61.1						44.0	44.0
Effective Green, g (s)					61.1						44.0	44.0
Actuated g/C Ratio					0.51						0.37	0.37
Clearance Time (s)					5.9						9.0	9.0
Vehicle Extension (s)					3.0						3.0	3.0
Lane Grp Cap (vph)					2673						1379	1086
v/s Ratio Prot					c0.13						c0.05	1000
v/s Ratio Perm					00.10						00.00	0.03
v/c Ratio					0.26						0.14	0.08
Uniform Delay, d1					16.6						25.4	24.8
Progression Factor					1.00						1.00	1.00
Incremental Delay, d2					0.2						0.0	0.0
Delay (s)					16.9						25.4	24.8
Level of Service					В						C	C
Approach Delay (s)		0.0			16.9			0.0			25.1	
Approach LOS		A			В			A			C	
Intersection Summary												
HCM 2000 Control Delay			20.0	Н	CM 2000	Level of	Service		В			
HCM 2000 Volume to Capaci	ty ratio		0.21									
Actuated Cycle Length (s)			120.0	S	um of lost	time (s)			14.9			
Intersection Capacity Utilization	on		30.5%		CU Level		!		Α			
Analysis Period (min)			15									
c Critical Lane Group												

	۶	→	←	*	1	1	
Movement	EBL	EBT	WBT	WBR	SBL	SBR	
Lane Configurations		ተ ተተ			777		
Traffic Volume (vph)	0	447	0	0	167	0	
Future Volume (vph)	0	447	0	0	167	0	
Ideal Flow (vphpl)	2000	2000	2000	2000	2000	2000	
Total Lost time (s)		5.9			6.0		
Lane Util. Factor		0.91			0.97		
Frt		1.00			1.00		
Flt Protected		1.00			0.95		
Satd. Flow (prot)		5151			3650		
Flt Permitted		1.00			0.95		
Satd. Flow (perm)		5151			3650		
Peak-hour factor, PHF	0.85	0.85	0.92	0.92	0.87	0.87	
Adj. Flow (vph)	0	526	0	0	192	0	
RTOR Reduction (vph)	0	0	0	0	117	0	
Lane Group Flow (vph)	0	526	0	0	75	0	
Heavy Vehicles (%)	6%	6%	2%	2%	1%	1%	
Turn Type		NA			Prot		
Protected Phases		2			8		
Permitted Phases							
Actuated Green, G (s)		61.1			47.0		
Effective Green, g (s)		61.1			47.0		
Actuated g/C Ratio		0.51			0.39		
Clearance Time (s)		5.9			6.0		
Vehicle Extension (s)		3.0			3.0		
Lane Grp Cap (vph)		2622			1429		
v/s Ratio Prot		c0.10			c0.02		
v/s Ratio Perm							
v/c Ratio		0.20			0.05		
Uniform Delay, d1		16.1			22.7		
Progression Factor		1.12			1.00		
Incremental Delay, d2		0.2			0.0		
Delay (s)		18.3			22.7		
Level of Service		В			С		
Approach Delay (s)		18.3	0.0		22.7		
Approach LOS		В	Α		С		
Intersection Summary							
HCM 2000 Control Delay			19.5	H	CM 2000	Level of Service)
HCM 2000 Volume to Capacity	/ ratio		0.14				
Actuated Cycle Length (s)			120.0		um of lost		
Intersection Capacity Utilization	n		30.5%	IC	U Level o	of Service	
Analysis Period (min)			15				
c Critical Lane Group							

Intersection						
Int Delay, s/veh	0					
		EDD	WDI	MOT	NDI	NDD
Movement	EBT	EBR	WBL	WBT	NBL	NBR
Lane Configurations	*	^	^	^	0	7
Traffic Vol, veh/h	663	0	0	0	0	0
Future Vol, veh/h	663	0	0	0	0	0
Conflicting Peds, #/hr	0	0	0	0	0	0
Sign Control	Free	Free	Stop	Stop	Stop	Stop
RT Channelized	-	None	-	None	-	None
Storage Length	-	-	-	-	-	0
Veh in Median Storage,	# 0	-	-	0	0	-
Grade, %	0	-	-	0	0	-
Peak Hour Factor	85	85	92	92	92	92
Heavy Vehicles, %	6	6	2	2	2	2
Mvmt Flow	780	0	0	0	0	0
NA . ' . /NA'	1.1.4				I'	
	1ajor1			I\	/linor1	
Conflicting Flow All	0	0			-	390
Stage 1	-	-			-	-
Stage 2	-	-			-	-
Critical Hdwy	-	-			-	7.14
Critical Hdwy Stg 1	-	-			-	-
Critical Hdwy Stg 2	-	-			-	-
Follow-up Hdwy	-	-			-	3.92
Pot Cap-1 Maneuver	-	-			0	520
Stage 1	-	-			0	-
Stage 2	-	_			0	_
Platoon blocked, %	_	_				
Mov Cap-1 Maneuver	-	_			_	520
Mov Cap-1 Maneuver	_	_			_	-
Stage 1	_					
	_	-				_
Stage 2	-	-			-	-
Approach	EB				NB	
HCM Control Delay, s	0				0	
HCM LOS					A	
110111 200					,,	
Minor Lane/Major Mvmt	: 1	NBLn1	EBT	EBR		
Capacity (veh/h)		-	-	-		
HCM Lane V/C Ratio		-	-	-		
HCM Control Delay (s)		0	-	-		
HCM Lane LOS		Α	-	-		
HCM 95th %tile Q(veh)		-	-	-		
2222 /0010 (1011)						

Intersection												
Int Delay, s/veh	1											
Movement	EBL	EBT	EBR	WBL	WBT	WBR	NBL	NBT	NBR	SBL	SBT	SBR
Lane Configurations		4			4		7	1		*	ĵ.	
Traffic Vol, veh/h	36	0	7	0	0	0	2	212	0	0	416	12
Future Vol, veh/h	36	0	7	0	0	0	2	212	0	0	416	12
Conflicting Peds, #/hr	0	0	0	0	0	0	0	0	0	0	0	0
Sign Control	Stop	Stop	Stop	Stop	Stop	Stop	Free	Free	Free	Free	Free	Free
RT Channelized	-	-	None	-	-	None	-	-	None	-	-	None
Storage Length	-	-	-	-	-	-	500	-	-	475	-	-
Veh in Median Storage	e,# -	0	-	-	0	-	-	0	-	-	0	-
Grade, %	-	0	-	-	0	-	-	0	-	-	0	-
Peak Hour Factor	92	92	92	92	92	92	93	93	93	92	92	92
Heavy Vehicles, %	2	2	2	2	2	2	5	5	5	2	2	2
Mvmt Flow	39	0	8	0	0	0	2	228	0	0	452	13
Major/Minor	Minor2			Minor1			Major1		1	Major2		
Conflicting Flow All	691	691	459	695	697	228	465	0	0	228	0	0
Stage 1	459	459	-	232	232	-	-	-	_	-	_	_
Stage 2	232	232	-	463	465	-	-	-	-	-	-	-
Critical Hdwy	7.12	6.52	6.22	7.12	6.52	6.22	4.15	-	-	4.12	-	-
Critical Hdwy Stg 1	6.12	5.52	-	6.12	5.52	-	-	-	-	-	-	-
Critical Hdwy Stg 2	6.12	5.52	-	6.12	5.52	-	-	-	-	-	-	-
Follow-up Hdwy	3.518	4.018	3.318	3.518	4.018	3.318	2.245	-	-	2.218	-	-
Pot Cap-1 Maneuver	359	368	602	357	365	811	1081	-	-	1340	-	-
Stage 1	582	566	-	771	713	-	-	-	-	-	-	-
Stage 2	771	713	-	579	563	-	-	-	-	-	-	-
Platoon blocked, %								-	-		-	-
Mov Cap-1 Maneuver	359	367	602	352	364	811	1081	-	-	1340	-	-
Mov Cap-2 Maneuver	359	367	-	352	364	-	-	-	-	-	-	-
Stage 1	581	566	-	769	712	-	-	-	-	-	-	-
Stage 2	770	712	-	572	563	-	-	-	-	-	-	-
Approach	EB			WB			NB			SB		
HCM Control Delay, s	15.7			0			0.1			0		
HCM LOS	С			A								
Minor Lane/Major Mvm	nt	NBL	NBT	NBR	EBLn1V	VBI n1	SBL	SBT	SBR			
Capacity (veh/h)		1081		-	384	-		-	-			
HCM Lane V/C Ratio		0.002	_		0.122	_	-	_	_			
HCM Control Delay (s)		8.3		_	15.7	0	0	_	_			
HCM Lane LOS		Α	_	_	C	A	A	_	_			
HCM 95th %tile Q(veh)	0	_	_	0.4	-	0	_	_			
Sim oour 70tho Q(Vol)	1											

Intersection						
Int Delay, s/veh	0					
Movement	WBL	WBR	NBT	NBR	SBL	SBT
Lane Configurations	**	אוטוג	7>	TOIL	<u> </u>	<u> </u>
Traffic Vol, veh/h	0	0	214	0	0	423
Future Vol, veh/h	0	0	214	0	0	423
Conflicting Peds, #/hr	0	0	0	0	0	423
			Free	Free	Free	Free
Sign Control RT Channelized	Stop	Stop				
	-	None	-	None	-	None
Storage Length	0	-	-	-	500	-
Veh in Median Storage		-	0	-	-	0
Grade, %	0	-	0	-	-	0
Peak Hour Factor	92	92	93	93	92	92
Heavy Vehicles, %	2	2	5	5	2	2
Mvmt Flow	0	0	230	0	0	460
Major/Minor	/linor1	N	Major1	ı	Majora	
			Major1		Major2	^
Conflicting Flow All	690	230	0	0	230	0
Stage 1	230	-	-	-	-	-
Stage 2	460	-	-	-	-	-
Critical Hdwy	6.42	6.22	-	-	4.12	-
Critical Hdwy Stg 1	5.42	-	-	-	-	-
Critical Hdwy Stg 2	5.42	-	-	-	-	-
Follow-up Hdwy	3.518	3.318	-	-	2.218	-
Pot Cap-1 Maneuver	411	809	-	-	1338	-
Stage 1	808	-	-	-	-	-
Stage 2	636	-	-	-	-	-
Platoon blocked, %			_	_		_
Mov Cap-1 Maneuver	411	809	_	_	1338	_
Mov Cap-1 Maneuver	506	000	_		1000	
Stage 1	808	-	-	-	-	
•		-	-	-	-	-
Stage 2	636	-	-	-	-	-
Approach	WB		NB		SB	
HCM Control Delay, s	0		0		0	
HCM LOS	A		U		U	
TIOWI LOO						
Minor Lane/Major Mvm	t	NBT	NBRV	VBLn1	SBL	SBT
Capacity (veh/h)		-	_	_	1338	_
HCM Lane V/C Ratio			_	_	-	_
HCM Control Delay (s)		_	-	0	0	-
HCM Lane LOS		_	_	A	A	_
HCM 95th %tile Q(veh)		-	-	-	0	
LICIVI SOILI 70IIIE CALVEID		_	_	_	U	_

Intersection							
Int Delay, s/veh	3						
Movement	EBL	EBT	WBT	WBR	SBL	SBR	
Lane Configurations		ተ			*		
Traffic Vol, veh/h	0	890	0	0	287	0	
Future Vol, veh/h	0	890	0	0	287	0	
Conflicting Peds, #/hr	0	0	0	0	0	0	
Sign Control	Free	Free	Stop	Stop	Stop	Stop	
RT Channelized	-	None	- -		-	None	
Storage Length	_	-	_	-	0	-	
Veh in Median Storage,		1082/8		_	0	_	
Grade, %	-	0	0	_	0	_	
Peak Hour Factor	84	84	92	92	93	93	
Heavy Vehicles, %	2	2	2	2	1	1	
Mvmt Flow	0	1060	0	0	309	0	
IVIVIIIL FIOW	U	1000	U	U	309	U	
Major/Minor M	lajor1			N	/linor2		
Conflicting Flow All	-	0			424	-	
Stage 1	-	-			0	-	
Stage 2	-	-			424	-	
Critical Hdwy	-	-			5.72	-	
Critical Hdwy Stg 1	-	-			-	-	
Critical Hdwy Stg 2	-	-			6.02	-	
Follow-up Hdwy	-	-			3.81	-	
Pot Cap-1 Maneuver	0	-			*739	0	
Stage 1	0	-			-	0	
Stage 2	0	-			*739	0	
Platoon blocked, %		-			1		
Mov Cap-1 Maneuver	-	-			*739	-	
Mov Cap-2 Maneuver	-	-			*739	-	
Stage 1	-	-			-	-	
Stage 2	_	-			*739	-	
J. H. G.							
A no no no no no	ED				CD		
Approach	EB				SB		
HCM Control Delay, s	0				13.3		
HCM LOS					В		
Minor Lane/Major Mvmt		EBT (SBLn1				
Capacity (veh/h)		-	739				
HCM Lane V/C Ratio		-	0.418				
HCM Control Delay (s)		-	13.3				
HCM Lane LOS		-	В				
HCM 95th %tile Q(veh)		-	2.1				
Notes							
	noit:	ф. D.	lov s	20 d = 20	100	0	sutation Not Defined * All major values in eletera
~: Volume exceeds capa	acity	\$: De	elay exc	ceeds 30	JUS	+: Comp	outation Not Defined *: All major volume in platoon

	۶	→	*	1	←	4	4	1	1	1	↓	4
Movement	EBL	EBT	EBR	WBL	WBT	WBR	NBL	NBT	NBR	SBL	SBT	SBR
Lane Configurations					ተ	7		↑			↑	7
Traffic Volume (vph)	0	0	0	0	1885	349	0	164	0	0	157	58
Future Volume (vph)	0	0	0	0	1885	349	0	164	0	0	157	58
Ideal Flow (vphpl)	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000
Total Lost time (s)					6.0	6.0		6.4			10.4	10.4
Lane Util. Factor					0.91	1.00		1.00			1.00	1.00
Frpb, ped/bikes					1.00	1.00		1.00			1.00	0.99
Flpb, ped/bikes					1.00	1.00		1.00			1.00	1.00
Frt					1.00	0.85		1.00			1.00	0.85
Flt Protected					1.00	1.00		1.00			1.00	1.00
Satd. Flow (prot)					5353	1667		1980			1869	1567
FIt Permitted					1.00	1.00		1.00			1.00	1.00
Satd. Flow (perm)					5353	1667		1980			1869	1567
Peak-hour factor, PHF	0.93	0.93	0.93	0.74	0.74	0.74	0.91	0.91	0.91	0.72	0.72	0.72
Adj. Flow (vph)	0	0	0	0	2547	472	0	180	0	0	218	81
RTOR Reduction (vph)	0	0	0	0	0	167	0	0	0	0	0	19
Lane Group Flow (vph)	0	0	0	0	2547	305	0	180	0	0	218	62
Confl. Peds. (#/hr)				-	-				1	1		
Confl. Bikes (#/hr)									1			2
Heavy Vehicles (%)	2%	2%	2%	2%	2%	2%	1%	1%	1%	7%	7%	7%
Turn Type					NA	Perm		NA			NA	Perm
Protected Phases					6			8			4	
Permitted Phases						6					•	4
Actuated Green, G (s)					68.0	68.0		39.6			35.6	35.6
Effective Green, g (s)					68.0	68.0		39.6			35.6	35.6
Actuated g/C Ratio					0.57	0.57		0.33			0.30	0.30
Clearance Time (s)					6.0	6.0		6.4			10.4	10.4
Vehicle Extension (s)					3.0	3.0		3.0			3.0	3.0
Lane Grp Cap (vph)					3033	944		653			554	464
v/s Ratio Prot					c0.48	311		0.09			c0.12	707
v/s Ratio Perm					00.40	0.18		0.00			00.12	0.04
v/c Ratio					0.84	0.32		0.28			0.39	0.13
Uniform Delay, d1					21.5	13.8		29.6			33.6	30.9
Progression Factor					0.98	1.70		0.00			1.00	1.00
Incremental Delay, d2					2.3	0.7		0.2			0.5	0.1
Delay (s)					23.4	24.1		0.2			34.1	31.0
Level of Service					C	C		Α			С	C
Approach Delay (s)		0.0			23.5	0		0.2			33.2	J
Approach LOS		Α			C			Α			C	
Intersection Summary												
HCM 2000 Control Delay			23.1	Н	CM 2000	Level of	Service		С			
HCM 2000 Volume to Capacity	v ratio		0.69		OW 2000	LCVCIOI	JCI VICC					
Actuated Cycle Length (s)	Tallo		120.0	Q	um of lost	t time (s)			16.4			
Intersection Capacity Utilizatio	n		56.1%			of Service			В			
Analysis Period (min)			15	IC	O LGVGI (or oor vide			ט			
c Critical Lane Group			10									
C Chilical Lane Group												

	۶	-	*	•	←	4	4	1	1	1		4
Movement	EBL	EBT	EBR	WBL	WBT	WBR	NBL	NBT	NBR	SBL	SBT	SBR
Lane Configurations		ተ	7					↑	7		^	
Traffic Volume (vph)	0	937	240	0	0	0	0	164	375	0	157	0
Future Volume (vph)	0	937	240	0	0	0	0	164	375	0	157	0
Ideal Flow (vphpl)	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000
Total Lost time (s)		6.0	6.0					10.4	10.4		6.4	
Lane Util. Factor		0.91	1.00					1.00	1.00		1.00	
Frpb, ped/bikes		1.00	1.00					1.00	0.99		1.00	
Flpb, ped/bikes		1.00	1.00					1.00	1.00		1.00	
Frt		1.00	0.85					1.00	0.85		1.00	
Flt Protected		1.00	1.00					1.00	1.00		1.00	
Satd. Flow (prot)		5353	1667					1980	1660		1869	
FIt Permitted		1.00	1.00					1.00	1.00		1.00	
Satd. Flow (perm)		5353	1667					1980	1660		1869	
Peak-hour factor, PHF	0.84	0.84	0.84	0.92	0.92	0.92	0.91	0.91	0.91	0.72	0.72	0.72
Adj. Flow (vph)	0	1115	286	0	0	0	0	180	412	0	218	0
RTOR Reduction (vph)	0	0	124	0	0	0	0	0	56	0	0	0
Lane Group Flow (vph)	0	1115	162	0	0	0	0	180	356	0	218	0
Confl. Peds. (#/hr)									1	1		
Confl. Bikes (#/hr)									1			2
Heavy Vehicles (%)	2%	2%	2%	2%	2%	2%	1%	1%	1%	7%	7%	7%
Turn Type		NA	Perm					NA	Perm		NA	
Protected Phases		2						4			8	
Permitted Phases			2						4			
Actuated Green, G (s)		68.0	68.0					35.6	35.6		39.6	
Effective Green, g (s)		68.0	68.0					35.6	35.6		39.6	
Actuated g/C Ratio		0.57	0.57					0.30	0.30		0.33	
Clearance Time (s)		6.0	6.0					10.4	10.4		6.4	
Vehicle Extension (s)		3.0	3.0					3.0	3.0		3.0	
Lane Grp Cap (vph)		3033	944					587	492		616	
v/s Ratio Prot		c0.21						0.09			0.12	
v/s Ratio Perm			0.10						c0.21			
v/c Ratio		0.37	0.17					0.31	0.72		0.35	
Uniform Delay, d1		14.2	12.5					32.7	37.8		30.5	
Progression Factor		0.76	0.43					1.00	1.00		0.00	
Incremental Delay, d2		0.3	0.4					0.3	5.2		0.3	
Delay (s)		11.1	5.7					32.9	43.0		0.4	
Level of Service		В	Α					С	D		Α	
Approach Delay (s)		10.0			0.0			40.0			0.4	
Approach LOS		В			Α			D			Α	
Intersection Summary												
HCM 2000 Control Delay			17.1	Н	CM 2000	Level of S	Service		В			
HCM 2000 Volume to Capacity	ratio		0.49									
Actuated Cycle Length (s)			120.0	Sı	um of lost	time (s)			16.4			
Intersection Capacity Utilization)		56.1%			of Service			В			
Analysis Period (min)			15									
c Critical Lane Group												

Intersection						
Int Delay, s/veh	0					
Movement	EBL	EBT	WBT	WBR	SBL	SBR
Lane Configurations	EDL		VVDI	אסא		SDR
Traffic Vol, veh/h	0	1312	0	0	5	0
Future Vol, veh/h	0	1312	0	0	3	0
Conflicting Peds, #/hr		0	0	0	0	0
Sign Control	Free	Free	Stop	Stop	Stop	Stop
RT Channelized		None	Stop -		Stop -	
Storage Length	-	None -	-	-	0	NONE -
Veh in Median Storag				-	0	-
Grade, %	e, # - -	0	41104	-	0	-
Peak Hour Factor		88	92	92	60	60
	95					
Heavy Vehicles, %	2	1	2	2	0	0
Mvmt Flow	0	1491	0	0	5	0
Major/Minor	Major1			N	/linor2	
Conflicting Flow All		0			596	
Stage 1	_	-			0	_
Stage 2	_	_			596	_
Critical Hdwy	_	_			5.7	_
Critical Hdwy Stg 1	-	-			5.7	-
Critical Hdwy Stg 2	-				6	-
Follow-up Hdwy					3.8	-
	0	-			*688	0
Pot Cap-1 Maneuver		-				
Stage 1	0	-			*000	0
Stage 2	0	-			*688	0
Platoon blocked, %		-			1	
Mov Cap-1 Maneuver		-			*688	-
Mov Cap-2 Maneuver	· -	-			*688	-
Stage 1	-	-			-	-
Stage 2	-	-			*688	-
Approach	EB				SB	
					10.3	
HCM Control Delay, s	U					
HCM LOS					В	
Minor Lane/Major Mvi	mt	EBT S	SBLn1			
Capacity (veh/h)		_	688			
HCM Lane V/C Ratio		_	0.007			
HCM Control Delay (s	:)	_	10.3			
HCM Lane LOS	7)		В			
HCM 95th %tile Q(vel	n)	-	0			
`	')	-	U			
Notes						
~: Volume exceeds ca	apacity	\$: De	lay exc	eeds 30	00s	+: Com

Intersection						
Int Delay, s/veh	1.4					
Movement	EBT	EBR	WBL	WBT	NBL	NBR
Lane Configurations				^ ^	7	
Traffic Vol, veh/h	0	0	0	2156	81	0
Future Vol, veh/h	0	0	0	2156	81	0
Conflicting Peds, #/hr	0	0	0	0	0	0
Sign Control	Stop	Stop	Free	Free	Stop	Stop
RT Channelized	-	None	-	None	-	None
Storage Length	-	-	-	-	0	-
Veh in Median Storage,	# 3	-	-	0	0	-
Grade, %	0	-	-	0	0	-
Peak Hour Factor	92	92	93	74	63	63
Heavy Vehicles, %	2	2	2	2	1	1
Mvmt Flow	0	0	0	2914	129	0
					0	
Major/Minor		N	Major2		/linor1	
Conflicting Flow All			-	-	1166	-
Stage 1			-	-	0	-
Stage 2			-	-	1166	-
Critical Hdwy			-	-	5.72	-
Critical Hdwy Stg 1			-	-	-	-
Critical Hdwy Stg 2			-	-	6.02	-
Follow-up Hdwy			-	-	3.81	-
Pot Cap-1 Maneuver			0	_	258	0
Stage 1			0	_	-	0
Stage 2			0	_	234	0
Platoon blocked, %				_		
Mov Cap-1 Maneuver			_		258	_
Mov Cap-1 Maneuver				-	258	_
			-	-	200	-
Stage 1				-	234	
Stage 2			-	-	234	-
Approach			WB		NB	
HCM Control Delay, s			0		32.1	
HCM LOS					D	
Minor Lane/Major Mvmt	1	NBLn1	WBT			
Capacity (veh/h)		258	-			
HCM Lane V/C Ratio		0.498	-			
HCM Control Delay (s)		32.1	-			
HCM Lane LOS		D	-			
HCM 95th %tile Q(veh)		2.6	-			
2000 2000						

Intersection						
Int Delay, s/veh	0.2					
Movement	EBL	EBT	WBT	WBR	SBL	SBR
Lane Configurations		ተ			*	
Traffic Vol, veh/h	0	1234	0	0	23	0
Future Vol, veh/h	0	1234	0	0	23	0
Conflicting Peds, #/hr	0	0	0	0	0	0
Sign Control	Free	Free	Stop	Stop	Stop	Stop
RT Channelized	-		-		-	None
Storage Length	-	-	-	-	0	-
Veh in Median Storage,	# -	0	0	-	0	-
Grade, %	-	0	0	-	0	-
Peak Hour Factor	88	88	92	92	92	92
Heavy Vehicles, %	1	1	2	2	14	14
Mvmt Flow	0	1402	0	0	25	0
	1ajor1			1	/linor2	
Conflicting Flow All	-	0			561	-
Stage 1	-	-			0	-
Stage 2	-	-			561	-
Critical Hdwy	-	-			5.98	-
Critical Hdwy Stg 1	-	-			-	-
Critical Hdwy Stg 2	-	-			6.28	-
Follow-up Hdwy	-	-			3.94	-
Pot Cap-1 Maneuver	0	-			482	0
Stage 1	0	-			-	0
Stage 2	0	-			460	0
Platoon blocked, %		-				
Mov Cap-1 Maneuver	-	-			482	_
Mov Cap-2 Maneuver	_	_			482	_
Stage 1	_	_			-	-
Stage 2	_	_			460	_
Olugo Z					700	
Approach	EB				SB	
HCM Control Delay, s	0				12.9	
HCM LOS					В	
Minor Long/Maior M.		EDT (2DL 4			
Minor Lane/Major Mvmt			SBLn1			
Capacity (veh/h)		-	482			
HCM Lane V/C Ratio		-	0.052			
HCM Control Delay (s)		-	12.9			
HCM Lane LOS		-	В			
HCM 95th %tile Q(veh)		-	0.2			
HOW JOHN JOHN Q(VEII)			0.2			

	۶	→	7	1	←	*	1	†	1	1	Į.	1
Movement	EBL	EBT	EBR	WBL	WBT	WBR	NBL	NBT	NBR	SBL	SBT	SBR
Lane Configurations					ተ						^	77
Traffic Volume (vph)	0	0	0	0	1630	0	0	0	0	0	170	549
Future Volume (vph)	0	0	0	0	1630	0	0	0	0	0	170	549
Ideal Flow (vphpl)	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000
Total Lost time (s)					5.9						9.0	9.0
Lane Util. Factor					0.91						0.95	0.88
Frt					1.00						1.00	0.85
Flt Protected					1.00						1.00	1.00
Satd. Flow (prot)					5353						3725	2933
Flt Permitted					1.00						1.00	1.00
Satd. Flow (perm)					5353						3725	2933
Peak-hour factor, PHF	0.92	0.92	0.92	0.84	0.84	0.84	0.92	0.92	0.92	0.68	0.68	0.68
Adj. Flow (vph)	0	0	0	0	1940	0	0	0	0	0	250	807
RTOR Reduction (vph)	0	0	0	0	0	0	0	0	0	0	0	16
Lane Group Flow (vph)	0	0	0	0	1940	0	0	0	0	0	250	791
Turn Type					NA						NA	Perm
Protected Phases					6						4	
Permitted Phases												4
Actuated Green, G (s)					59.1						46.0	46.0
Effective Green, g (s)					59.1						46.0	46.0
Actuated g/C Ratio					0.49						0.38	0.38
Clearance Time (s)					5.9						9.0	9.0
Vehicle Extension (s)					3.0						3.0	3.0
Lane Grp Cap (vph)					2636						1427	1124
v/s Ratio Prot					c0.36						0.07	
v/s Ratio Perm												c0.27
v/c Ratio					0.74						0.18	0.70
Uniform Delay, d1					24.2						24.5	31.2
Progression Factor					1.00						1.00	1.00
Incremental Delay, d2					1.9						0.1	2.0
Delay (s)					26.1						24.5	33.3
Level of Service					С						С	С
Approach Delay (s)		0.0			26.1			0.0			31.2	
Approach LOS		Α			С			Α			С	
Intersection Summary												
HCM 2000 Control Delay			27.9	Н	CM 2000	Level of S	Service		С			
HCM 2000 Volume to Capacity ratio			0.72									
Actuated Cycle Length (s)			120.0	S	um of lost	time (s)			14.9			
Intersection Capacity Utilization			60.6%	IC	CU Level o	of Service			В			
Analysis Period (min)			15									

	۶	→	←	*	1	4			
Movement	EBL	EBT	WBT	WBR	SBL	SBR			
Lane Configurations		ተተተ			77				
Traffic Volume (vph)	0	723	0	0	170	0			
Future Volume (vph)	0	723	0	0	170	0			
Ideal Flow (vphpl)	2000	2000	2000	2000	2000	2000			
Total Lost time (s)		5.9			6.0				
Lane Util. Factor		0.91			0.97				
Frt		1.00			1.00				
FIt Protected		1.00			0.95				
Satd. Flow (prot)		5406			3614				
Flt Permitted		1.00			0.95				
Satd. Flow (perm)		5406			3614				
Peak-hour factor, PHF	0.88	0.88	0.92	0.92	0.68	0.68			
Adj. Flow (vph)	0	822	0	0	250	0			
RTOR Reduction (vph)	0	0	0	0	138	0			
ane Group Flow (vph)	0	822	0	0	112	0			
Heavy Vehicles (%)	1%	1%	2%	2%	2%	2%			
urn Type		NA			Prot				
rotected Phases		2			8				
Permitted Phases									
Actuated Green, G (s)		59.1			49.0				
Effective Green, g (s)		59.1			49.0				
ctuated g/C Ratio		0.49			0.41				
Clearance Time (s)		5.9			6.0				
/ehicle Extension (s)		3.0			3.0				
ane Grp Cap (vph)		2662			1475				
/s Ratio Prot		c0.15			c0.03				
/s Ratio Perm									
/c Ratio		0.31			0.08				
Jniform Delay, d1		18.2			21.7				
Progression Factor		1.07			0.02				
ncremental Delay, d2		0.3			0.0				
Pelay (s)		19.7			0.5				
evel of Service		В			Α				
Approach Delay (s)		19.7	0.0		0.5				
Approach LOS		В	Α		Α				
ntersection Summary									
HCM 2000 Control Delay			15.2	H	CM 2000	Level of Service	,	В	
HCM 2000 Volume to Capacity	ratio		0.21						
Actuated Cycle Length (s)			120.0		um of lost			14.9	
Intersection Capacity Utilization	1		60.6%	IC	U Level c	of Service		В	
Analysis Period (min)			15						
C Critical Lane Group									

Intersection						
Int Delay, s/veh	0					
		EDD	MDI	MPT	ND	NDD
Movement	EBT	EBR	WBL	WBT	NBL	NBR
Lane Configurations	ተ ቀሴ	•	•	•	•	7
Traffic Vol, veh/h	1257	0	0	0	0	0
Future Vol, veh/h	1257	0	0	0	0	0
Conflicting Peds, #/hr	0	0	0	0	0	0
Sign Control	Free	Free	Stop	Stop	Stop	Stop
RT Channelized	-	None	-	None	-	None
Storage Length	-	-	-	-	-	0
Veh in Median Storage,	# 0	-	-	0	0	-
Grade, %	0	-	-	0	0	-
Peak Hour Factor	88	88	92	92	92	92
Heavy Vehicles, %	1	1	2	2	2	2
Mvmt Flow	1428	0	0	0	0	0
NA . ' . /NA'	1.1.1				I'	
	/lajor1			I\	/linor1	
Conflicting Flow All	0	0			-	714
Stage 1	-	-			-	-
Stage 2	-	-			-	-
Critical Hdwy	-	-			-	7.14
Critical Hdwy Stg 1	-	-			-	-
Critical Hdwy Stg 2	-	-			-	-
Follow-up Hdwy	-	-			-	3.92
Pot Cap-1 Maneuver	-	-			0	321
Stage 1	-	-			0	-
Stage 2	-	-			0	-
Platoon blocked, %	-	-				
Mov Cap-1 Maneuver	_	_			_	321
Mov Cap-1 Maneuver	_	_			_	- 021
Stage 1	_	_				_
Stage 2	_					
Olaye Z	_	-			-	_
Approach	EB				NB	
HCM Control Delay, s	0				0	
HCM LOS					Α	
		UDL 4				
Minor Lane/Major Mvmt	t ſ	NBLn1	EBT	EBR		
Capacity (veh/h)		-	-	-		
HCM Lane V/C Ratio		-	-	-		
HCM Control Delay (s)		0	-	-		
HCM Lane LOS		Α	-	-		
HCM 95th %tile Q(veh)		-	-	-		

Intersection												
Int Delay, s/veh	0.7											
Movement	EBL	EBT	EBR	WBL	WBT	WBR	NBL	NBT	NBR	SBL	SBT	SBR
Lane Configurations		4			4		7	1		7	1	
Traffic Vol, veh/h	25	0	3	0	0	0	4	514	0	0	360	37
Future Vol, veh/h	25	0	3	0	0	0	4	514	0	0	360	37
Conflicting Peds, #/hr	0	0	0	0	0	0	0	0	0	0	0	0
Sign Control	Stop	Stop	Stop	Stop	Stop	Stop	Free	Free	Free	Free	Free	Free
RT Channelized	-	-	None	-	-	None	-	-	None	-	-	None
Storage Length	-	-	-	-	-	-	500	-	-	475	-	-
Veh in Median Storage	e, # -	0	-	-	0	-	-	0	-	-	0	-
Grade, %	-	0	-	-	0	-	-	0	-	-	0	-
Peak Hour Factor	92	92	92	92	92	92	91	91	91	92	92	92
Heavy Vehicles, %	2	2	2	2	2	2	1	1	1	2	2	2
Mvmt Flow	27	0	3	0	0	0	4	565	0	0	391	40
Major/Minor	Minor2			Minor1			Major1			Major2		
Conflicting Flow All	984	984	411	986	1004	565	431	0	0	565	0	0
Stage 1	411	411	-	573	573	-	-	_	-	-	_	-
Stage 2	573	573	-	413	431	-	_	_	_	-	_	-
Critical Hdwy	7.12	6.52	6.22	7.12	6.52	6.22	4.11	_	_	4.12	_	-
Critical Hdwy Stg 1	6.12	5.52	-	6.12	5.52	-	-	-	-	-	-	-
Critical Hdwy Stg 2	6.12	5.52	-	6.12	5.52	-	-	-	-	-	-	-
Follow-up Hdwy	3.518	4.018	3.318	3.518	4.018	3.318	2.209	-	-	2.218	-	-
Pot Cap-1 Maneuver	228	248	641	227	242	524	1134	-	-	1007	-	-
Stage 1	618	595	-	505	504	-	-	-	-	-	-	-
Stage 2	505	504	-	616	583	-	-	-	-	-	-	-
Platoon blocked, %								-	-		-	-
Mov Cap-1 Maneuver	227	247	641	225	241	524	1134	-	-	1007	-	-
Mov Cap-2 Maneuver	227	247	-	225	241	-	-	-	-	-	-	-
Stage 1	616	595	-	503	502	-	-	-	-	-	-	-
Stage 2	503	502	-	613	583	-	-	-	-	-	-	-
Approach	EB			WB			NB			SB		
HCM Control Delay, s	21.8			0			0.1			0		
HCM LOS	C C			A			0.1			U		
TIOW LOS	U											
Minor Long/Major Mare	.4	NDI	NDT	NDD	EDI 54V	VDI 51	CDI	CDT	CDD			
Minor Lane/Major Mvm	IL	NBL	NBT		EBLn1V		SBL	SBT	SBR			
Capacity (veh/h)		1134	-	-	244	-	1007	-	-			
HCM Cantrol Dalay (a)		0.004	-		0.125	-	-	-	-			
HCM Lang LOS		8.2	-	-	21.8	0	0	-	-			
HCM Of the % tills O(yeah)	١	A	-	-	C	Α	A	-	-			
HCM 95th %tile Q(veh))	0	-	-	0.4	-	0	-	-			

Intersection						
Int Delay, s/veh	0					
Movement	WBL	WBR	NBT	NBR	SBL	SBT
Lane Configurations	WDL	TOR	1\01 ↑	HOIN	SDL	<u>361</u>
Traffic Vol, veh/h	0	0	518	0	0	T 363
Future Vol, veh/h	0	0	518	0	0	363
	0	0	518	0	0	363
Conflicting Peds, #/hr						Free
Sign Control	Stop	Stop	Free	Free	Free	
RT Channelized	-	None	-	None	-	None
Storage Length	0	-	-	-	500	-
Veh in Median Storage		-	0	-	-	0
Grade, %	0	-	0	-	-	0
Peak Hour Factor	92	92	91	91	92	92
Heavy Vehicles, %	2	2	1	1	2	2
Mvmt Flow	0	0	569	0	0	395
Major/Minor N	Minor1	N	Major1	, N	Major2	
Conflicting Flow All	964	569	0	0	569	0
Stage 1	569	509		U	209	
			-			-
Stage 2	395	6.00	-	-	1.40	-
Critical Hdwy	6.42	6.22	-	-	4.12	-
Critical Hdwy Stg 1	5.42	-	-	-	-	-
Critical Hdwy Stg 2	5.42	-	-	-	-	-
Follow-up Hdwy	3.518		-	-	2.218	-
Pot Cap-1 Maneuver	283	522	-	-	1003	-
Stage 1	566					
Stage 2	681	-	-	-	-	-
Platoon blocked, %			-	-		-
Mov Cap-1 Maneuver	283	522	-	-	1003	-
Mov Cap-2 Maneuver	409	-	-	-	-	-
Stage 1	566	-	_	_	-	-
Stage 2	681	-	-	-	-	_
Clayo Z	501			_		
Approach	WB		NB		SB	
HCM Control Delay, s	0		0		0	
HCM LOS	Α		_			_
Minor Long/Maior M	+	NDT	NDDV	VDI -4	CDI	CDT
Minor Lane/Major Mvm	l	NBT	MRKA	VBLn1	SBL	SBT
Capacity (veh/h)		-	-	-	1003	-
HCM Lane V/C Ratio		-	-	-	-	-
HCM Control Delay (s)		-	-	0	0	-
HCM Lane LOS		-	-	Α	Α	-
HCM 95th %tile Q(veh)		-	-	-	0	-

Intersection: 10: EB 12-Mile Road & WB-to-EB XO, W. of Meadowbrook

Movement	SB
Directions Served	L
Maximum Queue (ft)	91
Average Queue (ft)	62
95th Queue (ft)	82
Link Distance (ft)	23
Upstream Blk Time (%)	33
Queuing Penalty (veh)	94
Storage Bay Dist (ft)	
Storage Blk Time (%)	
Queuing Penalty (veh)	

Intersection: 11: WB-to-EB XO, W. of Meadowbrook & WB 12-Mile Road

Movement	WB	WB
Directions Served	L	Т
Maximum Queue (ft)	125	8
Average Queue (ft)	37	0
95th Queue (ft)	98	6
Link Distance (ft)		651
Upstream Blk Time (%)		
Queuing Penalty (veh)		
Storage Bay Dist (ft)	250	
Storage Blk Time (%)		
Queuing Penalty (veh)		

Intersection: 20: Meadowbrook Road & WB 12-Mile Road

Movement	WB	WB	WB	WB	SB	SB
Directions Served	Т	Т	Т	R	T	R
Maximum Queue (ft)	161	152	134	53	154	71
Average Queue (ft)	95	80	54	19	68	27
95th Queue (ft)	152	134	111	47	133	56
Link Distance (ft)	148	148	148	148	837	
Upstream Blk Time (%)	1	0	0			
Queuing Penalty (veh)	3	1	1			
Storage Bay Dist (ft)						275
Storage Blk Time (%)						
Queuing Penalty (veh)						

Intersection: 21: Meadowbrook Road & EB 12-Mile Road

Movement	EB	EB	EB	EB	NB	NB	SB
Directions Served	T	Т	Т	R	Т	R	Т
Maximum Queue (ft)	77	85	101	114	94	80	9
Average Queue (ft)	36	31	39	49	32	39	0
95th Queue (ft)	69	70	78	92	74	69	5
Link Distance (ft)	634	634	634		878		56
Upstream Blk Time (%)							
Queuing Penalty (veh)							
Storage Bay Dist (ft)				350		250	
Storage Blk Time (%)							
Queuing Penalty (veh)							

Intersection: 30: EB 12-Mile Road & WB-to-EB XO, E. of Meadowbrook

Movement
Directions Served
Maximum Queue (ft)
Average Queue (ft)
95th Queue (ft)
Link Distance (ft)
Upstream Blk Time (%)
Queuing Penalty (veh)
Storage Bay Dist (ft)
Storage Blk Time (%)
Queuing Penalty (veh)

Intersection: 31: WB-to-EB XO, E. of Meadowbrook & WB 12-Mile Road

Movement	WB	WB	WB
Directions Served	Т	Т	Т
Maximum Queue (ft)	63	35	6
Average Queue (ft)	5	2	0
95th Queue (ft)	37	19	4
Link Distance (ft)	506	506	506
Upstream Blk Time (%)			
Queuing Penalty (veh)			
Storage Bay Dist (ft)			
Storage Blk Time (%)			
Queuing Penalty (veh)			

Intersection: 40: EB-to-WB XO, E. of Meadowbrook & WB 12-Mile Road

Movement	NB
Directions Served	L
Maximum Queue (ft)	56
Average Queue (ft)	25
95th Queue (ft)	47
Link Distance (ft)	18
Upstream Blk Time (%)	6
Queuing Penalty (veh)	3
Storage Bay Dist (ft)	
Storage Blk Time (%)	
Queuing Penalty (veh)	

Intersection: 41: EB 12-Mile Road & EB-to-WB XO, E. of Meadowbrook

Movement
Directions Served
Maximum Queue (ft)
Average Queue (ft)
95th Queue (ft)
Link Distance (ft)
Upstream Blk Time (%)
Queuing Penalty (veh)
Storage Bay Dist (ft)
Storage Blk Time (%)
Queuing Penalty (veh)
Queuing Penalty (veh)

Intersection: 50: EB 12-Mile Road & WB-to-EB XO, W. of Summit Dr.

Movement	SB
Directions Served	L
Maximum Queue (ft)	36
Average Queue (ft)	9
95th Queue (ft)	32
Link Distance (ft)	23
Upstream Blk Time (%)	1
Queuing Penalty (veh)	0
Storage Bay Dist (ft)	
Storage Blk Time (%)	
Queuing Penalty (veh)	

Intersection: 51: WB-to-EB XO, W. of Summit Dr. & WB 12-Mile Road

Queuing Penalty (veh)

Intersection: 60: SB M-5 Exit-Ramp & WB 12-Mile Road

Movement	WB	WB	WB	SB	SB	SB	SB
Directions Served	T	T	Т	Т	Т	R	R
Maximum Queue (ft)	181	150	60	147	173	94	49
Average Queue (ft)	87	35	14	37	89	47	16
95th Queue (ft)	153	99	43	103	148	76	43
Link Distance (ft)	1226	1226	1226			958	
Upstream Blk Time (%)							
Queuing Penalty (veh)							
Storage Bay Dist (ft)				250	250		250
Storage Blk Time (%)							
Queuing Penalty (veh)							

Intersection: 61: EB 12-Mile Road & SB M-5 Exit-Ramp

Movement	EB	EB	EB	SB
Directions Served	T	Т	Т	L
Maximum Queue (ft)	105	101	114	5
Average Queue (ft)	38	32	39	0
95th Queue (ft)	80	78	92	4
Link Distance (ft)	141	141	141	22
Upstream Blk Time (%)			0	0
Queuing Penalty (veh)			0	0
Storage Bay Dist (ft)				
Storage Blk Time (%)				
Queuing Penalty (veh)				

Intersection: 70: Site Drive #1 & EB 12-Mile Road

Movement
Directions Served
Maximum Queue (ft)
Average Queue (ft)
95th Queue (ft)
Link Distance (ft)
Upstream Blk Time (%)
Queuing Penalty (veh)
Storage Bay Dist (ft)
Storage Blk Time (%)
Queuing Penalty (veh)

Intersection: 80: Meadowbrook Road & Elm Creek Drive/Site Drive #2

Movement	EB	NB
Directions Served	LTR	L
Maximum Queue (ft)	56	11
Average Queue (ft)	26	1
95th Queue (ft)	51	7
Link Distance (ft)	364	
Upstream Blk Time (%)		
Queuing Penalty (veh)		
Storage Bay Dist (ft)		500
Storage Blk Time (%)		
Queuing Penalty (veh)		

Intersection: 90: Meadowbrook Road & Site Drive #3

Movement
Directions Served
Maximum Queue (ft)
Average Queue (ft)
95th Queue (ft)
Link Distance (ft)
Upstream Blk Time (%)
Queuing Penalty (veh)
Storage Bay Dist (ft)
Storage Blk Time (%)
Queuing Penalty (veh)

Zone Summary

Zone wide Queuing Penalty: 103

Intersection: 10: EB 12-Mile Road & WB-to-EB XO, W. of Meadowbrook

Movement	SB
Directions Served	L
Maximum Queue (ft)	87
Average Queue (ft)	63
95th Queue (ft)	81
Link Distance (ft)	23
Upstream Blk Time (%)	41
Queuing Penalty (veh)	119
Storage Bay Dist (ft)	
Storage Blk Time (%)	
Queuing Penalty (veh)	

Intersection: 11: WB-to-EB XO, W. of Meadowbrook & WB 12-Mile Road

Movement	WB
Directions Served	L
Maximum Queue (ft)	168
Average Queue (ft)	45
95th Queue (ft)	119
Link Distance (ft)	
Upstream Blk Time (%)	
Queuing Penalty (veh)	
Storage Bay Dist (ft)	250
Storage Blk Time (%)	
Queuing Penalty (veh)	

Intersection: 20: Meadowbrook Road & WB 12-Mile Road

Movement	WB	WB	WB	WB	NB	SB	SB
Directions Served	Т	Т	Т	R	Т	Т	R
Maximum Queue (ft)	172	181	184	150	14	203	71
Average Queue (ft)	149	154	151	69	1	92	21
95th Queue (ft)	189	191	195	121	8	168	53
Link Distance (ft)	148	148	148	148	56	837	
Upstream Blk Time (%)	10	10	9	0			
Queuing Penalty (veh)	54	58	52	1			
Storage Bay Dist (ft)							275
Storage Blk Time (%)							
Queuing Penalty (veh)							

Intersection: 21: Meadowbrook Road & EB 12-Mile Road

Movement	EB	EB	EB	EB	NB	NB
Directions Served	Т	Т	Т	R	Т	R
Maximum Queue (ft)	128	149	185	119	175	283
Average Queue (ft)	70	74	97	40	92	110
95th Queue (ft)	117	132	166	79	159	215
Link Distance (ft)	634	634	634		878	
Upstream Blk Time (%)						
Queuing Penalty (veh)						
Storage Bay Dist (ft)				350		250
Storage Blk Time (%)						1
Queuing Penalty (veh)						1

Intersection: 30: EB 12-Mile Road & WB-to-EB XO, E. of Meadowbrook

Movement	SB
Directions Served	L
Maximum Queue (ft)	23
Average Queue (ft)	1
95th Queue (ft)	12
Link Distance (ft)	19
Upstream Blk Time (%)	0
Queuing Penalty (veh)	0
Storage Bay Dist (ft)	
Storage Blk Time (%)	
Queuing Penalty (veh)	

Intersection: 31: WB-to-EB XO, E. of Meadowbrook & WB 12-Mile Road

Movement	WB	WB	WB	WB	
Directions Served	Т	Т	Т	Т	
Maximum Queue (ft)	211	230	217	86	
Average Queue (ft)	63	67	56	3	
95th Queue (ft)	153	160	148	45	
Link Distance (ft)	506	506	506		
Upstream Blk Time (%)					
Queuing Penalty (veh)					
Storage Bay Dist (ft)				150	
Storage Blk Time (%)			0		
Queuing Penalty (veh)			3		

Intersection: 40: EB-to-WB XO, E. of Meadowbrook & WB 12-Mile Road

Movement	NB
Directions Served	L
Maximum Queue (ft)	66
Average Queue (ft)	42
95th Queue (ft)	70
Link Distance (ft)	18
Upstream Blk Time (%)	36
Queuing Penalty (veh)	34
Storage Bay Dist (ft)	
Storage Blk Time (%)	
Queuing Penalty (veh)	

Intersection: 41: EB 12-Mile Road & EB-to-WB XO, E. of Meadowbrook

Movement	EB	EB
Directions Served	L	Т
Maximum Queue (ft)	140	38
Average Queue (ft)	18	1
95th Queue (ft)	81	28
Link Distance (ft)		506
Upstream Blk Time (%)		
Queuing Penalty (veh)		
Storage Bay Dist (ft)	250	
Storage Blk Time (%)		
Queuing Penalty (veh)		

Intersection: 50: EB 12-Mile Road & WB-to-EB XO, W. of Summit Dr.

Movement	SB	
Directions Served	L	
Maximum Queue (ft)	72	
Average Queue (ft)	19	
95th Queue (ft)	55	
Link Distance (ft)	23	
Upstream Blk Time (%)	3	
Queuing Penalty (veh)	1	
Storage Bay Dist (ft)		
Storage Blk Time (%)		
Queuing Penalty (veh)		

Intersection: 51: WB-to-EB XO, W. of Summit Dr. & WB 12-Mile Road

Movement	WB
Directions Served	L
Maximum Queue (ft)	14
Average Queue (ft)	0
95th Queue (ft)	10
Link Distance (ft)	
Upstream Blk Time (%)	
Queuing Penalty (veh)	
Storage Bay Dist (ft)	300
Storage Blk Time (%)	
Queuing Penalty (veh)	

Intersection: 60: SB M-5 Exit-Ramp & WB 12-Mile Road

Movement	WB	WB	WB	SB	SB	SB	SB	
Directions Served	Т	T	Т	Т	Т	R	R	
Maximum Queue (ft)	355	324	267	188	260	304	282	
Average Queue (ft)	176	123	99	43	101	147	108	
95th Queue (ft)	294	245	200	128	189	246	219	
Link Distance (ft)	1226	1226	1226			958		
Upstream Blk Time (%)								
Queuing Penalty (veh)								
Storage Bay Dist (ft)				250	250		250	
Storage Blk Time (%)					0	1	0	
Queuing Penalty (veh)					0	4	1	

Intersection: 61: EB 12-Mile Road & SB M-5 Exit-Ramp

Movement	EB	EB	EB	SB	
Directions Served	Т	Т	T	L	_
Maximum Queue (ft)	121	134	161	5	
Average Queue (ft)	42	48	59	0	
95th Queue (ft)	99	109	122	4	
Link Distance (ft)	141	141	141	22	
Upstream Blk Time (%)	0	0	1	0	
Queuing Penalty (veh)	0	0	2	0	
Storage Bay Dist (ft)					
Storage Blk Time (%)					
Queuing Penalty (veh)					

Intersection: 70: Site Drive #1 & EB 12-Mile Road

Movement
Directions Served
Maximum Queue (ft)
Average Queue (ft)
95th Queue (ft)
Link Distance (ft)
Upstream Blk Time (%)
Queuing Penalty (veh)
Storage Bay Dist (ft)
Storage Blk Time (%)
Queuing Penalty (veh)

Intersection: 80: Meadowbrook Road & Elm Creek Drive/Site Drive #2

Movement	EB	NB
Directions Served	LTR	L
Maximum Queue (ft)	56	17
Average Queue (ft)	22	1
95th Queue (ft)	49	7
Link Distance (ft)	364	
Upstream Blk Time (%)		
Queuing Penalty (veh)		
Storage Bay Dist (ft)		500
Storage Blk Time (%)		
Queuing Penalty (veh)		

Intersection: 90: Meadowbrook Road & Site Drive #3

lovement
irections Served
laximum Queue (ft)
verage Queue (ft)
5th Queue (ft)
ink Distance (ft)
pstream Blk Time (%)
dueuing Penalty (veh)
torage Bay Dist (ft)
torage Blk Time (%)
lueuing Penalty (veh)

Zone Summary

Zone wide Queuing Penalty: 331

Intersection						
Int Delay, s/veh	5					
		EDT	WDT	WDD	CDI	CDD
	EBL	EBT	WBI	WBR	SBL	SBR
Lane Configurations	0	*	^	0	200	^
Traffic Vol, veh/h	0	536	0	0	292	0
Future Vol, veh/h	0	536	0	0	292	0
Conflicting Peds, #/hr	0	_ 0	0	0	0	0
	Free	Free	Stop	Stop	Stop	Stop
RT Channelized	-		-		-	None
Storage Length	-	-	-	-	0	-
Veh in Median Storage, #		108208		-	0	-
Grade, %	-	0	0	-	0	-
Peak Hour Factor	90	90	92	92	88	88
Heavy Vehicles, %	4	4	2	2	2	2
Mvmt Flow	0	596	0	0	332	0
Major/Minor Ma	ajor1			N	/linor2	
				IN.		
Conflicting Flow All	-	0			238	-
Stage 1	-	-			0	-
Stage 2	-	-			238	-
Critical Hdwy	-	-			5.74	-
Critical Hdwy Stg 1	-	-			-	-
Critical Hdwy Stg 2	-	-			6.04	-
Follow-up Hdwy	-	-			3.82	-
Pot Cap-1 Maneuver	0	-			730	0
Stage 1	0	-			-	0
Stage 2	0	-			715	0
Platoon blocked, %		-				
Mov Cap-1 Maneuver	-	-			730	-
Mov Cap-2 Maneuver	-	-			730	-
Stage 1	_	_			-	_
Stage 2	_	_			715	_
Olago Z					, 10	
Approach	EB				SB	
HCM Control Delay, s	0				14	
HCM LOS					В	
NASSES AND		EDT (א- וחר			
Minor Lane/Major Mvmt			SBLn1			
Capacity (veh/h)		-				
HCM Lane V/C Ratio		-	0.455			
HCM Control Delay (s)		-	14			
HCM Lane LOS HCM 95th %tile Q(veh)		-	B 2.4			

	۶	→	*	•	←	4	1	1	~	1	↓	1
Movement	EBL	EBT	EBR	WBL	WBT	WBR	NBL	NBT	NBR	SBL	SBT	SBR
Lane Configurations					ተ	7		↑			↑	7
Traffic Volume (vph)	0	0	0	0	821	68	0	63	0	0	121	95
Future Volume (vph)	0	0	0	0	821	68	0	63	0	0	121	95
Ideal Flow (vphpl)	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000
Total Lost time (s)					6.0	6.0		6.4			10.4	10.4
Lane Util. Factor					0.91	1.00		1.00			1.00	1.00
Frpb, ped/bikes					1.00	0.98		1.00			1.00	1.00
Flpb, ped/bikes					1.00	1.00		1.00			1.00	1.00
Frt					1.00	0.85		1.00			1.00	0.85
Flt Protected					1.00	1.00		1.00			1.00	1.00
Satd. Flow (prot)					5301	1616		1905			1923	1635
FIt Permitted					1.00	1.00		1.00			1.00	1.00
Satd. Flow (perm)					5301	1616		1905			1923	1635
Peak-hour factor, PHF	0.90	0.90	0.90	0.73	0.73	0.73	0.93	0.93	0.93	0.88	0.88	0.88
Adj. Flow (vph)	0	0	0	0	1125	93	0	68	0	0	138	108
RTOR Reduction (vph)	0	0	0	0	0	47	0	0	0	0	0	31
Lane Group Flow (vph)	0	0	0	0	1125	46	0	68	0	0	138	77
Confl. Peds. (#/hr)	1					1			1	1		
Heavy Vehicles (%)	4%	4%	4%	3%	3%	3%	5%	5%	5%	4%	4%	4%
Turn Type					NA	Perm		NA			NA	Perm
Protected Phases					6			8			4	
Permitted Phases						6						4
Actuated Green, G (s)					59.0	59.0		48.6			44.6	44.6
Effective Green, g (s)					59.0	59.0		48.6			44.6	44.6
Actuated g/C Ratio					0.49	0.49		0.41			0.37	0.37
Clearance Time (s)					6.0	6.0		6.4			10.4	10.4
Vehicle Extension (s)					3.0	3.0		3.0			3.0	3.0
Lane Grp Cap (vph)					2606	794		771			714	607
v/s Ratio Prot					c0.21			0.04			c0.07	
v/s Ratio Perm						0.03						0.05
v/c Ratio					0.43	0.06		0.09			0.19	0.13
Uniform Delay, d1					19.7	16.0		22.0			25.5	24.9
Progression Factor					1.08	2.11		0.00			1.00	1.00
Incremental Delay, d2					0.5	0.1		0.0			0.1	0.1
Delay (s)					21.8	33.8		0.1			25.7	24.9
Level of Service		0.0			C	С		A			С	С
Approach Delay (s)		0.0			22.7			0.1			25.3	
Approach LOS		Α			С			Α			С	
Intersection Summary												
	HCM 2000 Control Delay		22.2	Н	CM 2000	Level of S	Service		С			
HCM 2000 Volume to Capacity	/ ratio		0.33						40.4			
Actuated Cycle Length (s)			120.0		um of lost				16.4			
Intersection Capacity Utilizatio	n		36.4%	IC	U Level o	of Service			A			
Analysis Period (min)			15									

	۶	→	*	•	←	*	1	1	-	1	↓	4
Movement	EBL	EBT	EBR	WBL	WBT	WBR	NBL	NBT	NBR	SBL	SBT	SBR
Lane Configurations		ተ	7					↑	7		↑	
Traffic Volume (vph)	0	509	319	0	0	0	0	63	225	0	121	0
Future Volume (vph)	0	509	319	0	0	0	0	63	225	0	121	0
Ideal Flow (vphpl)	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000
Total Lost time (s)		6.0	6.0					10.4	10.4		6.4	
Lane Util. Factor		0.91	1.00					1.00	1.00		1.00	
Frpb, ped/bikes		1.00	1.00					1.00	0.99		1.00	
Flpb, ped/bikes		1.00	1.00					1.00	1.00		1.00	
Frt		1.00	0.85					1.00	0.85		1.00	
Flt Protected		1.00	1.00					1.00	1.00		1.00	
Satd. Flow (prot)		5250	1635					1905	1598		1923	
Flt Permitted		1.00	1.00					1.00	1.00		1.00	
Satd. Flow (perm)		5250	1635					1905	1598		1923	
Peak-hour factor, PHF	0.90	0.90	0.90	0.73	0.73	0.73	0.93	0.93	0.93	0.88	0.88	0.88
Adj. Flow (vph)	0	566	354	0	0	0	0	68	242	0	138	0
RTOR Reduction (vph)	0	0	180	0	0	0	0	0	152	0	0	0
Lane Group Flow (vph)	0	566	174	0	0	0	0	68	90	0	138	0
Confl. Peds. (#/hr)	1					1			1	1		
Heavy Vehicles (%)	4%	4%	4%	3%	3%	3%	5%	5%	5%	4%	4%	4%
Turn Type		NA	Perm					NA	Perm		NA	
Protected Phases		2						4			8	
Permitted Phases			2						4			
Actuated Green, G (s)		59.0	59.0					44.6	44.6		48.6	
Effective Green, g (s)		59.0	59.0					44.6	44.6		48.6	
Actuated g/C Ratio		0.49	0.49					0.37	0.37		0.41	
Clearance Time (s)		6.0	6.0					10.4	10.4		6.4	
Vehicle Extension (s)		3.0	3.0					3.0	3.0		3.0	
Lane Grp Cap (vph)		2581	803					708	593		778	
v/s Ratio Prot		c0.11						0.04			c0.07	
v/s Ratio Perm			0.11						0.06			
v/c Ratio		0.22	0.22					0.10	0.15		0.18	
Uniform Delay, d1		17.4	17.4					24.6	25.1		22.9	
Progression Factor		0.83	0.53					1.00	1.00		0.00	
Incremental Delay, d2		0.2	0.6					0.1	0.1		0.1	
Delay (s)		14.6	9.9					24.6	25.2		0.1	
Level of Service		В	Α					С	С		Α	
Approach Delay (s)		12.8			0.0			25.1			0.1	
Approach LOS		В			А			С			Α	
Intersection Summary												
HCM 2000 Control Delay			14.3	Н	CM 2000	Level of S	Service		В			
HCM 2000 Volume to Capacity	y ratio		0.21									
Actuated Cycle Length (s)			120.0	Sı	um of lost	time (s)			16.4			
Intersection Capacity Utilizatio	n		36.4%		U Level				Α			
Analysis Period (min)			15									

Intersection						
Int Delay, s/veh	0					
Movement	EBL	EBT	WBT	WBR	SBL	SBR
Lane Configurations	LUL	ተተተ	VVDI	אטוע	JDL 1	אופט
Traffic Vol, veh/h	0	734	0	0	0	0
Future Vol, veh/h	0	734	0	0	0	0
Conflicting Peds, #/hr	0	0	0	0	0	0
Sign Control	Free	Free	Stop	Stop	Stop	Stop
RT Channelized	-	None	-		-	None
Storage Length		-	_	-	0	-
Veh in Median Storage,	# -	108 0 5	41184	_	0	_
Grade, %	π -	0	0	_	0	_
Peak Hour Factor	85	85	92	92	92	92
Heavy Vehicles, %	6	6	2	2	2	2
Mymt Flow	0	864	0	0	0	0
IVIVIIIL FIOW	U	004	U	U	U	U
Major/Minor N	1ajor1			N	/linor2	
Conflicting Flow All	-	0			346	-
Stage 1	-	-			0	-
Stage 2	-	-			346	_
Critical Hdwy	-	_			5.74	_
Critical Hdwy Stg 1	_	_			-	_
Critical Hdwy Stg 2	_	_			6.04	_
Follow-up Hdwy	_	_			3.82	_
Pot Cap-1 Maneuver	0	_			649	0
Stage 1	0	_			-	0
Stage 2	0	_			630	0
Platoon blocked, %	U				030	U
		-			649	
Mov Cap-1 Maneuver	-	-				-
Mov Cap-2 Maneuver	-	-			649	-
Stage 1	-	-			-	-
Stage 2	-	-			630	-
Approach	EB				SB	
HCM Control Delay, s	0				0	
HCM LOS	U				A	
TIOW LOG						
Minor Lane/Major Mvmt		EBT S	SBLn1			
Capacity (veh/h)		-	-			
HCM Lane V/C Ratio		-	-			
HCM Control Delay (s)		-	0			
HCM Lane LOS		-	Α			
HCM 95th %tile Q(veh)		-	-			

Intersection						
Int Delay, s/veh	0.8					
		EDD	WDI	WDT	NDI	NDD
Movement	EBT	EBR	WBL	WBT	NBL	NBR
Lane Configurations	^	^	0	^	\	0
Traffic Vol, veh/h	0	0	0	826	63	0
Future Vol, veh/h	0	0	0	826	63	0
Conflicting Peds, #/hr	0	0	0	_ 0	0	0
Sign Control	Stop	Stop	Free	Free	Stop	Stop
RT Channelized	-	None		None	-	None
Storage Length	-	-	-	-	0	-
Veh in Median Storage,		-	-	0	0	-
Grade, %	0	-	-	0	0	-
Peak Hour Factor	92	92	90	73	80	80
Heavy Vehicles, %	2	2	3	3	3	3
Mvmt Flow	0	0	0	1132	79	0
Major/Minor		N	Major2	N	/linor1	
		ľ				
Conflicting Flow All			-	-	453	-
Stage 1			-	-	0	-
Stage 2			-	-	453	-
Critical Hdwy			-	-	5.76	-
Critical Hdwy Stg 1			-	-	-	-
Critical Hdwy Stg 2			-	-	6.06	-
Follow-up Hdwy			-	-	3.83	-
Pot Cap-1 Maneuver			0	-	574	0
Stage 1			0	-	-	0
Stage 2			0	-	553	0
Platoon blocked, %				-		
Mov Cap-1 Maneuver			-	-	574	-
Mov Cap-2 Maneuver			-	-	574	-
Stage 1			-	-	-	-
Stage 2			-	-	553	-
A			1645			
Approach			WB		NB	
HCM Control Delay, s			0		12.3	
HCM LOS					В	
Minor Lane/Major Mvmt	- 1	NBLn1	WBT			
Capacity (veh/h)	· · ·	574	-			
HCM Lane V/C Ratio		0.137	-			
HCM Control Delay (s)		12.3				
HCM Lane LOS		12.3 B	-			
HCM 95th %tile Q(veh)		0.5				
How som while Q(ven)		0.5	-			

Intersection						
Int Delay, s/veh	0.8					
Movement	EBL	EBT	WBT	WBR	SBL	SBR
Lane Configurations		ተተተ			ሻ	
Traffic Vol, veh/h	0	671	0	0	36	0
Future Vol, veh/h	0	671	0	0	36	0
Conflicting Peds, #/hr	0	0	0	0	0	0
Sign Control	Free	Free	Stop	Stop	Stop	Stop
RT Channelized	-	None	-	None	-	None
Storage Length	-	-	-	-	0	-
Veh in Median Storage,	,# -	0	0	-	0	-
Grade, %	-	0	0	-	0	-
Peak Hour Factor	85	85	92	92	60	60
Heavy Vehicles, %	6	6	2	2	0	0
Mvmt Flow	0	789	0	0	60	0
			•			
	/lajor1			Λ	/linor2	
Conflicting Flow All	-	0			316	-
Stage 1	-	-			0	-
Stage 2	-	-			316	-
Critical Hdwy	-	-			5.7	-
Critical Hdwy Stg 1	-	-			-	-
Critical Hdwy Stg 2	-	-			6	_
Follow-up Hdwy	_	-			3.8	-
Pot Cap-1 Maneuver	0	_			676	0
Stage 1	0	_			-	0
Stage 2	0	-			658	0
Platoon blocked, %	U	_			000	U
Mov Cap-1 Maneuver	_	_			676	_
Mov Cap-1 Maneuver	-	-			676	-
	-				0/0	-
Stage 1		-			GEO.	
Stage 2	-	-			658	-
Approach	EB				SB	
HCM Control Delay, s	0				10.8	
HCM LOS					В	
110111 200						
Minor Lane/Major Mvm	t	EBT S	SBLn1			
Capacity (veh/h)		-	676			
HCM Lane V/C Ratio		-	0.089			
HCM Control Delay (s)		-	10.8			
HCM Lane LOS		-	В			
HCM 95th %tile Q(veh)		-	0.3			
7000 00(1011)			3.5			

	۶	→	*	1	←	*	1	†	~	1	Į.	4
Movement	EBL	EBT	EBR	WBL	WBT	WBR	NBL	NBT	NBR	SBL	SBT	SBR
Lane Configurations					ተ						^	77
Traffic Volume (vph)	0	0	0	0	661	0	0	0	0	0	167	201
Future Volume (vph)	0	0	0	0	661	0	0	0	0	0	167	201
Ideal Flow (vphpl)	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000
Total Lost time (s)					5.9						9.0	9.0
Lane Util. Factor					0.91						0.95	0.88
Frt					1.00						1.00	0.85
FIt Protected					1.00						1.00	1.00
Satd. Flow (prot)					5250						3762	2962
FIt Permitted					1.00						1.00	1.00
Satd. Flow (perm)					5250						3762	2962
Peak-hour factor, PHF	0.92	0.92	0.92	0.91	0.91	0.91	0.92	0.92	0.92	0.87	0.87	0.87
Adj. Flow (vph)	0	0	0	0	726	0	0	0	0	0	192	231
RTOR Reduction (vph)	0	0	0	0	0	0	0	0	0	0	0	150
Lane Group Flow (vph)	0	0	0	0	726	0	0	0	0	0	192	81
Heavy Vehicles (%)	2%	2%	2%	4%	4%	4%	2%	2%	2%	1%	1%	1%
Turn Type					NA						NA	Perm
Protected Phases					6						4	
Permitted Phases												4
Actuated Green, G (s)					63.1						42.0	42.0
Effective Green, g (s)					63.1						42.0	42.0
Actuated g/C Ratio					0.53						0.35	0.35
Clearance Time (s)					5.9						9.0	9.0
Vehicle Extension (s)					3.0						3.0	3.0
Lane Grp Cap (vph)					2760						1316	1036
v/s Ratio Prot					c0.14						c0.05	
v/s Ratio Perm												0.03
v/c Ratio					0.26						0.15	0.08
Uniform Delay, d1					15.7						26.7	26.1
Progression Factor					1.00						1.00	1.00
Incremental Delay, d2					0.2						0.1	0.0
Delay (s)					15.9						26.8	26.1
Level of Service		0.0			B			0.0			С	С
Approach Delay (s)		0.0			15.9			0.0			26.4	
Approach LOS		Α			В			Α			С	
Intersection Summary												
HCM 2000 Control Delay			19.8	Н	CM 2000	Level of	Service		В			
HCM 2000 Volume to Capacity	ratio		0.22									
Actuated Cycle Length (s)			120.0		um of lost				14.9			
Intersection Capacity Utilization			31.2%	IC	CU Level of	of Service			Α			
Analysis Period (min)			15									
c Critical Lane Group												

	۶	-	•	*	1	4		
Movement	EBL	EBT	WBT	WBR	SBL	SBR		
Lane Configurations		ተ			ሻሻ			
Traffic Volume (vph)	0	508	0	0	167	0		
Future Volume (vph)	0	508	0	0	167	0		
Ideal Flow (vphpl)	2000	2000	2000	2000	2000	2000		
Total Lost time (s)		5.9			6.0			
Lane Util. Factor		0.91			0.97			
Frt		1.00			1.00			
Flt Protected		1.00			0.95			
Satd. Flow (prot)		5151			3650			
FIt Permitted		1.00			0.95			
Satd. Flow (perm)		5151			3650			
Peak-hour factor, PHF	0.85	0.85	0.92	0.92	0.87	0.87		
Adj. Flow (vph)	0	598	0	0	192	0		
RTOR Reduction (vph)	0	0	0	0	120	0		
Lane Group Flow (vph)	0	598	0	0	72	0		
Heavy Vehicles (%)	6%	6%	2%	2%	1%	1%		
Turn Type		NA			Prot			
Protected Phases		2			8			
Permitted Phases								
Actuated Green, G (s)		63.1			45.0			
Effective Green, g (s)		63.1			45.0			
Actuated g/C Ratio		0.53			0.38			
Clearance Time (s)		5.9			6.0			
Vehicle Extension (s)		3.0			3.0			
_ane Grp Cap (vph)		2708			1368			
//s Ratio Prot		c0.12			c0.02			
/s Ratio Perm								
ı/c Ratio		0.22			0.05			
Jniform Delay, d1		15.3			23.9			
Progression Factor		1.17			1.00			
ncremental Delay, d2		0.2			0.0			
Delay (s)		18.0			23.9			
Level of Service		В			С			
Approach Delay (s)		18.0	0.0		23.9			
Approach LOS		В	Α		С			
Intersection Summary								
HCM 2000 Control Delay			19.5	H	CM 2000	Level of Service	!	В
HCM 2000 Volume to Capacity	y ratio		0.16					
Actuated Cycle Length (s)			120.0		um of lost			14.9
Intersection Capacity Utilizatio	n		31.2%	IC	U Level c	of Service		Α
Analysis Period (min)			15					
c Critical Lane Group								

Intersection						
Int Delay, s/veh	1.3					
Movement	EBT	EBR	WBL	WBT	NBL	NBR
	ተ ቀሴ					7
Traffic Vol, veh/h	680	27	0	0	0	82
Future Vol, veh/h	680	27	0	0	0	82
Conflicting Peds, #/hr	0	0	0	0	0	0
Sign Control	Free	Free	Stop	Stop	Stop	Stop
RT Channelized	-		-		-	None
Storage Length	-	-	-	-	-	0
Veh in Median Storage	e, # 0	-	-	0	0	-
Grade, %	0	-	-	0	0	-
Peak Hour Factor	85	85	92	92	92	92
Heavy Vehicles, %	6	6	2	2	2	2
Mvmt Flow	800	32	0	0	0	89
NA ' (NA'	NA				A'	
	Major1				Minor1	4
Conflicting Flow All	0	0			-	416
Stage 1	-	-			-	-
Stage 2	-	-			-	-
Critical Hdwy	-	-			-	7.14
Critical Hdwy Stg 1	-	-			-	-
Critical Hdwy Stg 2	-	-			-	-
Follow-up Hdwy	-	-			-	3.92
Pot Cap-1 Maneuver	-	-			0	500
Stage 1	-	-			0	-
Stage 2	-	-			0	-
Platoon blocked, %	-	-				
Mov Cap-1 Maneuver	-	-			-	500
Mov Cap-2 Maneuver	-	-			-	-
Stage 1	-	-			-	-
Stage 2	-	-			-	-
Approach	ED				ND	
Approach	EB				NB	
HCM Control Delay, s	0				13.8	
HCM LOS					В	
Minor Lane/Major Mvm	nt 1	NBLn1	EBT	EBR		
Capacity (veh/h)		500	-	_		
HCM Lane V/C Ratio		0.178	_	_		
HCM Control Delay (s)		13.8	_	_		
HCM Lane LOS		В	_	_		
HCM 95th %tile Q(veh))	0.6	_	_		
TION JOHN JOHN JOHN WING		0.0				

Intersection												
Int Delay, s/veh	1.6											
Movement	EBL	EBT	EBR	WBL	WBT	WBR	NBL	NBT	NBR	SBL	SBT	SBR
Lane Configurations		4			4		7	f		7	f)	
Traffic Vol, veh/h	36	0	7	11	0	24	2	228	3	6	422	12
Future Vol, veh/h	36	0	7	11	0	24	2	228	3	6	422	12
Conflicting Peds, #/hr	0	0	0	0	0	0	0	0	0	0	0	0
Sign Control	Stop	Stop	Stop	Stop	Stop	Stop	Free	Free	Free	Free	Free	Free
RT Channelized	-	-	None	-	-	None	-	-	None	-	-	None
Storage Length	-	-	-	-	-	-	500	-	-	475	-	-
Veh in Median Storage	e, # -	0	-	-	0	-	-	0	-	-	0	-
Grade, %	-	0	-	-	0	-	-	0	-	-	0	-
Peak Hour Factor	92	92	92	92	92	92	93	93	93	92	92	92
Heavy Vehicles, %	2	2	2	2	2	2	5	5	5	2	2	2
Mvmt Flow	39	0	8	12	0	26	2	245	3	7	459	13
Major/Minor	Minor2			Minor1			Major1		-	Major2		
Conflicting Flow All	744	732	466	735	737	247	472	0	0	248	0	0
Stage 1	480	480	-	251	251		-	-	-	-	-	-
Stage 2	264	252	_	484	486	_	_	_	_	-	-	-
Critical Hdwy	7.12	6.52	6.22	7.12	6.52	6.22	4.15	_	-	4.12	_	-
Critical Hdwy Stg 1	6.12	5.52	_	6.12	5.52	_	-	_	-	_	_	-
Critical Hdwy Stg 2	6.12	5.52	-	6.12	5.52	-	_	_	-	_	_	-
Follow-up Hdwy	3.518	4.018	3.318	3.518	4.018	3.318	2.245	-	-	2.218	-	-
Pot Cap-1 Maneuver	331	348	597	335	346	792	1074	_	-	1318	_	-
Stage 1	567	554	-	753	699	_	_	_	-	-	-	-
Stage 2	741	698	_	564	551	_	_	_	_	_	_	-
Platoon blocked, %								-	-		-	-
Mov Cap-1 Maneuver	318	346	597	329	344	792	1074	-	-	1318	-	-
Mov Cap-2 Maneuver	318	346	-	329	344	-	-	-	-	-	-	-
Stage 1	566	551	-	751	698	-	-	-	-	-	-	-
Stage 2	715	697	-	554	548	-	-	_	-	-	-	-
Ŭ												
Approach	EB			WB			NB			SB		
HCM Control Delay, s	17.1			12			0.1			0.1		
HCM LOS	С			В								
Minor Lane/Major Mvm	nt	NBL	NBT	NBR	EBLn1V	VBL n1	SBL	SBT	SBR			
Capacity (veh/h)		1074	-	-	344	549	1318	-	-			
HCM Lane V/C Ratio		0.002	_		0.136			_	_			
HCM Control Delay (s)		8.4	_	_	17.1	12	7.7	_	_			
HCM Lane LOS		Α	_	_	C	В	Α	_	_			
HCM 95th %tile Q(veh))	0	_	_	0.5	0.2	0	_	_			
		- 0			0.0	0.2						

Intersection						
Int Delay, s/veh	0.5					
Movement	WBL	WBR	NBT	NBR	SBL	SBT
		WDK		NOK		
Lane Configurations	12	10	247	1	\	124
Traffic Vol, veh/h	12	16	217	4	6	434
Future Vol, veh/h	12	16	217	4	6	434
Conflicting Peds, #/hr	O Stop		0 Eroo	0 Eroo		0 Eroo
Sign Control RT Channelized	Stop	Stop	Free	Free	Free	Free
	-		-	None	- 500	None
Storage Length	0	-	-	-	500	-
Veh in Median Storage		-	0	-	-	0
Grade, %	0	-	0	-	-	0
Peak Hour Factor	92	92	93	93	92	92
Heavy Vehicles, %	2	2	5	5	2	2
Mvmt Flow	13	17	233	4	7	472
Major/Minor I	Minor1	N	Major1		Major2	
Conflicting Flow All	721	235	0	0	237	0
Stage 1	235	-	-	-	-	-
Stage 2	486	_	_	_	_	_
Critical Hdwy	6.42	6.22	_	_	4.12	_
Critical Hdwy Stg 1	5.42	0.22			7.12	_
Critical Hdwy Stg 2	5.42		<u> </u>	-		
Follow-up Hdwy	3.518	3.318	_	_	2.218	
Pot Cap-1 Maneuver	394	804		-	1330	_
Stage 1	804	- 00-	_		1000	
Stage 2	618			-		-
Platoon blocked, %	010	-	-	-	-	-
	300	804			1220	
Mov Cap-1 Maneuver	392	004	-	-	1330	-
Mov Cap-2 Maneuver	490	-	-	-	-	-
Stage 1	804	-	-	-	-	-
Stage 2	615	-	-	-	-	-
Approach	WB		NB		SB	
HCM Control Delay, s	11		0		0.1	
HCM LOS	В		U		0.1	
TOW LOO	D					
Minor Long/Major My	.+	NDT	NDDV	VDI 51	CDI	CDT
Minor Lane/Major Mvm	ı	NBT		VBLn1	SBL	SBT
Capacity (veh/h)		-	-		1330	-
HCM Lane V/C Ratio		-	-	0.048		-
HCM Control Delay (s)		-	-	11	7.7	-
HCM Lane LOS		-	-	В	Α	-
HCM 95th %tile Q(veh)		-	-	0.2	0	-

Movement	Intersection						
Movement		3.2					
Lane Configurations ↑↑↑ ↑↑↑ Traffic Vol, veh/h 0 913 0 0 307 0 Future Vol, veh/h 0 913 0 - 0 - 0 - 0 - 0 - 0 - 0 - 0 - 0 - 0 - 0 - 0 - 0 - 0 - 0 - 0 - 0 0 3 3 0 0 <td></td> <td></td> <td>EDT</td> <td>WDT</td> <td>WDD</td> <td>CDI</td> <td>CDD</td>			EDT	WDT	WDD	CDI	CDD
Traffic Vol, veh/h Future Vol, veh/h O 913 O 0307 O Conflicting Peds, #/hr O 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0 0				WBI	WBK		SBK
Future Vol, veh/h Conflicting Peds, #/hr O O O O O O O O O O O O O O O O O O O			TŤŤ	0	0		0
Conflicting Peds, #/hr 0 0 0 0 0 0 0 Stop St	· ·						
Sign Control Free RTC None Stop None None							
RT Channelized							
Storage Length							
Veh in Median Storage, # - 1082894336 - 0 - Grade, % - 0 0 - 0 - Peak Hour Factor 84 84 92 92 93 93 Heavy Vehicles, % 2 2 2 2 1 1 Mwmt Flow 0 1087 0 330 0 Migory/Minor Major/Minor Minor2 Conflicting Flow All - 0 435 - Stage 1 - 0 - - Stage 2 - - 435 - Critical Hdwy Stg 2 - - 6.02 - Critical Hdwy Stg 1 - <							
Grade, % - 0 0 - 0 - Peak Hour Factor 84 84 92 92 93 93 Heavy Vehicles, % 2 2 2 2 2 1 1 Mwmt Flow 0 1087 0 330 0 Major/Minor Major/Minor Minor2 Conflicting Flow All - 0 435 - Stage 1 - 0 - - Stage 2 - - 435 - Critical Hdwy Stg 1 - - - - Critical Hdwy Stg 2 - - 6.02 - Critical Hdwy Stg 2 - - 6.02 - Critical Hdwy Stg 2 - - 6.02 - Critical Hdwy Stg 2 - - 0 - * 739 0 Stage 1 0 -							
Peak Hour Factor 84 84 92 92 93 93 Heavy Vehicles, % 2 2 2 2 1 1 Mwmt Flow 0 1087 0 0 330 0 Major/Minor Major/Minor Minor2 Conflicting Flow All - 0 435 - Stage 1 - 0 - - Stage 2 - - 435 - Critical Howy Stg 1 - - - - Critical Howy Stg 2 - - 6.02 - Critical Howy Stg 2 - - 6.02 - Critical Howy Stg 2 - - 6.02 - Critical Howy Stg 2 - - 0 - Critical Howy Stg 2 - - 0 - - 0 - - 0 - - - <td></td> <td>_</td> <td></td> <td></td> <td></td> <td></td> <td></td>		_					
Heavy Vehicles, % 2 2 2 2 1 1 Mvmt Flow							
Mymmt Flow 0 1087 0 0 330 0 Major/Minor Major1 Minor2 Conflicting Flow All - 0 435 - Stage 1 - 0 - - Stage 2 - 435 - - Critical Hdwy Stg 1 - - - - Critical Hdwy Stg 2 - - 6.02 - <t< td=""><td></td><td></td><td></td><td></td><td></td><td></td><td></td></t<>							
Major/Minor Major1 Minor2 Conflicting Flow All - 0 435 - Stage 1 - - 0 - Stage 2 - - 435 - Critical Hdwy - - - - Critical Hdwy Stg 1 - - - - Critical Hdwy Stg 2 - - 6.02 - Follow-up Hdwy - - 3.81 - Pot Cap-1 Maneuver 0 - 739 0 Stage 1 0 - - 0 Stage 2 0 - *739 0 Platoon blocked, % - 1 1 Mov Cap-1 Maneuver - *739 - Stage 1 - - - Stage 2 - *739 - Stage 2 - *739 - Approach EB SB HCM LOS B <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td>							
Conflicting Flow All - 0 435 - Stage 1 - - 0 - Stage 2 - - 435 - Critical Hdwy - - - - Critical Hdwy Stg 1 - - - - Critical Hdwy Stg 2 - - 6.02 - Follow-up Hdwy - - 3.81 - Pot Cap-1 Maneuver 0 *739 0 Stage 1 0 - - 0 Stage 1 0 - - 0 Stage 2 0 - *739 - Mov Cap-1 Maneuver - - *739 - Mov Cap-2 Maneuver - *739 - Stage 1 - - - - Stage 2 - *739 - Approach EB SB HCM Control Delay, s 0 13.7 HCM LOS B Minor Lane/Major Mvmt EBT SBLn1 Capacity (veh/h) - 739 HCM Lane LOS - B			1001	- 0		- 000	
Stage 1							
Stage 1 - - 0 - Stage 2 - - 435 - Critical Hdwy Stg 1 - - - Critical Hdwy Stg 2 - - - Follow-up Hdwy - - - Pot Cap-1 Maneuver 0 - - 0 Stage 1 0 - - 0 Stage 2 0 - *739 0 Platoon blocked, % - 1 Mov Cap-1 Maneuver - *739 - Mov Cap-2 Maneuver - *739 - Stage 1 - - - Stage 2 - *739 - Approach EB SB HCM Control Delay, s 0 13.7 HCM LOS B Minor Lane/Major Mvmt EBT SBLn1 Capacity (veh/h) - 739 HCM Lane V/C Ratio - 0.447 HCM Control Delay (s) - 13.7 HCM Lane LOS - B HCM 95th %tile Q(veh) - 2.3 Notes Notes		Major1			1		
Stage 2 - - 435 - Critical Hdwy Stg 1 - - - - Critical Hdwy Stg 2 - - - - Follow-up Hdwy - - 3.81 - Pot Cap-1 Maneuver 0 - 7739 0 Stage 1 0 - - 0 Stage 2 0 - *739 0 Poltoon blocked, % - 1 Mov Cap-1 Maneuver - *739 - Mov Cap-2 Maneuver - *739 - Stage 1 - - - - Stage 2 - *739 - Approach EB SB HCM Control Delay, s 0 13.7 HCM Lane V/C Ratio - 0.447 HCM Control Delay (s) - 13.7 HCM Control Delay (s) - 13.7 HCM Lane LOS		-	0				-
Critical Hdwy - <		-	-				-
Critical Hdwy Stg 1 -		-	-				-
Critical Hdwy Stg 2 - - 6.02 - Follow-up Hdwy - - 3.81 - Pot Cap-1 Maneuver 0 - 739 0 Stage 1 0 - - 0 Stage 2 0 - *739 0 Platoon blocked, % - 1 - - Mov Cap-1 Maneuver - *739 - Mov Cap-2 Maneuver - *739 - Stage 1 - - - Stage 2 - *739 - Approach EB SB HCM Control Delay, s 0 13.7 HCM Los Minor Lane/Major Mvmt EBT SBLn1 Capacity (veh/h) - 739 HCM Lane V/C Ratio - 0.447 HCM Control Delay (s) - 13.7 HCM Lane LOS - B HCM 95th %tile Q(veh) - 2.3 Notes Notes		-	-			5.72	-
Follow-up Hdwy 3.81 - Pot Cap-1 Maneuver 0 - *739 0 Stage 1 0 0 Stage 2 0 - *739 0 Platoon blocked, % - 1 Mov Cap-1 Maneuver *739 - Mov Cap-2 Maneuver *739 - Stage 1 Stage 2 - *739 - Stage 2 - *739 - Mov Cap-2 Maneuver *739 - Stage 1 Stage 2 - *739 - Approach EB SB HCM Control Delay, s 0 13.7 HCM LOS B Minor Lane/Major Mvmt EBT SBLn1 Capacity (veh/h) - 739 HCM Lane V/C Ratio - 0.447 HCM Control Delay (s) - 13.7 HCM Lane LOS - B HCM 95th %tile Q(veh) - 2.3 Notes		-	-			-	-
Pot Cap-1 Maneuver		-	-				-
Stage 1 0 - - 0 Stage 2 0 - *739 0 Platoon blocked, % - 1 Mov Cap-1 Maneuver - *739 - Mov Cap-2 Maneuver - - - Stage 1 - - - Stage 2 - - *739 - Approach EB SB HCM Control Delay, s 0 13.7 HCM LOS B Minor Lane/Major Mvmt EBT SBLn1 Capacity (veh/h) - 739 HCM Lane V/C Ratio - 0.447 HCM Control Delay (s) - 13.7 HCM Lane LOS - B HCM 95th %tile Q(veh) - 2.3 Notes Notes			-				
Stage 2 0 - *739 0 Platoon blocked, % - 1 Mov Cap-1 Maneuver - *739 - Mov Cap-2 Maneuver - - - Stage 1 - - - Stage 2 - - *739 - Approach EB SB HCM Control Delay, s 0 13.7 B Minor Lane/Major Mvmt EBT SBLn1 Capacity (veh/h) - 739 B HCM Lane V/C Ratio - 0.447 B HCM Control Delay (s) - 13.7 HCM Lane LOS - B HCM 95th %tile Q(veh) - 2.3			-			*739	
Platoon blocked, %			-				
Mov Cap-1 Maneuver - *739 - Mov Cap-2 Maneuver - - *739 - Stage 1 - - - - Stage 2 - - *739 - Approach EB SB HCM Control Delay, s 0 13.7 HCM LOS B Minor Lane/Major Mvmt EBT SBLn1 Capacity (veh/h) - 739 HCM Lane V/C Ratio - 0.447 HCM Control Delay (s) - 13.7 HCM Lane LOS - B HCM 95th %tile Q(veh) - 2.3 Notes		0	-				0
Mov Cap-2 Maneuver -			-			-	
Stage 1 - - - Stage 2 - - *739 - Approach EB SB HCM Control Delay, s 0 13.7 HCM LOS B Minor Lane/Major Mvmt EBT SBLn1 Capacity (veh/h) - 739 HCM Lane V/C Ratio - 0.447 HCM Control Delay (s) - 13.7 HCM Lane LOS - B HCM 95th %tile Q(veh) - 2.3 Notes			-				-
Stage 2		er -	-			*739	-
Approach EB SB HCM Control Delay, s 0 13.7 HCM LOS B Minor Lane/Major Mvmt EBT SBLn1 Capacity (veh/h) - 739 HCM Lane V/C Ratio - 0.447 HCM Control Delay (s) - 13.7 HCM Lane LOS - B HCM 95th %tile Q(veh) - 2.3 Notes	•	-	-			-	-
HCM Control Delay, s 0 13.7 HCM LOS B Minor Lane/Major Mvmt EBT SBLn1 Capacity (veh/h) - 739 HCM Lane V/C Ratio - 0.447 HCM Control Delay (s) - 13.7 HCM Lane LOS - B HCM 95th %tile Q(veh) - 2.3 Notes	Stage 2	-	-			*739	-
HCM Control Delay, s 0 13.7 HCM LOS B Minor Lane/Major Mvmt EBT SBLn1 Capacity (veh/h) - 739 HCM Lane V/C Ratio - 0.447 HCM Control Delay (s) - 13.7 HCM Lane LOS - B HCM 95th %tile Q(veh) - 2.3 Notes							
HCM Control Delay, s 0 13.7 HCM LOS B Minor Lane/Major Mvmt EBT SBLn1 Capacity (veh/h) - 739 HCM Lane V/C Ratio - 0.447 HCM Control Delay (s) - 13.7 HCM Lane LOS - B HCM 95th %tile Q(veh) - 2.3 Notes	Approach	EB				SB	
Minor Lane/Major Mvmt EBT SBLn1 Capacity (veh/h) - 739 HCM Lane V/C Ratio - 0.447 HCM Control Delay (s) - 13.7 HCM Lane LOS - B HCM 95th %tile Q(veh) - 2.3 Notes							
Minor Lane/Major Mvmt EBT SBLn1 Capacity (veh/h) - 739 HCM Lane V/C Ratio - 0.447 HCM Control Delay (s) - 13.7 HCM Lane LOS - B HCM 95th %tile Q(veh) - 2.3 Notes		J 3				-	
Capacity (veh/h) - 739 HCM Lane V/C Ratio - 0.447 HCM Control Delay (s) - 13.7 HCM Lane LOS - B HCM 95th %tile Q(veh) - 2.3 Notes						J	
Capacity (veh/h) - 739 HCM Lane V/C Ratio - 0.447 HCM Control Delay (s) - 13.7 HCM Lane LOS - B HCM 95th %tile Q(veh) - 2.3 Notes	Mineral and /M. C. D.C.		EDT (אות ב			
HCM Lane V/C Ratio - 0.447 HCM Control Delay (s) - 13.7 HCM Lane LOS - B HCM 95th %tile Q(veh) - 2.3 Notes		vmt					
HCM Control Delay (s) - 13.7 HCM Lane LOS - B HCM 95th %tile Q(veh) - 2.3 Notes							
HCM Lane LOS - B HCM 95th %tile Q(veh) - 2.3 Notes							
HCM 95th %tile Q(veh) - 2.3 Notes		(S)					
Notes		ا اما					
	HCM 95th %tile Q(ve	en)	-	2.3			
	Notes						
		capacity	\$: De	lay exc	eeds 30	0s -	+: Comr

	۶	→	•	•	←	•	1	†	~	\	↓	4
Movement	EBL	EBT	EBR	WBL	WBT	WBR	NBL	NBT	NBR	SBL	SBT	SBR
Lane Configurations					ተተተ	7		^			†	7
Traffic Volume (vph)	0	0	0	0	1919	349	0	168	0	0	163	58
Future Volume (vph)	0	0	0	0	1919	349	0	168	0	0	163	58
Ideal Flow (vphpl)	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000
Total Lost time (s)					6.0	6.0		6.4			10.4	10.4
Lane Util. Factor					0.91	1.00		1.00			1.00	1.00
Frpb, ped/bikes					1.00	1.00		1.00			1.00	0.99
Flpb, ped/bikes					1.00	1.00		1.00			1.00	1.00
Frt					1.00	0.85		1.00			1.00	0.85
Flt Protected					1.00	1.00		1.00			1.00	1.00
Satd. Flow (prot)					5353	1667		1980			1869	1567
Flt Permitted					1.00	1.00		1.00			1.00	1.00
Satd. Flow (perm)					5353	1667		1980			1869	1567
Peak-hour factor, PHF	0.93	0.93	0.93	0.74	0.74	0.74	0.91	0.91	0.91	0.72	0.72	0.72
Adj. Flow (vph)	0	0	0	0	2593	472	0	185	0	0	226	81
RTOR Reduction (vph)	0	0	0	0	0	164	0	0	0	0	0	19
Lane Group Flow (vph)	0	0	0	0	2593	308	0	185	0	0	226	62
Confl. Peds. (#/hr)									1	1		
Confl. Bikes (#/hr)									1			2
Heavy Vehicles (%)	2%	2%	2%	2%	2%	2%	1%	1%	1%	7%	7%	7%
Turn Type					NA	Perm		NA			NA	Perm
Protected Phases					6			8			4	
Permitted Phases						6						4
Actuated Green, G (s)					67.0	67.0		40.6			36.6	36.6
Effective Green, g (s)					67.0	67.0		40.6			36.6	36.6
Actuated g/C Ratio					0.56	0.56		0.34			0.31	0.31
Clearance Time (s)					6.0	6.0		6.4			10.4	10.4
Vehicle Extension (s)					3.0	3.0		3.0			3.0	3.0
Lane Grp Cap (vph)					2988	930		669			570	477
v/s Ratio Prot					c0.48			0.09			c0.12	
v/s Ratio Perm						0.18						0.04
v/c Ratio					0.87	0.33		0.28			0.40	0.13
Uniform Delay, d1					22.7	14.4		29.0			33.0	30.2
Progression Factor					0.98	1.39		0.00			1.00	1.00
Incremental Delay, d2					2.7	0.7		0.2			0.5	0.1
Delay (s)					24.9	20.7		0.2			33.4	30.3
Level of Service					С	С		Α			С	С
Approach Delay (s)		0.0			24.2			0.2			32.6	
Approach LOS		Α			С			Α			С	
Intersection Summary												
HCM 2000 Control Delay			23.7	Н	CM 2000	Level of S	Service		С			
HCM 2000 Volume to Capacity	ratio		0.70									
Actuated Cycle Length (s)			120.0	S	um of lost	t time (s)			16.4			
Intersection Capacity Utilization			57.0%			of Service			В			
Analysis Period (min)			15									
c Critical Lane Group												

	۶	-	•	€	—	4	4	†	~	/	Ţ	√
Movement	EBL	EBT	EBR	WBL	WBT	WBR	NBL	NBT	NBR	SBL	SBT	SBR
Lane Configurations		ተተተ	7						7		1	
Traffic Volume (vph)	0	949	271	0	0	0	0	168	395	0	163	0
Future Volume (vph)	0	949	271	0	0	0	0	168	395	0	163	0
Ideal Flow (vphpl)	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000	2000
Total Lost time (s)		6.0	6.0					10.4	10.4		6.4	
Lane Util. Factor		0.91	1.00					1.00	1.00		1.00	
Frpb, ped/bikes		1.00	1.00					1.00	0.99		1.00	
Flpb, ped/bikes		1.00	1.00					1.00	1.00		1.00	
Frt		1.00	0.85					1.00	0.85		1.00	
FIt Protected		1.00	1.00					1.00	1.00		1.00	
Satd. Flow (prot)		5353	1667					1980	1660		1869	
Flt Permitted		1.00	1.00					1.00	1.00		1.00	
Satd. Flow (perm)		5353	1667					1980	1660		1869	
Peak-hour factor, PHF	0.84	0.84	0.84	0.92	0.92	0.92	0.91	0.91	0.91	0.72	0.72	0.72
Adj. Flow (vph)	0	1130	323	0	0	0	0	185	434	0	226	0
RTOR Reduction (vph)	0	0	143	0	0	0	0	0	51	0	0	0
Lane Group Flow (vph)	0	1130	180	0	0	0	0	185	383	0	226	0
Confl. Peds. (#/hr)									1	1		
Confl. Bikes (#/hr)									1			2
Heavy Vehicles (%)	2%	2%	2%	2%	2%	2%	1%	1%	1%	7%	7%	7%
Turn Type		NA	Perm					NA	Perm		NA	
Protected Phases		2	_					4			8	
Permitted Phases			2						4			
Actuated Green, G (s)		67.0	67.0					36.6	36.6		40.6	
Effective Green, g (s)		67.0	67.0					36.6	36.6		40.6	
Actuated g/C Ratio		0.56	0.56					0.31	0.31		0.34	
Clearance Time (s)		6.0	6.0					10.4	10.4		6.4	
Vehicle Extension (s)		3.0	3.0					3.0	3.0		3.0	
Lane Grp Cap (vph)		2988	930					603	506		632	
v/s Ratio Prot		c0.21	0.44					0.09	0.00		0.12	
v/s Ratio Perm		0.00	0.11					0.04	c0.23		0.00	
v/c Ratio		0.38	0.19					0.31	0.76		0.36	
Uniform Delay, d1		14.8	13.1					32.0	37.7		29.9	
Progression Factor		0.76	0.43					1.00	1.00		0.00	
Incremental Delay, d2		0.4	0.5					0.3 32.3	6.4		0.3	
Delay (s)		11.7	6.1					32.3 C	44.1		0.3	
Level of Service		B 10.5	A		0.0			40.6	D		A 0.3	
Approach Delay (s) Approach LOS		10.5 B			0.0 A			40.6 D			0.5 A	
Intersection Summary											, ,	
HCM 2000 Control Delay			17.6	H	CM 2000	Level of S	Service		В			
HCM 2000 Volume to Capacity	ratio		0.51	111	CIVI 2000	_0 v 01 01 0	J 51 V 10 C		U			
Actuated Cycle Length (s)	13110		120.0	Sı	um of lost	time (s)			16.4			
Intersection Capacity Utilization			57.0%			of Service			В			
Analysis Period (min)			15	10	5 207010	. 001 7100			- 5			
c Critical Lane Group												

ntersection								
nt Delay, s/veh	0							
Movement	EBL	EBT	WBT	WBR	SBL	SBR		
ane Configurations		ተተተ			ሻ			
affic Vol, veh/h	0	1344	0	0	3	0		
uture Vol, veh/h	0	1344	0	0	3	0		
onflicting Peds, #/hr	0	0	0	0	0	0		
ign Control	Free	Free	Stop	Stop	Stop	Stop		
T Channelized	_		_	None	_			
torage Length	-	-	-	-	0	-		
eh in Median Storage,	,# -	108 0 5	41184	-	0	-		
rade, %	-	0	0	-	0	-		
ak Hour Factor	95	88	92	92	60	60		
eavy Vehicles, %	2	1	2	2	0	0		
mt Flow	0	1527	0	0	5	0		
ajor/Minor N	Major1			N	/linor2			
		^		T N				
onflicting Flow All	-	0			611	-		
Stage 1	-	-						
Stage 2	-	-			611 5.7	-		
itical Hdwy	-	-			5.7	-		
itical Hdwy Stg 1	-	_			6	-		
tical Hdwy Stg 2	-	-			3.8	-		
ollow-up Hdwy ot Cap-1 Maneuver	0	-			*688	0		
Stage 1	0	-			-	0		
Stage 2	0				*688	0		
atoon blocked, %	U	_			1	U		
ov Cap-1 Maneuver	_				*688	_		
ov Cap-1 Maneuver	-				*688	-		
Stage 1	<u>-</u>				-			
Stage 2	_	_			*688	_		
Oldgo Z					500			
oproach	EB				SB			
ICM Control Delay, s	0				10.3			
ICM LOS					В			
nor Lane/Major Mvm	t	EBT S	SBLn1					
pacity (veh/h)			688					
CM Lane V/C Ratio		_	0.007					
CM Control Delay (s)		_	10.3					
CM Lane LOS		_	В					
CM 95th %tile Q(veh)		_	0					
otes		A -						
Volume exceeds cap	acity	\$: De	lay exc	eeds 30	0s	+: Comp	utation Not Defined	*: All major volume in platoon

Intersection						
Int Delay, s/veh	1.5					
		EDD	MDI	MPT	ND	NDD
	EBT	EBR	WBL	WBT	NBL	NBR
Lane Configurations	•	•	•	^	ሻ	•
Traffic Vol, veh/h	0	0		2183	88	0
Future Vol, veh/h	0	0	0	2183	88	0
Conflicting Peds, #/hr	0	0	0	0	0	0
	Stop	Stop	Free	Free	Stop	Stop
RT Channelized	-	None	-	None	-	None
Storage Length	-	-	-	-	0	-
Veh in Median Storage, #		-	-	0	0	-
Grade, %	0	-	-	0	0	-
Peak Hour Factor	92	92	93	74	65	63
Heavy Vehicles, %	2	2	2	2	1	1
Mvmt Flow	0	0	0	2950	135	0
Major/Minor		N	Major?	N	liner1	
Major/Minor		1	Major2		/linor1	
Conflicting Flow All			-	-	1180	-
Stage 1			-	-	0	-
Stage 2			-	-	1180	-
Critical Hdwy			-	-	5.72	-
Critical Hdwy Stg 1			-	-	-	-
Critical Hdwy Stg 2			-	-	6.02	-
Follow-up Hdwy			-	-	3.81	-
Pot Cap-1 Maneuver			0	-	254	0
Stage 1			0	-	-	0
Stage 2			0	-	230	0
Platoon blocked, %				-		
Mov Cap-1 Maneuver			-	-	254	-
Mov Cap-2 Maneuver			-	-	254	-
Stage 1			-	-	-	-
Stage 2			_	_	230	_
Approach			WB		NB	
HCM Control Delay, s			0		34.3	
HCM LOS					D	
Minor Lane/Major Mvmt	N	NBLn1	WBT			
	ľ					
Capacity (veh/h)		254	-			
HCM Caretral Dalay (a)		0.533	-			
HCM Control Delay (s)		34.3	-			
HCM Lane LOS		D	-			
HCM 95th %tile Q(veh)		2.9	-			

Intersection						
Int Delay, s/veh	1.1					
		EDT	WDT	WDD	CDI	CDD
	EBL	EBT	WBI	WBR	SBL	SBR
Lane Configurations	^	^	^	^	ነ	^
Traffic Vol, veh/h	0	1259	0	0	105	0
Future Vol, veh/h	0	1259	0	0	105	0
Conflicting Peds, #/hr	0	0	0	0	0	0
	Free	Free	Stop	Stop	Stop	Stop
RT Channelized	-	None	-	None	-	None
Storage Length	-	-	-	-	0	-
Veh in Median Storage, #	‡ -	0	0	-	0	-
Grade, %	-	0	0	-	0	-
Peak Hour Factor	88	88	92	92	92	92
Heavy Vehicles, %	1	1	2	2	14	14
Mvmt Flow	0	1431	0	0	114	0
Major/Minor NA	nior1				Aincr0	
	ajor1				Minor2	
Conflicting Flow All	-	0			572	-
Stage 1	-	-			0	-
Stage 2	-	-			572	-
Critical Hdwy	-	-			5.98	-
Critical Hdwy Stg 1	-	-			-	-
Critical Hdwy Stg 2	-	-			6.28	-
Follow-up Hdwy	-	-			3.94	-
Pot Cap-1 Maneuver	0	-			475	0
Stage 1	0	-			-	0
Stage 2	0	-			453	0
Platoon blocked, %		-				
Mov Cap-1 Maneuver	_	-			475	_
Mov Cap-2 Maneuver	_	_			475	_
Stage 1	_	_			-	_
Stage 2	_	_			453	_
Olago Z					700	
Approach	EB				SB	
HCM Control Delay, s	0				15	
HCM LOS					С	
NASSES AND ASSESS NASSES		EDT (ייי וחכ			
Minor Lane/Major Mvmt			SBLn1			
Capacity (veh/h)		-	475			
HCM Lane V/C Ratio		-	0.24			
HCM Control Delay (s)		-	15			
HCM Lane LOS		-	С			
HCM 95th %tile Q(veh)		-	0.9			

Movement EBL EBT EBR WBL WBT WBR NBL NBT NBR SBL SBT	SBR
Lane Configurations †††	77
Traffic Volume (vph) 0 0 0 0 1720 0 0 0 0 170	568
Future Volume (vph) 0 0 0 1720 0 0 0 170	568
Ideal Flow (vphpl) 2000 2000 2000 2000 2000 2000 2000 20	2000
Total Lost time (s) 5.9 9.0	9.0
Lane Util. Factor 0.91 0.95	0.88
Frt 1.00 1.00	0.85
Fit Protected 1.00 1.00	1.00
Satd. Flow (prot) 5353 3725	2933
Flt Permitted 1.00 1.00	1.00
Satd. Flow (perm) 5353 3725	2933
Peak-hour factor, PHF 0.92 0.92 0.92 0.84 0.84 0.84 0.92 0.92 0.92 0.68 0.68	0.68
Adj. Flow (vph) 0 0 0 0 2048 0 0 0 0 250	835
RTOR Reduction (vph) 0 0 0 0 0 0 0 0 0	16
Lane Group Flow (vph) 0 0 0 0 2048 0 0 0 0 250	819
Turn Type NA NA	Perm
Protected Phases 6 4	
Permitted Phases	4
Actuated Green, G (s) 60.1 45.0	45.0
Effective Green, g (s) 60.1 45.0	45.0
Actuated g/C Ratio 0.50 0.38	0.38
Clearance Time (s) 5.9 9.0	9.0
Vehicle Extension (s) 3.0	3.0
Lane Grp Cap (vph) 2680 1396	1099
v/s Ratio Prot c0.38 0.07	
v/s Ratio Perm	c0.28
v/c Ratio 0.76 0.18	0.74
Uniform Delay, d1 24.2 25.1	32.5
Progression Factor 1.00 1.00	1.00
Incremental Delay, d2 2.1 0.1	2.8
Delay (s) 26.4 25.2	35.3
Level of Service C	D
Approach Delay (s) 0.0 26.4 0.0 33.0	
Approach LOS A C A C	
Intersection Summary	
HCM 2000 Control Delay 28.6 HCM 2000 Level of Service C	
HCM 2000 Volume to Capacity ratio 0.76	
Actuated Cycle Length (s) 120.0 Sum of lost time (s) 14.9	
Intersection Capacity Utilization 62.9% ICU Level of Service B	
Analysis Period (min) 15	

c Critical Lane Group

	۶	-	←	*	\	4		
Movement	EBL	EBT	WBT	WBR	SBL	SBR		
Lane Configurations		^ ^			ኻኻ			
Traffic Volume (vph)	0	769	0	0	170	0		
Future Volume (vph)	0	769	0	0	170	0		
(1 /	2000	2000	2000	2000	2000	2000		
Total Lost time (s)		5.9			6.0			
Lane Util. Factor		0.91			0.97			
Frt		1.00			1.00			
Flt Protected		1.00			0.95			
Satd. Flow (prot)		5406			3614			
FIt Permitted		1.00			0.95			
Satd. Flow (perm)		5406			3614			
Peak-hour factor, PHF	0.88	0.88	0.92	0.92	0.68	0.68		
Adj. Flow (vph)	0.00	874	0.02	0.02	250	0		
RTOR Reduction (vph)	0	0	0	0	126	0		
Lane Group Flow (vph)	0	874	0	0	124	0		
Heavy Vehicles (%)	1%	1%	2%	2%	2%	2%		
Turn Type	. , ,	NA			Prot			
Protected Phases		2			8			
Permitted Phases					- 0			
Actuated Green, G (s)		60.1			48.0			
Effective Green, g (s)		60.1			48.0			
Actuated g/C Ratio		0.50			0.40			
Clearance Time (s)		5.9			6.0			
Vehicle Extension (s)		3.0			3.0			
Lane Grp Cap (vph)		2707			1445			
v/s Ratio Prot		c0.16			c0.03			
v/s Ratio Perm		00.10			00.00			
v/c Ratio		0.32			0.09			
Uniform Delay, d1		17.8			22.4			
Progression Factor		1.08			0.02			
Incremental Delay, d2		0.3			0.0			
Delay (s)		19.5			0.4			
Level of Service		В			A			
Approach Delay (s)		19.5	0.0		0.4			
Approach LOS		В	А		А			
Intersection Summary								
HCM 2000 Control Delay			15.3	Н	CM 2000	Level of Service	В	
HCM 2000 Volume to Capacity	ratio		0.22					
Actuated Cycle Length (s)			120.0	Sı	um of lost	time (s)	14.9	
Intersection Capacity Utilization			62.9%		U Level c		В	
Analysis Period (min)			15					
c Critical Lane Group								

Intersection						
Int Delay, s/veh	0.8					
Movement	EBT	EBR	WBL	WBT	NBL	NBR
Lane Configurations	ተተኈ					7
Traffic Vol, veh/h	1270	94	0	0	0	59
Future Vol, veh/h	1270	94	0	0	0	59
Conflicting Peds, #/hr	0	0	0	0	0	0
Sign Control	Free	Free	Stop	Stop	Stop	Stop
RT Channelized	_	None	-		-	None
Storage Length	_	-	-	-	-	0
Veh in Median Storage	, # 0	_	_	0	0	-
Grade, %	0	_	_	0	0	_
Peak Hour Factor	88	88	92	92	92	92
Heavy Vehicles, %	1	1	2	2	2	2
Mymt Flow	1443	107	0	0	0	64
INTALLIC LICAN	1770	101	U	U	0	UT
Major/Minor	Major1			N	/linor1	
Conflicting Flow All	0	0			-	775
Stage 1	-	-			-	-
Stage 2	-	-			-	-
Critical Hdwy	-	-			-	7.14
Critical Hdwy Stg 1	-	-			-	-
Critical Hdwy Stg 2	-	-			-	-
Follow-up Hdwy	-	-			-	3.92
Pot Cap-1 Maneuver	_	-			0	292
Stage 1	_	_			0	-
Stage 2	_	-			0	_
Platoon blocked, %	_	_				
Mov Cap-1 Maneuver	_				_	292
Mov Cap-1 Maneuver	_	_			_	232
Stage 1	-				_	_
	-	-				-
Stage 2	-	-			-	-
Approach	EB				NB	
HCM Control Delay, s	0				20.8	
HCM LOS					С	
		151 1				
Minor Lane/Major Mvm	nt l	NBLn1	EBT	EBR		
Capacity (veh/h)		292	-	-		
HCM Lane V/C Ratio		0.22	-	-		
HCM Control Delay (s)		20.8	-	-		
HCM Lane LOS		С	-	-		
HCM 95th %tile Q(veh))	8.0	-	-		

Intersection												
Int Delay, s/veh	1.2											
Movement	EBL	EBT	EBR	WBL	WBT	WBR	NBL	NBT	NBR	SBL	SBT	SBR
Lane Configurations		4			4		ች	₽			₽	
Traffic Vol, veh/h	25	0	3	4	0	13	4	525	7	21	376	37
Future Vol, veh/h	25	0	3	4	0	13	4	525	7	21	376	37
Conflicting Peds, #/hr	0	0	0	0	0	0	0	0	0	0	0	0
Sign Control	Stop	Stop	Stop	Stop	Stop	Stop	Free	Free	Free	Free	Free	Free
RT Channelized	<u> </u>	-	None	-	-	None	-	-	None	-	-	None
Storage Length	-	-	-	-	-	-	500	-	-	475	-	-
Veh in Median Storage	e,# -	0	-	-	0	-	-	0	-	-	0	-
Grade, %	_	0	-	-	0	-	-	0	-	-	0	-
Peak Hour Factor	92	92	92	92	92	92	91	91	91	92	92	92
Heavy Vehicles, %	2	2	2	2	2	2	1	1	1	2	2	2
Mvmt Flow	27	0	3	4	0	14	4	577	8	23	409	40
Major/Minor	Minor2			Minor1			Major1			Major2		
Conflicting Flow All	1071	1068	429	1066	1084	581	449	0	0	585	0	0
Stage 1	475	475	429	589	589	1 00	443	U	U	500	-	U
Stage 2	596	593		477	495	-	-	-	-	-		-
	7.12	6.52	6.22	7.12	6.52	6.22	4.11	-	-	4.12	-	-
Critical Hdwy	6.12	5.52	0.22	6.12	5.52	0.22	4.11	-	-	4.12	-	-
Critical Hdwy Stg 1	6.12	5.52	-	6.12	5.52	-	-	-	-	-	-	-
Critical Hdwy Stg 2			3.318	3.518	4.018	3.318	2 200	-	-	2.218	-	-
Follow-up Hdwy	3.518	4.018						-			-	-
Pot Cap-1 Maneuver	198	222	626	200	217	514	1117	-	-	990	-	-
Stage 1	570	557	-	494	495	-	-	-	-	-	-	-
Stage 2	490	493	-	569	546	-	-	-	-	-	-	-
Platoon blocked, %	100	246	606	105	211	E11	1117	-	-	000	-	-
Mov Cap-1 Maneuver	189	216	626	195	211 211	514	1117	-	-	990	-	-
Mov Cap-2 Maneuver	189	216 544	-	195		-	-	-	-	-	-	-
Stage 1	568	491	-	492	493	-	-	-	-	-	-	-
Stage 2	475	491	-	553	533	-	-	-	-	-	-	-
Approach	EB			WB			NB			SB		
HCM Control Delay, s	25.7			15.2			0.1			0.4		
HCM LOS	D			С								
Minor Lane/Major Mvm	nt	NBL	NBT	NBR	EBLn1V	VBLn1	SBL	SBT	SBR			
Capacity (veh/h)		1117	-	-	204	371	990	-	_			
HCM Lane V/C Ratio		0.004	_	_	0.149		0.023	_	_			
HCM Control Delay (s)		8.2	-	_	25.7	15.2	8.7	-	_			
HCM Lane LOS		A	_	_	D	C	A	_	_			
HCM 95th %tile Q(veh)	0	-	_	0.5	0.2	0.1	_	-			
	,				0.0	0.2	J. 1					

Intersection						
Int Delay, s/veh	0.4					
Movement	WBL	WBR	NBT	NBR	SBL	SBT
Lane Configurations	WDL.	וטייי	1 301	וטוו	JDL	^
Traffic Vol, veh/h	T 4	11	525	7	16	3 67
Future Vol, veh/h	4	11	525	7	16	367
Conflicting Peds, #/hr	0	0	0	0	0	0
Sign Control		Stop	Free	Free	Free	Free
RT Channelized	Stop -	None				None
			-	None	-	
Storage Length	0	-	-	-	500	-
Veh in Median Storage		-	0	-	-	0
Grade, %	0	-	0	- 04	-	0
Peak Hour Factor	92	92	91	91	92	92
Heavy Vehicles, %	2	2	1	1	2	2
Mvmt Flow	4	12	577	8	17	399
Major/Minor I	Minor1	N	Major1	N	//ajor2	
Conflicting Flow All	1014	581	0	0	585	0
Stage 1	581	-	-	<u>_</u>	505	-
Stage 2	433	-	_	-	-	
Critical Hdwy	6.42	6.22		-	4.12	
V			-	-	4.12	-
Critical Hdwy Stg 1	5.42	-	-	-	-	-
Critical Hdwy Stg 2	5.42	- 240	-	-	- 0.04.0	-
Follow-up Hdwy	3.518		-	-	2.218	-
Pot Cap-1 Maneuver	264	514	-	-	990	-
Stage 1	559	-	-	-	-	-
Stage 2	654	-	-	-	-	-
Platoon blocked, %			-	-		-
Mov Cap-1 Maneuver	260	514	-	-	990	-
Mov Cap-2 Maneuver	391	-	-	-	-	-
Stage 1	559	-	-	-	-	-
Stage 2	643	-	-	-	-	-
y -						
Approach	WB		NB		SB	
HCM Control Delay, s	12.9		0		0.4	
HCM LOS	В					
Minor Long/Major My	.+	NDT	NDDV	MDI -1	CDI	CDT
Minor Lane/Major Mvm	IL	NBT		VBLn1	SBL	SBT
Capacity (veh/h)		-	-		990	-
HCM Lane V/C Ratio		-	-	0.034		-
HCM Control Delay (s)		-	-		8.7	-
HCM Lane LOS		-	-	В	Α	-
HCM 95th %tile Q(veh))	-	-	0.1	0.1	-

Intersection: 10: EB 12-Mile Road & WB-to-EB XO, W. of Meadowbrook

Movement	SB
Directions Served	L
Maximum Queue (ft)	91
Average Queue (ft)	63
95th Queue (ft)	84
Link Distance (ft)	23
Upstream Blk Time (%)	35
Queuing Penalty (veh)	104
Storage Bay Dist (ft)	
Storage Blk Time (%)	
Queuing Penalty (veh)	

Intersection: 11: WB-to-EB XO, W. of Meadowbrook & WB 12-Mile Road

Movement	WB	WB
Directions Served	L	Т
Maximum Queue (ft)	146	15
Average Queue (ft)	46	1
95th Queue (ft)	121	11
Link Distance (ft)		651
Upstream Blk Time (%)		
Queuing Penalty (veh)		
Storage Bay Dist (ft)	250	
Storage Blk Time (%)		
Queuing Penalty (veh)		

Intersection: 20: Meadowbrook Road & WB 12-Mile Road

Movement	WB	WB	WB	WB	SB	SB	
Directions Served	T	Т	Т	R	Т	R	
Maximum Queue (ft)	159	154	129	57	190	81	
Average Queue (ft)	89	76	50	21	76	26	
95th Queue (ft)	152	134	111	50	145	57	
Link Distance (ft)	148	148	148	148	837		
Upstream Blk Time (%)	1	0	0				
Queuing Penalty (veh)	2	1	0				
Storage Bay Dist (ft)						275	
Storage Blk Time (%)					0		
Queuing Penalty (veh)					0		

Intersection: 21: Meadowbrook Road & EB 12-Mile Road

Movement	EB	EB	EB	EB	NB	NB	SB
Directions Served	T	Т	T	R	Т	R	Т
Maximum Queue (ft)	90	83	117	130	96	112	5
Average Queue (ft)	40	30	40	52	38	45	0
95th Queue (ft)	75	69	86	104	86	83	5
Link Distance (ft)	634	634	634		878		56
Upstream Blk Time (%)							
Queuing Penalty (veh)							
Storage Bay Dist (ft)				350		250	
Storage Blk Time (%)							
Queuing Penalty (veh)							

Intersection: 30: EB 12-Mile Road & WB-to-EB XO, E. of Meadowbrook

Movement
Directions Served
Maximum Queue (ft)
Average Queue (ft)
95th Queue (ft)
Link Distance (ft)
Upstream Blk Time (%)
Queuing Penalty (veh)
Storage Bay Dist (ft)
Storage Blk Time (%)
Queuing Penalty (veh)

Intersection: 31: WB-to-EB XO, E. of Meadowbrook & WB 12-Mile Road

Movement	WB	WB	WB
Directions Served	T	T	Т
Maximum Queue (ft)	65	27	11
Average Queue (ft)	5	1	0
95th Queue (ft)	30	13	8
Link Distance (ft)	506	506	506
Upstream Blk Time (%)			
Queuing Penalty (veh)			
Storage Bay Dist (ft)			
Storage Blk Time (%)			
Queuing Penalty (veh)			

Intersection: 40: EB-to-WB XO, E. of Meadowbrook & WB 12-Mile Road

Movement	NB
Directions Served	L
Maximum Queue (ft)	54
Average Queue (ft)	28
95th Queue (ft)	50
Link Distance (ft)	18
Upstream Blk Time (%)	9
Queuing Penalty (veh)	6
Storage Bay Dist (ft)	
Storage Blk Time (%)	
Queuing Penalty (veh)	

Intersection: 41: EB 12-Mile Road & EB-to-WB XO, E. of Meadowbrook

Movement	EB
Directions Served	L
Maximum Queue (ft)	5
Average Queue (ft)	0
95th Queue (ft)	4
Link Distance (ft)	
Upstream Blk Time (%)	
Queuing Penalty (veh)	
Storage Bay Dist (ft)	250
Storage Blk Time (%)	
Queuing Penalty (veh)	

Intersection: 50: EB 12-Mile Road & WB-to-EB XO, W. of Summit Dr.

Movement	SB	
Directions Served	L	
Maximum Queue (ft)	36	
Average Queue (ft)	21	
95th Queue (ft)	44	
Link Distance (ft)	23	
Upstream Blk Time (%)	4	
Queuing Penalty (veh)	2	
Storage Bay Dist (ft)		
Storage Blk Time (%)		
Queuing Penalty (veh)		

Intersection: 51: WB-to-EB XO, W. of Summit Dr. & WB 12-Mile Road

Movement

Directions Served

Maximum Queue (ft)

Average Queue (ft)

95th Queue (ft)

Link Distance (ft)

Upstream Blk Time (%)

Queuing Penalty (veh)

Storage Bay Dist (ft)

Storage Blk Time (%)

Queuing Penalty (veh)

Intersection: 60: SB M-5 Exit-Ramp & WB 12-Mile Road

Movement	WB	WB	WB	SB	SB	SB	SB		
Directions Served	T	Т	Т	Т	Т	R	R		
Maximum Queue (ft)	167	123	68	147	169	102	65		
Average Queue (ft)	89	39	17	35	92	49	17		
95th Queue (ft)	153	91	49	109	149	79	48		
Link Distance (ft)	1226	1226	1226			958			
Upstream Blk Time (%)									
Queuing Penalty (veh)									
Storage Bay Dist (ft)				250	250		250		
Storage Blk Time (%)									
Queuing Penalty (veh)									

Intersection: 61: EB 12-Mile Road & SB M-5 Exit-Ramp

Movement	EB	EB	EB	SB
Directions Served	T	Т	Т	L
Maximum Queue (ft)	100	107	123	5
Average Queue (ft)	40	40	48	0
95th Queue (ft)	82	85	96	5
Link Distance (ft)	141	141	141	22
Upstream Blk Time (%)			0	1
Queuing Penalty (veh)			0	1
Storage Bay Dist (ft)				
Storage Blk Time (%)				
Queuing Penalty (veh)				

Intersection: 70: Site Drive #1 & EB 12-Mile Road

Movement	NB
Directions Served	R
Maximum Queue (ft)	67
Average Queue (ft)	33
95th Queue (ft)	55
Link Distance (ft)	454
Upstream Blk Time (%)	
Queuing Penalty (veh)	
Storage Bay Dist (ft)	
Storage Blk Time (%)	
Queuing Penalty (veh)	

Intersection: 80: Meadowbrook Road & Elm Creek Drive/Site Drive #2

Movement	EB	WB	NB	SB
Directions Served	LTR	LTR	L	L
Maximum Queue (ft)	65	56	11	22
Average Queue (ft)	24	24	0	1
95th Queue (ft)	53	51	6	8
Link Distance (ft)	364	417		
Upstream Blk Time (%)				
Queuing Penalty (veh)				
Storage Bay Dist (ft)			500	475
Storage Blk Time (%)				
Queuing Penalty (veh)				

Intersection: 90: Meadowbrook Road & Site Drive #3

Movement	WB	SB	
Directions Served	LR	L	
Maximum Queue (ft)	36	16	
Average Queue (ft)	19	1	
95th Queue (ft)	44	9	
Link Distance (ft)	413		
Upstream Blk Time (%)			
Queuing Penalty (veh)			
Storage Bay Dist (ft)		500	
Storage Blk Time (%)			
Queuing Penalty (veh)			

Zone Summary

Zone wide Queuing Penalty: 116

Intersection: 10: EB 12-Mile Road & WB-to-EB XO, W. of Meadowbrook

Movement	SB
Directions Served	L
Maximum Queue (ft)	86
Average Queue (ft)	64
95th Queue (ft)	78
Link Distance (ft)	23
Upstream Blk Time (%)	47
Queuing Penalty (veh)	144
Storage Bay Dist (ft)	
Storage Blk Time (%)	
Queuing Penalty (veh)	

Intersection: 11: WB-to-EB XO, W. of Meadowbrook & WB 12-Mile Road

Movement	WB	WB
Directions Served	L	Т
Maximum Queue (ft)	197	63
Average Queue (ft)	57	3
95th Queue (ft)	142	34
Link Distance (ft)		651
Upstream Blk Time (%)		
Queuing Penalty (veh)		
Storage Bay Dist (ft)	250	
Storage Blk Time (%)	0	
Queuing Penalty (veh)	0	

Intersection: 20: Meadowbrook Road & WB 12-Mile Road

Movement	WB	WB	WB	WB	NB	SB	SB
Directions Served	Т	Т	Т	R	Т	Т	R
Maximum Queue (ft)	181	184	183	153	9	237	97
Average Queue (ft)	144	149	146	66	0	93	28
95th Queue (ft)	193	193	192	121	5	175	71
Link Distance (ft)	148	148	148	148	56	837	
Upstream Blk Time (%)	9	10	9	0			
Queuing Penalty (veh)	52	56	52	1			
Storage Bay Dist (ft)							275
Storage Blk Time (%)						0	
Queuing Penalty (veh)						0	

Intersection: 21: Meadowbrook Road & EB 12-Mile Road

Movement	EB	EB	EB	EB	NB	NB	SB
Directions Served	T	Т	Т	R	Т	R	Т
Maximum Queue (ft)	150	164	197	111	225	239	12
Average Queue (ft)	70	76	104	49	95	106	1
95th Queue (ft)	119	139	173	90	182	202	12
Link Distance (ft)	634	634	634		878		56
Upstream Blk Time (%)							0
Queuing Penalty (veh)							1
Storage Bay Dist (ft)				350		250	
Storage Blk Time (%)					0	0	
Queuing Penalty (veh)					0	0	

Intersection: 30: EB 12-Mile Road & WB-to-EB XO, E. of Meadowbrook

Movement	SB
Directions Served	L
Maximum Queue (ft)	34
Average Queue (ft)	2
95th Queue (ft)	13
Link Distance (ft)	19
Upstream Blk Time (%)	0
Queuing Penalty (veh)	0
Storage Bay Dist (ft)	
Storage Blk Time (%)	
Queuing Penalty (veh)	

Intersection: 31: WB-to-EB XO, E. of Meadowbrook & WB 12-Mile Road

Movement	WB	WB	WB	WB	
Directions Served	Т	Т	Т	Т	
Maximum Queue (ft)	219	208	201	12	
Average Queue (ft)	70	67	61	0	
95th Queue (ft)	178	174	166	6	
Link Distance (ft)	506	506	506		
Upstream Blk Time (%)					
Queuing Penalty (veh)					
Storage Bay Dist (ft)				150	
Storage Blk Time (%)	0		1		
Queuing Penalty (veh)	0		7		

Intersection: 40: EB-to-WB XO, E. of Meadowbrook & WB 12-Mile Road

Movement	NB
Directions Served	L
Maximum Queue (ft)	64
Average Queue (ft)	43
95th Queue (ft)	72
Link Distance (ft)	18
Upstream Blk Time (%)	40
Queuing Penalty (veh)	41
Storage Bay Dist (ft)	
Storage Blk Time (%)	
Queuing Penalty (veh)	

Intersection: 41: EB 12-Mile Road & EB-to-WB XO, E. of Meadowbrook

Movement	EB	EB	EB	EB
Directions Served	L	Т	Т	Т
Maximum Queue (ft)	222	104	82	32
Average Queue (ft)	36	12	4	1
95th Queue (ft)	163	115	63	19
Link Distance (ft)		506	506	506
Upstream Blk Time (%)				
Queuing Penalty (veh)				
Storage Bay Dist (ft)	250			
Storage Blk Time (%)	3	0		
Queuing Penalty (veh)	14	0		

Intersection: 50: EB 12-Mile Road & WB-to-EB XO, W. of Summit Dr.

Movement	SB
Directions Served	L
Maximum Queue (ft)	85
Average Queue (ft)	47
95th Queue (ft)	77
Link Distance (ft)	23
Upstream Blk Time (%)	23
Queuing Penalty (veh)	24
Storage Bay Dist (ft)	
Storage Blk Time (%)	
Queuing Penalty (veh)	

Intersection: 51: WB-to-EB XO, W. of Summit Dr. & WB 12-Mile Road

Movement	WB
Directions Served	L
Maximum Queue (ft)	56
Average Queue (ft)	6
95th Queue (ft)	32
Link Distance (ft)	
Upstream Blk Time (%)	
Queuing Penalty (veh)	
Storage Bay Dist (ft)	300
Storage Blk Time (%)	
Queuing Penalty (veh)	

Intersection: 60: SB M-5 Exit-Ramp & WB 12-Mile Road

Movement	WB	WB	WB	SB	SB	SB	SB	
Directions Served	Т	Т	T	Т	T	R	R	
Maximum Queue (ft)	380	378	304	173	228	343	313	
Average Queue (ft)	197	158	116	40	102	166	122	
95th Queue (ft)	328	296	238	118	186	280	252	
Link Distance (ft)	1226	1226	1226			958		
Upstream Blk Time (%)								
Queuing Penalty (veh)								
Storage Bay Dist (ft)				250	250		250	
Storage Blk Time (%)					0	2	0	
Queuing Penalty (veh)					0	12	2	

Intersection: 61: EB 12-Mile Road & SB M-5 Exit-Ramp

Movement	EB	EB	EB	SB
Directions Served	T	Т	Т	L
Maximum Queue (ft)	131	135	167	9
Average Queue (ft)	51	54	67	1
95th Queue (ft)	108	114	136	6
Link Distance (ft)	141	141	141	22
Upstream Blk Time (%)	0	0	1	1
Queuing Penalty (veh)	0	1	2	1
Storage Bay Dist (ft)				
Storage Blk Time (%)				
Queuing Penalty (veh)				

Intersection: 70: Site Drive #1 & EB 12-Mile Road

Movement	NB
Directions Served	R
Maximum Queue (ft)	60
Average Queue (ft)	31
95th Queue (ft)	55
Link Distance (ft)	454
Upstream Blk Time (%)	
Queuing Penalty (veh)	
Storage Bay Dist (ft)	
Storage Blk Time (%)	
Queuing Penalty (veh)	

Intersection: 80: Meadowbrook Road & Elm Creek Drive/Site Drive #2

Movement	EB	WB	NB	SB
Directions Served	LTR	LTR	L	L
Maximum Queue (ft)	52	40	17	29
Average Queue (ft)	19	16	1	7
95th Queue (ft)	45	42	7	26
Link Distance (ft)	364	417		
Upstream Blk Time (%)				
Queuing Penalty (veh)				
Storage Bay Dist (ft)			500	475
Storage Blk Time (%)				
Queuing Penalty (veh)				

Intersection: 90: Meadowbrook Road & Site Drive #3

Movement	WB	SB	
Directions Served	LR	L	
Maximum Queue (ft)	36	34	
Average Queue (ft)	14	3	
95th Queue (ft)	40	19	
Link Distance (ft)	413		
Upstream Blk Time (%)			
Queuing Penalty (veh)			
Storage Bay Dist (ft)		500	
Storage Blk Time (%)			
Queuing Penalty (veh)			

Zone Summary

Zone wide Queuing Penalty: 412

		HCS Freewa	y V	Weaving Repo	rt	
Project Information						
Analyst		SA		Date		10/8/2024
Agency		Fleis & VandenBrin Engineering	nk	Analysis Year		2024
Jurisdiction		RCOC		Time Analyzed		Future AM Peak Hour
Project Description		Site Drive # 1 to EE to-WB X/O, W. of M-5	3-	Units		U.S. Customary
Geometric Data				<u> </u>		
Number of Lanes (N), In		3		Segment Type		CD Roadway
Segment Length (Ls), ft		600		Number of Maneuve	r Lanes (NWL), In	0
Weaving Configuration		Two-Sided		Ramp-to-Freeway La	ne Changes (LCRF), lc	1
Terrain Type		Level		Freeway-to-Ramp La	ne Changes (LCFR), lc	1
Percent Grade, %		-		Ramp-to-Ramp Lane	Changes (LCRR), lc	2
Interchange Density (ID), int/mi		4.00		Cross Weaving Mana	No	
Adjustment Factors				`		<u>'</u>
Driver Population	All Familiar		Final Speed Adjustme	1.000		
Weather Type		Non-Severe Weather		Demand Adjustment	1.000	
Incident Type		No Incident		Capacity Adj. Factor f	1.000	
Proportion of CAVs in Traffic Stream		0		Final Capacity Adjust	ment Factor (CAF)	1.000
Demand and Capacity				`		<u>'</u>
		FF	Π	RF	RR	FR
Demand Volume (Vi), veh/h	68	0	66		16	0
Peak Hour Factor (PHF)	0.8	35	0.9	92	0.92	0.92
Total Trucks, %	6.0	00	2.0	00	2.00	0.00
Heavy Vehicle Adjustment Factor (fHV)	0.9	943	0.9	980	0.980	1.000
Flow Rate (vi), pc/h	84	8	73		18	0
Weaving Flow Rate (vw), pc/h	18		Ide	Ideal Conditions Capacity (cIFL), pc/h/ln		2200
Non-Weaving Flow Rate (vnw), pc/h	92	1	De	ensity-Based Capacity (5096	
Total Flow Rate (v), pc/h	93	9	De	emand Flow-Based Cap	-	
Volume Ratio (VR)	0.0)19	We	eaving Area Capacity (5096	
Minimum Lane Change Rate (LCMIN), lc/h	36		Ad	ljusted Weaving Area (5096	
Maximum Weaving Length (LMAX), ft	5903		De	emand-to-Capacity Rat	0.17	
Speed and Density						
Non-Weaving Vehicle Index (INW)		221		Average Weaving Sp	41.9	
Non-Weaving Lane Change Rate (LCNW), I	c/h	n 0		Average Non-Weavir	43.2	
Weaving Lane Change Rate (LCW), lc/h		256		Average Speed (S), m	43.2	
Total Lane Change Rate (LCAII), lc/h		256		Density (D), pc/mi/ln	7.2	
Weaving Intensity Factor (W)	0.115		Level of Service (LOS	Α		

		HCS Freewa	y V	Weaving Repo	rt	
Project Information						
Analyst		SA		Date		10/8/2024
Agency		Fleis & VandenBrink Engineering		Analysis Year		2024
Jurisdiction		RCOC		Time Analyzed		Future AM Peak Hour
Project Description		WB-to-EB X/O, W. Summit Dr to Site Drive # 1	of	Units		U.S. Customary
Geometric Data						
Number of Lanes (N), In		3		Segment Type		CD Roadway
Segment Length (Ls), ft		300		Number of Maneuve	r Lanes (NWL), In	0
Weaving Configuration		Two-Sided		Ramp-to-Freeway La	ne Changes (LCRF), lc	1
Terrain Type		Level		Freeway-to-Ramp La	ne Changes (LCFR), lc	1
Percent Grade, %		-		Ramp-to-Ramp Lane	Changes (LCRR), lc	2
Interchange Density (ID), int/mi		4.00		Cross Weaving Mana	No	
Adjustment Factors						
Driver Population	All Familiar		Final Speed Adjustme	1.000		
Veather Type		Non-Severe Weather		Demand Adjustment	1.000	
ncident Type		No Incident		Capacity Adj. Factor f	1.000	
Proportion of CAVs in Traffic Stream		0		Final Capacity Adjust	ment Factor (CAF)	1.000
Demand and Capacity						•
	Π	FF		RF	RR	FR
Demand Volume (Vi), veh/h	68	0	14		22	5
Peak Hour Factor (PHF)	0.8	35	0.6	50	0.60	0.85
Total Trucks, %	6.0	00	0.0	00	0.00	0.00
Heavy Vehicle Adjustment Factor (fHV)	0.9	943	1.0	000	1.000	1.000
Flow Rate (vi), pc/h	84	8	23		37	6
Weaving Flow Rate (vw), pc/h	37		Ide	deal Conditions Capacity (cIFL), pc/h/ln		2200
Non-Weaving Flow Rate (vNW), pc/h	87	7	De	ensity-Based Capacity (4984	
Total Flow Rate (v), pc/h	91	4	De	emand Flow-Based Cap	-	
Volume Ratio (VR)	0.0)40	We	eaving Area Capacity (4984	
Minimum Lane Change Rate (LCMIN), lc/h	74		Ad	ljusted Weaving Area (4984	
Maximum Weaving Length (LMAX), ft	60	99	De	emand-to-Capacity Rat	0.17	
Speed and Density						
Non-Weaving Vehicle Index (INW)		105		Average Weaving Sp	42.9	
Non-Weaving Lane Change Rate (LCNW), lo	c/h	0		Average Non-Weavir	43.0	
Weaving Lane Change Rate (LCW), lc/h		74		Average Speed (S), m	ni/h	43.0
Total Lane Change Rate (LCAII), lc/h		74		Density (D), pc/mi/ln		7.1
Weaving Intensity Factor (W)	0.075		Level of Service (LOS	Α		


		HCS Freewa	y V	Weaving Repo	rt	
Project Information						
Analyst		SA		Date		10/8/2024
Agency		Fleis & VandenBrink Engineering		Analysis Year		2024
Jurisdiction		RCOC		Time Analyzed		Future PM Peak Hour
Project Description		Site Drive # 1 to EE to-WB X/O, W. of M-5	3-	Units		U.S. Customary
Geometric Data						<u> </u>
Number of Lanes (N), In		3		Segment Type		CD Roadway
Segment Length (Ls), ft		600		Number of Maneuve	r Lanes (NWL), In	0
Weaving Configuration		Two-Sided		Ramp-to-Freeway La	ne Changes (LCRF), lc	1
Terrain Type		Level		Freeway-to-Ramp La	ne Changes (LCFR), lc	1
Percent Grade, %		-		Ramp-to-Ramp Lane	Changes (LCRR), lc	2
Interchange Density (ID), int/mi		4.00		Cross Weaving Mana	No	
Adjustment Factors						
Driver Population	All Familiar		Final Speed Adjustm	1.000		
Weather Type		Non-Severe Weather		Demand Adjustment	1.000	
Incident Type		No Incident		Capacity Adj. Factor	for CAVs (CAFCAV)	1.000
Proportion of CAVs in Traffic Stream		0		Final Capacity Adjust	ment Factor (CAF)	1.000
Demand and Capacity						<u>'</u>
	Τ	FF	Π	RF	RR	FR
Demand Volume (Vi), veh/h	12	70	52		7	0
Peak Hour Factor (PHF)	0.8	38	0.9	92	0.92	0.92
Total Trucks, %	1.0	00	2.0	00	2.00	0.00
Heavy Vehicle Adjustment Factor (fHV)	0.9	990	0.9	980	0.980	1.000
Flow Rate (vi), pc/h	14	58	58		8	0
Weaving Flow Rate (vw), pc/h	8		Ide	eal Conditions Capacity	2200	
Non-Weaving Flow Rate (vNW), pc/h	15	16	De	ensity-Based Capacity (5355	
Total Flow Rate (v), pc/h	15	24	De	emand Flow-Based Cap	-	
Volume Ratio (VR)	0.0	005	We	eaving Area Capacity (5355	
Minimum Lane Change Rate (LCMIN), lc/h	16		Ad	ljusted Weaving Area (5355	
Maximum Weaving Length (LMAX), ft	57	5774		emand-to-Capacity Rat	0.28	
Speed and Density						
Non-Weaving Vehicle Index (INW)		364		Average Weaving Sp	41.6	
Non-Weaving Lane Change Rate (LCNW), l	c/h	60		Average Non-Weavir	42.4	
Weaving Lane Change Rate (LCW), lc/h		236		Average Speed (S), m	42.4	
Total Lane Change Rate (LCAII), lc/h		296		Density (D), pc/mi/ln	12.0	
Weaving Intensity Factor (W)	0.129		Level of Service (LOS	Α		

		HCS Freewa	y V	Weaving Repo	rt	
Project Information						
Analyst		SA		Date		10/8/2024
Agency		Fleis & VandenBrink Engineering		Analysis Year		2024
Jurisdiction		RCOC		Time Analyzed		Future PM Peak Hour
Project Description		WB-to-EB X/O, W. Summit Dr to Site Drive # 1	of	Units		U.S. Customary
Geometric Data				`		
Number of Lanes (N), In		3		Segment Type		CD Roadway
Segment Length (Ls), ft		300		Number of Maneuve	r Lanes (NWL), ln	0
Weaving Configuration		Two-Sided		Ramp-to-Freeway La	ne Changes (LCRF), lc	1
Terrain Type		Level		Freeway-to-Ramp La	ne Changes (LCFR), lc	1
Percent Grade, %		-		Ramp-to-Ramp Lane	Changes (LCRR), lc	2
Interchange Density (ID), int/mi		4.00		Cross Weaving Mana	No	
Adjustment Factors						
Driver Population	All Familiar		Final Speed Adjustme	1.000		
Weather Type		Non-Severe Weather		Demand Adjustment	1.000	
Incident Type		No Incident		Capacity Adj. Factor f	for CAVs (CAFCAV)	1.000
Proportion of CAVs in Traffic Stream		0		Final Capacity Adjust	ment Factor (CAF)	1.000
Demand and Capacity				<u> </u>		
	Τ	FF		RF	RR	FR
Demand Volume (Vi), veh/h	12	70	23		82	12
Peak Hour Factor (PHF)	0.8	38	0.9	92	0.92	0.95
Total Trucks, %	1.0	00	14.00		0.00	0.00
Heavy Vehicle Adjustment Factor (fHV)	0.9	990	0.877		1.000	1.000
Flow Rate (vi), pc/h	14	.58	29		89	13
Weaving Flow Rate (vw), pc/h	89	1	Ide	eal Conditions Capacity	2200	
Non-Weaving Flow Rate (vNW), pc/h	15	00	De	ensity-Based Capacity (5175	
Total Flow Rate (v), pc/h	15	89	De	emand Flow-Based Cap	-	
Volume Ratio (VR)	0.0	056	We	eaving Area Capacity (5175	
Minimum Lane Change Rate (LCMIN), lc/h	17	8	Ad	ljusted Weaving Area (5175	
Maximum Weaving Length (LMAX), ft	6250		De	emand-to-Capacity Rat	0.30	
Speed and Density						
Non-Weaving Vehicle Index (INW)		180		Average Weaving Sp	41.1	
Non-Weaving Lane Change Rate (LCNW), I	c/h	0		Average Non-Weavir	41.2	
Weaving Lane Change Rate (LCW), lc/h		178		Average Speed (S), m	41.2	
Total Lane Change Rate (LCAII), lc/h		178		Density (D), pc/mi/ln	12.9	
Weaving Intensity Factor (W)	0.150		Level of Service (LOS	В		

12-Mile Road and Site Drive # 1

FIGURE 6-3

WARRANT FOR RIGHT TURN DECELERATION LANE OR TAPER



2023 ADT = 26,000 vpd (MDOT) 0.50% @ 7yrs= +924 vpd The Grove New Trips = +1951 vpd 2030 ADT= 28,875 vpd RT Lane RECOMMENDED




Figure IX.10

(Ord. No. 99-124.11, Pt. XXXIII, 7-26-99)




Figure IX.10

(Ord. No. 99-124.11, Pt. XXXIII, 7-26-99)